POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER QF-LDC-08 DAILY REPORT Reporting Date : 18-Sep-22 14782.0 Hrs Till now the maximum generation is: 21:00 16-Apr-22 The Summary of Yesterday's Day Peak Generation : Evening Peak Generation : Today's Actual Min Gen. & Probable Gen. & Demand Min. Gen. at 7:00 10466 MW Available Max Generation : 14011 MW 17-Sep-22 **Generation & Demand** 11391.0 MW 12:00 13431.0 MW Hour 20:00 E.P. Demand (at gen end) 13669.0 MW Hour 20:00 Max Demand (Evening) 14000 MW Maximum Generation 13431.0 MW Hour 20:00 Reserve(Generation el 11 MW Total Gen. (MKWH) 0 MW 280.8 System Load Factor EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR 87.10% Load Shed Export from East grid to West grid :- Maximum 995 MW 19:00 Energy MKWHR Import from West grid to East grid :- Maximum Level of Kaptai Lake at 6:00 A M on MKWHR. MW Energy 18-Sep-22 Actual : 96.70 Ft.(MSL), Rule curve : 102.91 Ft.(MSL) Gas Consumed : Total = 1040.19 MMCFD Oil Consumed (PDB): Liter Liter HSD Cost of the Consumed Fuel (PDB+P Gas Tk157 242 068 : Tk1,134,675,665 Total : Tk1,538,740,834 Coal Load Shedding & Other Information Area Yesterday Today Rates of Shedding (On Estimated Demand) Estimated Shedding (S/S end) MW Estimated Demand (S/S end) MW MW Dhaka 4547 40 Chittagong Area Khulna Area Rajshahi Area 0 0:00 1288 0% 0:00 1700 1508 0% 0% 0% Cumilla Area 27 0:00 1284 1061 474 0% 0% 0% Mymensingh Area 152 0.00 Sylhet Area 0 0:00 Barisal Area 0:00 387 Rangpur Area 0:00 0% 13086 Information of the Generating Units under shut down. Planned Shut- Down Forced Shut-Down 1) Barapukuria ST: Unit-2 2) Ghorasal-3, 3) Ashugani-5 4) Baghabari-71,100 MW 5) Raozan unit-2 6) Siddhirganj 210 MW 7) Sikalbaha 225 MW 8) Shajibazar 330 MW Shahjibazar GT8 Additional Information of Machines, lines, Interruption / Forced Load shed etc. a) Haripur-Ullon 132 kV Ckt was under shut down from 09:16 to 13:54 for C/M by DPDC. b) Ullon-Dhanmondi 132 kV Ckt-2 was under shut down from 09:14 to 14:00 for C/M by DPDC. c) Cumilla(N)-Daudkandi 132 kV Ckt-2 tripped at 09:39 from Cumilla(N) end showing Dist. C-phase, Z1 relay and was switched on at 09:58. d Siddhirganj-Siddhirganj 335 MW P/P 230 kV Ckt was under shut down from 12:43 to 16:02 due to protection test. e) BSRM-AKSM 230 kV Ckt tripped at 13:05 from both end showing Dist. R-phase, Z1 relays and was switched on at 13:31. switched of lat 7:05P GT was synchronized at 13:48. g) BSRM-AKSM 230 kV Ckt was under shut down from 15:03 to 17:15 due to tree trimming by BSRM. h) Haripur-Bhulta 132 kV Ckt tripped at 16:11 from Bhulta end showing O/C relay & due to Doreen About 210 MW power interruption occurred under Bhulta, Norsingdi S/S area from 16:11 to 16:31. 22 MW tripped and was switched on at 16:31. (1) Greenmangal 132/33 kV T-1 & T-2 transformers tripped at 19:01 due to 33 kV Kodupur feeder fault and was switched on at 19:05. About 37 MW power interruption occurred under Sreemangal S/S area from 19:01 to 19:05.)) Khulna® 132/33 kV T-1 transformer was under shut down from 16:00 to 17:18 due to 33/11 kV new feeder addition. k) Narail 132/33 kV T-1 & T-2 transformers tripped at 20:41 from both end showing O/C, E/F relays and were switched on at 22:11, 22:13 respectively. About 28 MW power interruption occurred under Narail S/S area from 20:41 to 22:11. were switched on at 22-11, 22-13 respectively. I) Hathazari-Baroirhat 132 kV Ckt-1 & 2 tripped at 04:27(18-09-2022) from both end showing Dist.Z1, A,R-phase, E/F relays and was switched on at 04:54(18-09-2022), m) Natore 132/33 kV T-1 & T-2 transformers were under shut down from 06:41(18-09-22) to 07:44(18-09-22) due to red hot maintenance at 33 kV Bus DS by NESCO. About 50 MW power interruption occurred under Natore S/S area from 06:41(18-09-22) to 07:44. About 20 MW power interruption occurred under Chowmuhani S/S area from 06:10(18-09-22) to 06:34. n) Chowmuhani 132/33 kV T-1 & T-2 transformers tripped at 06:10(18-09-22) due to 33 kV feeder fault n) Chowmuhan 132/33 kV 1-1 & 1-2 transformers tripped at u6:10(18-09-22) due to 33 kV feeder fault and was switched on at 06:34(18-09-22). o) Kodda 132/33 kV T-2 transformer with 33 kV bus was under shut down from 06:50 to 08:44(18-09-22) due to red hot maintenance at 33 kV Bus isolator.

Executive Engineer

Network Operation Division

Superintendent Engineer

Load Despatch Circle

Sub Divisional Engineer

Network Operation Division