

**Bangladesh Power Development Board**  
**DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation  
Tel : 9564667, 9551095

Month October, 2022		Day : Saturday				Date : 08.10.22						
Probable Maximum Demand :		13600 MW		Probable Maximum Generation :				12435 MW				
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 97.70 ft		Today = 97.92 ft				Rule Curve = 106.54 ft				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	07.10.22 (Yesterday)		08.10.22 (Today)		07.10.22 (Yesterday)	08.10.22 (Today)	Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)					Gen. shortfall for : Gas/Coal/Oil/Water Limitation MW
					Day	Evening	Day	Evening				
<b>(A) Plants in operation:</b>												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	109	101	100	100	79	Gas Shortage	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0			
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Under maint.	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	93	93	93	93			
5	Tong 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Under maint.	
6	Hanpur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0		Contract Expired	
7	Hanpur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	142	152	340	150	208	Gas Shortage	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	175	195	225	225	255	Gas Shortage	
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Hanpur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	318	337	0	330	75	Gas Shortage	
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	90	85	100	100		STG Under maint.	
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	335	Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	30	30	15	15	25	Fuel oil shortage	
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	8	80	24	64	22	Fuel oil shortage	
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	19	19	19			
17	Summit Power,(Madhab+Ashulia)	Gas (SIPP, REB)	6x1.67+4x1.73	80	80	51	52	49	51			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	25	25			
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	22	22	24	24			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	41	39	32	41			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	88	88	88	88			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	16	128	32	130	21	Fuel oil shortage	
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	54	17	54			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	110	293	115	290			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	16	53	16	50			
26	Keraniganj 330 MW PP (ABR)	HSD (IPP)	25x8.14	300	300	0	157	100	100			
27	Birangaganj 100 MW PP (Agreko)	HSD (IPP)	23x0.85+9+1x.959	100	100	0	50	0	50			
28	Aurahat 100MW PP (Agreko)	HSD (IPP)	23x0.85+9+1x.959	100	100	0	50	0	50			
29	Nababganj 55 MW PP (Southern power )	HFO (IPP)	3x19.3	55	55	17	55	17	55			
30	Manirganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	17	55	17	55			
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	74	17	72	30	Fuel oil shortage	
32	Manirganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	162	17	162			
33	Manirganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	16	0	30	0			
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	54	54	54			
35	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	24	58	25	50	42	Fuel oil shortage	
36	Meghnaghat 100 MW(IEEL)	HFO (NENP)	12x8.9	100	100	24	83	24	80			
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0			
<b>Dhaka Zone Total</b>				<b>6004</b>	<b>5847</b>	<b>1519</b>	<b>2644</b>	<b>1615</b>	<b>2577</b>	<b>1302</b>	<b>845</b>	
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	153	152	151	151		Unit 1 under rehabilitation	
	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	2	0	5	0	0			
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25	25			
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	12	0	20	0			
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	44	44	43	43			
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	105	105	87	105			
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	228	224	225	225			
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	196	300	195	300			
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	11	30	20	20	70	Fuel oil shortage	
49	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	17	50	17	51	52	Fuel oil shortage	
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	23	26	23	30			
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	16	16	16	16			
*	Malancha, Ctg,EPZ (United)	Gas	5x8.73+3x9.34			40	34	15	30			
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0	108	Fuel oil shortage	
53	Sikalbaha 54 MW PP(Jodioc Power)	HFO (IPP)	3x18.55+1x3.6	54	54	36	54	17	36			
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	105	105	87	105			
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	10	20	20	20	80	Fuel oil shortage	
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	10	22	22	22	78	Fuel oil shortage	
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	107	107	107	107			
	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			0	0	0	0			
<b>Chattogram Zone Total</b>				<b>2442</b>	<b>2382</b>	<b>1140</b>	<b>1314</b>	<b>1095</b>	<b>1286</b>	<b>568</b>	<b>330</b>	
58	Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0			
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	36	36	35	35			
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1775	221	221	105	208	180	180			
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	40	75	310	310			
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	280	355	320	320			
63	Ashuganj 420 MW CCPP(East) GT	Gas (APSCL)	1x284	284	284	4	0	10	10	284	Gas Shortage	
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	35	49	50	50			
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20'9.73+1'116	195	195	8	63	8	8	132	Gas Shortage	
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51			
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	130	103	110	120			
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	45	37	35	35			
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	83	82	80	80			
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	180	200	200	200			
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	21	22	22	22			
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	9	8	9	9			
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	25	25	25	25			
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	43	43	43			
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	17	21	21	21			
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	89x1.4+40x1.515+15x1.056	200	200	0	60	0	100			
77	Feni 114 MW (Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	17	114	17	114			
78	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	9	29	28	28			
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	35	35	35	35			
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	18	72	17	72			
**	Impport (Trijura)	India		160	160	116	162	143	166			
<b>Cumilla Zone Total</b>				<b>3193</b>	<b>3169</b>	<b>1272</b>	<b>1850</b>	<b>1749</b>	<b>2034</b>	<b>416</b>	<b>0</b>	
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	72	101	70	100	101	Gas Shortage	
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	13	13	16	16			
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	68	98	99	99			
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	106	152	86	155	48	Fuel oil shortage	
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0			
86	Sutahkhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	15	0	50	0			
87	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	12	12	12	12			
<b>Mymensingh Zone Total</b>				<b>622</b>	<b>614</b>	<b>287</b>	<b>376</b>	<b>335</b>	<b>382</b>	<b>149</b>	<b>0</b>	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	07.10.22 (Yesterday)		08.10.22 (Today)		07.10.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/Oil/Water Limitation		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	MW	Machines shut down (MW)		
88	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	40	30	30	30		40	GT-1 Under maint.
89	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	20	30	30	30		60	GT-4 Under maint.
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	53	14	10	10			
91	Kushiara 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	113	113	0	0	109	54	STG Under maint.
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11			
93	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	62	57	65	65			
94	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	10	81	10	80			
96	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	0	0	140	140			
97	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	0	0	0	0	20		Gas Shortage
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	9	10	10			
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	20	24	0	0			
100	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	320	300	310	310			
101	Bibiyana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	404	405	400	400			
102	Bibiyana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	395	387	400	400			
103	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	24	11	0	0			
105	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	45	10	10	10			
<b>Sylhet Zone Total</b>				<b>2322</b>	<b>2477</b>	<b>1526</b>	<b>1482</b>	<b>1426</b>	<b>1496</b>	<b>129</b>	<b>584</b>	
106	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0			
107	Bheramara 410 MW CAPP	Gas (NWP/CGCL)	1 x 278+1 x 132	410	410	220	215	220	210	195		Gas Shortage
108	Fardipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	30	0	32			
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	67	0	65			
110	Khulna 225 MW CAPP	HSD (NWP/CGCL)	1 x 150+1x75	230	230	120	180	120	220			
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	0	0	0	50			
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	37	75	0	70	30		Fuel oil shortage
113	Madhumati 100 MW PP	HFO (NWP/CGCL)	6x18.445	105	105	15	50	0	67	55		Fuel oil shortage
114	Mongla Orion 100 MW Solar PP	Solar (IPP)	100	100	55	0	100	0	0			Fuel oil shortage
115	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	16	16	16	99		Fuel oil shortage
116	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	0	0	40		Fuel oil shortage
	Rampal 1320 MW	Coal (BIFPCL)				0	0	0	0			
	Khulna 330 MW CAPP	Gas/HSD (BPDB)		1000	1000	927	927	944	944			
**	Bheramara (HVDC)	India										
<b>Khulna Zone Total</b>				<b>2388</b>	<b>2384</b>	<b>1374</b>	<b>1560</b>	<b>1400</b>	<b>1674</b>	<b>419</b>	<b>0</b>	
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	16	16	32			
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	17	26	17	22			
119	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	50	60	60	60	134		Gas Shortage
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	680	850	1000	1000			
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	0			Line Overload
122	Bhola 220MW CAPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	165	221	165	220			
<b>Barishal Zone Total</b>				<b>1958</b>	<b>1958</b>	<b>912</b>	<b>1173</b>	<b>1258</b>	<b>1334</b>	<b>134</b>	<b>0</b>	
123	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	32	0	32			
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	100			
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	0			
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	83	0	85			
128	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	24	0	24			
129	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	34	25	0	0			
130	Santaher 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	26			
131	Sirajgonj 225MW CAPP Unit-1	Gas (NWP/CGCL)	1x150+1x75	210	210	177	169	170	170	41		Gas Shortage
132	Sirajgonj 225MW CAPP Unit-2	Gas (NWP/CGCL)	1x150+1x75	220	220	130	204	130	220	220		Running on HSD
133	Sirajgonj 225MW CAPP Unit-3	Gas (NWP/CGCL)	1x141+1x79	220	220	153	152	150	150	68		Gas Shortage
134	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	329	334	310	310			
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	22	22	22	22			
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11			
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	0	8			
138	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	95	113	35	113			
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	113	113	35	113			
140	Sirajgonj 6.55 MW Solar	Solar (NWP/CGCL)	1x6	6	6	3	0	6	0			
<b>Rajshahi Zone Total</b>				<b>2129</b>	<b>2129</b>	<b>1067</b>	<b>1290</b>	<b>869</b>	<b>1384</b>	<b>500</b>	<b>0</b>	
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	80	83	80	80			
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under Overhauling
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	0	0	0	0			
143	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	55	56	35	113			
145	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
146	Majpara, Tabula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	3	0	8	0			
147	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	76	0	75			
148	Lalmorichhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	6	0	12	0			
<b>Rangpur Zone Total</b>				<b>830</b>	<b>750</b>	<b>144</b>	<b>215</b>	<b>135</b>	<b>268</b>	<b>0</b>	<b>85</b>	
<b>Sub-total: Plants in operation</b>				<b>22088</b>	<b>21710</b>	<b>9241.0</b>	<b>11904</b>	<b>9882</b>	<b>12435</b>	<b>3617</b>	<b>1844</b>	
<b>(B) Plants under long term maintenance/ contract expired</b>												
149	Jamailpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			
150	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			
151	Bosilia 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			
152	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0			
153	Bogura 20 MW PP (Energyprima)	Gas (NENP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020
154	Mithora 30 MW PP(Sinhi)	HFO (QRPP)	7x7.79	30	0	0	0	0	0			Contract Expired on 11/01/2022
<b>Sub-Total: Plants under long term maintenance/ contract expired</b>				<b>424</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	
<b>Gross Total</b>				<b>22512</b>	<b>21710</b>	<b>9241</b>	<b>11904</b>	<b>9882</b>	<b>12435</b>	<b>3617</b>	<b>1844</b>	
<b>(C) Actual data of 07.10.22 (Yesterday) Friday :</b>												
01.	Max. Demand at eve. peak (Generation end)	: 12950 MW, at = 20:00 hrs		12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :								
02.	Max. Demand at eve. peak (Sub-station end)	: 12531 MW, at = 20:00 hrs		Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW	
03.	Highest Generation (Generation end)	: 11931 MW, at = 22:00 hrs		Dhaka	4331	4124	207	Mymensingh	1136	890	246	
04.	Minimum Generation (Generation end)	: 9231 MW, at = 8:00 hrs		Chattoogram	1283	1195	88	Sylhet	615	505	110	
05.	Day-peak Generation (Generation end)	: 9241 MW, at = 9:00 hrs		Khulna	1536	1486	50	Barishal	309	309	0	
06.	Evening-peak Generation (Generation end)	: 11904 MW, at = 20:00 hrs		Rajshahi	1226	1226	0	Rangpur	766	756	10	
07.	Evening Peak Load-shed (Sub-station end)	: 964 MW, at = 20:00 hrs		Cumilla	1330	1077	253					
08.	Minimum Generation Forecast up to 8:00 hrs.	: 9669 MW, at = 5:00 hrs										
09.	Generation shortfall at evening peak due to :	:										
	a) Gas/LF limitation	: 3617 MW		13.	Fuel cost :	(a) Gas = 132354002 Taka	(c) Coal = 194666390 Taka					
	d) Coal supply Limitation	: 0 MW				(b) Oil = 993645812 Taka	Total = 1320666204 Taka					
	b) Low water level in Kaptai lake	: 0 MW										
	c) Plants under shut down/ maintenance	: 1844 MW		14.	Maximum Temperature in Dhaka was :	34.3° C						
10.	Total Energy (Generation + India Import)	: 242.85 MKWh		15.	Export through East-West interconnections :							
	By Gas = 118.477 MKWh	By Oil = 71.593 MKWh			At evening peak-hour	: 9241 MW, at 20:00 hrs						
	By Coal = 22.290 MKWh	By Hydro = 3.596 MKWh			Maximum	: 715 MW, at 19:30 hrs						
	By Solar = 1.598 MKWh				Energy	: 0 MKWh						
11.	Total Gas Supplied	: 963.58 MMCFD										
<b>(D) Forecast of 08.10.22 (Today) Saturday :</b>												
01.	Maximum Demand	: 13600 MW (Generation end)		04.	Maximum Load-shed	: 1070 MW At evening peak (Sub-station end)						
02.	Maximum Generation	: 12435 MW (Generation end)		05.	Total Generation	: 276.82 MKWh						
03.	Reserve / Shortage	: -1165 MW (Generation end)										