

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month November, 2022				Day : Thursday				Date : 03.11.22			
Probable Maximum Demand : 12600 MW				Probable Maximum Generation : 12140 MW				Rule Curve = 108.80 ft.			
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 95.46 ft				Today = 95.36 ft			
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	02.11.22 (Yesterday)		03.11.22 (Today)		02.11.22 (Yesterday)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)	Probable Peak Generation (MW)	Actual Peak Generation (MW)	Probable Peak Generation (MW)	Gas/Coal/Water Limitation MW	Machines shut down (MW)	
					Day	Evening	Day	Evening			
(A) Plants in operation:											
1	Ghorasal Repowered CAPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work
2	a) Ghorasal Repowered CAPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0		Line Overload
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180		
3	Ghorasal 365 MW CAPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Under maint.
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	3x3.35	108	108	70	73	73	73		
5	Tongl 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0		Contract Expired
7	Haripur 360MW CAPP(HPL)	Gas (IPP)	1x235+1x125	360	360	233	218	240	240	142	Gas Shortage
8	Meghnaghat 450 MW CAPP(MPL)	Gas (IPP)	2x140+1x170	450	450	190	190	200	200	260	Gas Shortage
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
10	Haripur 412 MW CAPP	Gas (EGCB)	1x273+1x139	412	412	390	377	380	380		
11	Siddhirganj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage
12	Siddhirganj 335 MW CAPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335	Gas Shortage
13	Meghnaghat CAPP(Summit)	Gas (IPP)	2x110+1x110	335	335	133	132	135	135	203	Gas Shortage
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	40	40	55	55		
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	66	92	60	92		
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	16	19	16	16		
17	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	40	51	50	50		
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33		
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	26	28	33	33		
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	41	48	49	49		
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	88	88	88	88		
22	Kooda 150MW PP	HFO (BRPgen)	9x17.06	149	149	116	115	115	115	132	
23	Karnaphuli 54 MW PP (Baraka Energy)	HFO (IPP)	3x18.56	54	54	17	54	17	54		
24	Kooda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	240	240	225	275		
25	Kooda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	147	134	149	149		
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	200	108	150	150		
27	Bramhanganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	90	50	50	50		
28	Auraha 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	78	50	50	50		
29	Nabaganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	17	55	35	55		
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	35	55		
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	74	77	74	92		
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	90	162	35	162		
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	30	0	30	0		
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	16	17	17	17		
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	80	89	70	90		
36	Meghnaghat 100 MW(HEL)	HFO (NENP)	12x8.9	100	100	54	84	70	92		
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0		
Dhaka Zone Total				6004	5847	2830	2859	2714	3047	1255	740
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	31	150	152	152		Unit 1 under rehabilitation
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	4	0	5	0		
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	17	25	25	25		
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	11	0	20	0		
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	27	44	24	44		
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	51	105	70	105		
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.
46	Sikalbaha 225 MW CAPP	Gas (PDB)	1 x 150+1 x 75	225	225	151	151	150	150	74	STG Under maint.
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	124	300	125	300		
48	Juldah 100 MW PP Unit 3 (Accom)	HFO (IPP)	8x13.45	100	100	25	50	25	50		
49	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	17	51	17	51		
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	23	22	22	22		
51	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0	22	Gas Shortage
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34	108	108	2	5	5	10		
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0	108	Fuel oil shortage
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	36	36	36	36		
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	70	105	70	105		
55	Juldah unit-2 (Accom)	HFO (IPP)	8x13.6	100	100	25	50	25	50		
56	Juldah 100 MW Unit-1 (Accom)	HFO (QRPP)	8x13.45	100	100	22	58	22	55		
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	107	107	107	107		
	Mirsharal 150 MW	HFO (BRPgen)	9x18.5			0	0	0	0		on test
Chattogram Zone Total				2442	2382	743	1259	900	1262	310	404
58	Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	47	47	45	45		
60	Ashuganj 225 MW CAPP	Gas (APSCCL)	1x142+17x 221	221	221	180	194	175	190		
61	Ashuganj 450 MW CAPP(South)	Gas (APSCCL)	1x360	360	360	0	0	0	0	360	Under maint.
62	Ashuganj 450 MW CAPP(North)	Gas (APSCCL)	1x361	360	360	305	275	280	300		
63	Ashuganj 420 MW CAPP(East) GT	Gas (APSCCL)	1x284	284	284	0	0	0	0	284	Gas Shortage
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	40	47	50	50		
65	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20'9.73+1'16	195	195	180	180	190	190		
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	0	0	0	0	51	Gas Shortage
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	72	91	70	100		
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	21	35	32	32		
69	Chandpur 150 MW CAPP	Gas (PDB)	1X106+1x57	163	163	50	50	50	50	57	ST Under maint.
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	51	200	100	180		
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22		
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	10	10	10	10		
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	7	33	33	33		
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	42	8	43		
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	21	20	15	21		
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+66x1.915+15x1.098	200	200	121	70	100	100		
77	Feni 114 MW (Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	17	114	17	114		
78	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	0	0	0	9	113	Fuel Oil Shortage
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17		
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	53	115	53	115		
**	Impoport (Tripura)	India		160	160	120	160	143	166		
Cumilla Zone Total				3193	3169	1342	1722	1410	1787	582	417
81	RPCL 210MW CAPP	Gas (IPP)	4x35+1x70	210	202	32	51	35	70	151	Gas Shortage
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	16	18	18		
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	48	88	50	100		
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	48	98	48	98	102	Fuel oil shortage
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0		
86	Sutahali 50 MW Solar PP	Solar (IPP)	1x50	50	50	0	0	50	0		
87	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	12	12	12	12		
Mymensingh Zone Total				622	614	210	265	215	298	0	0

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	02.11.22 (Yesterday)		03.11.22 (Today)		02.11.22 (Yesterday) Gen. shortfall for : Gas/Coal/Oil/Water Limitation MW	Machines shut down (MW)	Status of Machines under shut-down/ Maintenance			
					Actual Peak Generation (MW)		Probable Peak Generation (MW)				Description/ Remarks	Probable start-up date		
					Day	Evening	Day	Evening						
88	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30	30		40	GT-1 Under maint.		
89	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	43	42	43	43		48	GT-4 Under maint.		
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	0	50	0	0					
91	Kushiara 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0	109	54	STG Under maint.		
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0					
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	56	63	66	65					
94	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.		
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	0	81	0	81					
96	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	145	0	145	145		231	ST Under maint.		
97	Sylhet 20 MW GTPP	Gas (PDB)	1x20	20	20	18	18	18	18					
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10					
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	8	0	8	17		Gas Shortage		
100	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	300	290	290					
101	Bibiyana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	405	410	400	400					
102	Bibiyana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	396	400	400	400					
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work		
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	0	12	0	0	38		Gas Shortage		
105	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12x3.3+5x2	50	50	0	46	0	0	4		Gas Shortage		
Sylhet Zone Total					2522	2477	1403	1470	1402	1500	168	803		
106	Bheramara GTTP Unit- 3	HSD (PDB)	1x20	20	16	0	0	0	0					
107	Bheramara 410 MW CAPP	Gas (NWPGL)	1x278+1x132	410	410	130	255	180	240	155		Gas Shortage		
108	Fariapur 50 MW Peaking PP	HFO (PDB)	8x6.98	50	50	0	31	0	35					
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	75	0	65					
110	Khulna 225 MW CAPP	HSD (NWPGL)	1x150+1x75	230	230	0	0	0	0					
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	20	0	50					
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	57	94	60	94					
113	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	0					
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	83	0	100	0					
115	Khulna 115 MW PP (KPC-2)	HFO (NENP)	7x17	115	115	10	32	0	32	83		Fuel oil shortage		
116	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5x8	40	40	0	8	0	8	32		Fuel oil shortage		
	Rampal 1320 MW	Coal (BHPCL)				0	0	0	0					
	Khulna 330 MW CAPP	Gas/HSD (BPDB)				0	0	0	0					
**	Bheramara (HVDCL) India			1000	1000	913	921	941	941					
Khulna Zone Total					2388	2384	1193	1436	1281	1465	270	110		
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7x17.076	110	110	0	0	0	16		110	Line Overload		
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	17	24	16	22					
119	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	50	21	65	65	173		Gas Shortage		
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	800	940	850	950					
121	Potuskhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	0		150	Line Overload		
	Barisal Electric 307 MW	Coal (IPP)				0	60	0	0					
122	Bhola 220MW CAPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	222	221	220	220					
Barishal Zone Total					1958	1958	1089	1266	1151	1273	173	260		
123	a) Baghabari 71 MW GTPP	Gas (PDB)	1x71	71	71	0	0	0	0	71		Gas Shortage		
	b) Baghabari 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0	100		Gas Shortage		
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	32	0	32					
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	20	0	100					
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	22		71	Under maint.		
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	87	0	86					
128	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	16	24	0	32					
129	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	0	0	50		Fuel Oil Shortage		
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	31	0	25					
131	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	215	200	170	180					
132	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	0	0	0	0	220		Gas Shortage		
133	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0		220	Under maint.		
134	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	142	414	220	300			Gas Shortage		
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	0	0	0	0	22		Gas Shortage		
136	Lilapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0	11		Gas Shortage		
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	8	8	8					
138	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6x18.55	113	113	76	113	95	113					
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	94	35	95					
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	4	0	6	0					
Raishahi Zone Total					2129	2129	496	1023	534	993	474	291		
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1x125	125	85	82	80	80	80					
	b) Barapukuria TPP Unit-2	Coal (PDB)	1x125	125	85	0	0	0	0		85	Under Overhauling		
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1x274	274	274	250	250	250	250			Under maint.		
143	Rangpur 20 MW GTPP	HSD (PDB)	1x20	20	20	0	0	0	0					
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7x16x2x3	113	113	50	71	55	70					
145	Saidpur 20 MW GTPP	HSD (PDB)	1x20	20	20	0	0	0	0					
146	Majpara, Talua 8 MW Solar PP (Sympa Power)	Solar (IPP)	1x8	8	8	7	0	8	0					
147	Thakurgaon 119MW PP (Energypac)	HFO (IPP)	6x20	115	115	113	115	113	115					
148	Lalmohitha 30 MW Solar (Intraco)	Solar (IPP)	1x30	30	30	21	0	12	0					
Rangpur Zone Total					830	750	523	516	518	515	0	85		
Sub-total: Plants in operation					22088	21710	9829.0	11816	10125	12140	3485	3000		
(B) Plants under long term maintenance/ contract expired														
149	Jamalpur 95 MW PP (Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0					
150	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.50	51	0	0	0	0	0					
151	Bosilia 108MW PP (CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0					
152	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	6x13.45	100	0	0	0	0	0					
153	Bogura 20 MW PP (Energyprima)	Gas (NENP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020		
154	Amshura 30 MW PP (Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 1/10/2022		
Sub-Total: Plants under long term maintenance/ contract expired					424	0	0	0	0	0	0	0		
Gross Total					22512	21710	9829	11816	10125	12140	3485	3000		
(C) Actual data of 02.11.22 (Yesterday) Wednesday :														
01.	Max. Demand at eve. peak (Generation end)	:	12160	MW, at =	19:30	hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	11715	MW, at =	19:30	hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	11816	MW, at =	19:30	hrs	Dhaka	4528	4528	0	Mymensingh	932	815	117
04.	Minimum Generation (Generation end)	:	8712	MW, at =	8:00	hrs	Chattogram	1385	1385	0	Sylhet	482	412	70
05.	Day-peak Generation (Generation end)	:	9829	MW, at =	12:00	hrs	Khulna	1221	1221	0	Barishal	302	302	0
06.	Evening-peak Generation (Generation end)	:	11816	MW, at =	19:30	hrs	Rajshahi	1077	1077	0	Rangpur	629	629	0
07.	Evening Peak Load-shed (Sub-station end)	:	317	MW, at =	19:30	hrs	Cumilla	1160	1030	130				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	8666	MW, at =	5:00	hrs					Total	11715	11398	317
09.	Generation shortfall at evening peak due to :	:					13.	Fuel cost :	(a) Gas = 125593233 Taka	(c) Coal = 230066962 Taka				
	a) Gas/LF limitation	:	3485	MW				(b) Oil = 953782513 Taka	Total = 1309442707 Taka					
	d) Coal supply Limitation	:	0	MW										
	b) Low water level in Kaptai lake	:	0	MW										
	c) Plants under shut down/ maintenance	:	3000	MW										
10.	Total Energy (Generation + India Import)	:	240.67	MKWh			14.	Maximum Temperature in Dhaka was :	33.2° C					
	By Gas = 114.253 MKWh			By Oil = 68.718 MKWh			15.	Export through East-West interconnections :						
	By Coal = 29.040 MKWh			By Hydro = 2.922 MKWh				At evening peak-hour :	9829	MW, at	19:30	hrs		
	By Solar = 1.475 MKWh							Maximum	490	MW, at	7:00	hrs		