

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : 28-Nov-22

Page -2

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
1	Ghorasal Repowered CAPP-Unit-3 (GT)	PDB	1260	260	0	0	Under maint.
2	Ghorasal Repowered CAPP-Unit-4	PDB	1210	180	0	0	Line O/L
3	Ghorasal 365 MW CAPP-Unit-7	PDB	1243+1122	365	200	4841600	GBC problem
4	Ghorasal 78.5 MW PP(MAX)	QRPP	240	0	0	0	
5	Ghorasal 108MW PP (Regent)	IPP	343.35	108	22	550955	Gas shortage
6	Haripur GTPP	SBU, PDB	232	0	0	0	Under maint.
7	Haripur 412 MW CAPP	EGCB	1273+1139	412	279	7743490	Gas shortage
8	Haripur 360MW CAPP(HPL)	IPP	1235+1125	360	0	0	Gas shortage
9	Meghnaghat 450 MW CAPP(MPL)	IPP	2150+1150	450	225	4869300	GT-2 S/D due to Gas shortage
10	Meghnaghat 100 MW(HEL)	NENP	12*9	100	82	1230720	Engine problem
11	Meghnaghat CAPP(Summit)	IPP	2110+1110	335	235	5529367	
12	Madanagar 102 MW(Summit)	NENP	6*17	0	102	0	Under maint.
13	Madanagar-55 MW PPS(Summit)	IPP	3*17.08+11*1.3	55	45	1104527	
14	Keraniganj 100 MW PP (Powerpac)	QRPP	8*13.45	0	0	0	Contract Expired
15	Narsingdi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	19	375228	Engine problem
16	210 MW Siddhirganj TFP	PDB	1210	115	0	0	Under maint.
17	Siddhirganj 210 MW GTTP	EGCB	2105	210	0	0	Gas shortage
18	Siddhirganj 100 PP(Dutch) Bangla	NENP	12*9	100	80	1181760	Engine problem
19	Siddhirganj 335 MW CAPP	EGCB	1217+118	335	0	0	Gas shortage
20	Gagnagar 102 MW PP (Digital Power)	IPP	12*8.924	102	50	601920	Fuel shortage
21	Katipoti 52 MW PP (Sinha)	IPP	7*7.9	0	0	0	Fuel shortage
22	Kamalaghat 54 MW PP(Banco Energy)	IPP	3*18	54	17	437400	Fuel shortage
23	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	32	511200	Fuel shortage
24	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	55	733259	Fuel shortage
25	Nabaganj 55 MW PP (Southern power)	IPP	3*19.3	55	55	738561	Fuel shortage
26	Bosila 108MW PP(CLC)	IPP	12*8.775+1*3.5	0	0	0	
27	Summit Power (Madhabdi+Ashulia)	SIPP, REB	3*3.67+4*8.73	80	43	1051800	Engine problem
28	Madhabdi 33 MW PP(Summit)	SIPP, REB	4*8.73	33	33	76700	
29	Ruaganj 30 MW PP(Summit)	SIPP, REB	4*8.73	30	32	697200	Engine problem
30	Gazipur 52 MW PP	RPCL	6*8.9	52	49	916800	0.00
31	Tongi 80 MW GTTP	PDB	1*105	105	0	0	Under maint.
32	Kodda 300 MW PP Unit-2 (Summit)	IPP	18*17.076	300	145	2258182	Engine problem
33	Keraniganj 300 MW PP (APR)	IPP	256*1.4	300	302	2406670	
34	Bramhantha 100 MW PP (Aggreko)	IPP	11*9.959	100	0	0	Fuel conservation
35	Auraha 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	0	0	Fuel conservation
36	Kodda 149 MW PP Unit-1 (Summit)	IPP	8*18.45+8.97	149	60	122848	Engine problem
37	Gazipur 100 MW PP	RPCL	6*17.5	105	105	2039400	
38	Meghnaghat 104 MW PP (OPCL)	IPP	18.5*6	104	17	431040	Fuel shortage
39	Manikganj 162MW PP(MPGL)	IPP	9*18	162	144	1676520	Engine problem
40	Spectro Solar Plant Ltd.	IPP	35	35	0	187173	
41	Kanchan Flatbatal Power Generation Ltd.	IPP	18.4*3	55	17	387800	Fuel shortage
<b>Dhaka area Total</b>				<b>5847</b>	<b>2513</b>	<b>48932770</b>	
41	Chattoagram TTP-1	PDB	1210	180	0	0	Machine problem
42	Chattoagram TTP-2	PDB	1210	180	0	0	Gas shortage
43	Raazan 25 MW PP	RPCL	3*8.9	25	17	362646	Engine problem
44	Takraf 20MW PP (Salarlech)	IPP	20	20	0	81810	
45	Palenga 50MW PP (Baraka)	IPP	8*6.98	50	44	580320	Engine problem
46	Kapali Hydro Unit-1,2,3,4, 5	PDB	2*40+3*50	230	46	1087080	Low water level
47	Sikalbaha 225MW	PDB	1*1150+1*175	225	151	3605782	ST Under maint
48	Sikalbaha Peaking GT	PDB	1*150	150	0	0	Under maint.
49	Sikalbaha 105 MW PP (Baraka Sikalbaha)	IPP	6*17.5	105	87	602236	Engine problem
50	Hathazari -Kalaish 100 MW Peaking	PDB	11*9.9	106	58	644480	Fuel shortage
51	Juldah 100 MW Unit-1 (Accorn)	NENP	8*13.45	100	10	262560	Fuel shortage
52	Juldah 100 MW PP Unit-3 (Accorn)	IPP	8*13.5	100	12	295680	Fuel shortage
53	Barakunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	0	0	Engine problem
54	Malancha, Ctr. EPZ Unit-2	IPP	5*8.73+9.34	0	8	255360	
55	Chattoagram 108 MW PP (ECPV)	IPP	16*7	108	0	0	Fuel shortage
56	Kapali 7 MW Solar PP	PDB	7.4 MW	7	0	20402	
57	Anwara 300 MW PP (United)	IPP	17*17+24	300	283	2062473	Engine problem
58	Jodiak Power	IPP	3*18.55+1*3.6	54	36	774874	Engine problem
59	Kanapahuli Power Ltd.	IPP	18.415*6+8.5	110	74	1444394	Fuel shortage
60	Juldah unit-3 (Accorn)	IPP	8*13.5	100	12	304320	
61	Anlima Energy Ltd.	IPP	6*21.2	116	107	2571818	Engine problem
62	Minshaha 150 MW	BPDB-RPCL	18.5*9	0	0	48509	On test.
<b>Chattoagram area Total</b>				<b>2382</b>	<b>984</b>	<b>15495317</b>	
61	Ashuganj TTP Unit-3	APSCL	1150	0	0	0	Contract Expired
62	Ashuganj TTP Unit-4	APSCL	1150	0	0	0	Contract Expired
63	Ashuganj TTP Unit-5	APSCL	1150	134	0	0	Gas shortage
64	Ashuganj 225 MW CAPP	APSCL	1142+175	221	192	5096000	Gas shortage
65	Ashuganj 450 MW CAPP(North)	APSCL	1*360	360	0	0	Gas shortage
66	Ashuganj 450 MW CAPP(South)	APSCL	1*360	360	310	6098000	Gas shortage
67	Ashuganj 420 MW CAPP(East)	APSCL	284*1+136*1	284	288	6920200	On test.
68	Ashuganj 50 MW PP	APSCL	14*3.968	45	5	217368	Gas shortage
69	Ashuganj 150 MW PP (Precision)	QRPP	5*15	55	5	151200	Gas shortage
70	Ashuganj 195MW PP (APSCL-United)	IPP	20*9.73+1*16	195	8	117000	Gas shortage
71	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	5	154361	Gas shortage
72	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	88	1789818	Fuel shortage
73	Titas 50 MW Peaking PP	PDB	6*8.92	52	21	338672	Engine problem
74	Chandpur 150 MW CAPP	PDB	1*1106+1*57	163	84	1793070	Machine problem
75	Chandpur 200MW (Desh energy)	IPP	12*18.4	136	136	859200	High voltage
76	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	19	477540	
77	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	10	246240	
78	Impoport (Tripura)	Imported power	0	160	118	2371200	
79	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	28	617800	
80	Jangalia 33 MW PP (Lakshmi)	IPP	6*8.92	52	8	208694	Fuel shortage
81	Cumilla 25 MW PP (Summit)	SIPP, REB	3*3.67+2*6.97	25	15	347980	Engine problem
82	Daudkandi 200 MW PP (B. Trac)	IPP	15*41.4	200	120	1422440	Fuel conservation
83	Feni Lanka Power	IPP	7*18.415+1*9.78	114	17	428640	Fuel shortage
84	Chowmuhani 113 MW	IPP	12*9.78+2*3.1	113	75	2140320	Engine problem
85	Bharob 54.5 MW	IPP	3*18.2	54	17	418880	Engine problem
86	Chandpur 115 (Doreen)	IPP	4*18.5+2*22.5	115	115	1194240	
<b>Cumilla Area Total</b>				<b>3169</b>	<b>1664</b>	<b>33138553</b>	
87	RPCL 210MW CAPP	IPP	4*35+1*70	202	46	1441920	Gas shortage
88	Tangal 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	6	182448	Gas shortage
89	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.924	0	0	0	Under maint.
90	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	13000	
91	Mymensingh 200 MW PP (United)	IPP	9*78*21	58	200	1098800	Fuel shortage
92	Jamalpur 115 MW PP (United)	IPP	9*78*12	115	58	1251600	Fuel shortage
93	Suliakhali 50 MW Solar PP	IPP	50	50	0	297310	
94	Tangal Pali Power Gen 22 MW	IPP	4*6.7	22	12	292320	Engine problem
<b>Mymensingh Area Total</b>				<b>614</b>	<b>180</b>	<b>4575398</b>	
91	Fenchuganj CAPP Phase-1	PDB	2*32+1*33	70	30	716000	Machine problem
92	Fenchuganj CAPP Phase-2	PDB	2*35+1*35	43	90	876800	Machine problem
93	Kushkhara 163 MW CAPP (KP)	IPP	1109+1154	163	85	1537445	Gas shortage
94	Shahjibazar 330 MW CAPP	PDB	3*110	330	0	0	Under maint.
95	Fenchuganj 51 MW PP (Barakatullah)	RPP	19*2.90	51	53	1239000	
96	Fenchuganj 44MW (Energyprima)	NENP	12*3.3+5.2	50	40	996408	Gas shortage
97	Haldiganj 11MW PP (Confidence-E)	SIPP, REB	4*2.90	11	9	192388	Gas shortage
98	Shahjibazar GTTP Unit-1 & 9	PDB	2*35	86	88	168216	
99	Shahjibazar 86MW PP (Shahjibazar)	RPP	32*2.90	86	86	1407360	
100	Shahjibazar 100 MW GTTP	PDB	1*100	100	0	0	Under maint.
101	Sylhet 225 MW CAPP	PDB	1*142+1*89	231	0	0	Machine problem
102	Sylhet 20 MW GTTP	PDB	1*20	20	18	429900	
103	Sylhet 50MW PP (EPL)	NENP	2*72	50	32	726700	
104	Shahjahanulla 25 MW PP	SIPP, REB	3*9.34	25	24	544560	Gas shortage
105	Bibiana-II 341 MW CAPP (Summit)	IPP	1*222+1*119	341	0	0	Under maint.
106	Bibiyana-III 400 MW CAPP	PDB	400 MW	400	421	9888000	
107	Sylhet 10MW PP (Desh)	RPP	6*1.95	10	10	242460	
108	Bibiyana South 400 MW	PDB	400 MW	383	380	9395000	
<b>Sylhet Area Total</b>				<b>2477</b>	<b>1298</b>	<b>28991837</b>	
107	Bheramara GTTP Unit-3	PDB	120	16	0	0	Fuel shortage
108	Bheramara (HVDC)	Imported power	2*500	1000	888	20284363	
109	Khulna 115 PP MW (KPCL-2)	NENP	7*17	115	81	438720	Engine problem
110	Fardpur 50 MW Peaking PP	PDB	6*8.89	54	39	222720	Line O/L
111	Khulna 225 MW CAPP	NWPGCL	1150+175	230	0	0	Fuel shortage
112	Casapara 100 MW Peaking PP	PDB	1*61.98	109	75	534272	Engine problem
113	Bheramara 410 MW CAPP	NWPGCL	1278+1132	410	160	4166496	Gas shortage
114	Noapara 40 MW PP (Khanjahan Ali)	NENP	5*8.5	40	0	74250	Engine problem
115	Noapara 100 MW PP (Bangla Trac)	IPP	70*1.4	100	89	624000	Fuel conservation
116	Rupsha 105 MW PP (Orion rupsha)	IPP	6*18.445	105	75	1331040	High voltage
117	Madhumati 100 MW PP	NWPGCL	6*18	105	0	0	Fuel shortage
118	Mongia Orion 100 MW Solar PP	IPP	100	100	0	450720	
119	Khulna 330 MW CAPP (DIL)	BPDB	1220+1110	0	0	0	On test.
120	Rampal 1320 MW (BIFPCL)	NTPC&BPDB	0	0	0	0	On test.
<b>Khulna Area Total</b>				<b>2384</b>	<b>1407</b>	<b>28126581</b>	
117	Barisal 110 MW PP (Summit)	IPP	7*17.076	110	0	0	Line O/L
118	Bhola 33 MW PP (Venture)	NENP	1*34.50	40	18	362800	Engine problem
119	Bhola 225 MW CAPP	PDB	2*63+1*68	194	81	2052581	Gas shortage
120	Bhola 95 MW PP (Aggreko)	QRPP	96*1.10	0	0	0	Contract Expired
121	Payra 1320 MW	BCPCL	2*622	1244	460	9892300	Line O/L
122	Bhola Nutan Biddut BD LTD	IPP	220	220	221	5175000	
123	United Payra Power Ltd.	IPP	6*18.5+1*9.5	150	0	0	Line O/L
124	Barisal 307 MW	BCPCL	0	0	0	0	On test.
<b>Barisal Area Total</b>				<b>1958</b>	<b>780</b>	<b>17472681</b>	
124	Baghabari 71 MW GTTP	PDB	1*71	71	0	0	Gas shortage
125	Baghabari 100 MW GTTP	PDB	1*100	100	0	0	Gas shortage
126	Baghabari 50 MW Peaking PP	PDB	6*8.9	52	32	121232	Engine problem
127	Bera 70 MW Peaking PP	PDB	9*8.29	71	18	68984	
128	Amnara 50 MW PP (Sinha)	QRPP	7*7.9	0	0	0	Contract Expired
129	Katahal 50 MW PP (Northern)	QRPP	6*8.9	50	50	631331	Engine problem
130	Katahal 50 MW Peaking PP	PDB	6*8.7	50	40	168241	Engine problem
131	Sirajgonj Unit-1 225MW	NWPGCL	1150+175	210	167	4228918	Gas shortage
132	Sirajgonj Unit-2 225MW	NWPGCL	1150+175	220	0	0	
133	Sirajgonj Unit-3 225MW	NWPGCL	1141	220	0	0	Gas shortage
134	Sirajgonj 400 MW CAPP Unit-4	SNWPGCL	1262+1132	414	232	5752509	Gas shortage
135	Santalar 50 MW Peaking PP	IPP	6*8.7	50	27	231777	Engine problem
136	Bogra 22 MW PP (GBB)	RPP	6*4	22	22	443040	
137	Bogra 20 MW PP (Energyprima)	NENP	5*3.3+5.2	0	0	0	
138	Ullapara 11 MW PP (Summit)	SIPP, REB	4*2.90	11	11	239382	