Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month November, 2022 | Day : **Wednesday** | Date : **30.11.22**

Probable Maximum Demand : 10500 MW | **Probable Maximum Generation :** 11201 MW

Water Level of Kaptai Lake at 06:00 AM | Yesterday = 89.85 ft | Today = 89.79 ft | Rule Curve = 106.20 ft.

Sl. No.	Name of Power Station			Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	29.11.22 (Yesterday) Actual Peak Generation (MW)		30.11.22 (Today) Probable Peak Generation (MW)		29.11.22 (Yesterday) Gen. shortfall for :		Status of Machines under shut-down/ Maintenance	
							Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date
(A)	**Plants in operation:**													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas	(PDB)	1 x 260	260	260	0	0	0	0		260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas	(PDB)	1 x 210	210	180	0	0	0	0			Line Overload	
	b) Ghorasal TPP Unit-5	Gas	(PDB)	1 x 210	210	190	180	180	180	180				
3	Ghorasal 365 MW CCPP Unit-7	Gas	(PDB)	1x 254+1x 126	365	365	200	200	200	200		165	Under maint.	
4	Ghorashal 108MW PP (Regent)	Gas	(IPP)	34x3.35	108	108	22	22	22	22				
5	Tongi 80 MW GTPP	Gas	(PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage	
6	Haripur GTPP	Gas	(PDB)	1 x 32	32	20	0	0	0	0			Contract Expired	
7	Haripur 360MW CCPP(HPL)	Gas	(IPP)	1x235+1x125	360	360	0	0	0	0	360		Gas Shortage	
8	Meghnaghat 450 MW CCPP(MPL)	Gas	(IPP)	2x140+1x170	450	450	225	225	225	225	225		Gas Shortage	
9	210 MW Siddhirgonj TPP	Gas	(PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas	(EGCB)	1x273+1x139	412	412	309	279	300	280	133		Gas Shortage	
11	Siddhirgonj 2*120 MW GTPP	Gas	(EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage	
12	Siddhirganj 335 MW CCPP	Gas	(EGCB)	1 x 217+1x118	335	335	0	0	0	0	335		Gas Shortage	
13	Meghnaghat CCPP(Summit)	GAS	(IPP)	2x110+1x110	335	335	230	205	250	205	130		Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO	(IPP)	5x17.08+1x11.3	55	55	45	45	45	45				
15	Gagnagar 102 MW PP (Digital Power)	HFO	(IPP)	12x8.924	102	102	32	33	33	50				
16	Narshingdi 22 MW PP (Doreen)	Gas	(SIPP, REB)	8x2.90	22	22	19	16	16	16				
17	Summit Power,(Madhabdi+Ashulia)	Gas	(SIPP, REB)	6x3.67+7x8.73	80	80	47	44	46	46				
18	Maona 33 MW PP(Summit)	Gas	(SIPP, REB)	4x8.73	33	33	25	33	25	33				
19	Rupganj 33 MW PP(Summit)	Gas	(SIPP, REB)	4x8.73	33	33	23	25	25	25				
20	Gazipur 52 MW PP	HFO	(RPCL)	6x8.90	52	52	41	49	44	50				
21	Gazipur 100 MW PP	HFO	(RPCL)	6x18.415	105	105	88	105	88	105				
22	Kodda 150MW PP	HFO	(BRPgen)	9x17.06	149	149	32	32	32	32				
23	Kamalaghat 54 MW PP (Banco Energy)	HFO	(IPP)	3x18.69	54	54	17	54	17	54				
24	Kodda 300 MW PP Unit-2 (Summit)	HFO	(IPP)	18x17.076	300	300	80	145	95	285				
25	Kodda 149 MW PP Unit-1 (Summit)	HFO	(IPP)	8x18.415+1x8.97	149	149	43	61	45	64				
26	Keranigonj 300 MW PP (APR)	HSD	(IPP)	256x1.4	300	300	296	145	300	150				
27	Bramhangoan 100 MW PP (Aggreko)	HSD	(IPP)	23x0.85+91x.959	100	100	0	60	100	50				
28	Aurahati 100MW PP (Aggreko)	HSD	(IPP)	23x0.85+91x.959	100	100	0	0	0	50				
29	Nababganj 55 MW PP (Southern power)	HFO	(IPP)	3x19.3	55	55	35	55	35	55				
30	Manikganj 55 MW PP (Northern)	HFO	(IPP)	3x19.3	55	55	35	55	35	55				
31	Meghnaghat 104 MW PP (OPSL)	HFO	(IPP)	6x18.5	104	104	25	17	17	17				
32	Manikgonj 162MW PP(MPGL)	HFO	(IPP)	9x18	162	162	90	162	90	162				
33	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar	(IPP)	1x35	35	35	29	0	30	0				
34	Kanchan Purbachal Power Generation Ltd.	HFO	(IPP)	3x19.404	55	55	17	30	17	30				
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO	(NENP)	12x8.9	100	100	70	74	80	80				
36	Meghnaghat 100 MW(IEL)	HFO	(NENP)	12x8.9	100	100	66	73	73	73				
37	Madanganj 102 PP(Summit)	HFO	(NENP)	6x17	102	102	0	0	0	0				
	Dhaka Zone Total				**6004**	**5847**	**2321**	**2424**	**2465**	**2639**	**1498**	**540**		
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro	(PDB)	2x40, 3x50	230	230	46	46	46	46	184		Low water level	
39	a) Chattogram TPP-1	Gas	(PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage	
	b) Chattogram TPP-2	Gas	(PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.	
40	Kaptai 7 MW Solar PP	Solar	(PDB)		7	7	3	0	5	0				
41	Raozan 25 MW PP	HFO	(RPCL)	3x8.9	25	25	17	17	17	17				
42	Teknaf 20MW PP (Solartech)	Solar	(IPP)	1x20	20	20	16	0	20	0				
43	Patenga 50MW PP (Baraka)	HFO	(IPP)	8x6.89	50	50	19	44	26	44				
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO	(IPP)	6x18.415	105	105	17	105	17	105				
45	Shikalbaha Peaking GT	Gas	(PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.	
46	Sikalbaha 225 MW CCPP	Gas	(PDB)	1 x 150+1 x 75	225	225	151	151	151	151		74	STG Under maint.	
47	Anwara 300 MW PP (United)	HFO	(IPP)	17x17.076+ 3x8.04	300	300	232	298	200	290				
48	Juldah 100 MW PP Unit-3 (Acorn)	HFO	(IPP)	8x13.45	100	100	12	12	12	12				
49	Dohazari -Kalaish 100 MW Peaking	HFO	(PDB)	6x17.0	102	102	0	51	17	51				
50	Hathazari 100 MW peaking PP	HFO	(PDB)	11x8.9	98	98	24	24	22	60				
51	Barabkunda 22 MW PP (Regent)	Gas	(SIPP, PDB)	8x2.90	22	22	0	0	0	0	22		Gas Shortage	
*	Malancha, Ctg.EPZ (United)	Gas		5x8.73+3x9.34			2	10	2	10				
52	Chattogram 108 MW PP (ECPV)	HFO	(IPP)	16x7.00	108	108	0	0	0	0				
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO	(IPP)	3x18.55+1x3.6	54	54	54	36	36	36				
54	Karnaphuli Power Ltd.	HFO	(IPP)	6x18.41+1x6.4	110	110	55	73	53	74				
55	Juldah unit-2 (Acorn)	HFO	(IPP)	8x13.6	100	100	12	12	12	12				
56	Juldah 100 MW Unit-1 (Acorn)	HFO	(QRPP)	8x13.45	100	100	10	10	10	10				
57	Chattogram 116 MW PP (Anlima Energy Ltd.)	HFO	(IPP)	6x21.06	116	116	89	107	89	107				
	Mirsharai 150 MW	HFO	(BRPgen)	9x18.5			9	0	0	0			on test	
	Chattogram Zone Total				**2442**	**2382**	**768**	**996**	**735**	**1025**	**386**	**404**		
58	Ashuganj TPP Unit- 5	Gas	(APSCL)	1 x 150	150	134	0	0	0	0	134		Gas Shortage	
59	Ashuganj 50 MW PP	Gas	(APSCL)	14x3.968	53	45	44	5	43	43	40		Gas Shortage	
60	Ashuganj 225 MW CCPP	Gas	(APSCL)	1×142+1*75	221	221	221	149	190	200				
61	Ashuganj 450 MW CCPP(South)	Gas	(APSCL)	1x360	360	360	305	275	270	280				
62	Ashuganj 450 MW CCPP(North)	Gas	(APSCL)	1x361	360	360	0	200	200	330				
63	Ashuganj 420 MW CCPP(East) GT	Gas	(APSCL)	1x284	284	284	0	0	0	0				
64	Ashuganj 55 MW PP (Precision)	Gas	(RPP)	15*4	55	55	48	5	30	30	50		Gas Shortage	
65	Ashuganj 195MW PP (APSCL-United)	Gas	(IPP)	20*9.73+1*16	195	195	81	8	60	60	187		Gas Shortage	
66	Ashuganj 51 MW PP (Midland)	Gas	(IPP)	6x9.34	51	51	5	5	5	5	46		Gas Shortage	
67	Ashuganj 150MW PP (Midland)	HFO	(IPP)	23x7.015	150	150	85	149	80	149				
68	Titas 50 MW Peaking PP	HFO	(PDB)	6x8.92	52	52	22	36	21	30				
69	Chandpur 150 MW CCPP	Gas	(PDB)	1X106+1x57	163	163	70	64	70	70		57	ST Under maint.	
70	Chandpur 200MW (Desh energy)	HFO	(IPP)	12x18.415	200	200	17	155	17	200				
71	Feni 22MW PP (Doreen)	Gas	(SIPP, PDB)	8x2.90	22	22	19	22	19	21				
72	Feni 11 MW PP (Doreen)	Gas	(SIPP, REB)	4x2.90	11	11	10	10	11	11				
73	Jangalia 33MW PP (Summit)	Gas	(SIPP, PDB)	4x8.73	33	33	15	25	25	25				
74	Jangalia 52 MW PP (Lakdanavi)	HFO	(IPP)	6x8.92	52	52	8	8	8	8				
75	Cumilla 25 MW PP (Summit)	Gas	(SIPP, REB)	3x3.67+2x6.97	25	25	15	15	15	15				
76	Daudkandi 200 MW PP (B.Trac)	HSD	(IPP)	99x1.4+40x1.515+15x1.056	200	200	160	30	100	100				
77	Feni 114 MW (Lakdanavi)	HFO	(IPP)	7*18.415+1*9.78	114	114	17	99	17	99				
78	Chowmuhani 113 MW	HFO	(IPP)	12*9.78+2*3.1	113	113	101	115	104	113				
79	Bhairob 54 MW PP	HFO	(IPP)	3x18.2	54	54	17	36	17	36				
80	Chandpur 115MW PP (Doreen)	HFO	(IPP)	4x18.516+2x25.428	115	115	115	114	34	115				
**	Impoprt (Tripura)		India		160	160	108	124	143	166				
	Cumilla Zone Total				**3193**	**3169**	**1483**	**1649**	**1479**	**2106**	**457**	**57**		
81	RPCL 210MW CCPP	Gas	(IPP)	4x35+1x70	210	202	34	53	33	60	149		Gas Shortage	
82	Tangail 22 MW PP (Doreen)	Gas	(SIPP, PDB)	8x2.90	22	22	8	9	7	7				
83	Jamalpur 115 MW PP (United)	HFO	(IPP)	12x9.87	115	115	59	59	49	58				
84	Mymensingh 200 MW PP (United)	HFO	(IPP)	21x9.780	200	200	57	58	48	57				
85	Sarishabari 3 MW Solar Plant	Solar	(IPP)	1x3	3	3	2	0	1.6	0				
86	Sutiakhali 50 MW Solar PP	Solar	(IPP)	1x50	50	50	37	0	50	0				
87	Tangail 22 MW PP(PPGL)	HFO	(IPP)	4x6.7	22	22	12	12	12	12				
	Mymensing Zone Total				**622**	**614**	**209**	**191**	**201**	**194**	**149**	**0**		

Sl. No.	Name of Power Station			Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	29.11.22 (Yesterday) Actual Peak Generation (MW)		30.11.22 (Today) Probable Peak Generation (MW)		29.11.22 (Yesterday) Gen. shortfall for :		Status of Machines under shut-down/ Maintenance	
							Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date
88	Fenchugonj CCPP Phase-1	Gas	(PDB)	2x32+1x33	97	70	30	30	30	30		40	GT-1 Under maint.	
89	Fenchugonj CCPP Phase-2	Gas	(PDB)	2x35+1x35	104	90	0	0	0	0		90	GT-4 Under maint.	
90	Fenchugonj 51 MW PP (Barakatullah)	Gas	(RPP)	19x2.90	51	51	53	53	51	51				
91	Kushiara 163 MW CCPP (KP)	Gas	(IPP)	1x109+1x54	163	163	85	85	85	85	109	54	STG Under maint.	
92	Hobiganj 11MW PP Cofidence-E	Gas	(SIPP, REB)	4x2.90	11	11	8	8	8	8				
93	Shahjibazar GTPP Unit- 8 & 9	Gas	(PDB)	2x35	70	66	65	66	66	66				
94	Shajibazar 330 MW CCPP	Gas	(PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas	(RPP)	32x2.90	86	86	0	84	0	86				
96	Sylhet 225 MW CCPP	Gas	(PDB)	1x142+1x89	231	231	0	0	0	0				
97	Sylhet 20 MW GTPP	Gas	(PDB)	1 x 20	20	20	18	18	18	18				
98	Sylhet 10MW PP (Desh)	Gas	(RPP)	6x1.95	10	10	10	10	10	10				
99	Shahjahanulla 25 MW PP	Gas	(CIPP, REB)	3x9.34	25	25	22	24	21	24				
100	Bibiana-II 341 MW CCPP (Summit)	Gas	(IPP)	1x222+1x119	341	341	0	0	0	0		341	Major Inspection	31/12/2022
101	Bibiyana-III 400 MW CCPP	Gas	(PDB)	1x285+1x115	400	400	423	421	400	400				
102	Bibiyana South 383 MW CCPP	Gas	(PDB)	1x252+1x131	383	383	360	400	400	400				
103	Shahjibazar 100 MW GTPP	Gas	(PDB)	1x100	100	100	0	0	0	0		100	Under project work	
104	Sylhet 50MW PP (EPL)	Gas	(NENP)	2x27	50	50	31	32	32	32				
105	Fenchuganj 44MW (Energyprima)	Gas	(NENP)	12*3.3+5*2	50	50	40	42	40	40				
	Sylhet Zone Total				**2522**	**2477**	**1145**	**1273**	**1161**	**1250**	**109**	**955**		
106	Bheramara GTPP Unit- 3	HSD	(PDB)	1 x 20	20	16	0	0	0	0				
107	Bheramara 410 MW CCPP	Gas	(NWPGCL)	1 x 278+1 x 132	410	410	160	160	160	160	250		Gas Shortage	
108	Faridpur 50 MW Peaking PP	HFO	(PDB)	8x6.98	54	54	0	34	0	40				
109	Gopalganj 100 MW Peaking PP	HFO	(PDB)	16x6.98	109	109	0	65	0	75				
110	Khulna 225 MW CCPP	HSD	(NWPGCL)	1 x 150+1x75	230	230	0	0	0	0				
111	Noapara 100 MW PP (Bangla Trac)	HSD	(IPP)	70x1.4+7x1.515	100	100	50	0	0	50				
112	Rupsha 105 MW PP (Orion rupsha)	HFO	(IPP)	6x18.445	105	105	56	75	56	75				
113	Madhumati 100 MW PP	HFO	(NWPGCL)	6x18.415	105	105	0	0	0	0				
114	Mongla Orion 100 MW Solar PP	Solar	(IPP)		100	100	70	0	100	0				
115	Khulna 115 MW PP (KPCL-2)	HFO	(NENP)	7x17	115	115	16	32	16	32				
116	Noapara 40 MW PP (Khanjahan Ali)	HFO	(NENP)	5*8.5	40	40	0	8	0	8				
	Rampal 1320 MW	Coal	(BIFPCL)				0	443	400	400				
	Khulna 330 MW CCPP	Gas/HSD	(BPDB)				0	0	0	0				
**	Bheramara (HVDC)		India		1000	1000	902	893	910	910				
	Khulna Zone Total				**2388**	**2384**	**1254**	**1710**	**1642**	**1750**	**250**	**0**		
117	Barisal 110 MW PP (Summit)	HFO	(IPP)	7 x 17.076	110	110	0	0	0	0		110	Line Overload	
118	Bhola 33 MW PP (Venture)	Gas	(NENP)	1x34.50	40	40	12	19	15	19				
119	Bhola 225 MW CCPP	Gas	(PDB)	2x63+1x68	194	194	80	80	86	86	114		Gas Shortage	
120	Payra 1320 MW TPP	Coal	(BCPCL)	2x622	1244	1244	350	520	622	622				
121	Potuakhali 150MW PP (UPPL)	HFO	(IPP)	8x18.415+1x9.78	150	150	0	0	0	0		150	Line Overload	
	Barisal Electric 307 MW	Coal	(IPP)				0	0	0	0				
122	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD	(IPP)	2x75+1x70	220	220	160	222	200	220				
	Barishal Zone Total				**1958**	**1958**	**602**	**841**	**923**	**947**	**114**	**260**		
123	a) Baghabari 71 MW GTPP	Gas	(PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas	(PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
124	Baghabari 50 MW Peaking PP	HFO	(PDB)	6x8.9	52	52	0	32	0	32				
125	Baghabari 200 MW PP (Paramount)	HSD	(IPP)	135x1.6	200	200	0	0	0	0				
126	Bera 70 MW Peaking PP	HFO	(PDB)	9x8.29	71	71	0	16	0	20				
127	Chapainawabganj 100 MW Peaking PP	HFO	(PDB)	12x8.924	104	104	0	0	0	100				
128	Katakhali 50 MW Peaking PP	HFO	(PDB)	6x8.7	50	50	0	32	0	32				
129	Katakhali 50 MW PP (Northern)	HFO	(QRPP)	6x8.9	50	50	8	34	34	34				
130	Santahar 50 MW Peaking PP	HFO	(PDB)	6x8.7	50	50	0	26	0	35				
131	Sirajgonj 225MW CCPP Unit-1	Gas	(NWPGCL)	1x150+1x75	210	210	166	161	165	165				
132	Sirajgonj 225MW CCPP Unit-2	Gas	(NWPGCL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage	
133	Sirajgonj 225MW CCPP Unit-3	Gas	(NWPGCL)	1x141+1x79	220	220	0	0	0	0		220	Under maint.	
134	Sirajgonj 400 MW CCPP Unit-4	Gas	(IPP)	1x282+1x132	414	414	228	233	230	230	181		Gas Shortage	
135	Bogra 22 MW PP (GBB)	Gas	(RPP)	6x4.0	22	22	16	22	20	22				
136	Ullapara 11 MW PP (Summit)	Gas	(SIPP, REB)	4x2.90	11	11	11	11	11	11				
137	Natore 52 MW PP (Rajlanka)	HFO	(IPP)	6x8.92	52	52	8	43	8	43				
138	Bagura 113 MW (Confidence) U-1	HFO	(IPP)	6*18.55	113	113	35	95	35	95				
139	Bagura 113 MW PP (Confidence) U-2	HFO	(IPP)	6x18.55	113	113	50	113	50	113				
140	Sirajgonj 6.55 MW Solar	Solar	(NWPGCL)	1x6	6	6	4	0	6	0				
	Rajshahi Zone Total				**2129**	**2129**	**526**	**818**	**559**	**932**	**572**	**220**		
141	a) Barapukuria TPP Unit-1	Coal	(PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal	(PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
142	Barapukuria 275 MW TPP Unit-3	Coal	(PDB)	1 x 274	274	274	160	160	160	160	114		Coal Shortage	
143	Rangpur 20 MW GTPP	HSD	(PDB)	1 x 20	20	20	0	0	0	0				
144	Rangpur 113 MW PP (Confidence)	HFO	(IPP)	7*16x 2*3	113	113	34	77	34	85				
145	Saidpur 20 MW GTPP	HSD	(PDB)	1 x 20	20	20	0	0	0	0				
146	Majipara, Tatulia 8 MW Solar PP (Sympa Power)	Solar	(IPP)	1 x 8	8	8	6	0	8	0				
147	Thakurgaon 115MW PP (Energypac)	HFO	(IPP)	6*20	115	115	0	115	0	113				
148	Lalmonirhat 30 MW Solar (Intraco)	Solar	(IPP)	1*30	30	30	27	0	30	0				
	Rangpur Zone Total				**830**	**750**	**227**	**352**	**232**	**358**	**199**	**85**		
	Sub-total: Plants in operation				**22088**	**21710**	**8535.0**	**10254**	**9397**	**11201**	**3734**	**2521**		
(B) Plants under long term maintenance/ contract expired														
149	Jamalpur 95 MW PP(Powerpac)	HFO	(IPP)	12x8.924	95	0	0	0	0	0				
150	Katpotti 52 MW PP (Sinha)	HFO	(IPP)	7x7.90	51	0	0	0	0	0				
151	Bosila 108MW PP(CLC)	HFO	(IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
152	Keraniganj 100 MW PP (Powerpac)	HFO	(QRPP)	8x13.45	100	0	0	0	0	0				
153	Bogura 20 MW PP (Energyprima)	Gas	NENP	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
154	Amnura 50 MW PP(Sinha)	HFO	(QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022	
	Sub-Total: Plants under long term maintenance/ contract expired				424	0	0	0	0	0				
	Gross Total				**22512**	**21710**	**8535**	**10254**	**9397**	**11201**	**3734**	**2521**		

(C)	Actual data of 29.11.22 (Yesterday) Tuesday :					
01.	Max. Demand at eve. peak (Generation end)	:	10254	MW, at =		20:00 hrs
02.	Max. Demand at eve. peak (Sub-station end)	:	9744	MW, at =		20:00 hrs
03.	Highest Generation (Generation end)	:	10254	MW, at =		20:00 hrs
04.	Minimum Generation (Generation end)	:	7048	MW, at =		5:00 hrs
05.	Day-peak Generation (Generation end)	:	8535	MW, at =		12:00 hrs
06.	Evening-peak Generation (Generation end)	:	10254	MW, at =		20:00 hrs
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW, at =		20:00 hrs
08.	Minimum Generation Forecast up to 8:00 hrs.	:	7167	MW, at =		5:00 hrs
09.	Generation shortfall at evening peak due to :	:				
	a) Gas/LF limitation	:	3351	MW		
	d) Coal supply Limitation	:	199	MW		
	b) Low water level in Kaptai lake	:	184	MW		
	c) Plants under shut down/ maintenance	:	2521	MW		
10.	Total Energy (Generation + India Import)	:	205.18	MKWh		
	By Gas = 107.452 MKWH		By Oil =	51.177 MKWh		
	By Coal = 21.601 MKWH		By Hydro =	1.100 MKWh		
	By Solar= 1.140 MKWH					
11.	Total Gas Supplied	:	854.50	MMCFD		

12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
Dhaka	3788	3788	0	Mymensingh	699	699	0
Chattogram	1152	1152	0	Sylhet	380	380	0
Khulna	1050	1050	0	Barishal	265	265	0
Rajshahi	921	921	0	Rangpur	592	592	0
Cumilla	897	897	0				
				Total	**9744**	**9744**	**0**

13.	Fuel cost :	(a) Gas = 120897393 Taka		(c) Coal = 114181663	Taka
		(b) Oil = 712997447 Taka		Total = 948076503	Taka
14.	Maximum Temperature in Dhaka was :	29.8° C			
15.	Export through East-West interconnections :				
	At evening peak-hour	:	8535	MW, at	20:00 hrs
	Maximum	:	310	MW, at	11:00 hrs
	Energy	:	0	MKWh	

(D)	Forecast of 30.11.22 (Today) Wednesday :				
01.	Maximum Demand	:	10500	MW	(Generation end)
02.	Maximum Generation	:	11201	MW	(Generation end)
03.	Reserve / Shortage	:	701	MW	(Generation end)
04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)
05.	Total Generation	:	210.10	MKWh	
06.	Probable Max. Temperature in Dhaka :		29.6° C		

* Captive Power ** Imported Power

#Remarks: Highest Generation 14782 MW on 16-04-2022 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation