POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT

21:00 Hrs on 16-Apr-22

Today's Actual Min Gen. & Probable Gen. & Demand
Min. Gen. at
Available Max Generation
Max Demand (Evening):
Reserve(Generation end)
Load Shed 31-Jan-23 Till now the maximum generation is: The Summary of Yesterday's
Day Peak Generation:
Evening Peak Generation:
E.P. Demand (at gen end):
Maximum Generation:
Total Gen. (MKWH): 14782.0 30-Jan-23 Generation & Demand
9051.0 MW
10330.0 MW
10496.0 MW
10330.0 MW 6945 10834 10500 334 Hour : Hour : Hour : 12:00 19:00 19:00 19:00 208.9 System Load Factor : 84.24% EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR 0 Export from East grid to West grid :- Maximum
Import from West grid to East grid :- Maximum
Water Level of Kaptai Lake at 6:00 A M on 750 MW MW 7:00 Energy Energy 31-Jan-23 Actual : Ft.(MSL), Rule curve Ft.(MSL)

Gas Consumed : Total = 859.20 MMCFD. Oil Consumed (PDB):

HSD : FO :

Tk115,331,533 Tk292,586,051 Cost of the Consumed Fuel (PDB+Pvt) :

83.67

Total : Tk844,735,068

Load Shedding & Other Information

Area	Yesterday		Today		
			Estimated Demand (S/S end)	Estimated Shedding (S/S end)	Rates of Shedding
	MW		MW	MW	(On Estimated Demand)
Dhaka	0	0:00	3266	0	0%
Chittagong Area	0	0:00	925	0	0%
Khulna Area	0	0:00	1221	0	0%
Rajshahi Area	0	0:00	1083	0	0%
Cumilla Area	0	0:00	922	0	0%
Mymensingh Area	153	0:00	762	0	0%
Sylhet Area	0	0:00	341	0	0%
Barisal Area	0	0:00	278	0	0%
Rangpur Area	0	0:00	602	0	0%
Total	153		9400	0	

Information of the Generating Units under shut down.

Forced Shut- Down
1) Barapukuria ST: Unit- 2
2) Ghorasal- 3
3) Ashuganj- 5
4) Baghabar-70,100 MW
5) Raozan unit- 2
6) Siddhirganj 210 MW .
7) Shajibazar 330 MW
8) Sirajganj-1,2

97.20

Oil : Tk436,817,485

Outage	Restore	Additional Information of Machines, lines, Interruption / Forced Load shed etc.	Remai
Time	Time		
08:10	18:04	Bogura-Sirajganj 230 kV Ckt-1 Project Work S/D from Bogura 230/132kV end Due to Maintenance work. (Isolator	
		Replacement) and from Sirajgonj 230 end Due to Isolator Change on Bogura s/s end.	
08:15		Bibiyana-Fenchuganj 230 kV Ckt-1 Scheduled S/D from Fenchuganj 230/132/33kV end Due to annual maintenance	
		deadline checking and from Bibiana 400/230kV end Due to Annual Maintenance .	
	08:18	Savar 132/33kV S/S T-3 LT is restored.	
08:25 18:20		Ashuganj-Bhulta 400 kV Ckt-2 Scheduled S/D from Bhulta 400/230kV end Due to Dead line checking from Bhulta SS end.	
	08:30	Ashuganj-Cumilla(N) 230 kV Ckt-1 is restored.	
	08:30	Ashuganj-Cumilla(N) 230 kV Ckt-2 is restored.	
08:31		Ashuganj-Cumilla(N) 230 kV Ckt-2 Scheduled S/D from Cumilla(N) 230/132/33kV end Due to Line check due to trip.	
08:31	17:38	Ashuganj-Cumilla(N) 230 kV Ckt-1 Scheduled S/D from Cumilla(N) 230/132/33kV end Due to line check due to Trip.	
08:39	17:09	Aminbazar-Kaliakoir 230kV Ckt-1 Scheduled S/D from Kaliakoir 400/230/132kV end Due to Annual Maintenance.	
08:42	18:04	Barishal-Bhola 230 kV Ckt-2 Scheduled S/D from Barishal 230/132kV end Due to Annual Maintenance Work.	
08:59	17:46	Anowara-Sikalbaha 230 kV Ckt-1 Scheduled S/D from Shikalbaha 230/132kV end Due to Deadline checking.	
09:05	14:21	Shahjibazar-Sreemangal 132kV Ckt-1 Scheduled S/D from Shahjibazar 132/33kV end Due to S/D Taken by	
		sreemongal grid and from Sreemongol 132/33kV end Due to relay testing.	
09:07	16:47	Goalpara- Khulna (C) 132kV Ckt-2 Scheduled S/D from Goalpara 132/33kV end Due to Gantry painting work and from	
00.00	44.00	Khulna (C) end Due to Due to ALDC. working goalpara substation end.	
09:09	14:33	Chandraghona 132/33kV S/S TR-01(406T) HT Project Work S/D Due to G2G Project Work.	
09:20	17:14	Kalliakoir-Tongi 230kV Ckt-2 Scheduled S/D from Kalliakoir 400/230/132kV end Due to Annual Maintenance and	
09:24	16:47	from Tongi 230/132/33kV end Due to Annual Maintenance Work. Sawar 132/33kV SST-31 TS Scheduded Si/D Due to annual maintenance.	
09:25	15:48	Savar 132/35kV o/s 1-5 LT solrections of the description of the descri	
09:25	15:48	Hatmazari-Kaozan ZJUKV CKT-1 Scrieduled S/D Ize to marazari ZJUTZ/JSKV end Due to work purpose. Savar 132/33K V SKT-3 HT Scheduled S/D Ize to annual maintenance.	
10:03	12:52	Savar 132/334V 3/S 1-3 r1 Scriedured S/D Due to artinal maintentance. Cumilla(S) 132/334V 3/S TR-3 LT Project Work S/D Due to Relav test.	
10:03	12:52	Cumilia(s) 132/33kV 3/S TR-3 HT Project Work S/D Due to Relay test. Cumilia(s) 132/33kV 3/S TR-3 HT Project Work S/D Due to Relay Test.	
10:04	12.32	Cultimagn Lassaw and The Fright Wink and Due to Netary Test. Kamrangirchar GT-1 was S/D for Annual Maintenance.	
10.06	10:19	Natinaryincian (1-1 was 3-1) to Aminian wainerlance. Shyampur-APR 230V Ckt was switched on.	
10:45	18:33	Stripalipul - M. 2004 C M. 40 SWICHEU UII. Barishal 230/132kV S/ST - 4L T Project UVir S/ID Due to SAS Integration s/d taken by Energypac.	
10:46	18:30	Sarishai 230/132kV SIS T-4 HT Project Work S/D Due to SAS Integration std taken by Energypac. Barishai 230/132kV SIS T-4 HT Project Work S/D Due to SAS Integration std taken by Energypac.	
10:55	10.50	Sirajanj unit-3 tripped.	126 MW generation interrup.
11:50	14:23	Shahijibazar-Sreemangal 132kV Ckt-2 Scheduled S/D from Sreemongol 132/33kV end Due to for relay testing.	120 mm gonoradon interrap.
11.00	11:51	Straiganj unit-3 GT was sync.	
	12:53	Sirajganj unit-3 ST was sync.	
12:47	14:45	Rangpur 132/33kV S/S T-1(414T) HT Scheduled S/D Due to Energy metre replacement.	
13:03	16:18	Cumilla(S) 132/33kV S/S TR-4 LT Project Work S/D.	
13:04	16:18	Curnilla(S) 132/33kV S/S TR-4 HT Project Work S/D.	
13:04	16:18	Cumilla(S) 132/33kV S/S TR-4 HT Project Work S/D.	
15:05	16:04	Joydebpur-Kodda B 132 kV Ckt-1 Forced S/D from Joydebpur 132/33kV end Due to Removing nest.	
15:12	16:56	Nawabgani 132/33kV S/S 132kV Main Bus-2 Scheduled S/D Due to Annual maintenance work.	
16:01		Ashuqani CCPP 225MW ST tripped.	80 MW generation interrup.
	16:18	Aminbazar 400/230/132kV S/S 230/132kv Tr-03 LT is restored.	,
	16:20	Aminbazar 400/230/132kV S/S 230/132kv Tr-03 HT is restored.	
	16:55	Khulna(S) 230/132kV S/S TR-1 HT is restored.	
	16:58	Khulna(S) 230/132kV S/S TR-1 LT is restored.	
	17:14	Kaliakoir-Tongi 230kV Ckt-2 is restored.	
22:45		Ashugonj (S) 230kv bus-coupler open to lower the flow through the OAT12.	1
00:23		Madanganj 132/33kV S/S Madanganj -Shitalakhya 132 kv Ckt Forced S/D.	1
	01:25	Kushiara 163MW GT was sync.	1
02:32	I	Meghnaghat-Shyampur 230kV Ckt-2 Forced S/D from Meghnaghat 230/132kV end Due to Due to dense fog tripping.	1
07:38	İ	Chauddagram-Cumilla(S) 132 kV Ckt-1 Scheduled S/D from Cumilla(S) 132/33kV end Due to Annual Maintenance.	1
	İ		1
	İ		