POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT

21:00 Hrs on 16-Apr-22

Today's Actual Min Gen. & Probable Gen. & Demand
Min. Gen. at
Available Max Generation
Max Demand (Evening):
Reserve(Generation end)
Load Shed Till now the maximum generation is: The Summary of Yesterday's
Day Peak Generation:
Evening Peak Generation:
E.P. Demand (at gen end):
Maximum Generation:
Total Gen. (MKWH): 14782.0 12-Feb-23 Generation & Demand 8780.0 MW 10355.0 MW 10600.0 MW 10355.0 MW 12:00 20:00 20:00 20:00 7371 10888 10750 138 Hour : Hour : Hour : Total Gen. (Micver)

Export from East grid to West grid :- Maximum Import from West grid to East grid :- Maximum

Water Level of Kaptal Lake at 6:00 A M on Achial :- Representation of Ft. (MSL), 211.0 System Load Factor : 84.90% EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR 0 776 MW MW 19:30 Energy Energy 13-Feb-23 Ft.(MSL) Rule curve 95.32

Gas Consumed : Total = 846.67 MMCFD. Oil Consumed (PDB):

HSD : FO :

Tk111,238,227 Tk299,022,144 Cost of the Consumed Fuel (PDB+Pvt) :

Oil : Tk515,473,868 Total : Tk925,734,239

Load Shedding & Other Information

Area	Yesterday		Today		
			Estimated Demand (S/S end)	Estimated Shedding (S/S end)	Rates of Shedding
	MW		MW	MW	(On Estimated Demand)
Dhaka	60	0:00	3442	0	0%
Chittagong Area	0	0:00	975	0	0%
Khulna Area	0	0:00	1287	0	0%
Rajshahi Area	40	0:00	1142	0	0%
Cumilla Area	0	0:00	972	0	0%
Mymensingh Area	76	0:00	803	0	0%
Sylhet Area	0	0:00	359	0	0%
Barisal Area	0	0:00	293	0	0%
Rangpur Area	50	0:00	634	0	0%
Total	226		9907	0	

Information of the Generating Units under shut down.

Forced Shut- Down
1) Barapukuria ST: Unit- 2
2) Ghorasal-3,5,7
3) Ashuganj-5
4) Baghabari-70,100 MW
5) Raozan unit-2
6) Siddhirganj 210 MW .
7) Shajibazar 330 MW
8) Sirajganj-2

Outage	Restore	Additional Information of Machines, lines, Interruption / Forced Load shed etc.	Remark
Time	Time		
8:19	16:07	Haripur 230/132kV S/S Bus-2 Scheduled S/D Due to Annual maintenance.	
-	8:21	Ashuganj-Cumilla(N) 230 kV Ckt-1 is restored.	
8:23	17:18	Kaliakoir-Kodda(300MW) 230kV Ckt-1 Scheduled S/D from Kaliakoir 400/230/132kV end Due to Annual Maintenance and dead line checking.	
-	8:24	Ashuganj-Cumilla(N) 230 kV Ckt-2 is restored.	
8:29	17:27	Chowmuhani-Ramganj 132 kV Ckt-2 Scheduled S/D from Chowmuhani 132/33kV end Due to yearly maintenance from end and from	
		Ramganj 132/33kV end Due to Shut down due to Annual Maintenance.	
8:31	15:04	Baroaulia-Khulshi 132 kV Ckt-1 Scheduled S/D from Baroaulia 132/33kV end Due to Annual Maintenance.	
8:31	15:39	AKSML-Baroaulia 132kV Ckt-1 Scheduled S/D from Baroaulia 132/33kV end Due to Annual Maintenance and from AKS 132/33kV	
		end Due to annual maintenance for Baroawlia demand.	
8:33	16:25	Baroaulia-KSRM 132 kV Ckt-1 Scheduled S/D from Baroaulia 132/33kV end Due to Annual Maintenance.	
8:35	-	Goalpara- Khulna (C) 132kV Ckt-1 Scheduled S/D from Goalpara 132/33kV end Due to Gantry Tower and Structure Painting works.	
		and from Khulna (C) end Due to Due maintenance work in goalpara s/s.	
8:36	15:19	Baroaulia 132/33kV S/S T-1(405T) LT Scheduled S/D Due to Annual Maintenance.	24.0MW load interrup.
8:36	15:08	Baroaulia 132/33kV S/S T2(415T) LT Scheduled S/D Due to Annual Maintenance.	23.0MW load interrup.
8:37	15:18	Baroaulia 132/33kV S/S T-1(405T) HT Scheduled S/D Due to Annual Maintenance.	24.0MW load interrup.
8:37	15:06	Baroaulia 132/33kV S/S T2(415T) HT Scheduled S/D Due to Annual Maintenance.	23.0MW load interrup.
8:41	17:07	Baroaulia-Hathazari 132 kV Ckt-2 Scheduled S/D from Baroaulia 132/33kV end Due to Annual Maintenance.	' ' ' ' ' ' ' ' ' ' ' ' ' ' ' ' ' ' '
8:41	15:04	Baroaulia 132/33kV S/S 132kv Main Bus Scheduled S/D Due to Annual Maintenance.	77.0MW load interrup.
8:41	16:33	Baroaulia-Hathazari 132 kV Ckt-1 Scheduled S/D from Baroaulia 132/33kV end Due to Annual Maintenance.	
8:59	15:02	Sunamgani 132/33kV S/S Tr-2 LT Scheduled S/D Due to Annual Maintenance Works.	
9:02	15:02	Cumilla(N)-Shahjibazar 230 kV Ckt-2 Scheduled S/D from Cumilla(N) 230/132/33kV end.	
9:20	15:38	Chandraghona-Madunaghat 132 kV Ckt-1 Scheduled S/D from Madunaghat 132/33kV end Due to For annual maintenance and	
0.20	10.00	deadline checking, and from Chandraghona 132/33kV end Due to Annual maintenance of line.	
9:24	15:01	Sunamgani 132/33kV S/S Tr-2 HT Scheduled S/D Due to Annual Maintenance Works.	
9:31	-	Dhaka university 132/33 KV GT-1 was shutdown for A/M.	
9:55	17:25	Jamalpur 132/33kV S/S T-2 HT Scheduled S/D Due to Transformer Painting work.	
9:55	17:25	Jamalpur 132/33kV S/S T-2 LT Scheduled S/D Due to Transformer Painting work.	
10:37	11:21	Gulsan-Rampura 132kV Ckt-1 Forced S/D from Rampura 230/132kV end Due to Command by NLDC. and from Gulshan 132/33kV	
10.01		end Due to Corrective Maintenance of Rampura Ckt - 1. Relay Functionality Test.	
11:15	11:40	Gulshan 132/33kV S/S MT-2 HT Scheduled S/D Due to Corrective Maintenance of MT - 2 Transformer. Relay Functionality Test.	
11:50	12:10	Gulsan-Rampura 132kV Ckt-2 Forced S/D from Rampura 230/132kV end Due to For Gulshsn ss end protection works taken by NLDC.	
		and from Gulshan 132/33kV end Due to Corrective Maintenance of Rampura Ckt - 2. Relay Functionality Test.	
12:09	12:27	Gulshan 132/33kV S/S MT-1 HT Scheduled S/D Due to Corrective Maintenance of MT - 1 Transformer. Relay Functionality Test.	
12:25	16:03	Rampur 230/132/33 S/S ATR-02 (716T) HT Project Work S/D Due to Project work.	
12:48	15:08	Kalurghat 132/33kV S/S TRF0-02(516T) LT Forced S/D Due to Bus connector maintainance by BPDB.	
15:02	17:40	Ashugani-Cumilla(N) 230 kV Ckt-1 Scheduled S/D from Cumilla(N) 230/132/33kV end.	
10.02	16:05	Rampur 230/132/33 S/S ATR-01 (706T) LT is restored.	
	16:24	Biblyana-3 400MW ST was sync.	
	16:42	goalpara-khulna central ckt-1 is restored.	
	17:16	Aminbazar-Kaliakoir 230kV Ckt-2 is restored.	
17:50	20:26	Ashuganj-Cumilla(N) 230 kV Ctt-2 Scheduled S/D from Cumilla(N) 230/132/33kV end Due to 158 no tower insulator disk cleaning.	
	18:20	Aminbazar-Mirpur 132kV Ckt-2 is restored.	
	4:05	Coxsbazar 132/33kV S/S T3 HT Project Work S/D Due to Primary BR.	
6:42	1.00	Ashugani-Kishoreani 132kV Ckt-2 Scheduled S/D from Kishoreani 132/33kV end.	
7:03		Khulshi-Madunaghat 132kV Ckt-2 Project Work S/D from Khulshi 132/33kV end Due to LILO work for Sholoshaher S/S and from	
7.00		Madunaghat 132/33kV end Due to Alteration of the circuit through the GNDP project and connecting the circuit as Madunaghat-Sholshahar	
		meaning rise Carbon Visit and Date to Alteration of the Carbon transport of Carbon project and confidence in a confidence as meading inter-original and Sholashar-Khulsi.	
7:12	1 .	artu ortolastiar-rotusis. Siddirganj CCPP 335MW was shutdown due to gas shortage.	
7:31	1	Aminbazar-Kaliakoir 230kV Ckt-2 Scheduled S/D from Kaliakoir 400/230/132kV end Due to Annual Maintenance and Dead line checking.	
7:51	1	Kallakoir-Kodda(300MW) 230kV Ckt-1 Scheduled S/D from Kallakoir 400/230/132kV end Due to Annual maintenance and Deadline check.	
7.51	1	Transfer Teadage Control 2001 Control Teadage Control Teadage Teadage Control	I