POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT Reporting Date : Hrs on 16-Apr-22 Today's Actual Min Gen. & Probable Gen. & Demand Min. Gen. at 5:00 Available Max Generation : 14782.0 21:00 Till now the maximum generation is: -17-Feb-23 Generation & Demand 8927.0 MW The Summary of Yesterday's Day Peak Generation : Evening Peak Generation : E.P. Demand (at gen end) : 6729 12:00 Hour 9646.0 MW 9670.0 MW Hour 19:00 11199 10500 Hour 19:00 Max Demand (Evening) : Reserve(Generation end) 9646.0 MW Hour 19:00 699 Load Shed Total Gen. (MKWH) 203.1 System Load Factor : 87.72% EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR 0 Export from East grid to West grid :- Maximum 30 MW 7:00 Energy Energy Import from West grid to East grid :- Maximum Water Level of Kaptai Lake at 6:00 A M on MW 18-Feb-23 Ft.(MSL), Actual 81.93 Rule curve 94.62 Ft.(MSL) Gas Consumed : Total = 876.03 MMCFD. Oil Consumed (PDB): HSD FO Cost of the Consumed Fuel (PDB+Pvt) : Tk115.057.670 Oil Tk371,034,326 Total : Tk699,164,288 Load Shedding & Other Information Today Estimated Shedding (S/S end) MW Estimated Demand (S/S end) MW 3732 1029 1352 1192 1018 836 378 305 660 10502 Rates of Shedding (On Estimated Demand) 0% Dhaka Chittagong Area Khulna Area Rajshahi Area Cumilla Area Mymensingh Area Sylhet Area Barisal Area 0 0 0 0 22 0 0% 0% 0% 0% 0% 0% Rangpur Are Total Information of the Generating Units under shut down. Forced Shut-Down 1) Barapukuria ST: Ur 10) Fenchuganj-1 2) Ghorasal-3,7 3) Ashuganj-5 4) Baghabari-70,100 MW 4) Baghabari-70,100 M 5) Raozan unit-2 6) Siddhirganj 210 MW 7) Shajibazar 330 MW 8) Sirajganj-2,3 9) Meghnaghat Summit Additional Information of Machines, lines, Interruption / Forced Load shed etc. Outage Restore Remark Time 16:09 Maniknagar 132/33kV S/S Motijheel Ckt-1 Scheduled S/D Due to oil leakege of line CT (Y Phase) & MotijheelCkt-1 Bay Maintenance. Baroirhat-Hathazari 132 kV Ckt-1 Scheduled S/D from Baroirhat 132/33kV end Due to Maintenance works of Hathazari grid s/s. Baroirhat-Hathazari 132 kV Ckt-2 Scheduled S/D from Baroirhat 132/33kV end Due to Maintenance works of Hathazari grid s/s. Baroirhat-Hathazari-Madunaghat 132/34kV end Due to For maintenance work at hathazari grid s/s end. Hathazari-Madunaghat 132/34kV end Due to For maintenance work at hathazari grid s/s end. Hathazari-Madunaghat 132/34kV end Due to For maintenance work at hathazari grid s/s end. Hathazari 23/33kV s/S TRFO-02/516T) HT Project Work S/D Due to maintenance. Kalurghat 132/33kV S/S TRFO-02/516T) HT Project Work S/D Due to Maintenance of Relay display. Jamaipur 132/33kV S/S Transformer of the total scheduled S/D Due to transformer painting work. Bogura 132/33kV S/S Transformer-3 HT is restored. Bogura 132/33kV S/S Transformer-3 HT is restored. 8:57 13:30 13:30 13:31 13:25 13:26 13:32 12:02 18:52 18:52 8:58 9:07 9:16 9:22 9:33 9:48 9:48 9:50 9:50 Bogura 132/33kV S/S Transformer-3 I T is restored 12:11 16:24 12:43 Kalurghat 132/33kV S/S TRFO-01(506T) HT Project Work S/D Due to Relay maintenance Narshingdi 132/33kV S/S T-2 HT is restor Narshingdi 132/33kV S/S T-2 HT is restored. Narshingdi 132/33kV S/S T-3 HT is restored. BIPTC S/S 20DF24 Tripped showing relay relays Due to Impedance 21R. Bhola Natun Biddut BD LTD GT2 was sync. Hathazari 132/33kV T-1 tripped hr s showing differential relay. Jashore 132/33kV S/S T-3 HT is restored. Jashore 132/33kV T stransformer 132kV side was charged. Fenchuganj CCPP-1 ST-1 was forced shutdown. Meghnaghat Summit CCPP 305MW ST was shutdown. 12:44 13:15 14:16 16:35 17:24 17:24 22:31 22:52 22:56 23:01 Fenchuganj CCPP-1 GT-2 was forced shutdown. Meghnaghat Summit CCPP 305 MW GT2 was S/D. weginaginal Sullimit CoPP 305 MW G12 was Si Sirajgonj Gas 210 MW Unit-1 ST tripped. Siddhirgonj 335 MW GT was sync. for testing. Haripur 412MW CCPP GT was sync. Siddhirgonj 335 MW GT was shutdown after test. 23:10 0:39 5:03

Sub Divisional Engineer Executive Enginee Superintendent Engineer twork Operation Division Network Operation Division Load Despatch Circle

-6:21