POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT

1-Apr-23 Generation & Demand 9272 0 MW 10593.0 MW 10593.0 MW 10593.0 MW 217.1 Reporting Date : 2-Apr-23 Till now the maximum generation is : The Summary of Yesterday's
Day Peak Generation :
Evening Peak Generation :
E.P. Demand (at gen end) :
Maximum Generation :
Total Gen. (MKWH) :
 23
 Generation & Domand

 2972.0
 IM
 Hour:
 12:00

 0593.0
 MW
 Hour:
 21:00

 0593.0
 MW
 Hour:
 21:00

 0593.0
 MW
 Hour:
 21:00

 217.1
 System Load Factor
 85:40%

 EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR
 7408 14415 12500 1915 0 Export from East grid to West grid :- Maximum
Import from West grid to East grid :- Maximum
Water Level of Kaptai Lake at 6:00 A M on
Actual : 75.98 Ft.(MSL), 460 MW 19:30 Energy Energy MW 2-Apr-23 Rule curve : 87.80 Ft.(MSL) Gas Consumed : 975.22 MMCFD. Oil Consumed (PDB): HSD : FO : Gas : Coal : Tk133,848,472 Tk197,085,558 Cost of the Consumed Fuel (PDB+Pvt) : Oil : Tk294,603,582 Total : Tk625,537,612

Load Shedding & Other Information

Area	Yesterday	1	Today		
			Estimated Demand (S/S end)	Estimated Shedding (S/S end)	Rates of Shedding
	MW		MW	MW	(On Estimated Demand)
Dhaka	0	0:00	3949	0	0%
Chittagong Area	0	0:00	1090	0	0%
Khulna Area	0	0:00	1433	0	0%
Rajshahi Area	0	0:00	1264	0	0%
Cumilla Area	0	0:00	1079	0	0%
Mymensingh Area	0	0:00	887	0	0%
Sylhet Area	0	0:00	401	0	0%
Barisal Area	0	0:00	323	0	0%
Rangpur Area	0	0:00	700	0	0%
Total	0		11126	0	-

Information of the Generating Units under shut down.

Planned Shut- Down	Forced Shut-Down
	1) Barapukuria ST: Unit- 1,2
	2) Ghorasal-3,7
	3) Kushiara 163 MW ST
	4) Baghabari-100 MW & 71 MW
	5) Raozan unit-1,2
	6) Siddhirganj 210 MW .
	7) Shajibazar 330 MW
	8) Sirajganj-2 & 3
	9) Bhula Nuton Biddut

Outage	Restore	Additional Information of Machines, lines, Interruption / Forced Load shed etc.	Remark
Time	Time		
	08:26	Shikalbaha 230/132kV S/S Hathazari-02 is restored.	
	08:26	Hathazari 230/132/33kV S/S Shikolbaha-02 is restored.	l
	09:12	Madunaghat I 400/230kV S/S ATR-01 LT is restored.	
	09:12	Madunagha 1400/230kV S/S ATR-01 HT is restored.	l
09:14	10:55	Industriaghts 1902/250KV S/S TR-06 LT Scheduled S/D Due to Jumuna feeder red hot maintenance.	
			l
09:15	10:54	Shahjibazar 132/33kV S/S TR-06 HT Scheduled S/D Due to Jumuna feeder red hot maintenance.	L
09:26	11:30	Bog-Sherpur 132/33kV S/S Transformer-2 (414T) LT Scheduled S/D Due to Red hot	20.0MW load interrup.
		S/D Due to Red hot	l
09:27	11:29	Bog-Sherpur 132/33kV S/S Transformer-1 (404T) LT Scheduled S/D Due to Red hot	l
09:28	11:27	Bog-Sherpur 132/33kV S/S Transformer-1 (404T) HT Scheduled S/D Due to Red hot	l
09:30	11:28	Bog-Sherpur 132/33kV S/S Transformer-2 (414T) HT Scheduled S/D Due to Red hot	l
09:52	21:17	BIPTC S/S Baharampur-3 Scheduled S/D Due to Shutdown is taken from Berhampore substation for	l
		maintenance work.	l
10:20	17:03	Aminbazar-Keraniganj 230kV Ckt-2 Scheduled S/D from Aminbazar end Due to Dead line cheking	l
10:45	11:43	Juldah 132/33kV S/S 132/33 KV 406T T-1 HT Forced S/D Due to Red Hot Mantanance	l
11:40	14:10	Hathazari 230/132/33kV S/S MT-04 LT Forced S/D Due to Red Red Hot Mantanance	l
11:40	14:09	Hathazari 230/13/2/38V S/S MT-04 ET POICE 3/D Due to Red Red Hot Manitaniance Hathazari 230/13/2/38V S/S MT-04 HT Forced S/D Due to Red Red Hot Manitaniance	l
	14.09		l
12:00		Day peak generation: 9272 MW.	l
12:01	12:35	Kabirpur -Tongi 132kV Ckt-1 Forced S/D from Tongi 230/132/33kV end Due to Shutdown taken by Kabirpur	l
14:07	14:45	Ghorasal-Tongi 230kV Ckt-1 Tripped from Tongi 230/132/33kV end showing 1.distance primary	l
		protection Phase-C fault Z1(0.4km) AR close 2.distance secondary protection	l
		D,T relays Due to None	l
14:07	14:41	Kodda(300MW)-Tongi 230kV Ckt-1 Tripped from Tongi 230/132/33kV end showing Pickup B-Phase,	18.0MW load interrup.
		SOTF Trip, Auto reclose-1,3,6 relays Due to None	· ·
14:07	14:47	Ghorasal-Tongi 230kV Ckt-2 Tripped from Tongi 230/132/33kV end showing 1 distance primary protection	l
		Phase-A,B,C 51/51N OPTD 2.distance secondary protection T relays Due to None	l
14:16	16:06	Shahmirpur 132/33kV S/S 416T LT Forced S/D Due to 33kv "R"phase bushing oil leakage	15.0MW load interrup.
14:17	16:03	Shahminpur 132/33kV S/S 416T HT Forced S/D Due to Tr-02(416T) 33kV "R" phase bushing oil leakage	15.0WW load interrup.
14:26	15:16	Straigani 132/33kV S/S T4-(445) HT Forced S/D Due to Emergency Red Hot maintenance.	l
15:24	13.10	Singjanji 1923/04/05 14-(443) Til Poles 3/D Due to Einegerick, real to the menterance. Haripur 230/132kV S/S Ullion (Maniknagar-2) Scheduled S/D Due to Work on other side by NLDC	l
			l
15:27		Maniknagar-Matuaii 132kV Ckt-1 Scheduled S/D from Maniknagar 132/33kV end Due to OPG Cable joint	l
		and maintenance.	l
15:42		Maniknagar 132/33kV S/S Haripur Ckt-2 Scheduled S/D Due to OPG Cable joint and maintenance.	l
15:45	17:30	Sirajganj 132/33kV S/S T4-(445) HT Forced S/D Due to Red Hot Bolt replace at CT P2 end.	l
	18:23	Bogura(New)-Naogaon 132 kV Ckt-2 is restored.	l
19:29	19:50	Kishoreganj 132/33kV S/S T3(A+B) (424TA & 424TB) HT Forced S/D Due to Hotspot maintenance	l
19:29	19:50	Kishoreganj 132/33kV S/S T3(A+B) (424TA & 424TB) LT Forced S/D Due to Hotspot maintenance	l
21:00		Evening Peak Gen. 10594 MW	l
22:21	23:42	Satkhira 132/33kV S/S Transformer-1 (T-1) LT Forced S/D Due to Due to red hot at 33 KV kalaroa feeder	55.0MW load interrup.
22:21	23:40	Salkhira 132/33kV S/S Transformer-1 (T-1) HT Forced S/D Due to Due to red hot at 33 KV kalaroa feeder	l ''
06:00		Minimum Generation = 7.408MW	I
06:50		Bogura(New)-Naogaon 132 kV Ckt-1 Project Work S/D from Naogaon 132/33kV end Due to project work	l
00.00		Doguta(rew)-industrial State Victor Fright Work of Industrial Industrial State to project work of Bogura s/s. and from Bogura 230/132kV end Due to project work	l
07:02	07:44		70 01414/ load internin
		Cumilla(N) 230/132/33kV S/S 132KV T-03 HT Tripped showing Overcurrent Relay relays.	70.0MW load interrup.
07:02	07:46	Cumilla(N) 230/132/33kV S/S 132KV T-03 LT Tripped showing Overcurrent Relay relays.	l
07:02	07:43	Cumilla(N) 230/132/33kV S/S 132KV T-04 LT Tripped showing Overcurrent Relay relays.	l
07:02	07:47	Cumilla(N) 230/132/33kV S/S 132KV T-05 LT Tripped showing Overcurrent Relay relays.	l
			l
			l
			l
			l
			l
			l
			l
			l
			l
l l	l Sub Divisio	I nal Engineer Executive Engineer	Superintendent Engineer
	Network Oper	ation Division Network Operation Division	Load Despatch Circle