				POWER GRID COMP. NATIONAL LOA DAIL						D	40.11	
Till now the maximum generation is:-			15648.0			Reporting Date : 16-May-23 21:00 Hrs on 19-Apr-23						
The Summary of Yester Day Peak Generation	rday's	15-May	23 Generation & E 9984.0 MW	Demand Hour :		12:00		Today's Actual Min G Min. Gen. at	en. & Proba	ble Gen. & D 6:00	emand	8843
Evening Peak Generation	:		11496.0 MW	Hour :		20:00		Available Max Generat		0.00		12126
E.P. Demand (at gen end)	:		13585.0 MW	Hour :		20:00		Max Demand (Evening):			14300
Maximum Generation Fotal Gen. (MKWH)	:		11496.0 MW 239.4	Hour :		20:00 86.77%		Reserve(Generation er Load Shed	nd)			2004
TOTAL GELL (MKVVII)	•		EXPORT / IMPOR	System Loa RT THROUGH EAST-WEST IN	ERCONNECTO	R		Load Siled				2004
Export from East grid to W					652	MW	at	7:00		Ene		
mport from West grid to E	ast grid :- Maximum Water Level	of Kaptai Lake at 6:00 A M on	16-May-23			MW	at	-		Ene	rgy	-
Actual :	Tratal Eave	73.83 Ft.(MSL) ,	To may 20		Rule curve :		79.15	Ft.(MSL)				
Gas Consumed :		Total =	792.28 MMCFD.			011.0	sumed (PDB	١.				
sas Consumed :		rotal =	792.28 MMCFD.			Oil Cons	sumea (PDB):	HSD :			
									FO :			
Cost of the Consumed Fue	(DDB+D/4)		Gas :	Tk117,326,515								
Sost of the Consumed I de	(I DB-1 Vt).		Coal :	Tk311,024,631			Oil :	Tk812,866,452		Tota	I : Tk1,241,217,597	
		Load Shedding &	Other Information									
Area		Yesterday		F-t				Today	v(0 t)		Date of Observation	
		MW		Estimated Demand (S/S end) MW				Estimated Shedding (S	MW		Rates of Shedding (On Estimated Demand)	
Dhaka		631 0:00		4211						660	16% 17%	
Chittagong Area Chulna Area		142 0:00 0 0:00		1155 1617						200 280	17% 17%	
Rajshahi Area		251 0:00		1405						245	17%	
Cumilla Area Mymensingh Area		418 0:00 225 0:00		1156 860						200 145	17% 17%	
Nymensingh Area Sylhet Area		102 0:00		860 482						145 75	17%	
Barisal Area		0 0:00		402						64	16%	
Rangpur Area Fotal		226 0:00 1995		785 12073						135 2004	17%	
iotai				12075						2004		
		Information of the Generating Units under	shut down.									
		Planned Shut- Down				Forced	Shut- Down	<u> </u>				
						1) Barap	pukuria ST: U	nit- 2				
						2) Ghorasal-3,7 3) Bhula Nuton Biddut						
							abari-71,100					
							an unit-2					
						6) Siddh	hirganj 210 M bazar 330 MV	W .				
						8) Sirajo		v				
Outage Time	Restore Time	Additional Information of Ma	chines, lines, Interruption /	Forced Load shed etc.								Remark
08:18	Time	Juldah 132/33kV S/S 133/33 KV T-2 416T LT S	cheduled S/D Due to Increasin	g of transformer capacity/G2G pro	iect work).							
08:20		Juldah 132/33kV S/S 133/33 KV T-2 416T HT P	roject Work S/D Due to Increa	sing of transformer capacity(G2G	project work).							
08:33 08:33	08:53	Madanganj 132/33kV S/S Madanganj-Fatullah 1			e of Overload F	roblem						
00.55	00.55	Madanganj 132/33kV S/S Madanganj -Haripur 1 Madanganj-Fatullah ckt Forced S/D by NLDC, th	en 132KV Madangani-Haripur	CKT-2 tripped by Overload.								
08:37		Madanganj 132/33kV S/S Madanganj -Shitalakh	a 132 kv Ckt Forced S/D Due	to Overload Problem of 132KV								
	09:54	Madanganj-Fatulla ckt, NLDC Forced S/D this F- Mymensingh 132/33kV S/S Transformer-1 (404)	eder									
	09:54	Mymensingh 132/33kV S/S Transformer-1 (404)) H I is restored.									
10:11		Tongi 230/132/33kV S/S T-2 LT Scheduled S/D	Due to Relay Panel changing \	Work.								
10:11	10.56	Tongi 230/132/33kV S/S T-2 HT Scheduled S/D	Due to Relay Panel Changing	Work	Door !						70 04 04 15 - 4 1-4	
10:24	10:56	Barishal 132/33kV S/S T-1 (405T) HT Tripped st Due to 33kv Nolcity(PBS),Muladi (PBS) Feeder 1	iowing General trip, MT Bucho ault	iz, OLIC Bucholz, PRD, OTI/WT	relays Due to						72.0MW load interrup.	
10:24	10:57	Barishal 132/33kV S/S T-1 (405T) LT Tripped sh	 owing Lockout - 86 relays Due	to Due to 33kv Nolcity(PBS),Mul	idi (PBS)						72.0MW load interrup.	
40.01	40.00	Feeder fault									70.0184/1	
10:24	13:29	Barishal 132/33kV S/S T-2 (415T) LT Tripped sh Feeder fault	owing Lockout - 86 relays Due	e to ⊔ue to 33kv Nolcity(PBS),Mul	iai (SR2)						72.0MW load interrup.	
	10:44	Mahasthangarh 132/33kV S/S 416T MTR 2 HT	s restored.									
	10:45	Mahasthangarh 132/33kV S/S 406T MTR1 HT is	restored.									
	10:46 10:47	Mahasthangarh 132/33kV S/S 416T MTR 2 LT i Mahasthangarh 132/33kV S/S 406T MTR1 LT is	restored.									
11:42	13:28	Barishal 132/33kV S/S T-2 (415T) HT Forced S/	D Due to For check the transfe	ormer								
12:00		Day peak generation is 9984MW										
14:22 15:00	15:50	Cumilla(S)-Kachua 132 kV Ckt-1 Forced S/D fro Sikalbaha Gas 225MW GT was sync.	m Kachua 132/33kV end.									
15:00 18:58	19:05	Bagerhat 132/33kV S/S Transformer-1 (403T) L	Tripped showing O/C E/F re	lavs Due to 33 KV Chandanimah	Feeder fault						17.0MW load interrup.	
18:58	19:02	Bagerhat 132/33kV S/S Transformer-2 (413 T) L	T Tripped showing O/C, E/F re	elays Due to 33KV Chandanimaha	Feeder fault.						17.0MW load interrup.	
20:00 20:50	23:42	Evening Peak Generation = 11,496MW										
20:50	23:42	Daudkandi 132/33kV S/S Transformer-3 LT Trip Daudkandi 132/33kV S/S Transformer-3 HT Trip	ped snowing no relay relays Di ped showing GENERAL Trin f	ue to under ground cable fault. DIFF I 1 I 2 I 3 relays Due to Und	r around							
22:56	00:00	Cumilla(S) 132/33kV S/S Tripura Ckt-1 Forced S	Due to For SF6 gas refilling	g on SM nagor end.								
23:08	23:33	Feni 132/33kV S/S T-1(405T) LT Tripped showing	g over current and earth fault	relays Due to 33kv reb-2 and dore	en 22MW						19.0MW load interrup.	
23:28		feeder fault Rangpur 132/33kV S/S Rangpur-Teesta Solar-2	Trinned showing Zone 2 DDb-	se Cohase 86 Operated relevo D	e to Zore							
		2.BPhase,Cphase.86 Operated	impped Siluwing Zune Z.BPNs	iso, opriase.ou Operateu relays Di	e to ZUITE							
01:30		Bhola CCPP GT1 was forced shutdown at 01:30	hrs due to bleed valve probler	n.								
06:00 06:02		Minimum generation: 8843 MW. Keranigonj 230/132/33kV S/S TR-2 LT Schedule	d S/D Due to Maintananc - · · · ·	rk for Ped Hot at 22to amilia	ride DS							
		conneting loop clamp (B -Phase) & high tempera	ture at different joint.									
06:03		Keranigonj 230/132/33kV S/S TR-2 HT Schedule	ed S/D Due to Maintenance wo	ork for Red Hot at 33kv equipment	side DS							
		conneting loop clamp (B -Phase) & high tempera	ture at different joint								1	
		connecting loop claimp (b -1 hase) a high tempera	taro at amoronit joint.								1	
		connecting toop claimp (b -1 hase) & high tempera	aro at amorant joint.									
		connecting toop claimp (b -1 mase) a might empera	are at americal joint.									