POWER GRID COMPANY OF BANGLADESH LTD NATIONAL LOAD DESPATCH CENTER DAILY REPORT Reporting Date: 16-Oct-23 Till now the maximum generation is : The Summary of Yesterday's Day Peak Generation : Evening Peak Generation : E.P. Demand (at gen end) : Maximum Generation : 21:00 Hrs on 19-Apr-23 Today's Actual Min Gen. & Probable Gen. & Demand Min. Gen. at 6:00 Available Max Generation Max Demand (Evening): Reserve(Generation and) 15648.0 3 Generation & Demand 11898.0 MW 13826.0 MW 13826.0 MW 13826.0 MW 12:00 19:30 19:30 19:30 10163 14964 14000 964 Total Gen. (MKWH) 288.957 System Load Factor : 87.08% EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR Load Shed Export from East grid to West grid : Maximum Import from West grid to East grid : Maximum Water Level of Kaptai Lake at 6:00 A M on 106.14 20:00 232 MW MW Energy Energy 16-Oct-23 Ft.(MSL) Rule curve 107.40 Ft.(MSL) Gas Consumed : Total = 1061.45 MMCFD. Oil Consumed (PDB) Cost of the Consumed Fuel (PDB+Pvt) Tk156,509,886 Tk481,012,481 Oil : Tk485.338.375 Total: Tk1,122,860,742 Load Shedding & Other Information Area Today Estimated Shedding (S/S end) Rates of Shedding Estimated Demand (S/S end) Dhaka Chittagong Area Khulna Area Rajshahi Area Cumilla Area Mymensingh Area Sylhet Area 0:00 0:00 0:00 0:00 0:00 0:00 1336 1873 1628 1339 996 558 0% 0% 0% 0% 0% 0% 0% Rangpur Area Total 0:00 Information of the Generating Units under shut down Planned Shut- Down Forced Shut-Down 1) Barapukuria ST: Unit- 1,2 2) Ghorasal-3,7 3) Shajibazar 330 MW 4) Baghabari-71,100 MW 5) Raozan unit-2 6) Siddhirganj 210 MW. Outage Time Additional Information of Machines, lines, Interruption / Forced Load shed etc. Time 15:09 Additional Information of Machines, lines, interruption / Forced Load shed etc. Khulina (C) SIS Tr.2 415 T.LT Scheduled Si/D Due to For Annual maintenance Barapukuria-Bogura 230 kV Ckt.1 Project Work Si/D from Barapukuria 230/132/33kV end. Saidpur 132/33kV SIS TR-2 (404T) I.T Scheduled Si/D Due to DF-GMD-39 and the instructions of ALDC Bogura Jamaipur-Mymensigh 132kV Kct.1 Si/D from Jamaipur end Due to AMI. Khulina(S) 230/132kV SIS TR-3 LT Scheduled Si/D Due to Annual Maintenance work. Chandraghona-Madunaghat 132/35kV Ckt.1 Scheduled Si/D from Kalonaghat 132/33kV end Due to For annual deadline checking Ashugani-Kishoregani 132kV Ckt.1 Scheduled Si/D from Kishoregani 132/33kV end Due to Annual Maintenance SISKM-Mirshara 230 kV Ckt.1 Scheduled Si/D from Kishoregani 132/33kV end Due to Annual Maintenance SISKM-Mirshara 230 kV Ckt.1 Scheduled Si/D from SiSRM end Due to Annual Maintenance mork. Haripur 230/132kV SIS Auto TR-3 HT is restored. Bashundhara-frong 132 kV Ckt.1 Si/D from Togi 230/132/33kV end Due to Annual maintenance work. Aminbazar 400/230/132kV SIS 230/132kV Tr-02 HT is restored. Faridpur 132/33kV SIS AUX SIS 28 W Bus QI is restored. Aminbazar 400/230/132kV SIS 132 kV Bus QI is restored. 08:12 08:15 17:12 15:56 08:30 08:30 17:37 13:38 16:30 16:03 12:35 09:11 17:12 09:34 15:41 08:51 08:58 09:05 09:18 09:39 09:41 09:44 Aminbazar 400/230/132kV S/S 230/132kv Tr-02 LT is restored Aminbazar 400/2301/32W SIS 230/132W T-02 LT is restored. Ashuganj 2301/32/33W SIS 134W busbar-1 is restored. Ashuganj 2301/32/33W SIS T-34 Kralabagan HT is restored. Ashuganj 2301/32/33W SIS T-34 Kralabagan HT is restored. Fariqurs 1432/33W SIS Transformes -1 HT Scheduled SID Due to Due to project work Ashuganj 2301/32/33W SIS T-4 Kralabagan LT is restored. Kazia 132/33W SIS GT-2 HT Project Work SID Due to NLDC communication and Maintenance purpose Keranigonj 2301/32/33W SIS FR-1 LT is restored. Rangpur-Saidpur 132W Ckt-2 Tripped from Carmilla(N) end showing Distance Relay relays Due to O/V Cumilla(N)-Sniphibazar 230 W Ckt-2 Tripped from Cumilla(N) end showing Main-1: 21 trip2 com/EFMain-2: 21 trip8 phase, Mirpur 13/2/33W SIS Rase Reserve Bus SID Due to 132 kV Reserve Bus with Uttara Sector 18 ckt bay Maintenance. Maniknagan 13/2/33W SIS Kazia Ckt-2 Scheduled SID Due to Kazia-Matuali Maintenance work by DPDC. BSRM-Mirisharia 230 kV Ckt-2 In from Mirsorai end Due to Annual maintenance. 09:51 09:56 20:46 09:59 15:03 10:15 11:25 12:08 14:52 09:58 10:12 10-54 10:54 11:55 12:24 12:30 12:44 13:55 15:32 BSRM-Mirisharia 230 kV Ckt-2 SiD from Mirsoral end Due to Annual maintenance. Magura 1329348 VS ST -3.1 Ts Activated SiD Due to Transformer-3 Testing. Mirpur-Ultara 3PH 1324V Ckt-1 is restored. Meghnaghat 400kV 411 no. bay was switched on Chandraghna-Madunaghat 132 VK Ckt-1 is restored. Barapukruna-Bogura 230 kV Ckt-2 is restored. Pabna-Shahjaduru 1324V Ckt-1 Froed SID from Pabna end Due to instruction by aidc bogra. Rampura 230/1324V SIS NILDC Trafo LT Scheduled SID Due to Fuse replacing work in 11 kV Side kushtal 132/3348 VSS 112 LF Torond SID from Pabna-Shahjadvi SIS 71 LF Torond SID Due to For B bus Shut down (PBS 334V Feeder DS maintenance.) Kushtal 132/3348 VSS 112 kV Bus-A Forced SID Due to For B bus Shut down (PBS 334V Feeder CS maintenance.) 13:52 14:53 15:08 16:23 18:32 19:20 06:43 06:45

Kushlar 13/233W SS 13 2K V Bus-A Forced SID Due to For B bus Shut down (PBS 33KV Feeder CB maintenance.) Kushlar 13/233W SS 13 2K V Bus-B Forced SID Due to For B bus Shut down (PBS 33KV Feeder CB maintenance.) Chauddagram-Fen 132 KV Ckt-I Forced SID from Chauddagram end Due to Red hot maintenance in Fen gird SS. Chauddagram-Fen 132 KV Ckt-I Forced SID from Chauddagram end Due to Red hot maintenance in Fen gird SS. Shahijbazar 13/23/3W SS 13/23 KV T-3, 44PT I Forced SID from Chauddagram end plot spot Maentrenance. Load flow by TR-02 Barapulcuria 20/01/23/3W VS 13/23/S KV T-3, 44PT I Forced SID from the be Emergency end hot maintenance at 33KV Bus.

06:46 06:47 06:48 07:01 07:36 30 MW load interrup