## POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT

Oil : Tk240,129,681

Total : Tk1,213,539,309

6-Mar-24 21:00 Hrs on 19-Apr-23
Today's Actual Min Gen. & Probable Gen. & Demand
Min. Gen. at 5:00
Available Max Generation
Max Demand (Evening):
Reserve(Generation end)
Load Shed: Reporting Date : 5-Mar-24 Generation & Demand 11147.0 MW 11921.0 MW 12040.0 MW 11921.0 MW Till now the maximum generation is : ...
The Summary of Yesterday's
Day Peak Generation :
E.P. Demand (at gen end) :
Maximum Generation :
Total Gen. (MKWH) : 12:00 19:00 19:00 19:00 8334 13503 12300 1203 Hour Hour Hour 248.327 System Load Factor : 86.80%
EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR
720 MW
MW Export from East grid to West grid :- Maximum Import from West grid to East grid :- Maximum Water Level of Kaptai Lake at 6:00 A M on 83.31 7:00 Energy Energy 6-Mar-24 Ft.(MSL), Ft.( MSL ) Actual: Rule curve : 92.20 83.31 872.09 MMCFD. Oil Consumed (PDB):

Tk356,627,380 Tk616,782,248 Cost of the Consumed Fuel (PDB+Pvt) :

Load Shedding & Other Information							
Area	Yesterday		Today				
			Estimated Demand (S/S end)	Estimated Shedding (S/S end)	Rates of Shedding		
	MW		MW	MW	(On Estimated Demand)		
Dhaka	15	0:00	4049	0	0%		
Chittagong Area	0	0:00	1110	0	0%		
Khulna Area	0	0:00	1553	0	0%		
Rajshahi Area	0	0:00	1349	0	0%		
Cumilla Area	0	0:00	1111	0	0%		
Mymensingh Area	99	0:00	826	0	0%		
Sylhet Area	0	0:00	463	0	0%		
Barisal Area	0	0:00	386	0	0%		
Rangpur Area	0	0:00	754	0	0%		
Total	114		11600	0	-		

Information of the Generating Units under shut down.

-	
Planned Shut- Down	Forced Shut-Down
	1) Barapukuria ST: Unit- 1,2
	2) Ghorasal-3,5,7
	3) Shajibazar 330 MW
	4) Baghabari-71,100 MW
	5) Raozan unit-2
	6) Siddhirgani 210 MW .
	7) Ashugani North

Outage	Restore	Additional Information of Machines, lines, Interruption / Forced Load shed etc.	Remark
Time	Time		
08:24	17:32	Cumilla(N)-Meghnaghat 230 kV Ckt-2 Scheduled S/D from Cumilla(N) 230/132/33kV end. and from Meghnaghat 230/132kV	
		end Due to Dead line checking.	
08:30	16:34	Khagrachari-Rangamati 132kV Ckt-1 Scheduled S/D from Khagrachori 132/33kV end Due to Annual Deadline Checking	
00.50	10.54	Integration Programme To the Control of the Control	
	00.40		
08:30	20:40	Aminbazar 400/230/132kV S/S 230 kv Bus 01 Scheduled S/D Due to ATR-1 Jack Bus conductor changing work	
08:36	17:31	Kallyanpur 132/33kV S/S Reserve bus Scheduled S/D Due to Annual Maintenance	
08:39	11:27	Kallyanpur 132/33kV S/S GT-1 (132kV) HT Scheduled S/D Due to Annual Maintenance	
09:00		Rampal 1320 MW (BIFPCL) Syncronized with remarks:- Running Unit 2	
00.00	09:05	Kodda 132/33kV S/S Tr-4 (436T) HT is restored.	
	09:07	Kodda 132/33kV S/S Tr-4 (436T) LT is restored.	
09:15	16:58	Kodda(300MW)-Tongi 230kV Ckt-1 Scheduled S/D from Tongi 230/132/33kV end Due to Annual Maintenance	
09:21		Hathazari-Kaptai 132kV Ckt-2 Scheduled S/D from Hathazari 230/132/33kV end Due to dead line checking	
09:45		Sreepur 230/132 kV Tie Bay 3 (208) and Tie Bay 4 (211) shutdown taken.	
09:46	13:49	Ullon 132/33kV S/S GT-3 HT Forced S/D Due to Oil Leakage	
10:25	18:16	Sylhet (South) S/S Sylhet (S)-Biyanibazar 132KV Ckt-1 Project Work S/D Due to SAS witness works.	
10:38	17:12		
		Fenchuganj 230/132/33kV S/S 230 KV Bus-2 Scheduled S/D Due to PT Maintenance	
11:34	17:55	Kallyanpur 132/33kV S/S GT-3 (132kV) HT Scheduled S/D Due to X-former Oil Leakage and RDS 316 Maintenance work.	
12:00		Day peak generation is 11147 MW	
12:39	1	Ashugani CCPP 225 MW ST was sync.	
1 .2.00	14:56	Aminbazar-Medhnadhat 230kV Ckt-2 is restored.	
1	15:31	Halishahar-Khulshi 132kV Ckt-1 is restored.	
	15:31	Rampur 230/132/33 S/S Halishahar-1 is restored.	
	18:50	Savar 132/33kV S/S Transfer Bus is restored.	
19:00		Evening Peak Gen: 11921 MW	
22:35	23:45	Brahmanbaria 132/33kV S/S 401T HT Forced S/D Due to Kasba feeder 33KV Bus B-Phase Red Hot maintenance	40.0MW load interrup.
22:35	23:45	Brahmanbaria 132/33kV S/S 401T LT Forced S/D Due to Kasba feeder 33kV Bus B-Phase Red Hot maintenance	40.0MW load interrup.
22:35	23:45	Branimandana 132/33kV 5/5 4011 ET Forced 5/D Due to Kasda Teeder 33kV Bus B-Phase Red Hot maintenance	40.0WW load interrup.
05:00		Minimum Generation: 8334 MW.	
06:41		Chandraghona 132/33kV S/S TR-01(406T) LT Scheduled S/D Due to PBS work. 33 kv feeder RED HOT maintenance.	18.0MW load interrup.
06:42		Chandraghona 132/33kV S/S TR-01(406T) HT Scheduled S/D	18.0MW load interrup.
07:00		Minimum Generation = 8 335MW	10.0mm load intorrup.
07:53		Jhenaidah 230/132kV S/S 230 kV Bus Scheduled S/D Due to Busbar 1	
07:57		Jhenaidah-Khulna 230kV Ckt-1 Scheduled S/D from Khulna(S) 230/132kV end Due to Project Work at Jhenaidah S/S End. and	
		from Jhenaidah 230/132kV end Due to D/S maintenance	
07:03		Aminbazar-Meghnaghat 230kV Ckt-2 Scheduled S/D from	
		Aminbazar 400/230/132kV end.	
		Allindazai 400/230/132AV Grd.	
07:26		Rajshahi 132/33kV S/S Transformer T-1(405T) LT Scheduled	
07:26			
		S/D Due to General cleaning	
07:26		Rajshahi 132/33kV S/S Transformer T-1(405T) HT Scheduled	
		S/D	
07:28	07:32	Feni 132/33kV S/S T-2(415T) LT Scheduled S/D Due to 33 kv	18.0MW
07.20	07.52	Bus Coupler DS open from PDB (33 kv side)	load
		Bus Coupier DS open from PDB (33 kV side)	
			interrup.
	1		interrup.
1	1		
06:20		Chandour 132/33kV S/S 422T LT Scheduled S/D Due to 33 kv	13.0MW
		Bus coupler T5 maintenance, work	load
		and coupled to maintained. With	interrup.
	1		ппопар.
		L	
06:22		Bogura(New)-Naogaon 132 kV Ckt-1 Scheduled S/D from Naogaon	
		132/33kV end Due to S/D performed by oder of ALDC Bogura.	
1	1	and from Bogura 230/132kV end Due to project work	
1	1	· ·	
06:23		Bogura(New)-Naogaon 132 kV Ckt-2 Scheduled S/D from Naogaon	
1 00.20	1	Buguira(New)-Nacigatin 152 NY CALE Scriedures of a Intiminatogram) 132/33KV end Due to S/D performed by oder of ALDC Bogura.	
		and from Bogura 230/132kV end Due to project work	
1	1		
06:25	1	Bhandaria 132/33kV S/S Transformer-2 LT Project Work S/D	12.0MW
1	1	Due to 33 KV BUS DS Replacement.	load
1	1		interrup.
1	1		ппопар.
1	1	I and the second	