POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT 21:00 Hrs on 19-Apr.23 Today's Actual Min Gen. & Probable Gen. & Demand Min. Gen. at 5:00 Max Demand (Evening): Max Demand (Evening): Casesev(Generation end) Load Shed 10-Mar-24 Till now the maximum generation is : The Summary of Yesterday's Day Peak Generation : Evening Peak Generation : E.P. Demand (at gen end) : Maximum Generation : Total Gen. (MKWH) : 8334 13131 12300 831 0 Total Gen. (newv...) Export from East grid to West grid - Maximum Import from West grid to East grid - Maximum Water Level of Kaptal Lake at 6:00 A M on 82.64 FL(MSL). 9:00 Energy Energy 10-Mar-24 Rule curve : Ft(MSL) 91.56 Gas Consumed Total = 887.79 MMCFD. Oil Consumed (PDB): Tk351,977,748 Tk527,820,261 Cost of the Consumed Fuel (PDB+Pvt): Gas : Coal : Oil : Tk273,331,026 Total : Tk1,153,129,036 Load Shedding & Other Information Today Estimated Shedding (S/S end) MW Estimated Demand (S/S end) M/V 4049 1106 11553 1349 11111 826 463 386 754 11600 Rates of Shedding (On Estimated Demand) 0% Dhaka Chittagong Area Khulna Area Raishahi Area Cumilla Area Mymensingh Area Sylhet Area Barisal Area Rangpur Area Total 0% 0% 0% 0% 0% 0% 0%

Information of the Generating Units under shut down.

Planned Shut- Down

Forced Shut-Down

1) Barapukuria ST: Unit-1,2
2) Ghorasal-3,5,7
3) Shajibazar 330 MW
4) Baghabari-71,100 MW
5) Raozan unit-2
6) Siddhirganj 210 MW.
7) Ashuganj North

utage	Restore	Additional Information of Machines, lines, Interruption / Forced Load shed etc.	Rem
me 08:02	Time 12:59		I
		Baroirhat 132/33kV S/S TR-2, 416T LT Scheduled S/D Due to 33 KV bus Maintenance	18 MW Power interrupt.
08:09	11:03	Bogura 132/33kV S/S Transformer-1 LT Scheduled S/D Due to T-1 & T-2 33KV Busbar maintenance work by PBS-1	50 MW Power interrupt.
08:10	10:21	Bogura 132/33kV S/S Transformer-2 LT Scheduled S/D Due to T-1 & T-2 33KV Busbar maintenance work by PBS-1	
08:15	17:57	Mirpur 132/33kV S/S Main Bus Scheduled S/D Due to 132KV Main Bus Shift to Reserve Bus Work .	
08:24	16:21	Baroaulia-Hathazari 132 kV Ckt-1 Scheduled S/D from Baroaulia 132/33kV end Due to Maintenance work at 158,158A,159 tower.	
1	08:25	Bagerhat-Bhandaria 132 kV Ckt-1 is restored.	
1	08:27	Bhandaria 132/33kV S/S Transformer-2 HT is restored.	
08:34	16:35	Madanganj 132/33kV S/S Madanganj -Haripur 132 kv Ckt-2 Scheduled S/D	
1	08:35	Faridpur 132/33kV S/S Transformer-2 HT is restored.	
08:35	16:35	Haripur 230/132kV S/S Madanganj-2 Scheduled S/D Due to Work on other end.	
08:44	13:26	Kallyanpur 132/33kV S/S Reserve bus Scheduled S/D Due to Aminbazar-1 RDS-306 Maintenance work.	
08:54	11:50	Ashuganj-Bhulta 400 kV Ckt-2 Scheduled S/D from Bhulta 400/230kV end Due to Due to maintenance works at Ashuganj end.	
08:55	10:37	Aminbazar-Kallyanpur 132kV Ckt-1 Scheduled S/D from Kallyanpur 132/33kV end Due to Aminbazar-1 RDS-306 Maintenance work.	
08:58	15:42	Kodda(300MW)-Tongi 230kV Ckt-1 Scheduled S/D from Tongi 230/132/33kV end Due to Annual maintenance work	
09:00	11:14	Ramganj 132/33kV S/S Transformer -02 HT Scheduled S/D Due to Due to annual maintenance of 33kv PBS	25 MW Power interrupt.
09:00			25 MVV Power Interrupt.
	16:22	Baroaulia-Hathazari 132 kV Ckt-2 Scheduled S/D from Hathazari 230/132/33kV end Due to Annual maintenance.	
09:19	14:07	Aminbazar-Manikgonj PP 132kV Ckt-2 Project Work S/D from Aminbazar 400/230/132kV end Due to Project work	110 MW Power interrupt.
09:19	14:07	Aminbazar-Manikgonj PP 132kV Ckt-1 Project Work S/D from Aminbazar 400/230/132kV end Due to Project work	
09:40	13:43	Khulna (C) S/S KPCL-2 Scheduled S/D Due to South ckt-2 bus isolater maintenance	
09:45	13:41	Khulna(C)-Khulna (S) 132kV Ckt-1 Scheduled S/D from Khulna (C) end Due to South ckt-2 Bus isolated maintenance.	
09:45	14:11	Savar 132/33kV S/S 132kV Manikganj PS-Savar Ckt-2 Scheduled S/D Due to hot spot Maintenance	
09:52	13:42	Khulna (C) S/S North- West Ckt-2 Scheduled S/D Due to South Ckt-2 bus isolater maintenance	
09:55	17:30	Sreepur 230/132/33kV S/S Sreepur-Ashuganj Ckt-1 Scheduled S/D Due to Auto Recloser logic & wiring of SAS panel.	
09:57	17:31	Ashuganj-Sreepur 230 kV Ckt-1 Forced S/D from Ashuganj 230/132/33kV end Due to shutdown by NLDC	
09:59	16:16	Bashundhara-Rampura 132 kV Ckt-2 S/D from Rampura 230/132kV end Due to S/D Taken By Gulshan SS Authority for armouring	
10:00	14:55	Savar 132/33kV S/S 132kV Manikganj PS-Savar Ckt-1 Scheduled S/D Due to hot sopot maintenance	
10:11	13:29	Khulna (C) S/S 132 kV Main Bus Section-1 Scheduled S/D Due to South ckt-2 Bus isolater maintenance	
10:14		Shahiibazar 100 MW GTPP Syncronized	
10:33	18:05	Sylhet (South) S/S Sylhet (S)-Fenchugonj 132KV Ckt-1 Project Work S/D Due to Project Work	
10:33	18:06	Sylhet (South) S/S Sylhet (S)-Fenchugon) 132KV Ckt-2 Project Work S/D Due to Project Work Sylhet (South) S/S Sylhet (S)-Fenchugon) 132KV Ckt-2 Project Work S/D Due to Project Work	
10:49	10.00	Syntac (Goda) and Syntac (Open Interlagent) 1321V CAPE Project Work SID But to Project Work Fenchugoni CCPP Phase-2 Shutdown with remarks: GT-3	
10.49	12:01	Periotogorij COFF Pritasez Structown war remarks. G1-3 Haripur-Meghnaghat 230kV Ckt-1 is restored.	
12-10	12:01		
		Meghnaghat 230/132kV S/S Meghnaghat-Start Up(MPL) S/D Due to For Preventive maintenance work shutdown.	
13:39	18:16	Barishal 230/132kV S/S T-4 LT Scheduled S/D Due to Repair Maintenance Work of 33 kv bus by PBS	
14:27		Shahjibazar 100 MW GTPP Shutdown	
15:12	15:50	Sirajganj 132/33kV S/S T4 Tripped showing 33kV -51/50-O/C relays Due to Economic zone 33kV Feeder B-Phase CT Blast	08 MW Power interrupt.
15:12	15:30	Sirajganj 132/33kV S/S T3 Tripped showing 33kV -51/50-O/C relays Due to Economic zone 33kV Feeder B-Phase CT Blast	
	15:21	Barishal 230/132kV S/S T-5 HT is restored.	
	16:01	Haripur 230/132kV S/S Auto TR-1 HT is restored.	
	16:10	Dohazari-Sikalbaha 132 kV Ckt-2 is restored.	
1	16:22	Baroaulia-Hathazari 132 kV Ckt-1 is restored.	
16:28	18:43	Bhandaria 132/33kV S/S Transformer-2 LT Project Work S/D Due to EEGBPSP project work.	22 MW Power interrupt.
	16:53	Cumilla(S)-Kachua 132 kV Ckt-1 is restored.	
17:06		Shahjibazar 100 MW GTPP Syncronized	
17:12		Meghaphat CCPP(Summit)-2 Syncronized	
17.12	18-11	wegmagnar cerregummerz syncionized	
	18:40	Barishal-Bhandaria 132 kV Ckt-1 is restored.	
19:40	18:40		
		Shahjibazar 100 MW GTPP Shutdown	
00:01		Meghnaghat CCPP(Summit) Shutdown with remarks:- ST	
00:14		Meghnaghat CCPP(Summit) Shutdown with remarks:- GT1	
06:11		Sylhet 225 MW CCPP Shutdown with remarks:- GT	
07:10		Haripur-Meghnaghat 230kV Ckt-2 S/D from Haripur 230/132kV end Due to Preventive Maintenance Work.	
07:14		Baroaulia-Hathazari 132 kV Ckt-1,2 Scheduled S/D from Hathazari end.Due to Maintenance work at 158,158A,159 tower.	
07:22		Bhaluka-Mymensingh 132 kV Ckt-1,2 Scheduled S/D from Mymensingh 132/33kV end Due to Annual maintenance	30 MW Power interrupt.
07:23		Gopalganj- Gopalganj(N) 132kV Ckt-2 S/D from Gopalganj 400/132kV end Due to PT change	
07:37		Bhaluka-Mymensingh 132 kV Ckt-1 Scheduled S/D from Bhaluka 132/33kV end Due to Annual maintenance	
07:39		Sreepur 230/132/33kV S/S Sreepur-Valuka Ckt-1 Scheduled S/D Due to From Bhaluka Side.	
07:52		Bhaluka 132/33kV S/S Bus B Scheduled S/D Due to Annual maintenance	
07:03		Aminbazar-Meghnaghat 230kV Ckt-2 Scheduled S/D from	
07.00		A 1 400/000(400)V	
		Aminbazar 400/230/132kV end.	
I			
07:26		Rajshahi 132/33kV S/S Transformer T-1(405T) LT Scheduled	
07.20			
		S/D Due to General cleaning	
07:26		Beishahi 122/23I/V C/C Transformer T 1/40ET\ LT Cahadulad	
07.20		Rajshahi 132/33kV S/S Transformer T-1(405T) HT Scheduled	
		IS/D	
1			
07:00	07.00	5 : 400/001V 0/0 T 0/445TV T 0 1 1 1 1 0/D D 1 00 1	40.04.04
07:28	07:32	Feni 132/33kV S/S T-2(415T) LT Scheduled S/D Due to 33 kv	18.0MW
		Bus Coupler DS open from PDB (33 kv side)	load
			interrup.
			interrup.
I			
06:20		Chandaur 132/33kV S/S 422T LT Scheduled S/D Due to 33 kv	13.0MW
00.20		Chandpur 132/33kV S/S 422T LT Scheduled S/D Due to 33 kv	
l		Bus coupler T5 maintenance. work	load
I			interrup.
			Interrup.
		Bogura(New)-Naogaon 132 kV Ckt-1 Scheduled S/D from Naogaon	
06:22		132/33kV end Due to S/D performed by oder of ALDC Bogura.	
06:22		prozestive the Due to 3/D perioritied by oder or ALDG bogura.	1
06:22			
06:22		and from Bogura 230/132kV end Due to project work	
06:22		and from Bogura 230/132kV end Due to project work	
06:22		and from Bogura 230/132kV end Due to project work Bogura(New)-Naogaon 132 kV Ckt-2 Scheduled S/D from Naogaon 132/33kV end Due to S/D performed by oder of ALDC Bogura.	