

**Bangladesh Power Development Board**  
**DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation  
Tel : 9564667, 9551095

Month March, 2024				Day : Tuesday				Date : 19.03.24				
Probable Maximum Demand : 13600 MW				Probable Maximum Generation : 13662 MW								
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 81.57 ft				Today = 81.37 ft				
				Rule Curve = 90.12 ft								
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	18.03.24 (Yesterday)		19.03.24 (Today)		18.03.24 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
					Day	Evening	Day	Evening	Gas/Coal/oil/ Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date
<b>(A) Plants in operation:</b>												
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	130	210	160	180			
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190	Gas Shortage	
3	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Awaiting for HGP/	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	37	30	30	71	Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450			
8	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
9	Haripur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	400	366	368	360	370			
10	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage	
11	Siddhirgonj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	332	332	335	335			
12	Meghnaghat 335MW CCGP(Summit)	Gas (IPP)	2x110+1x110	335	335	150	150	150	150	185	Gas Shortage	
13	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	15	15	15			
14	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	8	8	8	8			
15	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	0	0			
16	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+1x7.73	80	80	41	41	39	39			
17	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33			
18	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	32	32	33			
19	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	17	8	17			
20	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	105	17	105			
21	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	16	149	16	149			
22	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	17	0	17			
23	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	47	193	45	195			
24	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	6x18.415+1x8.97	149	149	30	149	35	149			
25	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	17	0	17			
26	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	17	0	17			
27	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	8	5	0	17			
28	Manikganj 162MW PP(MPL)	HFO (IPP)	9x18	162	162	0	54	0	54			
29	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	16	0	35	0			
30	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	17	0	17			
31	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	0	0	0	0			
32	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	0	0	0	17			
33	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	96	90	98	98			
34	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	15	25	15	25			
35	Unique Meghnaghat 584MW CCGP	Gas	1x400+1x184	584	584	0	0	0	0	584	Gas Shortage	
	Meghnaghat 589 MW CCGP(Summit)	Gas				190	0	0	0		Test run	
<b>Dhaka Zone Total</b>				<b>5828</b>	<b>5634</b>	<b>1993</b>	<b>2531</b>	<b>1881</b>	<b>2537</b>	<b>1345</b>	<b>740</b>	
36	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	30	30	30	30	200	Inadequate Water Level	
37	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	110	110	0	0	70	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
38	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	5	0	5	0			
39	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	6	25	8	25			
40	Teknaf 20MW PP (SolarsTech)	Solar (IPP)	1x20	20	20	19	0	20	0			
41	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	19	6	6			
42	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	17	17	17			
43	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
44	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	0	34	220	220		Was under maint.	
45	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	16	16	26	50			
46	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	12	12	12	12			
47	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	32	34	34	34			
48	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	24	40	33	64			
49	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	10	10	9	9			
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			2	26	10	25			
50	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	13	25	0	25			
51	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	17	0	17			
52	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	17	17	17			
53	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	23	10	12	23			
54	Juldah 100 MW Unit-1 (Acorn)	HFO (NENP)	8x13.45	100	100	25	25	25	25			
55	Chattogram 116 MW PP (Anlima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	0	0	17	17			
56	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	53	141	17	140			
57	Chattogram 2*612MW Coal Based PP (SS Power)	Coal (IPP)	2x612	1224	1224	275	270	270	270			
58	Matarbari 2*600 MW (CPGCL)	Coal (CPGCL)	1x575	575	575	808	803	810	810			
	Cox's Bazar Wind PP	(Wind) (IPP)				4	4	40	40		Test run	
	Sonagazi 75 MW Solar Plant	(Solar) (EGCB)				70	0	25	0		Test run	
<b>Chattogram Zone Total</b>				<b>4404</b>	<b>4344</b>	<b>1571</b>	<b>1685</b>	<b>1663</b>	<b>1876</b>	<b>270</b>	<b>330</b>	
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	34	42	46	46			
60	Ashuganj 225 MW CCGP	Gas (APSCL)	1x142+1*75	221	221	216	216	225	225			
61	Ashuganj 450 MW CCGP(South)	Gas (APSCL)	1x360	360	360	335	300	310	335			
62	Ashuganj 450 MW CCGP(North)	Gas (APSCL)	1x361	360	360	0	0	0	0	360	Gas Shortage	
63	Ashuganj 420 MW CCGP(East)	Gas (APSCL)	1x284+1x116	400	400	355	335	350	360			
64	Ashuganj 195MW PP (APSC-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	8		Gas Shortage	
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	0	0	0	0	187	Gas Shortage	
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	8	5	6	8			
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	38	46	47	47			
68	Chandpur 150 MW CCGP	Gas (PDB)	1X106+1x57	163	163	50	50	50	50		Test run	
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	34	200	34	200			
70	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	7	9	10			
71	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	25	33	33	33			
72	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	48	52	34	52			
73	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	19	19	19	19			
74	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	114	34	114			
75	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	38	78	45	78			
76	Bhainob 54 MW PP	HFO (IPP)	3x18.2	54	54	0	17	17	17			
77	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x5.428	115	115	0	95	0	94			
78	Ashuganj 55 MW PP (Precision)	Gas (NENP)	15*4	55	55	20	20	20	20			
**	Impoprt (Tripura)	India		160	160	144	130	128	141			
<b>Cumilla Zone Total</b>				<b>2937</b>	<b>2929</b>	<b>1397</b>	<b>1767</b>	<b>1415</b>	<b>1857</b>	<b>598</b>	<b>0</b>	
79	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	68	134	80	120	68	Gas Shortage	
80	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	59	99	60	90			
81	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	9	19	0	0			
82	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
83	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	37	0	50	0			
84	Tangail 22 MW PP(PGCL)	HFO (IPP)	4x6.7	22	22	0	6	0	6			
<b>Mymensingh Zone Total</b>				<b>600</b>	<b>592</b>	<b>175</b>	<b>258</b>	<b>192</b>	<b>216</b>	<b>68</b>	<b>0</b>	

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	18.03.24 (Yesterday)		19.03.24 (Today)		18.03.24 (Yesterday)		Status of Machines under shut-down/ Maintenance		
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
						Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation MW	Machines shut down (MW)			
85	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	35	42	42	42		28	Under maint.		
86	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	39	38	40	40		52	GT-4 Under maint.		
87	Fenchugonj 51 MW PP (Barakattullah)	Gas (RPP)	19x2.90	51	51	0	53	0	51					
88	Kushiara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163					
89	Hobiganj 11 MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0					
90	Shahjibazar GTPP Unit-8 & 9	Gas (PDB)	2x35	70	66	55	61	65	65					
91	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.		
92	Shahjibazar 86 MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	0	0	0	0			Contact Expired		
93	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	203	204	205	205					
94	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	20	20					
95	Sylhet 10 MW PP (Desh)	Gas (RPP)	6x1.95	10	10	0	0	10	10					
96	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	24	16	16					
97	Bibiyan-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	320	280	310	310					
98	Bibiyan-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	412	366	400	400					
99	Bibiyan South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	160	75	210	210					
100	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0			Test run		
101	Fenchugonj 44 MW (Energypirima)	Gas (NENP)	12*3.3+5*2	50	50	0	44	0	44					
<b>Sylhet Zone Total</b>						<b>2472</b>	<b>2427</b>	<b>1421</b>	<b>1368</b>	<b>1481</b>	<b>1576</b>	<b>0</b>	<b>410</b>	
102	Bheramara GTPP Unit-3	HSD (PDB)	1 x 20	20	16	0	0	0	0					
103	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0	410		Gas Shortage		
104	Fariapur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	44	0	50					
105	Gopalnani 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	76	0	70					
106	Khulna 225 MW CCPP	HSD/ Gas (NWPGL)	1 x 150+1x75	225	230	0	0	0	0					
107	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	18	17	17	17					
108	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	0					
109	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	67	0	100	0					
110	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	32	0	32					
111	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	8	0	0					
112	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x817	617	617	649	610	370	370					
113	Khulna 330 MW CCPP	Gas/HSD (BPDB)	1x220+1x116	336	336	0	0	0	0					
**	Bheramara (HVDC)	India		1000	1000	922	781	929	929					
<b>Khulna Zone Total</b>						<b>3241</b>	<b>3237</b>	<b>1656</b>	<b>1568</b>	<b>1416</b>	<b>1468</b>	<b>410</b>	<b>0</b>	
114	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	110	110	110					
115	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	5	9	7	7					
116	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	134	130	130	130		64	ST under maint.		
117	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	720	1244	1200	1200					
118	Potukhali 150 MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	54	0	54					
119	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	150	150	150	150					
120	Bhola 220 MW CCPP (Nutan Bidyt BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	111	110	180	180					
<b>Barishal Zone Total</b>						<b>2265</b>	<b>2265</b>	<b>1120</b>	<b>1807</b>	<b>1777</b>	<b>1831</b>	<b>0</b>	<b>64</b>	
121	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage		
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Under maint.		
122	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	34	25	40					
123	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	28	0	24					
124	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	81	50	90					
125	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	50	40	50					
126	Katakali 50 MW PP (Northern)	HFO (NENP)	6x8.9	50	50	42	42	42	42					
127	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	38	16	30					
128	Siraigonj 225 MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	185	174	180	180					
129	Siraigonj 225 MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage		
130	Siraigonj 225 MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0	220		Gas Shortage		
131	Siraigonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	414	414	414	414					
132	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	5	8					
133	Natore 52 MW PP (Rajkanka)	HFO (IPP)	6x8.92	52	52	16	52	52	8					
134	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	35	0	35					
135	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	35	0	35					
136	Armura 50 MW PP (Sinha)	HFO (NENP)	7x7.9	50	28	28	28	28	28					
137	Siraigonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	4	0	6	0					
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	1012	1014	1000	1000					
<b>Rajshahi Zone Total</b>						<b>3453</b>	<b>3431</b>	<b>1709</b>	<b>2033</b>	<b>1858</b>	<b>1984</b>	<b>511</b>	<b>100</b>	
138	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage		
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under Overhauling		
139	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	200	200	200	200	74		Coal Shortage		
140	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
141	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x2*3	113	113	6	35	6	42					
142	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
143	Majpara, Tatula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0					
144	Thakurgaon 115 MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	75	0	75					
145	Lalmoinhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	36	0	30	0					
146	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	148	0	130	0					
<b>Rangpur Zone Total</b>						<b>1030</b>	<b>950</b>	<b>397</b>	<b>310</b>	<b>374</b>	<b>317</b>	<b>159</b>	<b>85</b>	
<b>Sub-total: Plants in operation</b>						<b>26230</b>	<b>25809</b>	<b>11439.0</b>	<b>13327</b>	<b>12057</b>	<b>13662</b>	<b>3361</b>	<b>1729</b>	

(B) Plants under long term maintenance/ contract expired														
147	Katottli 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			Contract Expired		
148	Hariapur 360 MW CCPP (HPL)	Gas (IPP)	1x235+1x125	360	0	0	0	0	0			Contract Expired		
149	Jamalpur 95 MW PP (Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			Contract Expired		
150	Bosila 108 MW PP (CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Contract Expired		
<b>Sub-total: Plants under long term maintenance/ contract expired</b>						<b>614</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	
<b>Gross Total</b>						<b>26844</b>	<b>25809</b>	<b>11439</b>	<b>13327</b>	<b>12057</b>	<b>13662</b>	<b>3361</b>	<b>1729</b>	

(C) Actual data of 18.03.24 (Yesterday) Monday :													
01.	Max. Demand at eve. peak (Generation end)	:	13450	MW, at =	21:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand at eve. peak (Sub-station end)	:	12838	MW, at =	21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	13327	MW, at =	21:00 hrs	Dhaka	4620	4610	10	Mymensingh	1201	1111	90
04.	Minimum Generation (Generation end)	:	9609	MW, at =	6:00 hrs	Chattogram	1232	1232	0	Sylhet	479	479	0
05.	Day-peak Generation (Generation end)	:	11439	MW, at =	12:00 hrs	Khulna	1501	1501	0	Barishal	382	382	0
06.	Evening-peak Generation (Generation end)	:	13327	MW, at =	21:00 hrs	Rajshahi	1384	1384	0	Rangpur	822	822	0
07.	Evening Peak Load-shed (Sub-station end)	:	117	MW, at =	21:00 hrs	Cumilla	1217	1200	17	Total	12838	12721	117
08.	Minimum Generation Forecast up to 8:00 hrs.	:	9978	MW, at =	5:00 hrs								
09.	Generation shortfall at evening peak due to :	:											
a)	Gas/LF limitation	:	3002	MW									
c)	Coal supply Limitation	:	159	MW									
b)	Low water level in Kaptai lake	:	200	MW									
c)	Plants under shut down/ maintenance	:	1729	MW									
10.	Total Energy (Generation + India Import)	:	277.76	MKWh		14.	Maximum Temperature in Dhaka was : 33.3°C						
	By Gas = 122.940 MKWh			By Oil = 30.286 MKWh		15.	Export through East-West interconnections :						
	By Coal = 95.826 MKWh			By Hydro = 0.937 MKWh									
	By Solar = 2.777 MKWh												
11.	Total Gas Supplied	:	931.30	MMCFD									

(D) Forecast of 19.03.24 (Today) Tuesday :												
01.	Maximum Demand	:	13600	MW	(Generation end)	04.	Maximum Load-shed : 0 MW At evening peak (Sub-station end)					
02.	Maximum Generation	:	13662	MW	(Generation end)	05.	Total Generation : 283.45 MKWh					
03.	Reserve / Shortage	:	62	MW	(Generation end)	06.	Probable					