

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month March, 2024				Day : Monday				Date : 25.03.24				
Probable Maximum Demand : 12500 MW				Probable Maximum Generation : 13325 MW								
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 80.73 ft				Today = 80.61 ft				
				Rule Curve = 89.16 ft								
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	24.03.24 (Yesterday)		25.03.24 (Today)		24.03.24 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
					Day	Evening	Day	Evening	Gas/Coal/oil/ Water Limitation (MW)	Machines shut down (MW)		Description/ Remarks
(A) Plants in operation:												
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	130	130	130	130			
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	100	110	110	110	80	Gas Shortage	
3	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Awaiting for HGP/	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	5	5	30	50	103	Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	380	450	450	450			
8	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
9	Haripur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	400	332	289	280	280	111	Gas Shortage	
10	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage	
11	Siddhirgonj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	328	290	335	335			
12	Meghnaghat 335MW CCGP(Summit)	Gas (IPP)	2x110+1x110	335	335	152	150	150	150	185	Gas Shortage	
13	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	15	0	15			
14	Gagnagarj 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	8	8	8	8	83		
15	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	0	0	0		
16	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+1x7.73	80	80	32	32	39	39			
17	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33			
18	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	25	33	33			
19	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	17	8	17			
20	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	50	17	105			
21	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	32	64	32	149			
22	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	17	0	17			
23	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	47	60	45	195			
24	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	6x18.415+1x8.97	149	149	17	52	17	51			
25	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	17	0	17			
26	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	17	0	17			
27	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	30	52	54	54			
28	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	0	43	0	54			
29	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	27	0	35	0			
30	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	17	0	17			
31	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	0	0	0	0			
32	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	0	0	0	0			
33	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0			
34	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	24	15	25			
35	Unique Meghnaghat 584MW CCGP	Gas	1x400+1x184	584	584	0	0	0	0	584	Gas Shortage	
	Meghnaghat 589 MW CCGP(Summit)	Gas				0	0	0	0		Test run	
Dhaka Zone Total				5828	5634	1743	2042	1821	2426	1378	740	
36	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	30	30	30	30	200	Inadequate Water Level	
37	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
38	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	5	0	5	0			
39	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	25	8	25			
40	Teknaf 20MW PP (SolarsTech)	Solar (IPP)	1x20	20	20	18	0	20	0			
41	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	2	6	20			
42	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	34	16	17	17			
43	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
44	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	213	212	214	216			
45	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	16	32	16	32			
46	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	12	12	12	12			
47	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	34	34	34			
48	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	51	65	32	66			
49	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	10	10	10	10			
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			9	27	4	20			
50	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	6	19	0	25			
51	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	17	0	17			
52	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	17	17	17			
53	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	12	25	12	25			
54	Juldah 100 MW Unit-1 (Acorn)	HFO (NENP)	8x13.45	100	100	25	25	25	25			
55	Chattogram 116 MW PP (Anlima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	17	17	17			
56	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	53	71	54	127			
57	Chattogram 2*612MW Coal Based PP (SS Power)	Coal (IPP)	2x612	1224	1224	0	238	270	270			
58	Matarbari 2*600 MW (CPGCL)	Coal (CPGCL)	1x575	575	575	730	437	650	650			
	Cox's Bazar Wind PP	(Wind) (IPP)				6	2	40	40		Test run	
	Sonagazi 75 MW Solar Plant	(Solar) (EGCB)				73	0	25	0		Test run	
Chattogram Zone Total				4404	4344	1345	1333	1518	1695	380	330	
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	39	42	30	42			
60	Ashuganj 225 MW CCGP	Gas (APSCL)	1x142+1*75	221	221	136	148	225	225			
61	Ashuganj 450 MW CCGP(South)	Gas (APSCL)	1x360	360	360	340	305	300	300			
62	Ashuganj 450 MW CCGP(North)	Gas (APSCL)	1x361	360	360	0	0	0	0	360	Gas Shortage	
63	Ashuganj 420 MW CCGP(East)	Gas (APSCL)	1x284+1x116	400	400	325	335	335	335			
64	Ashuganj 195MW PP (APSC-United)	Gas (IPP)	20*9.73+1*16	195	195	0	36	8	8	159	Gas Shortage	
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51			
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	6	6	6	8			
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	22	31	47	47			
68	Chandpur 150 MW CCGP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0		Test run	
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	34	34	34	200			
70	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	0	8	9	10			
71	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	25	0	33	33			
72	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	25	25	25	52			
73	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	13	0	19	17			
74	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	52	17	114			
75	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	27	59	38	75			
76	Bhainrob 54 MW PP	HFO (IPP)	3x18.2	54	54	0	17	17	17			
77	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x5.428	115	115	0	94	0	95			
78	Ashuganj 55 MW PP (Precision)	Gas (NENP)	15*4	55	55	17	30	40	40			
**	Impoport (Tripura)	India		160	160	130	64	128	141			
Cumilla Zone Total				2937	2929	1207	1337	1362	1810	519	0	
79	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	74	132	107	120	70	Gas Shortage	
80	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	49	98	47	95			
81	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	56	45	56	56			
82	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0			
83	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	22	0	50	0			
84	Tangail 22 MW PP(PGCL)	HFO (IPP)	4x6.7	22	22	0	6	0	6			
Mymensingh Zone Total				600	592	202	281	262	277	70	0	

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	24.03.24 (Yesterday)		25.03.24 (Today)		24.03.24 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation MW	Machines shut down (MW)		
85	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	0	0	0	0	0	70	Under maint.	
86	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	39	39	40	40	0	51	GT-4 Under maint.	
87	Fenchugonj 51 MW PP (Barakattullah)	Gas (RPP)	19x2.90	51	51	0	0	0	0	0	0		
88	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	140	163	163	0	0		
89	Hobiganj 11 MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0	0	0		
90	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	40	62	65	65	0	0		
91	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0	0	330	Under maint.	
92	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	0	0	0	0	0	0	Contact Expired	
93	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	207	206	210	210	0	0		
94	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	16	18	20	20	0	0		
95	Sylhet 10 MW PP (Desh)	Gas (RPP)	6x1.95	10	10	0	0	10	10	0	0		
96	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	25	16	16	17	0	0		
97	Bibiyan-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	320	290	300	300	0	0		
98	Bibiyan-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	400	303	400	400	0	0		
99	Bibiyan South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	383	310	383	383	0	0		
100	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0	0	0	Test run	
101	Fenchugonj 44MW (Energypirima)	Gas (NENP)	12*3.3+5*2	50	50	0	0	0	0	0	0		
Sylhet Zone Total						2472	2427	1593	1384	1607	1608	0	451
102	Bheramara GTPP Unit-3	HSD (PDB)	1 x 20	20	16	0	0	0	0	0	0		
103	Bheramara 410 MW CCPP	Gas (NWPGLCL)	1 x 278+1 x 132	410	410	0	0	0	0	410	0	Gas Shortage	
104	Fariapur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	23	0	50	0	0		
105	Gopalnani 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	20	0	70	0	0		
106	Khulna 225 MW CCPP	HSD/ Gas (NWPGLCL)	1 x 150+1x75	225	230	0	0	0	0	0	0		
107	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	14	17	17	0	0		
108	Madhumati 100 MW PP	HFO (NWPGLCL)	6x18.415	105	105	0	0	0	0	0	0		
109	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	94	0	100	0	0	0		
110	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	0	0	0	0	0		
111	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	0	0	0	0		
112	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x817	617	617	384	384	370	370	0	0		
113	Khulna 330 MW CCPP	Gas/HSD (BPDB)	1x220+1x116	336	336	0	0	0	0	0	0		
**	Bheramara (HVDC)	India		1000	1000	929	785	941	797	0	0		
Khulna Zone Total						3241	3237	1407	1226	1428	1304	410	0
114	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	16	110	110	0	0		
115	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	5	10	7	7	0	0		
116	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	64	65	65	65	0	129	ST under maint.	
117	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	750	1030	1200	1200	0	0		
118	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	54	0	0		
119	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	150	200	150	150	0	0		
120	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	220	220	0	0		
Barishal Zone Total						2265	2265	1189	1541	1752	1806	0	129
121	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	60	60	71	0	Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100	0	Under maint.	
122	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	37	25	40	0	0		
123	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	4	0	24	0	0		
124	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	92	50	90	0	0		
125	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	40	40	50	0	0		
126	Katakali 50 MW PP (Northern)	HFO (NENP)	6x8.9	50	50	0	16	42	42	0	0		
127	Santalaha 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	38	16	38	0	0		
128	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGLCL)	1x150+1x75	210	210	196	170	170	170	0	0		
129	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGLCL)	1x150 + 1x75	220	220	0	0	0	0	220	0	Gas Shortage	
130	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGLCL)	1x141+1x79	220	220	0	0	0	0	220	0	Gas Shortage	
131	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	414	300	414	414	114	0	Gas Shortage	
132	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	5	5	5	8	0	0		
133	Natore 52 MW PP (Rajkanka)	HFO (IPP)	6x8.92	52	52	0	8	8	8	0	0		
134	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	35	0	35	0	0		
135	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	35	0	35	0	0		
136	Armura 50 MW PP (Sinha)	HFO (NENP)	7x7.79	50	28	0	14	28	28	0	0		
137	Sirajgonj 6.55 MW Solar	Solar (NWPGLCL)	1x6	6	6	5	0	6	0	0	0		
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	931	1019	1000	1000	625	100		
Rajshahi Zone Total						3453	3431	1551	1813	1864	2042	625	100
138	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	0	Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	0	Under Overhauling	
139	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	200	200	200	200	74	0	Coal Shortage	
140	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0	0	0		
141	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	0	34	6	42	0	0		
142	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0	0	0		
143	Majpara, Tatula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	4	0	8	0	0	0		
144	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	72	35	115	0	0		
145	Lalmoinhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	5	0	30	0	0	0		
146	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	80	0	130	0	0	0		
Rangpur Zone Total						1030	950	289	306	409	357	159	85
Sub-total: Plants in operation						26230	25809	10526.0	11263	12023	13325	3541	1835
(B) Plants under long term maintenance/ contract expired													
147	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0	0	0	0	Contract Expired
148	Hariapur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	0	0	0	0	0	0	0	0	Contract Expired
149	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0	0	0	0	Contract Expired
150	Bosila 108MW PP(CLCL)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0	0	0	0	Contract Expired
Sub-total: Plants under long term maintenance/ contract expired						614	0	0	0	0	0	0	0
Gross Total						26844	25809	10526	11263	12023	13325	3541	1835
(C) Actual data of 24.03.24 (Yesterday) Sunday :													
01.	Max. Demand at eve. peak (Generation end)	: 11263 MW, at = 19:30 hrs		12.		Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	: 11041 MW, at = 19:30 hrs		Zone		Demand MW	Supply MW	Load Shed	Zone	Demand MW	Supply MW	Load Shed MW	
03.	Highest Generation (Generation end)	: 11328 MW, at = 16:00 hrs		Dhaka		4101	4101	0	Mymensingh	908	908	0	
04.	Minimum Generation (Generation end)	: 7652 MW, at = 6:00 hrs		Chattogram		1240	1240	0	Sylhet	379	379	0	
05.	Day-peak Generation (Generation end)	: 10526 MW, at = 12:00 hrs		Khulna		1601	1601	0	Barishal	374	374	0	
06.	Evening-peak Generation (Generation end)	: 11263 MW, at = 19:30 hrs		Rajshahi		1179	1179	0	Rangpur	635	635	0	
07.	Evening Peak Load-shed (Sub-station end)	: 0 MW, at = 19:30 hrs		Cumilla		624	624	0					
08.	Minimum Generation Forecast up to 8:00 hrs.	: 8513 MW, at = 5:00 hrs							Total	11041	11041	0	
09.	Generation shortfall at evening peak due to :					Fuel cost :		(a) Gas = 366021016 Taka	(c) Coal = 538584105 Taka		Taka		
	a) Gas/LF limitation	: 3182 MW						(b) Oil = 322809105 Taka	Total = 1227414226 Taka		Taka		
	c) Coal supply Limitation	: 159 MW											
	b) Low water level in Kaptai lake	: 200 MW											
	c) Plants under shut down/ maintenance	: 1835 MW											
10.	Total Energy (Generation + India Import)	: 245.64 MKWh		14.		Maximum Temperature in Dhaka was : 32.7°C							
	By Gas = 119.450 MKWh	By Oil = 17.919 MKWh		15.		Export through East-West interconnections :							
	By Coal = 80.573 MKWh	By Hydro = 0.640 MKWh				At evening peak-hour		: 10526 MW, at 19:30 hrs					
	By Solar = 2.452 MKWh					Maximum		: 700 MW, at 21:00 hrs					
11.	Total Gas Supplied	: 911.93 MMCFD				Energy		: 0 MKWh					
(D) Forecast of 25.03.24 (Today) Monday :													
01.	Maximum Demand	: 12500 MW (Generation end)		04.		Maximum Load-shed : 0 MW At evening peak (Sub-station end)							
02.	Maximum Generation	: 13325 MW (Generation end)		05.		Total Generation : 271.06 MKWh							
03.	Reserve / Shortage	: 825 MW (Generation end)		06.		Probable Max. Temperature in Dhaka : 32.7°C							

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 2