

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month March, 2024				Day : Tuesday				Date : 26.03.24				
Probable Maximum Demand : 11500 MW				Probable Maximum Generation : 13315 MW								
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 80.61 ft				Today = 80.50 ft				
				Rule Curve = 89.00 ft								
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	25.03.24 (Yesterday)		26.03.24 (Today)		25.03.24 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
					Day	Evening	Day	Evening	Gas/Coal/oil/ Water Limitation (MW)	Machines shut down (MW)		Description/ Remarks
(A) Plants in operation:												
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	130	130	130	130			
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	110	110	110	110	80	Gas Shortage	
3	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Awaiting for HGP/	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	5	5	0	0	103	Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	420	450	450	450			
8	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
9	Haripur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	400	341	334	350	350	66	Gas Shortage	
10	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage	
11	Siddhirgonj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	333	300	335	335			
12	Meghnaghat 335MW CCGP(Summit)	Gas (IPP)	2x110+1x110	335	335	150	150	150	150	185	Gas Shortage	
13	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	20	30	0	30			
14	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	0	25	8	83			
15	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	0	0			
16	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+1x7.73	80	80	32	32	39	39			
17	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	33	33			
18	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33			
19	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	17	8	17			
20	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	105	17	105			
21	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	48	147	32	149			
22	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	17	0	17			
23	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	196	45	195			
24	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	6x18.415+1x8.97	149	149	17	52	17	51			
25	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	17	0	17			
26	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	17	0	17			
27	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	53	54	54			
28	Manikganj 162MW PP(MPL)	HFO (IPP)	9x18	162	162	0	54	0	54			
29	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	33	0	35	0			
30	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	0	0	17			
31	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	0	0	0	0			
32	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	0	0	0	0			
33	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0			
34	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	24	15	25			
35	Unique Meghnaghat 584MW CCGP	Gas	1x400+1x184	584	584	0	0	0	0	584	Gas Shortage	
	Meghnaghat 589 MW CCGP(Summit)	Gas				0	0	0	0		Test run	
Dhaka Zone Total				5828	5634	1739	2323	1861	2461	1333	740	
36	Karnaphuli Hydro PP Unit-1,2,3,4,5	Hydro (PDB)	2x40, 3x50	230	230	30	30	30	30	200	Inadequate Water Level	
37	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
38	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	4	0	5	0	0			
39	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	11	8	25			
40	Teknaf 20MW PP (SolarsTech)	Solar (IPP)	1x20	20	20	20	0	20	0			
41	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	19	6	20			
42	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	22	14	17	17			
43	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
44	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	212	211	214	216			
45	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	16	16	16	16			
46	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	12	12	12	12			
47	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	34	34	34	34			
48	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	24	50	32	66			
49	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	10	10	10	10			
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			7	32	10	20			
50	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	12	25	0	25			
51	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	17	0	17			
52	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	17	17	17			
53	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	12	12	12	12			
54	Juldah 100 MW Unit-1 (Acorn)	HFO (NENP)	8x13.45	100	100	25	25	25	25			
55	Chattogram 116 MW PP (Anlima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	17	17	17			
56	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	53	125	54	127			
57	Chattogram 2*612MW Coal Based PP (SS Power)	Coal (IPP)	2x612	1224	1224	280	275	270	270			
58	Matarani 2*600 MW (CPGCL)	Coal (CPGCL)	1x575	575	575	974	970	700	700			
	Cox's Bazar Wind PP	(Wind) (IPP)				0	0	40	40		Test run	
	Sonagazi 75 MW Solar Plant	(Solar) (EGCB)				62	0	25	0		Test run	
Chattogram Zone Total				4404	4344	1849	1922	1574	1716	380	330	
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	38	37	30	42			
60	Ashuganj 225 MW CCGP	Gas (APSCL)	1x142+1*75	221	221	213	208	225	225			
61	Ashuganj 450 MW CCGP(South)	Gas (APSCL)	1x360	360	360	335	270	300	300			
62	Ashuganj 450 MW CCGP(North)	Gas (APSCL)	1x361	360	360	0	0	0	0	360	Gas Shortage	
63	Ashuganj 420 MW CCGP(East)	Gas (APSCL)	1x284+1x116	400	400	328	310	335	335			
64	Ashuganj 195MW PP (APSC-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	0	0	187	Gas Shortage	
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	0	0			
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	5	6	8			
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	23	47	47			
68	Chandpur 150 MW CCGP	Gas (PDB)	1X106+1x57	163	163	0	0	50	50		Test run	
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	34	34	34	34			
70	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	8	9	10			
71	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	25	25	33	33			
72	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	18	52	25	52			
73	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	17	19	19	19			
74	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	98	98	114			
75	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	38	58	38	75			
76	Bhainob 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17			
77	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x5.428	115	115	0	94	0	95			
78	Ashuganj 55 MW PP (Precision)	Gas (NENP)	15*4	55	55	48	50	40	40			
**	Impoprt (Tripura)	India		160	160	146	144	128	141			
Cumilla Zone Total				2937	2929	1341	1511	1434	1637	547	0	
79	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	69	113	100	115	89	Gas Shortage	
80	Jamalpur 115 MW PP (United)	HFO (IPP)	115	115	49	100	49	100	100			
81	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	58	75	56	100			
82	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0			
83	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	26	0	50	0			
84	Tangail 22 MW PP(PGCL)	HFO (IPP)	4x6.7	22	22	0	6	0	6			
Mymensingh Zone Total				600	592	203	294	257	321	89	0	

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	25.03.24 (Yesterday)		26.03.24 (Today)		25.03.24 (Yesterday)		Status of Machines under shut-down/ Maintenance		
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
						Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation MW	Machines shut down (MW)			
85	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	0	0	0	0	0	70	Under maint.		
86	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	39	39	40	40	0	51	GT-4 Under maint.		
87	Fenchugonj 51 MW PP (Barakattullah)	Gas (RPP)	19x2.90	51	51	0	25	0	0	0	0			
88	Kushiara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163	0	0			
89	Hobiganj 11 MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0	0	0			
90	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	58	57	65	65	0	0			
91	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0	0	330	Under maint.		
92	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	0	0	0	0	0	0	Contact Expired		
93	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	203	204	135	135	0	0			
94	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	16	18	20	20	0	0			
95	Sylhet 10 MW PP (Desh)	Gas (RPP)	6x1.95	10	10	0	0	10	10	0	0			
96	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	16	16	17	0	0			
97	Bibiayana-III 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	310	280	300	300	0	0			
98	Bibiayana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	400	366	400	400	0	0			
99	Bibiayana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	380	340	383	383	0	0			
100	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0	0	0	Test run		
101	Fenchugonj 44MW (Energypirima)	Gas (NENP)	12*3.3+5*2	50	50	0	25	0	0	0	0			
Sylhet Zone Total						2472	2427	1577	1533	1532	1533	0	451	
102	Bheramara GTPP Unit-3	HSD (PDB)	1 x 20	20	16	0	0	0	0	0	0			
103	Bheramara 410 MW CCPP	Gas (NWPGLCL)	1 x 278+1 x 132	410	410	0	0	0	0	0	410	Gas Shortage		
104	Fariapur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	50	0	0			
105	Gopalgani 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	56	0	70	0	0			
106	Khulna 225 MW CCPP	HSD/ Gas (NWPGLCL)	1 x 150+1x75	225	230	0	0	0	0	0	0			
107	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	0	17	17	0	0			
108	Madhumati 100 MW PP	HFO (NWPGLCL)	6x18.415	105	105	0	0	0	0	0	0			
109	Mongla Orion 100 MW Solar PP	Solar (IPP)	100	100	96	0	100	0	0	0	0			
110	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	0	0	0	0	0			
111	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	0	0	0	0			
112	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x817	617	617	372	380	370	370	0	0			
113	Khulna 330 MW CCPP	Gas/HSD (BPDB)	1x220+1x116	336	336	0	0	0	0	0	0			
**	Bheramara (HVDC)	India		1000	1000	923	782	940	940	0	0			
Khulna Zone Total						3241	3237	1391	1218	1427	1447	410	0	
114	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	48	110	110	0	0			
115	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	6	10	7	7	0	0			
116	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	65	65	130	130	0	129	ST under maint.		
117	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	720	1220	1200	1200	0	0			
118	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	35	0	54	0	0			
119	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	150	299	150	150	0	0			
120	Bhola 220MW CCPP (Nutan Bidyt BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	220	220	0	0			
Barishal Zone Total						2265	2265	1161	1897	1817	1871	0	129	
121	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71	0	Gas Shortage		
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	0	100	Under maint.		
122	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	27	25	40	0	0			
123	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	30	0	24	0	0			
124	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	83	50	90	0	0			
125	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	50	40	50	0	0			
126	Katakali 50 MW PP (Northern)	HFO (NENP)	6x8.9	50	50	0	42	42	42	0	0			
127	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	38	16	38	0	0			
128	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGLCL)	1x150+1x75	210	210	214	190	170	190	0	0			
129	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGLCL)	1x150 + 1x75	220	220	0	0	0	0	220	0	Gas Shortage		
130	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGLCL)	1x141+1x79	220	220	0	0	0	0	220	0	Gas Shortage		
131	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	364	320	414	414	94	0	Gas Shortage		
132	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	5	5	5	8	0	0			
133	Natore 52 MW PP (Rajkanka)	HFO (IPP)	6x8.92	52	52	0	0	8	8	0	0			
134	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	35	0	35	0	0			
135	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	35	0	35	0	0			
136	Armura 50 MW PP (Sinha)	HFO (NENP)	7x7.9	50	28	0	0	28	28	0	0			
137	Sirajgonj 6.55 MW Solar	Solar (NWPGLCL)	1x6	6	6	2	0	6	0	0	0			
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	948	1011	1000	1000	605	100			
Rajshahi Zone Total						3453	3431	1533	1866	1804	2002	605	100	
138	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	0	Coal Shortage		
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	0	Under Overhauling		
139	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	200	200	170	170	74	0	Coal Shortage		
140	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0	0	0			
141	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	0	6	6	42	0	0			
142	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0	0	0			
143	Majpara, Tatula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	6	0	8	0	0	0	0			
144	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	113	35	115	0	0			
145	Lalmoinhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	33	0	30	0	0	0			
146	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	195	0	130	0	0	0			
Rangpur Zone Total						1030	950	434	319	379	327	159	85	
Sub-total: Plants in operation						26230	25809	11228.0	12883	12085	13315	3523	1835	
(B) Plants under long term maintenance/ contract expired														
147	Katottli 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0	0	0	0	Contract Expired	
148	Hariapur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	0	0	0	0	0	0	0	0	Contract Expired	
149	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0	0	0	0	Contract Expired	
150	Bosha 108MW PP(CLCL)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0	0	0	0	Contract Expired	
Sub-total: Plants under long term maintenance/ contract expired						614	0	0	0	0	0	0	0	
Gross Total						26844	25809	11228	12883	12085	13315	3523	1835	
(C) Actual data of 25.03.24 (Yesterday) Monday :														
01.	Max. Demand at eve. peak (Generation end)	: 12925 MW, at = 21:00 hrs		12.		Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :								
02.	Max. Demand at eve. peak (Sub-station end)	: 12377 MW, at = 21:00 hrs		Zone		Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW		
03.	Highest Generation (Generation end)	: 12883 MW, at = 21:00 hrs		Dhaka		4596	4596	0	Mymensingh	1077	1057	20		
04.	Minimum Generation (Generation end)	: 8513 MW, at = 6:00 hrs		Chattogram		1280	1280	0	Sylhet	480	470	10		
05.	Day-peak Generation (Generation end)	: 11228 MW, at = 12:00 hrs		Khulna		1392	1392	0	Barishal	393	393	0		
06.	Evening-peak Generation (Generation end)	: 12883 MW, at = 21:00 hrs		Rajshahi		1285	1285	0	Rangpur	683	683	0		
07.	Evening Peak Load-shed (Sub-station end)	: 40 MW, at = 21:00 hrs		Cumilla		1191	1181	10						
08.	Minimum Generation Forecast up to 8:00 hrs.	: 7965 MW, at = 5:00 hrs												
09.	Generation shortfall at evening peak due to :	:												
a)	Gas/LF limitation	: 3164 MW		13.		Fuel cost :		(a) Gas = 383814174 Taka	(c) Coal = 614667469 Taka					
c)	Coal supply Limitation	: 159 MW				(b) Oil = 394261041 Taka		Total = 1392742684 Taka						
b)	Low water level in Kaptai lake	: 200 MW												
c)	Plants under shut down/ maintenance	: 1835 MW												
10.	Total Energy (Generation + India Import)	: 264.78 MKWh		14.		Maximum Temperature in Dhaka was :		33.1°C						
	By Gas = 124.243 MKWh	By Oil = 21.667 MKWh		15.		Export through East-West interconnections :								
	By Coal = 92.488 MKWh	By Hydro = 0.723 MKWh				At evening peak-hour		: 11228 MW, at 21:00 hrs						
	By Solar = 2.208 MKWh					Maximum		: 700 MW, at 21:00 hrs						