

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month March, 2024				Day : Friday				Date : 29.03.24				
Probable Maximum Demand : 11200 MW				Probable Maximum Generation : 13708 MW								
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 80.26 ft				Today = 80.14 ft				
				Rule Curve = 88.84 ft								
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	28.03.24 (Yesterday)		29.03.24 (Today)		28.03.24 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)		Description/ Remarks
(A) Plants in operation:												
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	150	130	130	130	110	Gas Shortage	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	110	170	170	170			
3	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Awaiting for HGPI	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	5	5	5	5	103	Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450			
8	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
9	Haripur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	400	324	331	330	330			
10	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage	
11	Siddhirgonj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	330	335	335	335			
12	Meghnaghat 335MW CCGP(Summit)	Gas (IPP)	2x110+1x110	335	335	150	146	150	150	189	Gas Shortage	
13	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	30	0	30			
14	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	25	42	8	83			
15	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	0	0			
16	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+1x7.73	80	80	39	40	39	39			
17	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33			
18	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	33	33	33			
19	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	17	8	17			
20	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	105	17	105			
21	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	32	82	32	149			
22	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	17	0	17			
23	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	47	195	45	195			
24	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	6x18.415+1x8.97	149	149	17	39	17	54			
25	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	17	0	17			
26	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	17	0	17			
27	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	53	54	54			
28	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	0	54	0	17			
29	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	28	0	35	0			
30	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	0	0	17			
31	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	0	0	0	0			
32	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	0	0	0	0			
33	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0			
34	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	14	0	15	25			
35	Unique Meghnaghat 584MW CCGP	Gas	1x400+1x184	584	584	0	0	0	0	584	Gas Shortage	
	Meghnaghat 589 MW CCGP(Summit)	Gas				0	0	0	0		Test run	
Dhaka Zone Total				5828	5634	1821	2341	1906	2472	1301	740	
36	Karnaphuli Hydro PP Unit-1,2,3,4,5	Hydro (PDB)	2x40, 3x50	230	230	30	30	30	30	200	Inadequate Water Level	
37	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
38	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	2	0	5	0			
39	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	8	8	25			
40	Teknaf 20MW PP (SolarsTech)	Solar (IPP)	1x20	20	20	19	0	20	0			
41	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	19	6	19			
42	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	17	17	17			
43	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
44	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	211	211	210	211			
45	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	16	16	16	16			
46	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	12	12	12	12			
47	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	34	34	34	34			
48	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	39	34	41	75			
49	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	10	10	10	10			
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			5	34	15	35			
50	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	20	0	69			
51	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	0	0	17			
52	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	17	17	17			
53	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	12	12	12	12			
54	Juldah 100 MW Unit-1 (Acorn)	HFO (NENP)	8x13.45	100	100	35	0	25	25			
55	Chattogram 116 MW PP (Anlima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	17	17	17			
56	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	35	17	54	125			
57	Chattogram 2*612MW Coal Based PP (SS Power)	Coal (IPP)	2x612	1224	1224	275	450	370	370			
58	Matarani 2*600 MW (CPGCL)	Coal (CPGCL)	1x575	575	575	783	783	800	930			
	Cox's Bazar Wind PP	(Wind) (IPP)				0	0	40	40		Test run	
	Sonagazi 75 MW Solar Plant	(Solar) (EGCB)				64	0	25	0		Test run	
Chattogram Zone Total				4404	4344	1639	1741	1784	2106	380	330	
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	35	38	40	40			
60	Ashuganj 225 MW CCGP	Gas (APSCL)	1x142+1*75	221	221	206	221	220	225			
61	Ashuganj 450 MW CCGP(South)	Gas (APSCL)	1x360	360	360	335	330	330	330			
62	Ashuganj 450 MW CCGP(North)	Gas (APSCL)	1x361	360	360	0	0	0	0	360	Gas Shortage	
63	Ashuganj 420 MW CCGP(East)	Gas (APSCL)	1x284+1x116	400	400	340	380	340	340			
64	Ashuganj 195MW PP (APSC-United)	Gas (IPP)	20*9.73+1*16	195	195	8	16	8	36	179	Gas Shortage	
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51			
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	6	10	6	8			
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	39	30	46			
68	Chandpur 150 MW CCGP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0		Test run	
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	34	34	34	34			
70	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	0	0	8	8			
71	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	0	25	25	25			
72	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	25	52	25	52			
73	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	6	12	18	18			
74	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	98	70	98	114			
75	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	27	27	38	60			
76	Bhainob 54 MW PP	HFO (IPP)	3x18.2	54	54	0	17	17	17			
77	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x5.428	115	115	0	76	0	76			
78	Ashuganj 55 MW PP (Precision)	Gas (NENP)	15*4	55	55	51	20	30	30			
**	Impoprt (Tripura)	India		160	160	136	122	128	141			
Cumilla Zone Total				2937	2929	1358	1540	1446	1651	539	0	
79	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	94	113	101	150			
80	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	49	90	49	100			
81	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	58	98	56	100			
82	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
83	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	48	0	50	0			
84	Tangail 22 MW PP(PGCL)	HFO (IPP)	4x6.7	22	22	0	6	0	6			
Mymensingh Zone Total				600	592	251	307	258	356	0	0	

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	28.03.24 (Yesterday)		29.03.24 (Today)		28.03.24 (Yesterday)		Status of Machines under shut-down/ Maintenance		
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
						Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation MW	Machines shut down (MW)			
85	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	0	30	30	30		40	Under maint.		
86	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	40	30	40	40		60	GT-4 Under maint.		
87	Fenchugonj 51 MW PP (Barakattullah)	Gas (RPP)	19x2.90	51	51	25	25	25	25					
88	Kushiara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163					
89	Hobiganj 11 MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0					
90	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	56	59	65	65					
91	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.		
92	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	0	0	0	0			Contact Expired		
93	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	131	133	135	135					
94	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	16	18	18	18					
95	Sylhet 10 MW PP (Desh)	Gas (RPP)	6x1.95	10	10	0	0	0	0					
96	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	24	16	24	24					
97	Bibiayana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	310	295	300	300					
98	Bibiayana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	397	316	380	380					
99	Bibiayana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	380	398	340	340					
100	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0			Test run		
101	Fenchugonj 44MW (Energypirima)	Gas (NENP)	12*3.3+5*2	50	50	25	25	25	25					
Sylhet Zone Total						2472	2427	1567	1508	1545	1545	0	430	
102	Bheramara GTPP Unit-3	HSD (PDB)	1 x 20	20	16	0	0	0	0					
103	Bheramara 410 MW CCPP	Gas (NWPGLCL)	1 x 278+1 x 132	410	410	0	0	0	0		410	Gas Shortage		
104	Fariapur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	39	0	50					
105	Gopalnani 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	41	0	70					
106	Khulna 225 MW CCPP	HSD/ Gas (NWPGLCL)	1 x 150+1x75	225	230	0	0	0	0					
107	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	18	17	18					
108	Madhumati 100 MW PP	HFO (NWPGLCL)	6x18.415	105	105	0	0	0	0					
109	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	75	0	100	0					
110	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	0	0	0					
111	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	0	0					
112	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x817	617	617	370	382	375	375					
113	Khulna 330 MW CCPP	Gas/HSD (BPDB)	1x220+1x116	336	336	0	0	0	0					
**	Bheramara (HVDC)	India		1000	1000	905	771	933	788					
Khulna Zone Total						3241	3237	1350	1251	1425	1301	410	0	
114	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	48	110	110					
115	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	5	9	7	10					
116	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	133	133	130	135			61	ST under maint.	
117	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	940	1140	1200	1200					
118	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	54					
119	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	150	200	150	200					
120	Bhola 220MW CCPP (Nutan Bidyt BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	220	220					
Barishal Zone Total						2265	2265	1448	1750	1817	1929	0	61	
121	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage		
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.		
122	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	43	25	40					
123	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	25	0	25					
124	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	92	50	90					
125	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	50	40	50					
126	Katakali 50 MW PP (Northern)	HFO (NENP)	6x8.9	50	50	34	0	42	42					
127	Santalaha 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	38	16	38					
128	Siraigonj 225MW CCPP Unit-1	Gas (NWPGLCL)	1x150+1x75	210	210	192	173	180	210					
129	Siraigonj 225MW CCPP Unit-2	Gas (NWPGLCL)	1x150 + 1x75	220	220	0	0	0	0		220	Gas Shortage		
130	Siraigonj 225MW CCPP Unit-3	Gas (NWPGLCL)	1x141+1x79	220	220	0	0	0	0		220	Gas Shortage		
131	Siraigonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	414	414	414	414					
132	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	5	8					
133	Natore 52 MW PP (Rajkanka)	HFO (IPP)	6x8.92	52	52	8	16	8	16					
134	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	35	0	35					
135	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	30	0	0	35					
136	Armura 50 MW PP (Sinha)	HFO (NENP)	7x7.79	50	28	21	0	28	28					
137	Siraigonj 6.55 MW Solar	Solar (NWPGLCL)	1x6	6	6	4	0	6	0					
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	1016	1003	1000	1000					
Rajshahi Zone Total						3453	3431	1727	1897	1814	2031	511	100	
138	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Coal Shortage		
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling		
139	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	200	200	200	200		74	Coal Shortage		
140	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
141	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	6	42	6	42					
142	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
143	Majpara, Tatula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	4	0	8	0					
144	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	75	35	75					
145	Lalmoinhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	15	0	30	0					
146	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	199	0	130	0					
Rangpur Zone Total						1030	950	424	317	409	317	159	85	
Sub-total: Plants in operation						26230	25809	11585.0	12652	12404	13708	3300	1746	
(B) Plants under long term maintenance/ contract expired														
147	Katottli 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				Contract Expired	
148	Hariapur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	0	0	0	0	0				Contract Expired	
149	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				Contract Expired	
150	Bosila 108MW PP(CLCL)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				Contract Expired	
Sub-total: Plants under long term maintenance/ contract expired						614	0	0	0	0	0	0	0	
Gross Total						26844	25809	11585	12652	12404	13708	3300	1746	

(C) Actual data of 28.03.24 (Yesterday) Thursday :														
01.	Max. Demand at eve. peak (Generation end)	:	12695	MW,	at =	21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	12277	MW,	at =	21:00 hrs	Zone	Demand MW	Supply MW	Load Shed	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	12652	MW,	at =	21:00 hrs	Dhaka	4517	4517	0	Mymensingh	1126	1085	41
04.	Minimum Generation (Generation end)	:	9405	MW,	at =	6:00 hrs	Chattogram	1172	1172	0	Sylhet	486	486	0
05.	Day-peak Generation (Generation end)	:	11585	MW,	at =	11:00 hrs	Khulna	1598	1598	0	Rajshahi	361	361	0
06.	Evening-peak Generation (Generation end)	:	12652	MW,	at =	21:00 hrs	Rajshahi	1314	1314	0	Rangpur	673	673	0
07.	Evening Peak Load-shed (Sub-station end)	:	41	MW,	at =	21:00 hrs	Cumilla	1031	1031	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	9493	MW,	at =	5:00 hrs					Total	12277	12236	41
09.	Generation shortfall at evening peak due to :	:												
	a) Gas/LF limitation	:	2941	MW			13.	Fuel cost :	(a) Gas =	397626122	Taka	(c) Coal =	631477104	Taka
	d) Coal supply Limitation	:	159	MW					(b) Oil =	454923099	Taka	Total =	1484026325	Taka
	b) Low water level in Kaptai lake	:	200	MW										
	c) Plants under shut down/ maintenance	:	1746	MW										
10.	Total Energy (Generation + India Import)	:	275.89	MKWh			14.	Maximum Temperature in Dhaka was : 32.3°C						
	By Gas =	128.215	MKWh	By Oil =	24.811	MKWh	15.	Export through East-West interconnections :						
	By Coal =	94.855	MKWh	By Hydro =	0.722	MKWh		At evening peak-hour	:	11585	MW,	at	21:00 hrs	
	By Solar =	2.942	MKWh					Maximum	:					