

**Bangladesh Power Development Board**  
**DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation  
Tel : 9564667, 9551095

Month April, 2024			Day : Tuesday				Date : 02.04.24					
Probable Maximum Demand : 14700 MW			Probable Maximum Generation : 14204 MW									
Water Level of Kaptai Lake at 06:00 AM			Yesterday = 79.77 ft		Today = 79.56 ft		Rule Curve = 88.00 ft.					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	01.04.24 (Yesterday)		02.04.24 (Today)		01.04.24 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW			
					Day	Evening	Day	Evening	Machines shut down (MW)	Description/ Remarks	Probable start-up date	
<b>(A) Plants in operation:</b>												
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		Under project work	
2	a) Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	170	170	170	170			
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	170	170	180	180			
3	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Awaiting for HGPI	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	5	5	5	5	103	Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450			
8	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
9	Haripur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	400	367	353	320	350			
10	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage	
11	Siddhirgonj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	316	329	335	335			
12	Meghnaghat 335MW CCGP(Summit)	Gas (IPP)	2x110+1x110	335	335	146	149	150	150	186	Gas Shortage	
13	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	15	15	15			
14	Gagnagarj 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	14	50	8	50			
15	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	0	0			
16	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+1x7.73	80	80	40	40	40	40			
17	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33			
18	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	32	32	33	33			
19	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	25	8	25			
20	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	105	17	105			
21	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	48	142	32	149			
22	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	17	0	17			
23	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	75	245	47	242			
24	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	6x18.415+1x8.97	149	149	61	135	60	135			
25	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	55	0	55			
26	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	17	35	0	17			
27	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	34	17	34			
28	Manikganj 162MW PP(MPL)	HFO (IPP)	9x18	162	162	0	90	0	90			
29	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	34	0	35	0			
30	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	33	0	17			
31	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	0	0	0	0			
32	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	0	0	0	0			
33	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0			
34	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	23	13	15	25			
35	Unique Meghnaghat 584MW CCGP	Gas	1x400+1x184	584	584	0	0	0	0	584	Gas Shortage	
	Meghnaghat 589 MW CCGP(Summit)	Gas				0	0	0	0		Test run	
<b>Dhaka Zone Total</b>				<b>5828</b>	<b>5634</b>	<b>2058</b>	<b>2725</b>	<b>1970</b>	<b>2713</b>	<b>1188</b>	<b>740</b>	
36	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	30	60	30	30	170	Inadequate Water Level	
37	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
38	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	2	0	5	0			
39	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	6	25	8	25			
40	Teknaf 20MW PP (SolarsTech)	Solar (IPP)	1x20	20	20	19	0	20	0			
41	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	26	6	26			
42	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	17	17	17			
43	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
44	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	211	211	210	211			
45	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	16	16	16	16			
46	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	0	0	0	0			
47	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	34	34	34	34			
48	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	48	67	70	80			
49	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	5	5	7	7			
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			3	26	10	20			
50	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	25	26	8	25			
51	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	17	0	17			
52	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	26	15	15	17			
53	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	12	12	12	12			
54	Juldah 100 MW Unit-1 (Acorn)	HFO (NENP)	8x13.45	100	100	36	46	36	46			
55	Chattogram 116 MW PP (Anlima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	17	17	17			
56	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	0	144	54	150			
57	Chattogram 2*612MW Coal Based PP (SS Power)	Coal (IPP)	2x612	1224	1224	490	488	490	490			
58	Matarbari 2*600 MW (CPGCL)	Coal (CPGCL)	1x575	575	575	793	794	800	800			
	Cox's Bazar Wind PP	(Wind) (IPP)				27	12	40	40		Test run	
	Sonagazi 75 MW Solar Plant	(Solar) (EGCB)				45	0	25	0		Test run	
<b>Chattogram Zone Total</b>				<b>4404</b>	<b>4344</b>	<b>1868</b>	<b>2058</b>	<b>1930</b>	<b>2080</b>	<b>350</b>	<b>330</b>	
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	25	25	25	30			
60	Ashuganj 225 MW CCGP	Gas (APSCL)	1x142+1*75	221	221	212	214	220	220			
61	Ashuganj 450 MW CCGP(South)	Gas (APSCL)	1x360	360	360	270	310	300	315			
62	Ashuganj 450 MW CCGP(North)	Gas (APSCL)	1x361	360	360	0	0	0	0	360	Gas Shortage	
63	Ashuganj 420 MW CCGP(East)	Gas (APSCL)	1x284+1x116	400	400	365	330	350	350			
64	Ashuganj 195MW PP (APSC-United)	Gas (IPP)	20*9.73+1*16	195	195	0	0	8	8	195	Gas Shortage	
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51			
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	5	5	6	6			
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	42	45	40	45			
68	Chandpur 150 MW CCGP	Gas (PDB)	1X106+1x57	163	163	50	50	0	0		Test run	
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	34	151	34	151			
70	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	0	6	6	6			
71	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	0	0	25	33			
72	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	25	52	25	52			
73	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	13	20	20	20			
74	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	98	17	100			
75	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	34	48	17	55			
76	Bhairoh 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17			
77	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x5.428	115	115	0	79	0	94			
78	Ashuganj 55 MW PP (Precision)	Gas (NENP)	15*4	55	55	20	20	20	20			
**	Impoprt (Tripura)	India		160	160	156	130	128	141			
<b>Cumilla Zone Total</b>				<b>2937</b>	<b>2929</b>	<b>1336</b>	<b>1651</b>	<b>1309</b>	<b>1714</b>	<b>555</b>	<b>0</b>	
79	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	65	127	101	130	75	Gas Shortage	
80	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	50	99	49	100			
81	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	58	107	56	100			
82	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
83	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	52	0	50	0			
84	Tangail 22 MW PP(PGCL)	HFO (IPP)	4x6.7	22	22	0	6	0	6			
<b>Mymensingh Zone Total</b>				<b>600</b>	<b>592</b>	<b>227</b>	<b>339</b>	<b>258</b>	<b>336</b>	<b>75</b>	<b>0</b>	

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	01.04.24 (Yesterday)		02.04.24 (Today)		01.04.24 (Yesterday)		Status of Machines under shut-down/ Maintenance		
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
						Day	Evening	Day	Evening	Gas/Coal/Water Limitation MW	Machines shut down (MW)			
85	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	Under maint.		
86	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	0	20	30	30		70	GT-4 Under maint.		
87	Fenchugonj 51 MW PP (Barakattullah)	Gas (RPP)	19x2.90	51	51	53	53	53	53					
88	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	110	108	110	110					
89	Hobiganj 11 MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0					
90	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	30	45	60	60					
91	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.		
92	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	0	0	0	0			Contact Expired		
93	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	138	135	135	140					
94	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0					
95	Sylhet 10 MW PP (Desh)	Gas (RPP)	6x1.95	10	10	0	0	0	0					
96	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	8	16	16					
97	Bibiyana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	310	310	300	300					
98	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	400	404	400	400					
99	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	45	150	340	340					
100	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0			Test run		
101	Fenchugonj 44MW (Energypima)	Gas (NENP)	12*3.3+5*2	50	50	44	46	45	45					
<b>Sylhet Zone Total</b>						<b>2472</b>	<b>2427</b>	<b>1181</b>	<b>1322</b>	<b>1532</b>	<b>1537</b>	<b>0</b>	<b>427</b>	
102	Bheramara GTPP Unit-3	HSD (PDB)	1 x 20	20	16	0	0	0	0					
103	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0		410	Gas Shortage		
104	Fariapur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	10	50	15	50					
105	Gopalnani 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	11	0	50	60					
106	Khulna 225 MW CCPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0					
107	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	18	35	17	18					
108	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	0					
109	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	94	0	100	0					
110	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	0	0	0					
111	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	0	0					
112	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x817	617	617	389	384	380	380					
113	Khulna 330 MW CCPP	Gas/HSD (BPDB)	1x220+1x116	336	336	0	0	0	0					
**	Bheramara (HVDC)	India		1000	1000	922	637	940	795					
<b>Khulna Zone Total</b>						<b>3241</b>	<b>3237</b>	<b>1444</b>	<b>1106</b>	<b>1502</b>	<b>1303</b>	<b>410</b>	<b>0</b>	
114	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	80	110	110	110					
115	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	0	0	7	10					
116	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	130	130	130	130			64	ST under maint.	
117	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	1110	1244	1200	1200					
118	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	150	17	150					
119	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	250	307	260	307					
120	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	220	220					
<b>Barishal Zone Total</b>						<b>2265</b>	<b>2265</b>	<b>1807</b>	<b>2161</b>	<b>1944</b>	<b>2127</b>	<b>0</b>	<b>64</b>	
121	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage		
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.		
122	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	32	25	40					
123	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	28	0	30					
124	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	81	50	90					
125	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	16	40	40	50					
126	Katakali 50 MW PP (Northern)	HFO (NENP)	6x8.9	50	50	25	16	16	16					
127	Santalaha 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	30	16	35					
128	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	187	206	190	200					
129	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0		220	Gas Shortage		
130	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0		220	Gas Shortage		
131	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	387	414	414	414					
132	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	0	10	5	8					
133	Natore 52 MW PP (Rajkanka)	HFO (IPP)	6x8.92	52	52	0	0	8	8					
134	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	55	0	55					
135	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	50	0	55					
136	Armura 50 MW PP (Sinha)	HFO (NENP)	7x7.9	50	28	28	28	28	28					
137	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0					
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	1014	1014	1000	1000					
<b>Rajshahi Zone Total</b>						<b>3453</b>	<b>3431</b>	<b>1662</b>	<b>2004</b>	<b>1798</b>	<b>2029</b>	<b>511</b>	<b>100</b>	
138	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Coal Shortage		
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling		
139	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	215	250	200	200		24	Coal Shortage		
140	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
141	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	13	49	6	50					
142	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
143	Majpara, Tatula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0					
144	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	92	35	115					
145	Lalmoinhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	35	0	30	0					
146	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	196	0	130	0					
<b>Rangpur Zone Total</b>						<b>1030</b>	<b>950</b>	<b>466</b>	<b>391</b>	<b>409</b>	<b>365</b>	<b>109</b>	<b>85</b>	
<b>Sub-total: Plants in operation</b>						<b>26230</b>	<b>25809</b>	<b>12049.0</b>	<b>13757</b>	<b>12652</b>	<b>14204</b>	<b>3198</b>	<b>1746</b>	
<b>(B) Plants under long term maintenance/ contract expired</b>														
147	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				Contract Expired	
148	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	0	0	0	0	0				Contract Expired	
149	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				Contract Expired	
150	Bosila 108MW PP(CLCL)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				Contract Expired	
<b>Sub-total: Plants under long term maintenance/ contract expired</b>						<b>614</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	
<b>Gross Total</b>						<b>26844</b>	<b>25809</b>	<b>12049</b>	<b>13757</b>	<b>12652</b>	<b>14204</b>	<b>3198</b>	<b>1746</b>	

<b>(C) Actual data of 01.04.24 (Yesterday) Monday :</b>															
01.	Max. Demand at eve. peak (Generation end)	:	14650	MW, at =	21:00 hrs	12.	<b>Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :</b>								
02.	Max. Demand at eve. peak (Sub-station end)	:	14042	MW, at =	21:00 hrs		<b>Demand</b>	<b>Supply</b>	<b>Load Shed</b>	<b>Zone</b>	<b>Demand</b>	<b>Supply</b>	<b>Load Shed</b>		
03.	Highest Generation (Generation end)	:	13757	MW, at =	21:00 hrs		<b>MW</b>	<b>MW</b>	<b>MW</b>		<b>MW</b>	<b>MW</b>	<b>MW</b>		
04.	Minimum Generation (Generation end)	:	10843	MW, at =	7:00 hrs	Dhaka	5084	4954	130	Mymensingh	1205	1135	70		
05.	Day-peak Generation (Generation end)	:	12049	MW, at =	12:00 hrs	Chattogram	1398	1308	90	Sylhet	451	411	40		
06.	Evening-peak Generation (Generation end)	:	13757	MW, at =	21:00 hrs	Khulna	1789	1659	130	Rajshahi	471	471	0		
07.	Evening Peak Load-shed (Sub-station end)	:	853	MW, at =	21:00 hrs	Rajshahi	1499	1349	150	Rangpur	867	797	70		
08.	Minimum Generation Forecast up to 8:00 hrs.	:	11162	MW, at =	5:00 hrs	Cumilla	1280	1107	173						
09.	Generation shortfall at evening peak due to :	:								<b>Total</b>	<b>14042</b>	<b>13189</b>	<b>853</b>		
	a) Gas/LF limitation	:	2919	MW		13.	Fuel cost :		(a) Gas = 380932904 Taka	(c) Coal = 711997357 Taka					
	d) Coal supply Limitation	:	109	MW					(b) Oil = 654585198 Taka	Total = 1747515459 Taka					
	b) Low water level in Kaptai lake	:	170	MW											
	c) Plants under shut down/ maintenance	:	1746	MW		14.	Maximum Temperature in Dhaka was : 37.7°C								
10.	Total Energy (Generation + India Import)	:	293.41	MKWh		15.	Export through East-West interconnections :								
	By Gas = 122.334 MKWh			By Oil = 35.783 MKWh			At evening peak-hour		:	12049	MW, at	21:00 hrs			
	By Coal = 106.412 MKWh			By Hydro = 1.058 MKWh			Maximum		:	740	MW, at	3:00 hrs			
	By Solar = 3.526 MKWh						Energy								