

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551995

Month April, 2024		Day : Friday				Date : 05.04.24						
Probable Maximum Demand :		15300 MW		Probable Maximum Generation :		14692 MW						
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 79.31 ft		Today = 79.08 ft		05.04.24 (Today)		Rule Curve = 87.20 ft				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	04.04.24 (Yesterday)		05.04.24 (Today)		Gen. shortfall for : Gas/Coal/oil/Water Limitation (MW)	Machines shut down (MW)	Status of Machines under shut-down/ Maintenance Description/ Remarks	Probable start-up date
					Actual Peak Generation (MW)		Probable Peak Generation (MW)					
					Day	Evening	Day	Evening				
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	170	170	170	170			
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	170	170	170	170			
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Awaiting for HGPL	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	3x3.35	108	108	5	5	5	5	103	Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage	
6	Harijpur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	0		
7	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225	Under maint	
8	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
9	Harijpur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	400	405	379	380	400	0	Gas Shortage	
10	Siddhirganj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		
11	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	318	329	335	335	0		
12	Meghnaghat 335MW CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	318	317	330	330	0		
13	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	40	15	40	0		
14	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	8	73	8	50	0		
15	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	0	0	0		
16	Summit Power.(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x3.73	80	80	27	39	40	40	0		
17	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	0	33	33	33	0		
18	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	18	18	33	33	0		
19	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	25	43	25	0		
20	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	105	17	105	0		
21	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	32	148	32	149	0		
22	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	17	0	17	0		
23	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	90	245	97	242	0		
24	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	60	149	60	149	0		
25	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	55	0	55	0		
26	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	55	0	55	0		
27	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	51	50	51	0		
28	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	35	126	35	126	0		
29	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	31	0	35	0	0		
30	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	17	17	35	0		
31	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	0	0	0	0	0		
32	Meghnaghat 100 MW(IEEL)	HFO (NENP)	12x8.9	100	100	0	0	0	0	0		
33	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0	0		
34	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	13	13	15	15	0		
35	Unique Meghnaghat 584MW CCPP	Gas	1x400+1x184	584	584	0	0	0	0	584	Gas Shortage	
	Meghnaghat 589 MW CCPP(Summit)	Gas				130	130	150	150	0	Test run	
Dhaka Zone Total				5828	5634	2097	2934	2295	3005	1002	965	
36	Kamaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	30	60	30	60	170	Inadequate Water Level	
37	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
38	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	3	0	5	0	0		
39	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	4	25	8	25	0		
40	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	19	0	20	0	0		
41	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	20	6	25	0		
42	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	34	17	34	0		
43	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
44	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	211	211	211	211	0		
45	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	16	82	16	16	0		
46	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	0	0	0	0	0		
47	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	34	51	51	51	0		
48	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	64	82	82	82	0		
49	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	5	5	7	7	0		
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			3	24	15	30	0		
50	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	13	26	8	25	0		
51	Sikalbaha 54 MW PP(Jodiak Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	19	0	19	0		
52	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	33	17	34	0		
53	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	12	12	12	12	0		
54	Juldah 100 MW Unit-1 (Acorn)	HFO (NENP)	8x13.45	100	100	48	58	46	46	0		
55	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	0	17	17	0		
56	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	45	126	54	150	0		
57	Chattogram 2*621MW Coal Based PP (SS Powe	Coal (IPP)	2x612	1224	1224	490	490	490	490	0		
58	Metarbari 2*600 MW (CPGCL)	Coal (CPGCL)	1x575	575	575	750	750	551	551	0		
	Cox's Bazar Wind PP	(Wind) (IPP)				8	0	40	40	0		Test run
	Sonagazi 75 MW Solar Plant	(Solar) (EGCB)				75	0	25	0	0		Test run
Chattogram Zone Total				4404	4344	1887	2108	1728	1925	350	330	
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	22	21	25	25	0		
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	212	215	220	220	0		
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	270	320	300	320	0		
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	0	30	50	250	330	Gas Shortage	
63	Ashuganj 420 MW CCPP(East)	Gas (APSCL)	1x284+1x116	400	400	275	260	300	300	0		
64	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	0	0	8	8	195	Gas Shortage	
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	51	51	51	0		
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	6	5	6	6	0		
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	35	35	36	42	0		
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	108	109	0	0	0		
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	33	147	34	151	0		
70	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	8	6	6	0		
71	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	15	15	15	15	0		
72	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	25	51	25	52	0		
73	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	20	20	20	0		
74	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	114	17	114	0		
75	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	19	48	17	55	0		
76	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	27	17	27	0		
77	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x5.428	115	115	72	95	72	95	0		
78	Ashuganj 55 MW PP (Precision)	Gas (NENP)	15*4	55	55	44	20	20	20	0		
**	Impport (Tiptura)	India		160	160	138	124	152	160	0		
Cumilla Zone Total				2937	2929	1379	1715	1391	1937	525	0	
79	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	34	109	70	120	93	Gas Shortage	
80	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	48	98	49	100	0		
81	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	58	107	56	110	0		
82	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0	0		
83	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	39	0	50	0	0		
84	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	6	18	10	10	0		
Mymensingh Zone Total				600	592	187	332	237	340	93	0	

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	04.04.24 (Yesterday)		05.04.24 (Today)		04.04.24 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
						Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation MW	Machines shut down (MW)		
85	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	41	43	43	43			27	Under maint.
86	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	29	30	30			61	GT-4 Under maint.
87	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	50	53	53	53				
88	Kushiana 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	110	110	110				
89	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0				
90	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	25	25	30	30				
91	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0			330	Under maint.
92	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	0	0	0	0				Contract Expired
93	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	133	132	135	140				
94	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	16	18	20	20				
95	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	0	0	0	0			10	Gas Shortage
96	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	0	16	25				
97	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	310	300	320	320				
98	Bibiana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	377	375	400	400				
99	Bibiana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	345	385	360	370				
100	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0				Test run
101	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	47	38	47	47				
Sylhet Zone Total				2472	2427	1502	1508	1564	1588	10	418		
102	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
103	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0	410			Gas Shortage
104	Fardipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	17	39	22	50				
105	Gopelganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	58	50	60				
106	Khulna 225 MW CAPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0				
107	Russha 105 MW PP (Oron russha)	HFO (IPP)	6x18.445	105	105	35	70	70	70				
108	Machumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	0				
109	Mongla Oron 100 MW Solar PP	Solar (IPP)		100	100	87	0	100	0				
110	Khulna 115 MW PP (RPL-2)	HFO (NENP)	7x17	115	115	0	0	0	0				
111	Nosara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	0	0				
112	Maitree Super Thermal 1320 MW PP (J-1)	Coal (BIFPCL)	1x617	617	617	349	350	385	385				
113	Khulna 330 MW CAPP	Gas/HSD (BPDB)	1x220+1x116	336	336	65	150	150	150				
**	Bheramara (HVDC)	India		1000	1000	914	627	936	647				
Khulna Zone Total				3241	3237	1467	1294	1713	1362	410	0		
114	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	64	110	64	110				
115	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	6	10	7	10				
116	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	100	130	130	130			64	ST under maint.
117	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	1040	1244	1244	1244				
118	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	17	17	17				
119	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	150	307	307	307				
120	Bhola 220MW CAPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	220	220				
Barishal Zone Total				2265	2265	1597	2038	1989	2038	0	64		
121	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71			Gas Shortage
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0			100	Under maint.
122	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	24	28	35	40				
123	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	30				
124	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	94	93	50	96				
125	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	39	46	40	50				
126	Katakali 50 MW PP (Northern)	HFO (NENP)	6x8.9	50	50	34	34	34	34				
127	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	21	38	30	35				
128	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	166	166	190	200				
129	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	0	0	0	0	220			Gas Shortage
130	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0	220			Gas Shortage
131	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	335	380	380	380				
132	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	10	11	5	10				
133	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	8	8				
134	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	95	0	95				
135	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	24	70	0	70				
136	Ammura 50 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	35	35	35	35				
137	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0				
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	1011	1013	1000	1000				
Raishahi Zone Total				3453	3431	1798	2017	1813	2083	511	100		
138	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85			Coal Shortage
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0			85	Under Overhauling
139	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	250	250	250	250	24			Coal Shortage
140	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
141	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	6	49	6	49				
142	Saidour 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
143	Majpara, Tabulia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0				
144	Thakurgaon 119MW PP (Energybase)	HFO (IPP)	6*20	118	118	0	0	35	115				
145	Lalmonirhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	34	0	30	0				
146	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	191	0	130	0				
Rangpur Zone Total				1030	950	488	299	459	414	109	85		
Sub-total: Plants in operation				26230	25809	12402.0	14245	13189	14692	3010	1962		

Actual data of 04.04.24 (Yesterday) Thursday :											
01.	Max. Demand at eve. peak (Generation end)	: 15500 MW, at = 21:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	: 14770 MW, at = 21:00 hrs		Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	: 14291 MW, at = 22:00 hrs		Dhaka	5415	5205	210	Mymensingh	1274	1082	192
04.	Minimum Generation (Generation end)	: 11689 MW, at = 7:00 hrs		Chattogram	1454	1311	143	Sylhet	422	362	60
05.	Day-peak Generation (Generation end)	: 12402 MW, at = 12:00 hrs		Khulna	1840	1674	166	Barishal	481	481	0
06.	Evening-peak Generation (Generation end)	: 14245 MW, at = 21:00 hrs		Rajshahi	1627	1485	142	Rangpur	837	741	96
07.	Evening Peak Load-shed (Sub-station end)	: 1199 MW, at = 21:00 hrs		Cumilla	1419	1229	190				
08.	Minimum Generation Forecast up to 8:00 hrs.	: 11832 MW, at = 5:00 hrs						Total	14770	13571	1199
09.	Generation shortfall at evening peak due to :			13.	Fuel cost :	(a) Gas = 408471756 Taka	(c) Coal = 705883658 Taka				
	a) Gas/LF limitation	: 2731 MW			(b) Oil = 772589111 Taka	Total = 1886944525 Taka					
	d) Coal supply Limitation	: 109 MW		14.	Maximum Temperature in Dhaka was :	35.5°C					
	b) Low water level in Kaptai lake	: 170 MW		15.	Export through East-West interconnections :						
	c) Plants under shut down/ maintenance	: 1962 MW			At evening peak-hour	: 12402 MW, at 21:00 hrs					
10.	Total Energy (Generation + India Import)	: 309.06 MKWh			Maximum	: 830 MW, at 19:30 hrs					
	By Gas = 133.917 MKWh	By Oil = 42.161 MKWh			Energy	: 0 MKWh					
	By Coal = 105.287 MKWh	By Hydro = 0.831 MKWh									
	By Solar = 3.403 MKWh			11.	Total Gas Supplied	: 1046.30 MMCFD					
Forecast of 05.04.24 (Today) Friday :											
01.	Maximum Demand	: 15300 MW (Generation end)	04.	Maximum Load-shed	: 349 MW At evening peak (Sub-station end)						
02.	Maximum Generation	: 14692 MW (Generation end)	05.	Total Generation	: 330.89 MKWh						
03.	Reserve / Shortage	: -608 MW (Generation end)	06.	Probable Max. Temperature in Dhaka :	35.5°C						

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation