

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date: 26-Apr-24

Page-2

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity		Peak Hour Generation		Energy Generated	Remarks
				MW	MW	MW	KWH		
Unit No. X Capacity									
1	Ghorasal Repowered CCGP-Unit-3 (GT)	PDB	1280	280	0	0	0	Under maint.	
2	Ghorasal Repowered CCGP Unit-4	PDB	1210	180	0	0	1156125		
3	Ghorasal TPP Unit-5	PDB	1210	190	180	0	4142250		
4	Ghorasal 365 MW CCGP Unit-7	PDB	1243+1122	365	0	0	0	Air Compressor problem	
5	Ghorasal 78.5 MW PP(MAX)	QRPP	240	0	0	0	0	Contract Expired	
6	Ghorasal 108 MW PP (Regent)	IPP	3*335	108	64	0	593818	Gas shortage	
7	Haripur GTTP	SBU, PDB	232	20	0	0	0	Under maint.	
8	Haripur 412 MW CCGP	EGCB	1273+1139	400	404	0	9075600		
9	Haripur 360 MW CCGP(HPL)	IPP	1235+1125	0	0	0	0	Contract Expired	
10	Meghnaghat 450 MW CCGP(MPL)	IPP	2150+1150	450	450	0	10245000		
11	Meghnaghat 100 MW CCGP	NENP	0	0	0	0	0	Contract Expired	
12	Meghnaghat CCGP(Summit)	IPP	2110+1110	335	300	0	7173993	Machine problem	
13	Madangan 102 PP(Summit)	NENP	617	0	0	0	0	Contract Expired	
14	Madangan-55 MW PP(Summit)	IPP	3*17.08+111.3	55	40	0	982751	Fuel shortage	
15	Keraniganj 100 MW PP (Powerpac)	NENP	813.45	75	0	0	0	Fuel shortage	
16	Narshingaj 22 MW PP (Doreen)	SIPP, REB	82.90	22	0	0	0	Contract Expired	
17	210 MW Siddhirganj PP	PDB	1210	115	0	0	0	Under maint.	
18	Siddhirganj 2120 MW GTTP	EGCB	2105	210	201	0	4045000		
19	Siddhirganj 109 PP(Dutch Bangla)	NENP	128.9	0	0	0	0	Contract Expired	
20	Siddhirganj 335 MW CCGP	EGCB	1217+118	335	321	0	7600259		
21	Ganagar 102 MW PP (Digital Power)	IPP	128.924	102	73	0	1154592	Engine problem	
22	Katpodi 52 MW PP (Sinha)	IPP	77.9	0	0	0	0	Fuel shortage	
23	Kamalaghat 54 MW PP(Banco Energy)	IPP	318	54	54	0	233280		
24	Kodda 150 MW PP	BPDB-RPCL	9*17.06	149	147	0	1158240		
25	Manikganj 55 MW PP (Northern)	IPP	319.3	55	55	0	251933		
26	Nabaganj 55 MW PP (Southern power)	IPP	319.3	55	55	0	249498		
27	Bosila 108 MW PP(CLC)	IPP	128.775+113.5	0	0	0	0		
28	Summit Power (Madhabdi+Ashulia)	SIPP, REB	3*3.67+4*8.73	80	33	0	735240	Engine problem	
29	Maona 33 MW PP(Summit)	SIPP, REB	4*8.73	33	33	0	692940		
30	Rugganji 33 MW PP(Summit)	SIPP, REB	4*8.73	33	25	0	726100	Engine problem	
31	Gaspur 52 MW PP	RPCL	82.9	16	16	0	283200	Fuel shortage	
32	Tongi 80 MW GTTP	PDB	1105	105	0	0	0	Gas shortage	
33	Kodda 300 MW PP Unit-2 (Summit)	IPP	1817.076	300	273	0	5399564	Engine problem	
34	Bramhangon 100 MW PP (Aggreko)	IPP	1140.959	0	0	0	0	Contract Expired	
35	Aurabhat 100MW PP (Aggreko)	IPP	0.8523+0.9591	0	0	0	0	Contract Expired	
36	Kodda 149 MW PP Unit-1 (Summit)	IPP	818.4524.97	149	145	0	3054384	Fuel shortage	
37	Gaspur 100 MW PP	RPCL	617.5	105	105	0	854400		
38	Meghnaghat 104 MW PP (OPCL)	IPP	18.56	104	52	0	815040	Fuel shortage	
39	Manikganj 162MW PP(MPGL)	IPP	9*18	162	162	0	986400		
40	Spectra Solar Plant Ltd	IPP	35	35	0	0	212587		
41	Kanchan Prakash Power Generation Ltd.	IPP	181.3	55	0	0	0	Engine problem	
42	Meghnaghat Uniques power	IPP	596	584	540	0	969836		
43	Summit Meghnaghat-2 589 MW(Gas)	IPP	589	0	230	0	8872991	On test.	
Dhaka area Total				5332	3958		80193821		
39	Chattogram TPP-1	PDB	1210	180	110	0	2700000	Gas shortage	
40	Chattogram TPP-2	PDB	1210	180	0	0	0	Gas shortage	
41	Razzan 25 MW PP	RPCL	318.9	25	25	0	206971		
42	Teknaf 20MW PP (SolarTech)	IPP	20	20	0	0	107595		
43	Patenga 50MW PP (Baraka)	IPP	8*6.98	50	6	0	151200	Fuel shortage	
44	Kapla Hydro Unit-1,2,3,4,5	PDB	2*40+3*50	230	60	0	748480	Low water level	
45	Sikalbaha 225MW	PDB	1150+175	225	212	0	5006664		
46	Sikalbaha Peaking	PDB	1150	0	0	0	0	Under maint.	
47	Sikalbaha 105 MW PP (Baraka Sikalabaha)	IPP	617.5	105	17	0	423200	Fuel shortage	
48	Hathazari 100 MW peaking PP	PDB	118.9	98	32	0	714720	Fuel shortage	
49	Dohazari-Kalaish 100 MW Peaking	PDB	617	102	51	0	1009034	Fuel shortage	
50	Juidah 100 MW Unit-1 (Acorn)	NENP	813.45	100	0	0	0	Contract Expired from 17/04/20	
51	Juidah 100 MW Unit-3 (Acorn)	IPP	813.5	100	12	0	286880	Fuel shortage	
52	Barabkunda 22 MW PP (Regent)	SIPP, PDB	82.90	22	5	0	109680	Engine problem	
53	Malancha, Cig. EPZ (United)	IPP	5*8.73+3*9.34	0	31	0	527520		
54	Chattogram 108 MW PP (ECPV)	IPP	167	108	26	0	294720	Fuel shortage	
55	Kapla 7 MW Solar PP	PDB	7.4 MW	7	0	0	30480		
56	Arwara 300 MW PP (United)	IPP	1717-24	300	16	0	384000	Fuel shortage	
57	Jodis Power	IPP	3*18.55+13.6	54	36	0	459579		
58	Karnaphuli Power Ltd.	IPP	18.4156+8.5	110	34	0	509340	Fuel shortage	
59	Juidah unit-2 (Acorn)	IPP	813.6	100	10	0	265920	Fuel shortage	
60	Anlima Energy Ltd.	IPP	6*21.2	116	17	0	418509	Fuel shortage	
61	Minshara 150 MW	BPDB-RPCL	18.59	163	163	0	930036		
62	SS Power	SS Power	2762	1224	272	0	6594544		
63	Cox's Bazar Wind	IPP	66	60	0	0	133440	On test.	
64	Matarbari 2*600 MW (CPGCL)	CPGCL	0	575	780	0	16181818		
65	Minshara 150 MW (Gas)	BPDB-RPCL	18.59	0	0	0	0	On test.	
66	Sonagazi 75 MW Solar Plant	EGCB	75	0	0	0	477982		
Chattogram area Total				4404	1915		38632312		
67	Ashuganj TPP Unit-3	APSCl	1150	0	0	0	0	Contract Expired	
68	Ashuganj TPP Unit-4	APSCl	1150	0	0	0	0	Contract Expired	
69	Ashuganj TPP Unit-5	APSCl	1150	0	0	0	0	Contract Expired	
70	Ashuganj 225 MW CCGP	APSCl	1142+175	221	204	0	5012000	FGMO	
71	Ashuganj 450 MW CCGP(North)	APSCl	1360	360	285	0	7590200	FGMO	
72	Ashuganj 450 MW CCGP(South)	APSCl	1360	360	270	0	6655000	FGMO	
73	Ashuganj 420 MW CCGP(East)	APSCl	2841+116*1	400	300	0	8850000	Gas shortage	
74	Ashuganj 50 MW PP	APSCl	143.968	45	37	0	876024	Gas shortage	
75	Ashuganj 55 MW PP (Precision)	QRPP	0	55	45	0	1093440	Gas shortage	
76	Ashuganj 195 MW PP (APSCl-United)	IPP	20*9.73+116	195	0	0	0	Gas shortage	
77	Ashuganj 51 MW PP (Midland)	IPP	619.34	51	51	0	1152877		
78	Ashuganj 150 MW PP (Midland)	IPP	237.015	150	6	0	148872	Fuel shortage	
79	Titas 50 MW Peaking PP	PDB	6*8.92	52	33	0	752912	Engine problem	
80	Chandpur 150 MW CCGP	PDB	1106+157	163	0	0	0	Under maint.	
81	Chandpur 200 MW (Desh energy)	IPP	1218.4	200	155	0	2762880	Fuel shortage	
82	Feni 11 MW PP (Doreen)	SIPP, REB	4.90	11	94	0	42230		
83	Impogri (Tripura)	Imported power	0	160	94	0	2603520		
84	Jangalia 33 MW PP (Summit)	SIPP, PDB	4*8.73	33	16	0	368200	Engine problem	
85	Jangalia 52 MW PP (Lakdanavi)	IPP	6*8.92	52	50	0	809712		
86	Cumilla 25 MW PP (Summit)	SIPP, REB	3*3.67+2*6.97	25	19	0	440970	Engine problem	
87	Daudkandi 200 MW PP (B. Trac)	IPP	0	0	0	0	0		
88	Feni Lanka Power	IPP	7*18.415+19.78	114	114	0	1762440		
89	Chowmuhani 113 MW	IPP	12*9.78+2*3.1	113	65	0	1079400	Fuel shortage	
90	Bhairab 54.5 MW	IPP	3*18.2	54	17	0	510120	Engine problem	
91	Chandpur 115 (Doreen)	IPP	4*18.5+2*22.5	115	97	0	1294080	Fuel shortage	
Cumilla Area Total				2929	1658		41671647		
92	RPCL 210MW CCGP1	IPP	4135+170	202	98	0	1628600	Gas shortage	
93	Jamalpur 95 MW PP(Powerpac)	IPP	0	0	0	0	0		
94	Sarishabari 3 MW Solar Plant	IPP	13	3	0	0	15550		
95	Mymensingh 200 MW PP (United)	IPP	978*21	200	104	0	1773600	Fuel shortage	
96	Jamalpur 115 MW PP (United)	IPP	978*12	115	97	0	1576800	Fuel shortage	
97	Sutakchi 50 MW Solar PP	IPP	0	50	0	0	317410		
98	Tangali Pali Power Gen 22 MW	IPP	4*6.7	22	18	0	380160	Engine problem	
Mymensingh Area Total				592	317		5892320		
99	Fenchugani CCGP Phase-1	PDB	2132+133	70	43	0	958000	Machine problem	
100	Fenchugani CCGP Phase-2	PDB	2135+135	90	28	0	654840	Machine problem	
101	Kushaura 163 MW CCGP (HP)	IPP	1109+154	163	112	0	2403082	ST under maint.	
102	Shahjibazar 330 MW CCGP	PDB	3110	330	0	0	0	Under maint.	
103	Fenchugani 51 MW PP (Barakatullah)	RPP	192.90	51	22	0	1084200	Line O/L	
104	Fenchugani 44 MW (Energyprima)	NENP	12*3.3+5.2	50	20	0	802152	Line O/L	
105	Hobiganj 11 MW PP Confidence-E	SIPP, REB	42.90	11	5	0	177504	Engine problem	
106	Shahjibazar GTTP Unit-8 & 9	IPP	2135	66	51	0	1266720		
107	Shahjibazar 86 MW PP (Shahjibazar)	RPP	322.90	0	0	0	0	Contract Expired	
108	Shahjibazar 100 MW GTTP	PDB	1100	100	88	0	1492854		
109	Sylhet 225 MW CCGP	PDB	1142+189	231	202	0	4107610	Machine problem	
110	Sylhet 20 MW GTTP	PDB	120	20	17	0	368000		
111	Sylhet 50 MW PP (EPL)	NENP	272	0	0	0	0	Contract Expired	
112	Shahjahanulla 25 MW PP	SIPP, REB	39.34	25	24	0	503280		
113	Bibiana-II 341 MW CCGP (Summit)	IPP	1222+1119	341	295	0	7118000	FGMO	
114	Bibiyana-III 400 MW CCGP	PDB	2851+1341	400	366	0	8860000	FGMO	
115	Sylhet 10MW PP (Desh)	RPP	61.95	0	0	0	0	Contract Expired	
116	Bibiyana South 400								