

**Bangladesh Power Development Board**  
**DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation  
Tel : 9564667, 9551095

Month May, 2024					Day : Wednesday				Date : 01.05.24			
Probable Maximum Demand : 16200 MW					Probable Maximum Generation : 16882 MW							
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 74.11 ft				Today = 73.87 ft			
					Rule Curve = 82.00 ft							
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	30.04.24 (Yesterday)		01.05.24 (Today)		30.04.24 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)	Probable Peak Generation (MW)	Gen. shortfall for : Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date		
					Day	Evening	Day	Evening				
<b>(A) Plants in operation:</b>												
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		Under project work	
2	a) Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180			
3	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365 Awaiting for HGPI	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	77	80	75	75	28	Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	0	105 Under maint.	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450			
8	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115 Under Overhauling	
9	Haripur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	400	400	401	400	400			
10	Siddhirgonj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage	
11	Siddhirgonj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	313	317	335	335			
12	Meghnaghat 335MW CCGP(Summit)	Gas (IPP)	2x110+1x110	335	335	301	240	310	310			
13	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	40	40	40	40			
14	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	49	90	48	90			
15	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	0	0			
16	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+1x8.73	80	80	35	20	35	36			
17	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	31	31	33	33			
18	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	29	29	33	33			
19	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	16	33	16	16			
20	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	35	105	35	105			
21	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	81	147	48	150			
22	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	54	17	54			
23	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	210	300	210	300			
24	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	6x18.415+1x8.97	149	149	127	149	52	149			
25	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	55	35	55			
26	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	55	35	55			
27	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	70	17	53			
28	Manikganj 162MW PP(MPL)	HFO (IPP)	9x18	162	162	27	162	90	162			
29	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	30	0	35	0			
30	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	0	0	0			
31	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	30	18	0	0			
32	Unique Meghnaghat 584MW CCGP	Gas	1x400+1x184	584	584	355	409	400	400			
	Siddhirgonj 100 MW PP (Dutch Bangla)	HFO (NENP)	12x8.9	0	0	0	72	100	100			
	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	0	0	0	0	100	100			
	Meghnaghat 100 MW (IEL)	HFO (NENP)	12x8.9	0	0	33	81	100	100			
	Meghnaghat 589 MW CCGP(Summit)	Gas				230	400	360	360		Test run	
<b>Dhaka Zone Total</b>				<b>5526</b>	<b>5332</b>	<b>3113</b>	<b>3988</b>	<b>3589</b>	<b>4141</b>	<b>418</b>	<b>845</b>	
33	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	30	30	25	25	200	Inadequate Water Level	
34	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	110	109	115	115			
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
35	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0			
36	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	1	25	8	25			
37	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	18	0	20	0			
38	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	50	6	6			
39	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	105	17	17			
40	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
41	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	211	210	211	211			
42	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.94	300	300	16	116	16	16			
43	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	0	20	36	60			
44	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	33	51	35	51			
45	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	40	64	40	64			
46	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	5	5	5	5			
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			2	14	15	30			
47	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	7	84	40	84			
48	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	54	13	36			
49	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	26	105	17	34			
50	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	6	20	40	70			
51	Juldah 100 MW Unit-1 (Acom)	HFO (NENP)	8x13.45	100	100	0	0	0	12			
52	Chattogram 116 MW PP (Anlima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	21	105	35	52			
53	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	54	163	54	163			
54	Chattogram 2*612MW Coal Based PP (SS Power)	Coal (IPP)	2x612	1224	1224	274	265	270	270			
55	Matarbari 2*600 MW (CPGCL)	Coal (CPGCL)	1x575	575	575	572	428	450	550			
56	Cox's Bazar Wind PP	(Wind) (IPP)		60	60	52	22	40	40			
	Sonagazi 75 MW Solar Plant	(Solar) (EGCB)				52	0	33	0			
<b>Chattogram Zone Total</b>				<b>4464</b>	<b>4404</b>	<b>1574</b>	<b>2045</b>	<b>1546</b>	<b>1936</b>	<b>200</b>	<b>330</b>	
57	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	25	29	34	34			
58	Ashuganj 225 MW CCGP	Gas (APSCL)	1x142+1*75	221	221	206	214	220	220			
59	Ashuganj 450 MW CCGP(South)	Gas (APSCL)	1x360	360	360	275	260	300	335			
60	Ashuganj 450 MW CCGP(North)	Gas (APSCL)	1x361	360	360	290	260	300	300			
61	Ashuganj 420 MW CCGP(East)	Gas (APSCL)	1x284+1x116	400	400	285	330	280	330			
62	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	0	0	0	0	195	Gas Shortage	
63	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51			
64	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	5	6	6	6			
65	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	25	35	36	41			
66	Chandpur 150 MW CCGP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163	Under maint.	
67	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	85	164	160	160			
68	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0			
69	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	15	32	33	33			
70	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	25	51	25	52			
71	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	14	16	20	20			
72	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	34	114	52	114			
73	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	36	78	36	75			
74	Bharob 54 MW PP	HFO (IPP)	3x18.2	54	54	25	54	17	35			
75	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x5.428	115	115	36	96	36	95			
76	Ashuganj 55 MW PP (Precision)	Gas (NENP)	15*4	55	55	41	47	50	50			
**	Impoport (Tripura)	India		160	160	96	94	146	151			
<b>Cumilla Zone Total</b>				<b>2937</b>	<b>2929</b>	<b>1569</b>	<b>1931</b>	<b>2102</b>	<b>2102</b>	<b>195</b>	<b>163</b>	
77	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	64	71	80	100	131	Gas Shortage	
78	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	47	97	50	97			
79	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	55	155	56	108			
80	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
81	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	43	0	50	0			
82	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	18	24	12	22			
<b>Mymensingh Zone Total</b>				<b>600</b>	<b>592</b>	<b>229</b>	<b>347</b>	<b>250</b>	<b>327</b>	<b>131</b>	<b>0</b>	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	30.04.24 (Yesterday)		01.05.24 (Today)		30.04.24 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for:		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)			
83	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	40	36	43	43		34	Under maint.	
84	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	28	28	28	28		62	GT-4 Under maint.	
85	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	50	53	50	50				
86	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	112	112	112				
87	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	11	5	5				
88	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	57	59	60	60				
89	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
90	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	200	200	210	210				
91	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	15	18	17	17				
92	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	8	25	25				
93	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	305	250	300	300				
94	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	374	301	400	400				
95	Bibiyana South 363 MW CCPP	Gas (PDB)	1x252+1x131	383	383	372	340	380	380				
96	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0			Test run	
97	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	39	40	44	44				
<b>Sylhet Zone Total</b>					<b>2376</b>	<b>2331</b>	<b>1616</b>	<b>1456</b>	<b>1674</b>	<b>1674</b>	<b>0</b>	<b>426</b>	
98	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	10	0	0				
99	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	360	345	400	410				
100	Fardpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	33	25	42				
101	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	46	44	62				
102	Khulna 225 MW CCPP	HSD/ Gas (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	0				
103	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	42	83	90	90				
104	Machumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	0	0	0				
105	Monoria Orion 100 MW Solar PP	Solar (IPP)	100	100	100	95	0	100	0				
106	Maitree Super Thermal 1320 MW PP	Coal (BIFPCL)	2x617	1234	1234	305	304	375	375				
107	Khulna 330 MW CCPP	Gas/HSD (BPDB)	1x220+1x116	336	336	0	0	0	0				
**	Bheramara (HVDC)	India		1000	1000	923	634	940	651				
<b>Khulna Zone Total</b>					<b>3703</b>	<b>3699</b>	<b>1725</b>	<b>1455</b>	<b>1974</b>	<b>1630</b>	<b>0</b>	<b>0</b>	
108	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	110	48	110				
109	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	10	9	10	10	10				
110	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	120	126	130	130		68	ST under maint.	
111	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	1120	1244	1244	1244				
112	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	72	17	27				
113	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	150	307	200	307				
114	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	220	220				
<b>Barishal Zone Total</b>					<b>2265</b>	<b>2235</b>	<b>1619</b>	<b>2089</b>	<b>1869</b>	<b>2048</b>	<b>0</b>	<b>68</b>	
115	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	40	40	0	0	31		Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.	
116	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	23	40	38	38				
117	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	19	0	25				
118	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	22	82	50	95				
119	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	42	47	40	50				
120	Katakali 50 MW PP (Northern)	HFO (NENP)	6x8.9	50	50	42	42	42	42				
121	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	30	23	33				
122	Sirajgonj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	187	181	185	200				
123	Sirajgonj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	187	183	185	200				
124	Sirajgonj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	0	0	0	0	220		Gas Shortage	
125	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	399	348	414	414				
126	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
127	Natore 52 MW PP (Rajanka)	HFO (IPP)	6x8.92	52	52	0	52	8	8				
128	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	95	35	95				
129	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	37	113	35	113				
130	Ammura 50 MW PP (Sinha)	HFO (NENP)	7x7.79	50	28	0	0	0	0				
131	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	5	0	6	0				
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	1211	1389	1200	1200				
<b>Rajshahi Zone Total</b>					<b>3453</b>	<b>3431</b>	<b>2241</b>	<b>2672</b>	<b>2272</b>	<b>2524</b>	<b>251</b>	<b>100</b>	
132	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	70	72	70	75				
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
133	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	230	230	230	230				
134	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
135	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x.2*3	113	113	37	77	56	80				
136	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
137	Majpara, Tahisa 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0				
138	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	55	115	35	115				
139	Lalmohithat 30 MW Solar (Intraac)	Solar (IPP)	1*30	30	30	32	0	30	0				
140	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	184	0	130	0				
<b>Rangpur Zone Total</b>					<b>1030</b>	<b>950</b>	<b>615</b>	<b>494</b>	<b>559</b>	<b>500</b>	<b>0</b>	<b>85</b>	
<b>Sub-total: Plants in operation</b>					<b>26354</b>	<b>25903</b>	<b>14301.0</b>	<b>16477</b>	<b>15535</b>	<b>16882</b>	<b>1195</b>	<b>2017</b>	
<b>(B) Plants under long term maintenance/ contract expired</b>													
141	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			Contract Expired	
142	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	0	0	0	0	0			Contract Expired	
143	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			Contract Expired	
144	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	0	0	0	0	0			Contract Expired	
145	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Contract Expired	
<b>Sub-Total: Plants under long term maintenance/ contract expired</b>					<b>700</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	
<b>Gross Total</b>					<b>27054</b>	<b>25903</b>	<b>14301</b>	<b>16477</b>	<b>15535</b>	<b>16882</b>	<b>1195</b>	<b>2017</b>	
<b>(C) Actual data of 30.04.24 (Yesterday) Tuesday :</b>													
01.	Max. Demand at eve. peak (Generation end)	: 17000 MW, at = 21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :										
02.	Max. Demand at eve. peak (Sub-station end)	: 16074 MW, at = 21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW			
03.	Highest Generation (Generation end)	: 16477 MW, at = 21:00 hrs	Dhaka	5814	5674	140	Mymensingh	1422	1202	220			
04.	Minimum Generation (Generation end)	: 13148 MW, at = 8:00 hrs	Chattogram	1468	1448	20	Sylhet	360	360	0			
05.	Day-peak Generation (Generation end)	: 14301 MW, at = 12:00 hrs	Khulna	1982	1967	15	Barishal	512	512	0			
06.	Evening-peak Generation (Generation end)	: 16477 MW, at = 21:00 hrs	Rajshahi	1870	1870	0	Rangpur	1075	991	84			
07.	Evening Peak Load-shed (Sub-station end)	: 499 MW, at = 21:00 hrs	Cumilla	1572	1552	20	Total	16074	15575	499			
08.	Minimum Generation Forecast up to 8:00 hrs.	: 12871 MW, at = 5:00 hrs											
09.	Generation shortfall at evening peak due to :												
a)	Gas/LF limitation	: 995 MW											
b)	Coal supply Limitation	: 0 MW											
c)	Low water level in Kaptai lake	: 200 MW											
d)	Plants under shut down/ maintenance	: 2017 MW											
10.	Total Energy (Generation + India Import)	: 343.98 MMCFD											
			By Gas = 173.247 MKWH	By Oil = 46.834 MKWh									
			By Coal = 96.613 MKWH	By Hydro = 0.697 MKWh									
			By Solar = 3.418 MKWH										
11.	Total Gas Supplied	: 1277.08 MMCFD											
<b>(D) Forecast of 01.05.24 (Today) Wednesday :</b>													
01.	Maximum Demand	: 16200 MW (Generation end)	04. Maximum Load-shed : 0 MW At evening peak (Sub-station end)										
02.	Maximum Generation	: 16882 MW (Generation end)	05. Total Generation : 338.20 MMCFD										
03.	Reserve / Shortage	: 682 MW (Generation end)	06. Probable Max. Temperature in Dhaka : 38.6°C										

#Remarks: Highest Generation 16477 MW on 30-04-2024 at 21:00

(Md. Helalur Rahman)  
Deputy Secretary, Generation