

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date: 6-May-24

Page-2

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity		Peak Hour Generation		Enervor Generated	Remarks
				MW	MW	MW	KWH		
				Unit No. X Capacity					
1	Ghorasal Repowered CCGP-Unit-3 (GT)	PDB	1720	280	0	0	0	0	Under maint
2	Ghorasal Repowered CCGP Unit-4	PDB	1210	180	0	0	0	0	Gas shortage
3	Ghorasal TPP Unit-5	PDB	1210	190	160	3244500	0	0	
4	Ghorasal 365 MW CCGP Unit-7	QRPP	1243+1122	365	0	0	0	0	Air Compressor problem
5	Ghorasal 78.5 MW PP(MAX)	QRPP	240	0	0	0	0	0	Contract Expired
6	Ghorasal 108 MW PP (Regent)	IPP	3*43.35	12	108	480405	12	0	Bad weather
7	Haripur GTPP	SBU, PDB	232	20	0	0	0	0	Under maint.
8	Haripur 412 MW CCGP	EGCB	1273+1139	400	365	8312400	0	0	Bad weather
9	Haripur 360 MW CCGP(HPL)	IPP	1235+1125	0	0	0	0	0	Contract Expired
10	Meghnaghat 450 MW CCGP(MPL)	IPP	2150+1150	450	350	8462500	0	0	Bad weather
11	Meghnaghat 100 MW Unit-1	NENP	0	0	0	0	0	0	Reserve
12	Meghnaghat CCGP(Summit)	IPP	2110+1110	335	290	6823389	0	0	Bad weather
13	Madanganj 102 PP(Summit)	NENP	617	0	0	0	0	0	Reserve.
14	Madanganj-55 MW PP(Summit)	IPP	3*17.08+111.3	55	40	383486	0	0	Engine problem
15	Keraniganj 100 MW PP (Powerpac)	NENP	813.45	75	0	185359	0	0	Reserve.
16	Narshahi 22 MW PP (Doreen)	SIPP, REB	82.90	22	0	0	0	0	Contract Expired
17	210 MW Siddhirganj PP	PDB	1210	115	0	0	0	0	Under maint
18	Siddhirganj 2120 MW GTPP	EGCB	2105	210	0	0	0	0	Gas line problem.
19	Siddhirganj 109 PP(Dutch Bangla)	NENP	128.9	0	0	0	0	0	Reserve.
20	Siddhirganj 335 MW CCGP	EGCB	1217+118	335	270	6452339	0	0	Bad weather
21	Gasapur 102 MW PP (Digital Power)	IPP	128.924	102	16	259344	0	0	Bad weather
22	Katpadi 52 MW PP (Sinha)	IPP	77.9	0	0	0	0	0	Fuel shortage
23	Kamalaghat 54 MW PP (Banco Energy)	IPP	318	54	0	9720	0	0	Reserve.
24	Kodda 150 MW PP	BPDB-RPCL	9*17.06	149	48	189120	0	0	Bad weather
25	Manikganj 55 MW PP (Northern)	IPP	319.3	55	17	106125	0	0	Bad weather
26	Nabaganj 55 MW PP (Southern power)	IPP	319.3	55	0	0	0	0	Reserve.
27	Bosila 108 MW PP(RCL)	IPP	128.775+113.5	0	0	0	0	0	
28	Summit Power (Madhabdi+Ashulia)	SIPP, REB	3*3.67+4*8.73	80	15	855120	0	0	Engine problem
29	Maona 33 MW PP(Summit)	SIPP, REB	4*8.73	33	25	596700	0	0	Engine problem
30	Rugganj 33 MW PP(Summit)	SIPP, REB	4*8.73	33	33	609400	0	0	
31	Gasipur 52 MW PP	RPCL	81.9	52	16	155940	0	0	Fuel shortage
32	Tongi 80 MW GTPP	PDB	1105	105	0	0	0	0	Gas shortage
33	Kodda 300 MW PP Unit-2 (Summit)	IPP	1817.076	300	0	0	0	0	Reserve.
34	Bramhangon 100 MW PP (Aggreko)	IPP	1140.959	0	0	0	0	0	Contract Expired
35	Auraha 100MW PP (Aggreko)	IPP	0.8523+0.9591	0	0	0	0	0	Contract Expired
36	Kodda 149 MW PP Unit-1 (Summit)	IPP	818.4324	149	65	497088	0	0	Bad weather
37	Gasipur 100 MW PP	RPCL	617.5	105	52	334080	0	0	Bad weather
38	Meghnaghat 104 MW PP (OPCL)	IPP	18.56	104	0	0	0	0	Reserve.
39	Manikganj 162MW PP(MPGL)	IPP	81.18	162	0	0	0	0	Reserve.
40	Spectra Solar Plant Ltd	IPP	35	35	0	118356	0	0	
41	Kanchan Purbasol Power Generation Ltd.	IPP	182.3	55	0	0	0	0	Under maint.
42	Meghnaghat Uniques power	IPP	589	584	250	6980454	0	0	Bad weather
43	Summit Meghnaghat-2 589 MW(Gas)	IPP	589	0	250	5870909	0	0	On test.
Dhaka area Total				5332	2264	50929474			
39	Chattogram TPP-1	PDB	1210	180	0	1500000	0	0	Tripped at 15:12.
40	Chattogram TPP-2	PDB	1210	180	0	0	0	0	Gas shortage
41	Razzan 25 MW PP	RPCL	318.9	25	0	26973	0	0	Reserve.
42	Teknaf 20MW PP (SolarTech)	IPP	20	20	0	98820	0	0	
43	Patenga 50MW PP (Baraka)	IPP	8*6.98	50	0	76800	0	0	Reserve.
44	Kapali Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	30	696000	0	0	Low water level
45	Sikalbaha 225MW	PDB	1150+1175	225	185	4804624	0	0	Bad weather
46	Sikalbaha Peaking	PDB	1150	0	0	0	0	0	Under maint.
47	Sikalbaha 105 MW PP (Baraka Sikalbaha)	IPP	6*17.5	105	0	0	0	0	Reserve.
48	Hathazari 100 MW peaking PP	PDB	118.9	98	8	243936	0	0	Bad weather
49	Dohazari-Kalaish 100 MW Peaking	PDB	617	102	0	146623	0	0	Reserve.
50	Judiah 100 MW Unit-1 (Acorn)	NENP	813.45	100	0	0	0	0	
51	Judiah 100 MW PP Unit-3 (Acorn)	IPP	813.5	100	0	499200	0	0	Reserve.
52	Barabandua 22 MW PP (Regent)	SIPP, PDB	82.90	22	0	136752	0	0	Engine problem
53	Malancha, Cig. EPZ (United)	IPP	5*8.73+3*9.34	0	0	253440	0	0	
54	Chattogram 108 MW PP (ECPV)	IPP	167	108	0	463680	0	0	Reserve.
55	Kapali 7 MW Solar PP	PDB	7.4	7	0	23281	0	0	
56	Arwara 300 MW PP (United)	IPP	1717+24	300	0	259099	0	0	Reserve.
57	Jodis Power	IPP	3*18.55+13.6	54	0	0	0	0	Reserve.
58	Karnaphuli Power Ltd.	IPP	18.4156+8.5	110	0	0	0	0	Reserve.
59	Judiah unit-2 (Acorn)	IPP	813.6	100	0	591360	0	0	Fuel shortage
60	Anlima Energy Ltd.	IPP	6*21.2	116	0	414000	0	0	Reserve.
61	Minshara 150 MW	BPDB-RPCL	18.59	163	0	0	0	0	Reserve.
62	SS Power	SS Power	2612	1224	270	8534544	0	0	Bad weather
63	Cox's Bazar Wind	IPP	66	60	44	354720	0	0	On test.
64	Matarbari 2*600 MW (CPGCL)	CPGCL	0	575	316	11432727	0	0	Bad weather
65	Minshara 150 MW (Gas)	BPDB-RPCL	18.59	0	0	0	0	0	On test.
66	Sonagazi 75 MW Solar Plant	EGCB	75	0	0	253209	0	0	
Chattogram area Total				4404	853	2880298			
67	Ashuganj TPP Unit-3	APSCl	1150	0	0	0	0	0	Contract Expired
68	Ashuganj TPP Unit-4	APSCl	1150	0	0	0	0	0	Contract Expired
69	Ashuganj TPP Unit-5	APSCl	1150	0	0	0	0	0	Contract Expired
70	Ashuganj 225 MW CCGP	APSCl	1142+1175	221	203	3181000	0	0	FGMO
71	Ashuganj 450 MW CCGP(North)	APSCl	1360	360	305	7516800	0	0	FGMO
72	Ashuganj 450 MW CCGP(South)	APSCl	1360	360	140	3063000	0	0	ST under maint
73	Ashuganj 420 MW CCGP(East)	APSCl	2841+116*1	400	275	6767500	0	0	FGMO
74	Ashuganj 50 MW PP	APSCl	14*3.968	45	38	865440	0	0	Bad weather
75	Ashuganj 55 MW PP (Precision)	QRPP	0	55	6	688800	0	0	Bad weather
76	Ashuganj 195 MW PP (APSCl-United)	IPP	20*9.73+116	195	0	50182	0	0	Bad weather
77	Ashuganj 11 MW PP (Midland)	IPP	619.34	51	5	550325	0	0	Bad weather
78	Ashuganj 150 MW PP (Midland)	IPP	237.015	150	0	0	0	0	Fuel shortage
79	Titas 50 MW Peaking PP	PDB	6*8.92	52	8	97568	0	0	Bad weather
80	Chandpur 150 MW CCGP	PDB	1106+157	163	0	0	0	0	Under maint.
81	Chandpur 200 MW (Desh energy)	IPP	1218.4	200	2	584640	0	0	Bad weather
82	Feni 11 MW PP (Doreen)	SIPP, REB	4.90	0	11	0	0	0	Reserve.
83	Impogri (Tripura)	Imported power	0	11	96	1985280	0	0	
84	Jangalia 33 MW PP (Summit)	SIPP, PDB	4*8.73	33	28	578700	0	0	Engine problem
85	Jangalia 52 MW PP (Lakdanari)	IPP	6*8.92	52	0	170093	0	0	Reserve.
86	Cumilla 25 MW PP (Summit)	SIPP, REB	3*3.67+2*6.97	25	8	113790	0	0	Engine problem
87	Daudkandi 200 MW PP (B.Trac)	IPP	0	0	0	0	0	0	Under maint.
88	Feni Lanka Power	IPP	7*18.415+19.78	114	0	250900	0	0	Reserve.
89	Chowmuhani 113 MW	IPP	12*9.78+2*3.1	113	9	304920	0	0	Bad weather
90	Bhairab 54.5 MW	IPP	3*18.2	54	35	538200	0	0	
91	Chandpur 115 (Doreen)	IPP	4*18.5+2*22.5	115	0	370560	0	0	Bad weather
Cumilla Area Total				2929	1158	2767598			
82	RPCL 210MW CCGP	IPP	4*35+170	202	136	284480	0	0	Gas shortage
83	Jamalpur 95 MW PP(Powerpac)	IPP	0	0	0	0	0	0	
84	Sarishabari 3 MW Solar Plant	IPP	13	3	0	8250	0	0	
85	Mymensingh 200 MW PP (United)	IPP	9*78.21	200	65	422400	0	0	Bad weather
86	Jamalpur 115 MW PP (United)	IPP	9*78.21	115	24	178800	0	0	Bad weather
87	Sutahat 50 MW Solar PP	IPP	0	50	0	201720	0	0	
88	Tangail Pali Power Gen 22 MW	IPP	4*6.7	22	18	216720	0	0	Engine problem
Mymensingh Area Total				592	243	3992370			
89	Fenchugani CCGP Phase-1	PDB	2*32+133	70	30	715000	0	0	Machine problem
90	Fenchugani CCGP Phase-2	PDB	2*35+135	90	20	465480	0	0	Machine problem
91	Kushaura 163 MW CCGP (KP)	IPP	1109+154	163	80	2118827	0	0	ST under maint
92	Shahbazar 330 MW CCGP	PDB	3110	330	0	0	0	0	Under maint.
93	Fenchugani 51 MW PP (Barakattullah)	RPP	192.90	51	5	207000	0	0	Bad weather
94	Fenchugani 44 MW (Energyprima)	NENP	12*3.3+5.2	50	5	297216	0	0	Bad weather
95	Hobiganj 11 MW PP Confidence-E	SIPP, REB	42.90	11	5	63024	0	0	Bad weather
96	Shahbazar GTTP Unit-8 & 9	PDB	2*35	66	40	1263744	0	0	Bad weather
97	Shahbazar 86 MW PP (Shahbazar)	RPP	32*2.90	0	0	0	0	0	Contract Expired
98	Shahbazar 100 MW GTTP	PDB	1100	100	0	0	0	0	Gas shortage
99	Sylhet 225 MW CCGP	PDB	1142+1189	231	102	2415120	0	0	Machine problem
100	Sylhet 20 MW GTTP	PDB	120	20	18	380000	0	0	
101	Sylhet 50 MW PP (EPL)	NENP	272	0	0	0	0	0	Contract Expired
102	Shyghhanulla 25 MW PP	SIPP, REB	3*9.34	25	16	361776	0	0	Engine problem
103	Bibiana-II 341 MW CCGP (Summit)	IPP	1222+1119	341	300	7005000	0	0	FGMO
104	Bibiyana-III 400 MW CCGP	PDB	2851+1341	400					