

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month May, 2024				Day : Tuesday				Date : 07.05.24				
Probable Maximum Demand : 14000 MW				Probable Maximum Generation : 16421 MW								
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 73.43 ft				Today = 73.51 ft				
				Rule Curve = 80.86 ft								
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	06.05.24 (Yesterday)		07.05.24 (Today)		06.05.24 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
					Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation MW	Machines shut down (MW)		Description/ Remarks
(A) Plants in operation:												
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		Under project work	
2	a) Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	100	160	180	180			
3	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365	Awaiting for HGPI
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	66	12	75	75	96	Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105	Under maint.
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	350	450	450			
8	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling
9	Haripur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	400	401	365	400	400			
10	Siddhirgonj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage	
11	Siddhirgonj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	317	270	335	335			
12	Meghnaghat 335MW CCGP(Summit)	Gas (IPP)	2x110+1x110	335	335	300	290	310	310			
13	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	28	40	40	40			
14	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	32	16	48	90			
15	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	0	0			
16	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+1x7.73	80	80	20	15	42	42			
17	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	25	25			
18	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	33	32	32			
19	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	16	16	16			
20	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	35	52	35	105			
21	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	16	48	32	150			
22	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	0	17	54			
23	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	0	210	300			
24	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	6x18.415+1x8.97	149	149	43	55	52	149			
25	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	0	35	55			
26	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	17	35	55			
27	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	0	17	53			
28	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	0	0	90	162			
29	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	24	0	35	0			
30	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	0	0	0			
31	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	29	0	0	15			
32	Unique Meghnaghat 584MW CCGP	Gas	1x400+1x184	584	584	302	250	500	500			
	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	0	0	0	0	60	80			
	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	0	0	0	0	80	80			
	Meghnaghat 100 MW(HEL)	HFO (NENP)	12x8.9	0	0	0	0	90	100			
	Meghnaghat 589 MW CCGP(Summit)	Gas				300	250	250	450			Test run
Dhaka Zone Total				5526	5332	2521	2264	3491	4303	486	845	
33	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	30	30	30	30	200		Inadequate Water Level
34	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	105	0	118	118			
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.
35	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0			
36	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	1	0	8	25			
37	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	19	0	20	0			
38	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	0	6	19			
39	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	0	0	17	34			
40	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.
41	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	211	185	210	210			
42	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.94	300	300	16	0	16	16			
43	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	62	0	36	60			
44	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	17	0	50	51			
45	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	20	8	40	64			
46	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	12	0	10	10			
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			2	0	5	20			
47	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	31	0	20	90			
48	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	0	17	54			
49	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	0	0	17	51			
50	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	60	0	40	70			
51	Juldah 100 MW Unit-1 (Acorn)	HFO (NENP)	8x13.45	100	100	0	0	0	0			
52	Chattogram 116 MW PP (Anlima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	31	0	35	72			
53	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	0	0	54	163			
54	Chattogram 2*612MW Coal Based PP (SS Power)	Coal (IPP)	2x612	1224	1224	272	270	270	270			
55	Matarbari 2*600 MW (CPGCL)	Coal (CPGCL)	1x575	575	575	338	316	350	760			
56	Cox's Bazar Wind PP	(Wind) (IPP)		60	60	0	44	40	40			
	Sonagazi 75 MW Solar Plant	(Solar) (EGCB)				52	0	33	0			
Chattogram Zone Total				4464	4404	1289	853	1447	2227	200	330	
57	Ashugani 50 MW PP	Gas (APSCL)	14x3.968	53	45	35	38	38	38			
58	Ashugani 225 MW CCGP	Gas (APSCL)	1x142+1*75	221	221	137	203	210	210			
59	Ashugani 450 MW CCGP(South)	Gas (APSCL)	1x360	360	360	180	140	0	0			
60	Ashugani 450 MW CCGP(North)	Gas (APSCL)	1x361	360	360	285	305	340	340			
61	Ashugani 420 MW CCGP(East)	Gas (APSCL)	1x284+1x116	400	400	285	275	350	350			
62	Ashugani 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	0	0	0	195	Gas Shortage	
63	Ashugani 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	5	51	51			
64	Ashugani 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	0	6	6			
65	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	8	8	36	41			
66	Chandpur 150 MW CCGP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0		163	Under maint.
67	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	51	2	100	136			
68	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0			
69	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	24	28	33	33			
70	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	16	0	25	52			
71	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	4	8	20	20			
72	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	0	70	114			
73	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	28	9	36	75			
74	Bharob 54 MW PP	HFO (IPP)	3x18.2	54	54	35	35	17	42			
75	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x5.428	115	115	35	0	54	95			
76	Ashugani 55 MW PP (Precision)	Gas (NENP)	15*4	55	55	50	6	50	50			
**	Impoport (Tripura)	India		160	160	82	96	146	151			
Cumilla Zone Total				2937	2929	1331	1158	1582	1804	195	163	
77	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	109	136	120	140			
78	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	0	24	50	97			
79	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	8	65	56	108			
80	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
81	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	25	0	50	0			
82	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	18	18	12	22			
Mymensingh Zone Total				600	592	162	243	290	367	0	0	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	06.05.24 (Yesterday)		07.05.24 (Today)		06.05.24 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for:		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)			
83	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30	30		40	Under maint.	
84	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	20	20	20	20		70	GT-4 Under maint.	
85	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	11	5	30	50				
86	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	80	80	112	112				
87	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	2	5	5	5				
88	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	62	40	60	60				
89	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
90	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	102	102	70	70				
91	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	18	18				
92	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	25	25				
93	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	270	300	300	300				
94	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	317	376	400	400				
95	Bibiyana South 363 MW CCPP	Gas (PDB)	1x252+1x131	383	383	320	350	340	360				
96	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0			Test run	
97	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	10	5	30	44				
Sylhet Zone Total					2376	2331	1258	1347	1440	1494	0	440	
98	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
99	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	405	260	400	400				
100	Fardpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	42				
101	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	44	62				
102	Khulna 225 MW CCPP	HSD/ Gas (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	0				
103	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	0	0	90				
104	Machumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	0	0	0				
105	Monoria Orion 100 MW Solar PP	Solar (IPP)	100	100	100	55	0	100	0				
106	Maitree Super Thermal 1320 MW PP	Coal (BIFPCL)	2x617	1234	1234	308	0	375	375				
107	Khulna 330 MW CCPP	Gas/HSD (BPDB)	1x220+1x116	336	336	0	0	0	0				
**	Bheramara (HVDC)	India		1000	1000	922	923	940	650				
Khulna Zone Total					3703	3699	1690	1183	1949	1619	0	0	
108	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	48	110				
109	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	10	8	0	10	10				
110	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	126	80	130	130		114	ST under maint.	
111	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	780	550	1244	1244				
112	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	17	35				
113	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	170	140	200	307				
114	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	180	170	220	220				
Barishal Zone Total					2265	2235	1264	940	1869	2056	0	114	
115	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.	
116	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	0	33				
117	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	25				
118	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	0	0	90				
119	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	42	42				
120	Katakali 50 MW PP (Northern)	HFO (NENP)	6x8.9	50	50	0	0	34	34				
121	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	28				
122	Siraigonj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	0	0	0	0				
123	Siraigonj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	150	161	170	200	59		Gas Shortage	
124	Siraigonj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	140	161	180	200	59		Gas Shortage	
125	Siraigonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	348	414	414	414				
126	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	5	5	11	11				
127	Natore 52 MW PP (Rajanka)	HFO (IPP)	6x8.92	52	52	0	0	8	8				
128	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	3	18	35	95				
129	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	0	35	113				
130	Ammura 50 MW PP (Sinha)	HFO (NENP)	7x7.79	50	28	0	0	0	0				
131	Siraigonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	3	0	6	0				
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	625	436	748	748				
Rajshahi Zone Total					3453	3431	1274	1195	1683	2041	189	100	
132	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	72	70	73	73				
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
133	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	230	200	230	230				
134	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
135	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x.2*3	113	113	35	38	56	92				
136	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
137	Majpara, Tatisa 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	3	0	8	0				
138	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	35	31	35	115				
139	Lalmohona 30 MW Solar (Intraac)	Solar (IPP)	1*30	30	30	12	0	30	0				
140	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	61	0	130	0				
Rangpur Zone Total					1030	950	448	339	562	510	0	85	
Sub-total: Plants in operation					26354	25903	11237.0	9522	14313	16421	1070	2077	
(B) Plants under long term maintenance/ contract expired													
141	Katobdi 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			Contract Expired	
142	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	0	0	0	0	0			Contract Expired	
143	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			Contract Expired	
144	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	0	0	0	0	0			Contract Expired	
145	Bosha 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Contract Expired	
Sub-Total: Plants under long term maintenance/ contract expired					700	0	0	0	0	0	0	0	
Gross Total					27054	25903	11237	9522	14313	16421	1070	2077	
(C) Actual data of 06.05.24 (Yesterday) Monday :													
01.	Max. Demand at eve. peak (Generation end)	: 9522	MW, at = 19:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :									
02.	Max. Demand at eve. peak (Sub-station end)	: 9197	MW, at = 19:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed		
03.	Highest Generation (Generation end)	: 11237	MW, at = 12:00 hrs	Dhaka	4235	4235	0	Mymensingh	901	901	0		
04.	Minimum Generation (Generation end)	: 9606	MW, at = 6:00 hrs	Chattogram	403	403	0	Sylhet	364	364	0		
05.	Day-peak Generation (Generation end)	: 11237	MW, at = 12:00 hrs	Khulna	554	554	0	Barishal	111	111	0		
06.	Evening-peak Generation (Generation end)	: 9522	MW, at = 19:00 hrs	Rajshahi	1234	1234	0	Rangpur	725	725	0		
07.	Evening Peak Load-shed (Sub-station end)	: 0	MW, at = 19:00 hrs	Cumilla	670	670	0						
08.	Minimum Generation Forecast up to 8:00 hrs.	: 7282	MW, at = 5:00 hrs					Total	9197	9197	0		
09.	Generation shortfall at evening peak due to :			13.	Fuel cost :	(a) Gas = 408969975 Taka	(c) Coal = 431559399 Taka						
	a) Gas/LF limitation	: 870	MW			(b) Oil = 162041164 Taka	Total = 1002570537 Taka						
	d) Coal supply Limitation	: 0	MW										
	b) Low water level in Kaptai lake	: 200	MW										
	c) Plants under shut down/ maintenance	: 2077	MW	14.	Maximum Temperature in Dhaka was :	29.8°C							
10.	Total Energy (Generation + India Import)	: 241.46	MKWh	15.	Export through East-West interconnections :								
	By Gas = 145.169 MKWh	By Oil = 8.959 MKWh			At evening peak-hour	: 11237	MW, at 19:00 hrs						
	By Coal = 62.788 MKWh	By Hydro = 0.696 MKWh			Maximum	: 10	MW, at 1:00 hrs						
	By Solar = 1.726 MKWh				Energy	: 2699.4	MKWh						
11.	Total Gas Supplied	: 1016.28	MMCFD										
(D) Forecast of 07.05.24 (Today) Tuesday :													
01.	Maximum Demand	: 14000	MW (Generation end)	04.	Maximum Load-shed	: 0	MW	At evening peak (Sub-station end)					
02.	Maximum Generation	: 16421	MW (Generation end)	05.	Total Generation	: 300.83	MKWh						
03.	Reserve / Shortage	: 2421	MW (Generation end)	06.	Probable Max. Temperature in Dhaka :	29.8°C							

#Remarks: Highest Generation 16477 MW on 30-04-2024 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation