

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month May, 2024				Day : Tuesday				Date : 14.05.24				
Probable Maximum Demand : 16000 MW				Probable Maximum Generation : 16954 MW								
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 73.75 ft				Today = 73.58 ft				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	13.05.24 (Yesterday)		14.05.24 (Today)		13.05.24 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
					Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation MW	Machines shut down (MW)		Description/ Remarks
(A) Plants in operation:												
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		Under project work	
2	a) Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180			
3	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365	Awaiting for HGPI
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	76	79	75	75	29	Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105	Under maint.
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	380	450	450			
8	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling
9	Haripur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	400	401	409	400	400			
10	Siddhirgonj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage	
11	Siddhirgonj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	316	316	300	335			
12	Meghnaghat 335MW CCGP(Summit)	Gas (IPP)	2x110+1x110	335	335	306	301	310	310			
13	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	55	43	43			
14	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	8	90	90	90			
15	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	0	0			
16	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+1x7.73	80	80	33	39	40	41			
17	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	0	33	33	33			
18	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	32	31	33	33			
19	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	8	8	16			
20	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	35	105	17	100			
21	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	16	150	64	150			
22	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	54	54	54			
23	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	95	300	300			
24	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	6x18.415+1x8.97	149	149	134	134	135	149			
25	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	55	55	55			
26	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	17	55	55	55			
27	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	72	72	72	72			
28	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	0	162	162	162			
29	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	30	0	35	0			
30	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	0	0	0			
31	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	0	0	15			
32	Unique Meghnaghat 584MW CCGP	Gas	1x400+1x184	584	584	0	0	400	400			
	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	0	0	9	85	60	85			
	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	0	0	17	80	96	96			
	Meghnaghat 100 MW(IEL)	HFO (NENP)	12x8.9	0	0	8	99	90	100			
	Meghnaghat 589 MW CCGP(Summit)	Gas				500	450	450	450			Test run
Dhaka Zone Total				5526	5332	2698	3517	4007	4249	419	845	
33	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	30	30	30	30	200		Inadequate Water Level
34	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	100	100	100	100			
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.
35	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	5	0	5	0			
36	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	25	8	25			
37	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	17	0	20	0			
38	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	19	6	18			
39	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	34	100	100			
40	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.
41	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	213	212	210	210			
42	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.94	300	300	51	52	52	52			
43	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	49	62	49	62			
44	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	85	51	85			
45	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	73	72	80	80			
46	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	11	13	14	14			
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			2	22	5	25			
47	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	80	20	80			
48	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	17	54			
49	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	32	34	110	110			
50	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	48	62	48	62			
51	Juldah 100 MW Unit-1 (Acorn)	HFO (NENP)	8x13.45	100	100	46	46	40	45			
52	Chattogram 116 MW PP (Anlima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	17	17	17			
53	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	0	126	54	163			
54	Chattogram 2*612MW Coal Based PP (SS Power)	Coal (IPP)	2x612	1224	1224	0	370	490	490			
55	Matarbari 2*600 MW (CPGCL)	Coal (CPGCL)	1x575	1254	575	753	638	530	530			
56	Cox's Bazar Wind PP	(Wind) (IPP)		60	60	4	0	40	40			
	Sonagazi 75 MW Solar Plant	(Solar) (EGCB)				45	0	33	0			
Chattogram Zone Total				4464	4404	1573	2153	2129	2392	200	330	
57	Ashugani 50 MW PP	Gas (APSCCL)	14x3.968	53	45	36	35	38	38			
58	Ashugani 225 MW CCGP	Gas (APSCCL)	1x142+1*75	221	221	191	215	210	210			
59	Ashugani 450 MW CCGP(South)	Gas (APSCCL)	1x360	360	360	285	270	300	300			
60	Ashugani 450 MW CCGP(North)	Gas (APSCCL)	1x361	360	360	295	295	300	300			
61	Ashugani 420 MW CCGP(East)	Gas (APSCCL)	1x284+1x116	400	400	300	250	300	300			
62	Ashugani 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	8	187		Gas Shortage
63	Ashugani 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51			
64	Ashugani 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	20	125	150	150			
65	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	23	36	41			
66	Chandpur 150 MW CCGP	Gas (PDB)	1X106+1x57	163	163	0	0	50	50			
67	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	17	17	17			
68	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0			
69	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	0	32	33	33			
70	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	40	52	52			
71	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	2	14	20	20			
72	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	98	98	98	98			
73	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	67	75	57	95			
74	Bharob 54 MW PP	HFO (IPP)	3x18.2	54	54	0	35	17	42			
75	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x5.428	115	115	63	75	115	115			
76	Ashugani 55 MW PP (Precision)	Gas (NENP)	15*4	55	55	46	41	50	50			
**	Impoprt (Tripura)	India		160	160	108	100	146	151			
Cumilla Zone Total				2937	2929	1595	1799	2048	2121	187	0	
77	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	90	108	100	120	94		Gas Shortage
78	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	55	99	50	100			
79	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	55	105	56	108			
80	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
81	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	51	0	50	0			
82	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	19	24	22	24			
Mymensingh Zone Total				600	592	272	336	280	352	94	0	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	13.05.24 (Yesterday)		14.05.24 (Today)		13.05.24 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)			
83	Fenchugonj CCGP Phase-1	Gas (PDB)	2x32+1x33	97	70	42	40	43	43	30	Under maint.		
84	Fenchugonj CCGP Phase-2	Gas (PDB)	2x35+1x35	104	90	0	0	20	20	90	Under maint.		
85	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	50	52	52	52				
86	Kushnara 163 MW CCGP (KP)	Gas (IPP)	1x109+1x54	163	163	112	112	112	112				
87	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8				
88	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	58	57	60	60				
89	Shahjibazar 330 MW CCGP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0	330	Under maint.		
90	Sylhet 225 MW CCGP	Gas (PDB)	1x142+1x89	231	231	130	131	150	150				
91	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0				
92	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	24	24	25	25				
93	Bibiana-II 341 MW CCGP (Summit)	Gas (IPP)	1x222+1x119	341	341	310	280	300	300				
94	Bibiyana-III 400 MW CCGP	Gas (PDB)	1x285+1x115	400	400	378	367	400	400				
95	Bibiyana South 383 MW CCGP	Gas (PDB)	1x252+1x131	383	383	345	340	340	360				
96	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0			Test run	
97	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	39	39	40	40				
Sylhet Zone Total					2376	2331	1496	1450	1550	1570	0	450	
98	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
99	Bheramara 410 MW CCGP	Gas (NWPGL)	1 x 278+1 x 132	410	410	355	345	400	400				
100	Fardpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	34	0	42				
101	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	40	44	62				
102	Khulna 225 MW CCGP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0				
103	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	73	90	90				
104	Machumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	0				
105	Monira Orion 100 MW Solar PP	Solar (IPP)		100	100	103	0	100	0				
106	Maitree Super Thermal 1320 MW PP	Coal (BIFPCL)	2x617	1234	1234	379	511	500	500				
107	Khulna 330 MW CCGP	Gas/HSD (BIFPCL)	1x220+1x116	336	336	0	0	0	0				
108	Ncopara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5x8.5	0	0	0	0	0	0				
109	Khulna 115 PP MW (KPCL-2)	HFO (NENP)	7x17	0	0	0	30	0	0				
**	Bheramara (HVDC)	India		1000	1000	912	913	935	625				
Khulna Zone Total					3703	3699	1766	1954	2069	1719	0	0	
108	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	48	110				
109	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	10	6	10	10	10				
110	Bhola 225 MW CCGP	Gas (PDB)	2x63+1x68	194	194	65	65	130	130	129	ST under maint.		
111	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	900	1080	1244	1244				
112	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	22	17	35				
113	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	240	260	150	200				
114	Bhola 220MW CCGP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	220	220				
Barishal Zone Total					2265	2235	1431	1657	1819	1949	0	129	
115	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71	Gas Shortage		
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100	Under maint.		
116	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	33	0	33				
117	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	5	0	25				
118	Chapanawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	89	0	90				
119	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	35	42	42				
120	Katakali 50 MW PP (Northern)	HFO (NENP)	6x8.9	50	50	0	8	34	34				
121	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	26	0	28				
122	Sirajgonj 225MW CCGP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210	Gas Shortage		
123	Sirajgonj 225MW CCGP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	186	187	200	200				
124	Sirajgonj 225MW CCGP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	199	185	200	200				
125	Sirajgonj 400 MW CCGP Unit-4	Gas (IPP)	1x282+1x132	414	414	414	270	400	414				
126	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	5	8	11	11				
127	Natore 52 MW PP (Rajjanka)	HFO (IPP)	6x8.92	52	52	0	8	8	8				
128	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	35	113	113				
129	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	35	35	113				
130	Ammura 50 MW PP (Sinha)	HFO (NENP)	7x7.79	50	28	0	0	0	28				
131	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0				
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	658	726	748	748				
Raishahi Zone Total					3453	3431	1467	1650	1797	2087	281	100	
132	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	69	70	70	70				
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Under Overhauling		
133	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	230	230	230	230				
134	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
135	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x.2*3	113	113	40	91	42	100				
136	Sardpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
137	Majpara Talsia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0				
138	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	35	112	35	115				
139	Lalmonirhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	30	0	30	0				
140	Teesa Solar Limited	Solar (IPP)	1 x 200	200	200	161	0	130	0				
Rangpur Zone Total					1030	950	572	503	545	515	0	85	
Sub-total: Plants in operation					26354	25903	12870.0	15019	16244	16954	1181	1939	
(B) Plants under long term maintenance/ contract expired													
141	Katobdi 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			Contract Expired	
142	Haripur 360MW CCGP(HPL)	Gas (IPP)	1x235+1x125	360	0	0	0	0	0			Contract Expired	
143	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			Contract Expired	
144	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	0	0	0	0	0			Contract Expired	
145	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Contract Expired	
Sub-Total: Plants under long term maintenance/ contract expired					700	0	0	0	0	0	0	0	
Gross Total					27054	25903	12870	15019	16244	16954	1181	1939	
(C) Actual data of 13.05.24 (Yesterday) Monday :													
01.	Max. Demand at eve. peak (Generation end)	:	15150 MW, at =	19:30 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	14479 MW, at =	19:30 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW	
03.	Highest Generation (Generation end)	:	15019 MW, at =	19:30 hrs	Dhaka	5191	5191	0	Mymensingh	1175	1095	80	
04.	Minimum Generation (Generation end)	:	10826 MW, at =	6:00 hrs	Chattogram	1408	1408	0	Sylhet	623	623	0	
05.	Day-peak Generation (Generation end)	:	12870 MW, at =	12:00 hrs	Khulna	1733	1733	0	Barishal	433	433	0	
06.	Evening-peak Generation (Generation end)	:	15019 MW, at =	19:30 hrs	Rajshahi	1541	1541	0	Rangpur	1033	1008	25	
07.	Evening Peak Load-shed (Sub-station end)	:	125 MW, at =	19:30 hrs	Cumilla	1342	1322	20					
08.	Minimum Generation Forecast up to 8:00 hrs.	:	12270 MW, at =	5:00 hrs					Total	14479	14354	125	
09.	Generation shortfall at evening peak due to :	:			13.	Fuel cost :							
a)	Gas/LF limitation	:	981 MW			a) Gas =	478434167 Taka		(c) Coal =	541483068 Taka			
d)	Coal supply Limitation	:	0 MW			b) Oil =	729396174 Taka		Total =	1749313409 Taka			
b)	Low water level in Kaptai lake	:	200 MW										
c)	Plants under shut down/ maintenance	:	1939 MW		14.	Maximum Temperature in Dhaka was :						34.0°C	
10.	Total Energy (Generation + India Import)	:	312.64 MKWh		15.	Export through East-West interconnections :							
	By Gas = 166.287 MKWh		By Oil = 40.131 MKWh			At evening peak-hour		:	12870 MW, at	19:30 hrs			
	By Coal = 79.675 MKWh		By Hydro = 0.676 MKWh			Maximum		:	148 MW, at	19:30 hrs			
	By Solar = 3.317 MKWh					Energy		:	3535.95 MKWh				
11.	Total Gas Supplied	:	1232.08 MCF										
(D) Forecast of 14.05.24 (Today) Tuesday :													
01.	Maximum Demand	:	16000 MW	(Generation end)	04.	Maximum Load-shed						0	
02.	Maximum Generation	:	16954 MW	(Generation end)	05.	Total Generation						333.07 MKWh	
03.	Reserve / Shortage	:	954 MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :						34.0°C	

#Remarks: Highest Generation 16477 MW on 30-04-2024 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation