

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month May, 2024				Day : Tuesday				Date : 21.05.24				
Probable Maximum Demand : 14600 MW				Probable Maximum Generation : 17069 MW								
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 72.66 ft				Today = 72.50 ft				
				Rule Curve = 78.00 ft								
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	20.05.24 (Yesterday)		21.05.24 (Today)		20.05.24 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)		Description/ Remarks
(A) Plants in operation:												
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		Under project work	
2	a) Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180			
3	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365	Awaiting for HGPI
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	12	12	12	12	96	Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105	Under maint.
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450			
8	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling
9	Haripur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	400	403	411	400	412			
10	Siddhirgonj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage
11	Siddhirgonj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	324	326	310	335			
12	Meghnaghat 335MW CCGP(Summit)	Gas (IPP)	2x110+1x110	335	335	320	302	310	310		33	Under maint.
13	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	55	30	55			
14	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	40	50	90	90			
15	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	0	0			
16	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+1x7.73	80	80	41	41	42	43			
17	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33			
18	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	30	32	33	33			
19	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	8	8	8			
20	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	50	17	52			
21	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	16	150	32	150			
22	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	17	54	54			
23	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	37	0	300	300			
24	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	6x18.415+1x8.97	149	149	133	80	70	149			
25	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	55	55	55	55			
26	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55			
27	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	53	70	53	72			
28	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	54	162	162			
29	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	11	0	35	0			
30	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	35	17	35			
31	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	0	0	15			
32	Unique Meghnaghat 584MW CCGP	Gas	1x400+1x184	584	400	400	420	350	420			
	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	0	0	0	50	85	90			
	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	0	0	0	63	80	80			
	Meghnaghat 100 MW(IEL)	HFO (NENP)	12x8.9	0	0	0	50	90	100			
	Meghnaghat 589 MW CCGP(Summit)	Gas				300	350	250	350			Test run
Dhaka Zone Total				5526	5332	3004	3399	3603	4100	486	878	
33	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	30	25	25	25	205		Inadequate Water Level
34	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	110	110	105	110			
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.
35	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	5	0	5	0			
36	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	8	8	25			
37	Teknaf 20MW PP (Solaritech)	Solar (IPP)	1x20	20	20	19	0	20	0			
38	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	14	6	20			
39	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	34	51	17	51			
40	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.
41	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	214	211	210	210			
42	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.94	300	300	52	51	52	52			
43	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	49	62	49	62			
44	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	68	85	51	85			
45	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	41	64	55	64			
46	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	13	13	13	13			
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			0	20	10	20			
47	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	45	58	45	100			
48	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	10	0	34	36			
49	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	51	68	51	72			
50	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	48	60	48	60			
51	Juldah 100 MW Unit-1 (Acorn)	HFO (NENP)	8x13.45	100	100	0	12	80	80			
52	Chattogram 116 MW PP (Anlima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	34	35	35	35			
53	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	17	17	54	163			
54	Chattogram 2*612MW Coal Based PP (SS Power)	Coal (IPP)	2x612	1224	1224	490	490	490	490			
55	Matarbari 2*600 MW (CPGCL)	Coal (CPGCL)	1x575	575	575	253	306	575	575			
56	Cox's Bazar Wind PP	(Wind) (IPP)		60	60	0	7	40	40			
	Sonagazi 75 MW Solar Plant	(Solar) (EGCB)				71	0	33	0			
Chattogram Zone Total				4464	4404	1660	1767	2111	2388	205	330	
57	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	30	36	35	36			
58	Ashuganj 225 MW CCGP	Gas (APSCCL)	1x142+1*75	221	221	187	199	200	220			
59	Ashuganj 450 MW CCGP(South)	Gas (APSCCL)	1x360	360	360	300	280	270	280	80		Gas Shortage
60	Ashuganj 450 MW CCGP(North)	Gas (APSCCL)	1x361	360	360	305	290	300	300			
61	Ashuganj 420 MW CCGP(East)	Gas (APSCCL)	1x284+1x116	400	400	195	230	320	320	170		Gas Shortage
62	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*16	195	195	112	8	8	8	187		Gas Shortage
63	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	43	43	43			
64	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	28	85	70	135			
65	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	38	47	39	47			
66	Chandpur 150 MW CCGP	Gas (PDB)	1X106+1x57	163	163	80	85	80	85	78		Gas Shortage
67	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	68	17	17			
68	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0			
69	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	32	32	32	32			
70	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	8	34	52			
71	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	11	17	20	20			
72	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	52	52	55	80			
73	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	65	46	55	85			
74	Bharob 54 MW PP	HFO (IPP)	3x18.2	54	54	16	17	50	50			
75	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x5.428	115	115	113	70	115	115			
76	Ashuganj 55 MW PP (Precision)	Gas (NENP)	15*4	55	55	50	50	50	55			
**	Impoprt (Tripura)	India		160	160	106	92	146	151			
Cumilla Zone Total				2937	2929	1788	1755	1939	2131	515	0	
77	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	64	70	80	80	132		Gas Shortage
78	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	49	98	57	100			
79	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	62	105	58	105			
80	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0			
81	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	36	0	50	0			
82	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	6	3	6	6			
Mymensingh Zone Total				600	592	218	276	253	291	132	0	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	20.05.24 (Yesterday)		21.05.24 (Today)		20.05.24 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)			
83	Fenchugonj CCGP Phase-1	Gas (PDB)	2x32+1x33	97	70	40	40	40	40	30	Under maint.		
84	Fenchugonj CCGP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	60	60	60	30	Under maint.		
85	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	46	49	50	50				
86	Kushiana 163 MW CCGP (KP)	Gas (IPP)	1x109+1x54	163	163	112	112	112	112				
87	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	5	5	5				
88	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	58	50	60	60				
89	Shahjibazar 330 MW CCGP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0	330	Under maint.		
90	Sylhet 225 MW CCGP	Gas (PDB)	1x142+1x89	231	231	205	201	204	204				
91	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0				
92	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	24	24	23	24				
93	Bibiana-II 341 MW CCGP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	300	300	300				
94	Bibiyana-III 400 MW CCGP	Gas (PDB)	1x285+1x115	400	400	365	373	400	400				
95	Bibiyana South 383 MW CCGP	Gas (PDB)	1x252+1x131	383	383	340	350	340	360				
96	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		Test run		
97	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3+5*2	50	50	37	37	34	37				
Sylhet Zone Total					2376	2331	1552	1601	1628	1652	0	390	
98	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
99	Bheramara 410 MW CCGP	Gas (NWPGL)	1 x 278+1 x 132	410	410	340	355	350	350				
100	Fardpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	42				
101	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	44	62				
102	Khulna 225 MW CCGP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0				
103	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	17	90	90				
104	Machumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	34	85	0	100				
105	Monira Orion 100 MW Solar PP	Solar (IPP)		100	100	55	0	100	0				
106	Maitree Super Thermal 1320 MW PP	Coal (BIFCL)	2x617	1234	1234	380	358	400	500				
107	Khulna 330 MW CCGP	Gas/HSD (BIFCL)	1x220+1x116	336	336	0	0	0	0				
108	Ncopara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5x8.5	0	0	0	0	0	0				
109	Khulna 115 PP MW (KPCL-2)	HFO (NENP)	7x17	0	0	0	0	0	20				
**	Bheramara (HVDC)	India		1000	1000	926	925	945	655				
Khulna Zone Total					3703	3699	1735	1740	1929	1819	0	0	
108	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	16	48	110				
109	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	10	5	9	10	10				
110	Bhola 225 MW CCGP	Gas (PDB)	2x63+1x68	194	194	130	134	90	130	60	ST under maint.		
111	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	540	760	1244	1244				
112	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	17	17				
113	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	180	250	200	307				
114	Bhola 220MW CCGP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	220	220				
Barishal Zone Total					2265	2235	1075	1389	1829	2038	0	60	
115	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	50	50	50	50	21	Gas Shortage		
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100	Under maint.		
116	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	42	40	42				
117	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	25				
118	Chapanawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	89	0	90				
119	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	30	42	42				
120	Katakali 50 MW PP (Northern)	HFO (NENP)	6x8.9	50	50	0	0	34	34				
121	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	30	0	30				
122	Sirajgonj 225MW CCGP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210	Gas Shortage		
123	Sirajgonj 225MW CCGP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	177	188	180	180		Gas Shortage		
124	Sirajgonj 225MW CCGP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	186	188	180	190		Gas Shortage		
125	Sirajgonj 400 MW CCGP Unit-4	Gas (IPP)	1x282+1x132	414	414	414	414	310	414		Gas Shortage		
126	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	2	5	11	11				
127	Natore 52 MW PP (Rajjanka)	HFO (IPP)	6x8.92	52	52	0	0	0	0				
128	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	0	70	113				
129	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	0	35	113				
130	Ammura 50 MW PP (Sinha)	HFO (NENP)	7x7.79	50	28	0	0	0	28				
131	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	0	0	6	0				
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	625	768	760	760				
Raishahi Zone Total					3453	3431	1454	1804	1718	2122	231	100	
132	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	70	70	62	70				
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Under Overhauling		
133	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	230	230	230	230				
134	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
135	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x.2*3	113	113	0	98	35	113				
136	Sardpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
137	Majpara Tabilis 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	3	0	8	0				
138	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	90	115	115				
139	Lalmonirhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	8	0	30	0				
140	Teesa Solar Limited	Solar (IPP)	1 x 200	200	200	114	0	130	0				
Rangpur Zone Total					1030	950	425	488	610	528	0	85	
Sub-total: Plants in operation					26354	25903	12911.0	14219	15620	17069	1569	1843	
(B) Plants under long term maintenance/ contract expired													
141	Katobdi 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0		Contract Expired		
142	Haripur 360MW CCGP(HPL)	Gas (IPP)	1x235+1x125	360	0	0	0	0	0		Contract Expired		
143	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0		Contract Expired		
144	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	0	0	0	0	0		Contract Expired		
145	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0		Contract Expired		
Sub-Total: Plants under long term maintenance/ contract expired					700	0	0	0	0	0	0	0	
Gross Total					27054	25903	12911	14219	15620	17069	1569	1843	
(C) Actual data of 20.05.24 (Yesterday) Monday :													
01.	Max. Demand at eve. peak (Generation end)	:	14376	MW, at =	19:30 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	13767	MW, at =	19:30 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	14219	MW, at =	19:30 hrs	Dhaka	5110	5010	100	Mymensingh	1138	1088	50
04.	Minimum Generation (Generation end)	:	10691	MW, at =	6:00 hrs	Chattogram	1418	1418	0	Sylhet	615	615	0
05.	Day-peak Generation (Generation end)	:	12911	MW, at =	12:00 hrs	Khulna	1551	1551	0	Barishal	349	349	0
06.	Evening-peak Generation (Generation end)	:	14219	MW, at =	19:30 hrs	Rajshahi	1467	1467	0	Rangpur	902	902	0
07.	Evening Peak Load-shed (Sub-station end)	:	150	MW, at =	19:30 hrs	Cumilla	1216	1216	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	11354	MW, at =	5:00 hrs	13. Fuel cost : (a) Gas = 483364603 Taka (c) Coal = 51984514 Taka (b) Oil = 560808841 Taka Total = 1563157958 Taka							
09.	Generation shortfall at evening peak due to :	:				14. Maximum Temperature in Dhaka was : 33.4°C							
	a) Gas/LF limitation	:	1364	MW		15. Export through East-West interconnections :							
	d) Coal supply Limitation	:	0	MW		At evening peak-hour : 12911 MW, at 19:30 hrs							
	b) Low water level in Kaptai lake	:	205	MW		Maximum : 316 MW, at 21:00 hrs							
	c) Plants under shut down/ maintenance	:	1843	MW		Energy : 6284.85 MKWh							
10.	Total Energy (Generation + India Import)	:	303.05	MKWh		11. Total Gas Supplied : 1278.09 MMCFD							
	By Gas = 170.781 MKWh			By Oil = 31.265 MKWh									
	By Coal = 75.265 MKWh			By Hydro = 0.670 MKWh									
	By Solar = 2.477 MKWh												
(D) Forecast of 21.05.24 (Today) Tuesday :													
01.	Maximum Demand	:	14600	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	17069	MW	(Generation end)	05.	Total Generation	:	311.17	MKWh			
03.	Reserve / Shortage	:	2469	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	35.4°C				

#Remarks: Highest Generation 16477 MW on 30-04-2024 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation