

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month May, 2024				Day : Saturday				Date : 25.05.24				
Probable Maximum Demand : 16300 MW				Probable Maximum Generation : 17239 MW								
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 71.99 ft				Today = 71.78 ft				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	24.05.24 (Yesterday)		25.05.24 (Today)		24.05.24 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
					Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation (MW)	Machines shut down (MW)		Description/ Remarks
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180			
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365	Awaiting for HGPI
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	3x43.35	108	108	12	12	12	12	96	Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105	Under maint.
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450			
8	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling
9	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	400	394	397	400	400			
10	Siddhirgonj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage	
11	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	301	306	310	335			
12	Meghnaghat 335MW CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	304	305	310	310			
13	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	40	40	40	55			
14	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	90	90	90	90			
15	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	0	0			
16	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+1x7.73	80	80	41	45	43	43			
17	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	33	33			
18	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	29	28	33	33			
19	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	8	8	8			
20	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	105	17	105			
21	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	32	149	48	150			
22	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	30	54	54	54			
23	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	45	300	300			
24	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	6x18.415+1x8.97	149	149	149	149	149	149			
25	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	40	55	55	55			
26	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55			
27	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	19	70	53	72			
28	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	162	144	162	162			
29	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	31	0	35	0			
30	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	35	17	35			
31	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	13	0	15			
32	Unique Meghnaghat 584MW CCPP	Gas	1x400+1x184	584	500	500	570	400	500			
	Siddhirgonj 100 MW PP (Dutch Bangla)	HFO (NENP)	12x8.9	0	0	16	83	85	90			
	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	0	0	51	80	80	80			
	Meghnaghat 100 MW (IEL)	HFO (NENP)	12x8.9	0	0	15	80	80	90			
	Meghnaghat 589 MW CCPP(Summit)	Gas				500	540	400	500			Test run
Dhaka Zone Total				5526	5332	3508	4113	3899	4361	486	845	
33	Karnaphuli Hydro PP Unit-1,2,3,4,5	Hydro (PDB)	2x40, 3x50	230	230	30	30	30	30	200		Inadequate Water Level
34	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	108	100	0	0			
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
35	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	5	0	5	0			
36	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	25	8	25			
37	Teknaf 20MW PP (Solaritech)	Solar (IPP)	1x20	20	20	17	0	20	0			
38	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	6	6	20			
39	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	20	51	34	51			
40	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
41	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	140	150	150			
42	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.94	300	300	49	52	52	52			
43	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	49	62	49	62			
44	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	17	51	51	85			
45	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	24	62	55	64			
46	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0			
	* Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			15	33	20	33			
47	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	12	46	45	60			
48	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	17	35	35			
49	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	24	68	51	110			
50	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	48	60	48	60			
51	Juldah 100 MW Unit-1 (Acorn)	HFO (NENP)	8x13.45	100	100	12	12	70	70			
52	Chattogram 116 MW PP (Anlima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	23	53	35	53			
53	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	54	35	54	163			
54	Chattogram 2*612MW Coal Based PP (SS Power)	Coal (IPP)	2x612	1224	1224	482	455	490	490			
55	Matarbari 2*600 MW (CPGCL)	Coal (CPGCL)	1x575	575	575	233	233	575	575			
56	Cox's Bazar Wind PP	(Wind) (IPP)		60	60	11	0	40	40			
	Sonagazi 75 MW Solar Plant	(Solar) (EGCB)				71	0	40	0			
Chattogram Zone Total				4464	4404	1310	1591	1963	2228	200	330	
57	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	32	34	35	36			
58	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	208	211	210	220			
59	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	250	280	270	280	80	Gas Shortage	
60	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	325	280	300	300	80	Gas Shortage	
61	Ashuganj 420 MW CCPP(East)	Gas (APSCL)	1x284+1x116	400	400	260	285	250	280	115	Gas Shortage	
62	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	0	0	0	0	195	Gas Shortage	
63	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	43	0	0			
64	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	12	62	12	50			
65	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	44	39	40			
66	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	50	50	163	Gas Shortage	
67	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	103	155	100	200			
68	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0			
69	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	21	29	32	32			
70	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	14	51	25	52			
71	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	11	11	20	20			
72	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	52	97	52	114			
73	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	36	74	36	75			
74	Bharob 54 MW PP	HFO (IPP)	3x18.2	54	54	17	34	50	50			
75	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x5.428	115	115	63	109	115	115			
76	Ashuganj 55 MW PP (Precision)	Gas (NENP)	15*4	55	55	47	48	50	50			
**	Impoport (Tripura)	India		160	160	76	84	146	151			
Cumilla Zone Total				2937	2929	1570	1931	1792	2115	633	0	
77	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	44	79	45	80	123	Gas Shortage	
78	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	48	98	57	100			
79	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	57	105	58	105			
80	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
81	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	35	0	50	0			
82	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	12	12	12	12			
Mymensingh Zone Total				600	592	198	294	224	297	123	0	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	24.05.24 (Yesterday)		25.05.24 (Today)		24.05.24 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)			
83	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	38	39	42	42		31	Under maint.	
84	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	48	58	60	60		32	Under maint.	
85	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	49	0	50	50				
86	Kushiana 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	112	0	0				
87	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	5	5	5				
88	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	53	58	60	60				
89	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
90	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	198	200	204	204				
91	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0				
92	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	23	24	24				
93	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	315	315	300	300				
94	Bibiyana-II 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	401	367	400	400				
95	Bibiyana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	360	340	345	360				
96	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0			Test run	
97	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3+5*2	50	50	39	42	42	42				
Sylhet Zone Total					2376	2331	1634	1559	1532	1547	0	393	
98	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
99	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0				
100	Fardpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	30	42				
101	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	50	60				
102	Khulna 225 MW CAPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0				
103	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	35	53	90				
104	Machumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	100				
105	Monira Orion 100 MW Solar PP	Solar (IPP)	100	100	100	99	0	100	0				
106	Maitree Super Thermal 1320 MW PP	Coal (BIFPCL)	2x617	1234	1234	402	413	620	620				
107	Khulna 330 MW CAPP	Gas/HSD (BIFPCL)	1x220+1x116	336	336	0	0	0	0				
108	Ncopara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5x8.5	0	0	0	32	0	32				
109	Khulna 115 PP MW (KPCL-2)	HFO (NENP)	7x17	0	0	0	0	20	20				
**	Bheramara (HVDC)	India	1000	1000	925	642	944	944	655				
Khulna Zone Total					3703	3699	1426	1122	1617	1619	0	0	
108	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110				
109	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	10	8	10	10	10				
110	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	120	126	90	130		68	ST under maint.	
111	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	920	1244	1244	1244				
112	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	17	17				
113	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	250	307	250	307				
114	Bhola 220MW CAPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	220	220				
Barishal Zone Total					2265	2235	1518	1907	1941	2038	0	68	
115	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	50	50	0	0	21		Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.	
116	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	32	40	40				
117	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	25				
118	Chapanawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	90	0	90				
119	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	43	42	42				
120	Katakali 50 MW PP (Northern)	HFO (NENP)	6x8.9	50	50	0	0	0	0				
121	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	22	0	30				
122	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage	
123	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	198	199	0	0				
124	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	200	198	180	190				
125	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	414	384	350	414				
126	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	2	8	11	11				
127	Natore 52 MW PP (Rajjanka)	HFO (IPP)	6x8.92	52	52	0	0	0	0				
128	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	75	50	113				
129	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	70	50	113				
130	Amnura 50 MW PP (Sinha)	HFO (NENP)	7x7.79	50	28	0	0	14	28				
131	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0				
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	826	1425	1425	1425				
Raishahi Zone Total					3453	3431	1695	2596	2168	2521	231	100	
132	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	65	64	65	65				
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
133	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	220	210	220	220				
134	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
135	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x.2*3	113	113	34	99	50	113				
136	Sardpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
137	Majpara Tabilis 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0				
138	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	35	115	115	115				
139	Lalmonirhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	34	0	30	0				
140	Teesa Solar Limited	Solar (IPP)	1 x 200	200	200	200	0	130	0				
Rangpur Zone Total					1030	950	595	488	618	513	0	85	
Sub-total: Plants in operation					26354	25903	13454.0	15601	15954	17239	1673	1821	
(B) Plants under long term maintenance/ contract expired													
141	Katobdi 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			Contract Expired	
142	Haripur 360MW CAPP(HPL)	Gas (IPP)	1x235+1x125	360	0	0	0	0	0			Contract Expired	
143	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			Contract Expired	
144	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	0	0	0	0	0			Contract Expired	
145	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Contract Expired	
Sub-Total: Plants under long term maintenance/ contract expired					700	0	0	0	0	0	0	0	
Gross Total					27054	25903	13454	15601	15954	17239	1673	1821	
(C) Actual data of 24.05.24 (Yesterday) Friday :													
01.	Max. Demand at eve. peak (Generation end)	: 15850 MW, at = 21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :										
02.	Max. Demand at eve. peak (Sub-station end)	: 15112 MW, at = 21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW			
03.	Highest Generation (Generation end)	: 15601 MW, at = 21:00 hrs	Dhaka	5245	5245	0	Mymensingh	1288	1143	145			
04.	Minimum Generation (Generation end)	: 11731 MW, at = 9:00 hrs	Chattogram	1388	1388	0		658	640	18			
05.	Day-peak Generation (Generation end)	: 13454 MW, at = 12:00 hrs	Khulna	1896	1896	0	Barishal	487	487	0			
06.	Evening-peak Generation (Generation end)	: 15601 MW, at = 21:00 hrs	Rajshahi	1598	1598	0	Rangpur	1000	960	40			
07.	Evening Peak Load-shed (Sub-station end)	: 238 MW, at = 21:00 hrs	Cumilla	1552	1517	35							
08.	Minimum Generation Forecast up to 8:00 hrs.	: 12955 MW, at = 5:00 hrs	13. Fuel cost : (a) Gas = 440154210 Taka (c) Coal = 634794681 Taka (b) Oil = 1050295484 Taka Total = 2125244375 Taka										
09.	Generation shortfall at evening peak due to :		14. Maximum Temperature in Dhaka was : 38.9°C										
	a) Gas/LF limitation	: 1473 MW	15. Export through East-West interconnections :										
	d) Coal supply Limitation	: 0 MW	At evening peak-hour : 13454 MW, at 21:00 hrs										
	b) Low water level in Kaptai lake	: 200 MW	Maximum : 248 MW, at 1:00 hrs										
	c) Plants under shut down/ maintenance	: 1821 MW	Energy : 2595.45 MKWh										
10.	Total Energy (Generation + India Import)	: 337.33 MKWh	By Gas = 160.697 MKWh By Oil = 57.601 MKWh										
			By Coal = 92.134 MKWh By Hydro = 0.672 MKWh										
			By Solar = 3.959 MKWh										
11.	Total Gas Supplied	: 1125.41 MMCFD											
(D) Forecast of 25.05.24 (Today) Saturday :													
01.	Maximum Demand	: 16300 MW (Generation end)	04. Maximum Load-shed : 0 MW At evening peak (Sub-station end)										
02.	Maximum Generation	: 17239 MW (Generation end)	05. Total Generation : 352.44 MKWh										
03.	Reserve / Shortage	: 939 MW (Generation end)	06. Probable Max. Temperature in Dhaka : 38.9°C										

#Remarks: Highest Generation 16477 MW on 30-04-2024 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation