

**Bangladesh Power Development Board**  
**DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation  
Tel : 9564667, 9551095

Month May, 2024				Day : Sunday				Date : 26.05.24				
Probable Maximum Demand : 15000 MW				Probable Maximum Generation : 15838 MW								
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 71.78 ft				Today = 71.68 ft				
				Rule Curve = 77.20 ft								
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	25.05.24 (Yesterday)		26.05.24 (Today)		25.05.24 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
					Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation MW	Machines shut down (MW)		Description/ Remarks
<b>(A) Plants in operation:</b>												
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		Under project work	
2	a) Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180			
3	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365	Awaiting for HGPI
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	12	0	0	0	108	Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105	Under maint.
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	400	450	450			
8	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling
9	Haripur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	400	396	396	400	400			
10	Siddhirgonj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage	
11	Siddhirgonj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	286	286	150	300			
12	Meghnaghat 335MW CCGP(Summit)	Gas (IPP)	2x110+1x110	335	335	306	300	310	310			
13	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	25	40	55	55			
14	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	40	90	90	90			
15	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	0	0			
16	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+1x7.73	80	80	43	40	43	43			
17	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	29	33	33			
18	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	26	14	33	33			
19	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	8	8	8			
20	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	50	52	17	50			
21	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	32	149	48	150			
22	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	21	54	54	54			
23	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	300	195	300	300			
24	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	6x18.415+1x8.97	149	149	149	99	115	149			
25	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	55	55	55	55			
26	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55			
27	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	70	70	53	72			
28	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	162	162	162	162			
29	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	31	0	35	0			
30	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	0	17	35			
31	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	10	0	15			
32	Unique Meghnaghat 584MW CCGP	Gas	1x400+1x184	584	584	0	0	0	0	584	Gas Shortage	
	Siddhirgonj 100 MW PP (Dutch Bangla)	HFO (NENP)	12x8.9	0	0	10	70	85	90			
	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	0	0	2	80	80	80			
	Meghnaghat 100 MW(HEL)	HFO (NENP)	12x8.9	0	0	4	93	90	90			
	Meghnaghat 589 MW CCGP(Summit)	Gas		0	0	0	0	0	0		Gas Shortage	
<b>Dhaka Zone Total</b>				<b>5526</b>	<b>5332</b>	<b>2755</b>	<b>2927</b>	<b>2918</b>	<b>3259</b>	<b>1082</b>	<b>845</b>	
33	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	30	30	30	30	200	Inadequate Water Level	
34	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0			
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.
35	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	4	0	5	0	0			
36	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	25	8	25			
37	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	20	0	20	0			
38	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	19	6	20			
39	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	51	51	34	51			
40	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.
41	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	143	137	150	150			
42	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.94	300	300	52	52	52	52			
43	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	48	62	49	62			
44	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	17	85	51	85			
45	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	53	72	55	64			
46	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0			
	* Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			2	12	10	20			
47	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	44	45	45	60			
48	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	35	35	35	35			
49	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	76	110	51	110			
50	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	48	60	48	60			
51	Juldah 100 MW Unit-1 (Acom)	HFO (NENP)	8x13.45	100	100	58	69	70	70			
52	Chattogram 116 MW PP (Anlima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	35	50	35	53			
53	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	35	163	54	163			
54	Chattogram 2162MW Coal Based PP (SS Power)	Coal (IPP)	2x612	1224	1224	410	488	490	490			
55	Matarbari 2160 MW (CPGCL)	Coal (CPGCL)	1x575	575	575	506	526	575	575			
56	Cox's Bazar Wind PP	(Wind) (IPP)		60	60	8	47	40	40			
	Sonagazi 75 MW Solar Plant	(Solar) (EGCB)				72	0	70	0			
<b>Chattogram Zone Total</b>				<b>4464</b>	<b>4404</b>	<b>1753</b>	<b>2138</b>	<b>1983</b>	<b>2215</b>	<b>200</b>	<b>330</b>	
57	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	33	33	35	36			
58	Ashuganj 225 MW CCGP	Gas (APSCL)	1x142+1175	221	221	200	214	210	220			
59	Ashuganj 450 MW CCGP(South)	Gas (APSCL)	1x360	360	360	270	265	270	280		95	Gas Shortage
60	Ashuganj 450 MW CCGP(North)	Gas (APSCL)	1x361	360	360	50	0	0	0		360	Gas Shortage
61	Ashuganj 420 MW CCGP(East)	Gas (APSCL)	1x284+1x116	400	400	260	280	250	280		120	Gas Shortage
62	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	0	0		187	Gas Shortage
63	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	0	0	0	0			
64	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	10	35	12	50			
65	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	36	43	39	40			
66	Chandpur 150 MW CCGP	Gas (PDB)	1X106+1x57	163	163	75	70	50	50		93	Gas Shortage
67	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	100	136	100	155			
68	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0			
69	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	31	31	32	32			
70	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	20	46	25	52			
71	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	17	10	20	20			
72	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	52	97	52	114			
73	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	45	73	36	75			
74	Bharob 54 MW PP	HFO (IPP)	3x18.2	54	54	17	0	50	50			
75	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x5.428	115	115	54	83	115	115			
76	Ashuganj 55 MW PP (Precision)	Gas (NENP)	15*4	55	55	43	41	50	50			
**	Impoport (Tripura)	India		160	160	78	82	146	151			
<b>Cumilla Zone Total</b>				<b>2937</b>	<b>2929</b>	<b>1399</b>	<b>1547</b>	<b>1492</b>	<b>1770</b>	<b>855</b>	<b>0</b>	
77	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	66	58	45	80	144	Gas Shortage	
78	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	47	97	57	100			
79	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	57	107	58	105			
80	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	0	0	1.6	0			
81	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	51	0	50	0			
82	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	12	12	12	12			
<b>Mymensingh Zone Total</b>				<b>600</b>	<b>592</b>	<b>233</b>	<b>274</b>	<b>224</b>	<b>297</b>	<b>144</b>	<b>0</b>	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	25.05.24 (Yesterday)		26.05.24 (Today)		25.05.24 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)			
83	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	38	40	42	42		30	Under maint.	
84	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	58	56	60	60		34	Under maint.	
85	Fenchugonj 51 MW PP (Barakattallah)	Gas (RPP)	19x2.90	51	51	44	49	50	50				
86	Kushiana 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0				
87	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	2	0	5	5				
88	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	54	60	60	60				
89	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
90	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	197	200	204	204				
91	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0				
92	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	19	16	24	24				
93	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	270	300	300				
94	Bibiana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	368	352	400	400				
95	Bibiyana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	360	385	345	360				
96	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0			Test run	
97	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	38	38	42	42				
<b>Sylhet Zone Total</b>					<b>2376</b>	<b>2331</b>	<b>1478</b>	<b>1466</b>	<b>1532</b>	<b>1547</b>	<b>0</b>	<b>394</b>	
98	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
99	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0		410	Gas Shortage	
100	Fardpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	30	33	30	42				
101	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	40	45	50	60				
102	Khulna 225 MW CAPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0				
103	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	73	90	53	90				
104	Machumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	15	85	15	100				
105	Monira Orion 100 MW Solar PP	Solar (IPP)		100	100	52	0	100	0				
106	Maitree Super Thermal 1320 MW PP	Coal (BIFCL)	2x617	1234	1234	580	600	620	620				
107	Khulna 330 MW CAPP	Gas/HSD (B/PDB)	1x220+1x116	336	336	0	0	0	0				
108	Ncopara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5x8.5	40	40	0	40	32	32				
109	Khulna 115 MW PP (KPCCL-2)	HFO (NENP)	7x17	0	0	0	85	20	85				
**	Bheramara (HVDC)	India		1000	1000	920	920	944	655				
<b>Khulna Zone Total</b>					<b>3703</b>	<b>3699</b>	<b>1710</b>	<b>1898</b>	<b>1864</b>	<b>1684</b>	<b>410</b>	<b>0</b>	
108	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	80	48	110	110				
109	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	10	8	2	10	10				
110	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	130	130	130	130		64	ST under maint.	
111	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	1140	870	1244	1244				
112	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	17	17	17				
113	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	307	276	250	307				
114	Bhola 220MW CAPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	220	220				
<b>Barishal Zone Total</b>					<b>2265</b>	<b>2235</b>	<b>1902</b>	<b>1563</b>	<b>1981</b>	<b>2038</b>	<b>0</b>	<b>64</b>	
115	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.	
116	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	32	40	40	40				
117	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	20	0	25				
118	Chapanawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	85	0	90				
119	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	21	35	42	42				
120	Katakali 50 MW PP (Northern)	HFO (NENP)	6x8.9	50	50	0	0	0	0				
121	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	30	0	30				
122	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0		210	Gas Shortage	
123	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0		220	Gas Shortage	
124	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	192	157	180	190				
125	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	414	370	350	414				
126	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	0	0	11	11				
127	Natore 52 MW PP (Rajanka)	HFO (IPP)	6x8.92	52	52	0	0	0	0				
128	Bagura 113 MW PP (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	113	50	113				
129	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	113	50	113				
130	Ammura 50 MW PP (Sinha)	HFO (NENP)	7x7.79	50	28	0	35	14	28				
131	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0				
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	1259	1319	1425	1425				
<b>Rajshahi Zone Total</b>					<b>3453</b>	<b>3431</b>	<b>1923</b>	<b>2317</b>	<b>2168</b>	<b>2521</b>	<b>501</b>	<b>100</b>	
132	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	62	64	65	65				
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
133	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	220	210	220	220				
134	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
135	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x.2*3	113	113	0	104	70	107				
136	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	8	0	0	0				
137	Majpara Talsia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	0	0	8	0				
138	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	41	115	115	115				
139	Lalmoinhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	31	0	30	0				
140	Teesa Solar Limited	Solar (IPP)	1 x 200	200	200	203	0	130	0				
<b>Rangpur Zone Total</b>					<b>1030</b>	<b>950</b>	<b>573</b>	<b>493</b>	<b>638</b>	<b>507</b>	<b>0</b>	<b>85</b>	
<b>Sub-total: Plants in operation</b>					<b>26354</b>	<b>25903</b>	<b>13726.0</b>	<b>14623</b>	<b>14800</b>	<b>15838</b>	<b>3192</b>	<b>1818</b>	
<b>(B) Plants under long term maintenance/ contract expired</b>													
141	Katobdi 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			Contract Expired	
142	Haripur 360MW CAPP(HPL)	Gas (IPP)	1x235+1x125	360	0	0	0	0	0			Contract Expired	
143	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			Contract Expired	
144	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	0	0	0	0	0			Contract Expired	
145	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Contract Expired	
<b>Sub-Total: Plants under long term maintenance/ contract expired</b>					<b>700</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	
<b>Gross Total</b>					<b>27054</b>	<b>25903</b>	<b>13726</b>	<b>14623</b>	<b>14800</b>	<b>15838</b>	<b>3192</b>	<b>1818</b>	
<b>(C) Actual data of 25.05.24 (Yesterday) Saturday :</b>													
01.	Max. Demand at eve. peak (Generation end)	: 14900 MW, at = 19:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :										
02.	Max. Demand at eve. peak (Sub-station end)	: 14471 MW, at = 19:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW			
03.	Highest Generation (Generation end)	: 14707 MW, at = 1:00 hrs	Dhaka	5944	5869	75	Mymensingh	1252	1062	190			
04.	Minimum Generation (Generation end)	: 12749 MW, at = 9:00 hrs	Chattogram	1423	1423	0	Sylhet	284	284	0			
05.	Day-peak Generation (Generation end)	: 13726 MW, at = 12:00 hrs	Khulna	1862	1862	0	Barishal	194	194	0			
06.	Evening-peak Generation (Generation end)	: 14623 MW, at = 19:00 hrs	Rajshahi	1441	1441	0	Rangpur	956	956	0			
07.	Evening Peak Load-shed (Sub-station end)	: 265 MW, at = 19:00 hrs	Cumilla	1116	1116	0							
08.	Minimum Generation Forecast up to 8:00 hrs.	: 12391 MW, at = 5:00 hrs											
09.	Generation shortfall at evening peak due to :	:											
a)	Gas/LF limitation	: 2992 MW	13. Fuel cost :		a) Gas = 383488311 Taka		Total		14471		14206		
b)	Coal supply Limitation	: 0 MW			b) Oil = 1338948457 Taka		Total =		2483715966		265		
c)	Low water level in Kaptai lake	: 200 MW											
d)	Plants under shut down/ maintenance	: 1818 MW											
10.	Total Energy (Generation + India Import)	: 337.88 MKWh	14. Maximum Temperature in Dhaka was : 38.8°C										
	By Gas = 125.966 MKWh	By Oil = 73.022 MKWh	15. Export through East-West interconnections :										
	By Coal = 111.680 MKWh	By Hydro = 0.723 MKWh	At evening peak-hour : 13726 MW, at 19:00 hrs										
	By Solar = 3.849 MKWh		Maximum : 244 MW, at 20:00 hrs										
11.	Total Gas Supplied	: 915.18 MMCFD	Energy : 5205.75 MKWh										
<b>(D) Forecast of 26.05.24 (Today) Sunday :</b>													
01.	Maximum Demand	: 15000 MW (Generation end)	04. Maximum Load-shed : 0 MW At evening peak (Sub-station end)										
02.	Maximum Generation	: 15838 MW (Generation end)	05. Total Generation : 344.61 MKWh										
03.	Reserve / Shortage	: 838 MW (Generation end)	06. Probable Max. Temperature in Dhaka : 38.9°C										

\* Captive Power \*\* Imported Power  
#Remarks: Highest Generation 16477 MW on 30-04-2024 at 21:00

(Md. Helalur Rahman)  
Deputy Secretary, Generation