

**Bangladesh Power Development Board**  
**DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation  
Tel : 9564667, 9551095

Month May, 2024				Day : Monday				Date : 27.05.24				
Probable Maximum Demand : 8500 MW				Probable Maximum Generation : 12772 MW								
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 71.68 ft				Today = 71.64 ft				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	26.05.24 (Yesterday)		27.05.24 (Today)		26.05.24 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)		Description/ Remarks
<b>(A) Plants in operation:</b>												
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		Under project work	
2	a) Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180			
3	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365	Awaiting for HGPI
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108	Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105	Under maint.
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	390	200	450			
8	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling
9	Haripur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	400	402	325	280	400			
10	Siddhirgonj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage	
11	Siddhirgonj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	45	318	0	0			
12	Meghnaghat 335MW CCGP(Summit)	Gas (IPP)	2x110+1x110	335	335	316	152	150	150			
13	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	55	55	55			
14	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	82	90	90	90			
15	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	0	0			
16	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x3.73	80	80	40	23	43	43			
17	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	10	33	33			
18	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	7	7	33	33			
19	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	8	8	8			
20	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	52	17	50			
21	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	16	150	48	150			
22	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54			
23	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	240	195	300	300			
24	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	6x18.415+1x8.97	149	149	115	79	115	149			
25	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	55	55	55	55			
26	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55			
27	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	64	70	53	72			
28	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	162	162	162	162			
29	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	27	0	35	0			
30	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	35	17	35			
31	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	24	0	15			
32	Unique Meghnaghat 584MW CCGP	Gas	1x400+1x184	584	584	0	0	0	0	584	Gas Shortage	
	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	0	0	70	40	85	90			
	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	0	0	34	17	80	80			
	Meghnaghat 100 MW(HEL)	HFO (NENP)	12x8.9	0	0	82	8	90	90			
	Meghnaghat 589 MW CCGP(Summit)	Gas				0	0	0	0			Gas Shortage
<b>Dhaka Zone Total</b>				<b>5526</b>	<b>5332</b>	<b>2618</b>	<b>2554</b>	<b>2238</b>	<b>2799</b>	<b>1082</b>	<b>845</b>	
33	Karnaphuli Hydro PP Unit-1,2,3,4,5	Hydro (PDB)	2x40, 3x50	230	230	48	30	30	30	200		Inadequate Water Level
34	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0			
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.
35	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	0	0	5	0			
36	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	25	8	25			
37	Teknaf 20MW PP (Solaritech)	Solar (IPP)	1x20	20	20	0	0	20	0			
38	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	0	6	20			
39	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	51	51	51	51			
40	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.
41	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	88	96	100	100			
42	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.94	300	300	52	51	52	52			
43	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	37	59	49	62			
44	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	17	68	51	85			
45	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	46	77	55	78			
46	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0			
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			0	15	10	15			
47	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	37	32	45	60			
48	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	35	35	35	35			
49	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	92	110	51	110			
50	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	48	48	48	60			
51	Juldah 100 MW Unit-1 (Acorn)	HFO (NENP)	8x13.45	100	100	68	46	70	70			
52	Chattogram 116 MW PP (Anilma Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	53	35	53			
53	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	54	152	54	152			
54	Chattogram 2612MW Coal Based PP (SS Power)	Coal (IPP)	2x612	1224	1224	348	490	270	490			
55	Matarbari 2600 MW (CPGCL)	Coal (CPGCL)	1x575	575	575	576	926	190	190			
56	Cox's Bazar Wind PP	(Wind) (IPP)		60	60	58	41	40	40			
	Sonagazi 75 MW Solar Plant	(Solar) (EGCB)				28	0	70	0			
<b>Chattogram Zone Total</b>				<b>4464</b>	<b>4404</b>	<b>1700</b>	<b>2405</b>	<b>1345</b>	<b>1778</b>	<b>200</b>	<b>330</b>	
57	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	20	5	35	36			
58	Ashuganj 225 MW CCGP	Gas (APSCCL)	1x142+175	221	221	177	209	200	220			
59	Ashuganj 450 MW CCGP(South)	Gas (APSCCL)	1x360	360	360	240	240	0	0	120	Gas Shortage	
60	Ashuganj 450 MW CCGP(North)	Gas (APSCCL)	1x361	360	360	0	0	0	0	360	Gas Shortage	
61	Ashuganj 420 MW CCGP(East)	Gas (APSCCL)	1x284+1x116	400	400	220	225	250	280	175	Gas Shortage	
62	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*16	195	195	0	0	0	0	195	Gas Shortage	
63	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	0	0	0	0			
64	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	12	52	12	50			
65	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	39	44	39	40			
66	Chandpur 150 MW CCGP	Gas (PDB)	1X106+1x57	163	163	50	50	50	50	113	Gas Shortage	
67	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	101	136	100	155			
68	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0			
69	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	32	32	32	32			
70	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	34	52	25	52			
71	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	17	17	20	20			
72	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	52	97	52	114			
73	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	37	57	36	75			
74	Bharob 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	50	50			
75	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x5.428	115	115	82	115	115	115			
76	Ashuganj 55 MW PP (Precision)	Gas (NENP)	15*4	55	55	10	5	50	50			
**	Impoprt (Tripura)	India		160	160	88	80	146	151			
<b>Cumilla Zone Total</b>				<b>2937</b>	<b>2929</b>	<b>1228</b>	<b>1433</b>	<b>1212</b>	<b>1490</b>	<b>963</b>	<b>0</b>	
77	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	32	69	45	80	133		Gas Shortage
78	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	49	87	57	100			
79	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	58	104	58	105			
80	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
81	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	35	0	50	0			
82	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	12	12	12	12			
<b>Mymensingh Zone Total</b>				<b>600</b>	<b>592</b>	<b>188</b>	<b>272</b>	<b>224</b>	<b>297</b>	<b>133</b>	<b>0</b>	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	26.05.24 (Yesterday)		27.05.24 (Today)		26.05.24 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)			
83	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	38	38	42	42			Under maint.	
84	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	58	60	60			Under maint.	
85	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	49	48	50	50				
86	Kushnara 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0				
87	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	2	5	5				
88	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	48	56	60	60				
89	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0			330	Under maint.
90	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	197	200	204	204				
91	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0				
92	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	24	24	24				
93	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	310	255	180	300				
94	Bibiana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	396	366	250	400				
95	Bibiyana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	356	325	345	360				
96	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0				Test run
97	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	41	10	42	42				
<b>Sylhet Zone Total</b>					<b>2376</b>	<b>2331</b>	<b>1486</b>	<b>1382</b>	<b>1262</b>	<b>1547</b>	<b>0</b>	<b>394</b>	
98	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
99	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0			410	Gas Shortage
100	Fardpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	33	45	30	42				
101	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	28	0	50	60				
102	Khulna 225 MW CAPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0				
103	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	53	0	53	90				
104	Machumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	15	0	15	100				
105	Monira Orion 100 MW Solar PP	Solar (IPP)		100	100	20	0	100	0				
106	Maitree Super Thermal 1320 MW PP	Coal (BIFCL)	2x617	1234	1234	377	440	0	0				
107	Khulna 330 MW CAPP	Gas/HSD (BIFCL)	1x220+1x116	336	336	0	0	0	0				
108	Ncopara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5x8.5	0	0	40	0	32	32				
109	Khulna 115 PP MW (KPCCL-2)	HFO (NENP)	7x17	0	0	16	0	20	85				
**	Bheramara (HVDC)	India		1000	1000	919	901	358	455				
<b>Khulna Zone Total</b>					<b>3703</b>	<b>3699</b>	<b>1501</b>	<b>1386</b>	<b>658</b>	<b>864</b>	<b>410</b>	<b>0</b>	
108	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	0	0	110				
109	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	10	0	0	10	10				
110	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	124	130	130	130			64	ST under maint.
111	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	760	710	620	620				
112	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	0	17	17				
113	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	180	210	150	307				
114	Bhola 220MW CAPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	180	160	200				
<b>Barishal Zone Total</b>					<b>2265</b>	<b>2235</b>	<b>1317</b>	<b>1230</b>	<b>1087</b>	<b>1394</b>	<b>0</b>	<b>64</b>	
115	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0			71	Gas Shortage
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0			100	Under maint.
116	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	25	31	40	40				
117	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	20	0	25				
118	Chapanawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	80	0	90				
119	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	42	0	42				
120	Katakali 50 MW PP (Northern)	HFO (NENP)	6x8.9	50	50	0	0	0	0				
121	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	22	0	30				
122	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0			210	Gas Shortage
123	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0			220	Gas Shortage
124	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	180	168	180	190				
125	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	414	354	350	414				
126	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	5	5	11	11				
127	Natore 52 MW PP (Rajanka)	HFO (IPP)	6x8.92	52	52	0	0	0	0				
128	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	50	113	50	113				
129	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6*18.55	113	113	50	94	50	113				
130	Amnura 50 MW PP (Sinha)	HFO (NENP)	7x7.79	50	28	14	35	14	28				
131	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	2	0	6	0				
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	1321	1310	890	1000				
<b>Rajshahi Zone Total</b>					<b>3453</b>	<b>3431</b>	<b>2061</b>	<b>2274</b>	<b>1591</b>	<b>2096</b>	<b>501</b>	<b>100</b>	
132	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	63	62	65	65				
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0			85	Under Overhauling
133	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	230	220	220	220				
134	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
135	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x.2*3	113	113	34	103	70	107				
136	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
137	Majpara Tabilis 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0				
138	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	75	114	115	115				
139	Lalmonirhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	38	0	30	0				
140	Teesa Solar Limited	Solar (IPP)	1 x 200	200	200	121	0	130	0				
<b>Rangpur Zone Total</b>					<b>1030</b>	<b>950</b>	<b>568</b>	<b>499</b>	<b>638</b>	<b>507</b>	<b>0</b>	<b>85</b>	
<b>Sub-total: Plants in operation</b>					<b>26354</b>	<b>25903</b>	<b>12667.0</b>	<b>13435</b>	<b>10255</b>	<b>12772</b>	<b>3289</b>	<b>1818</b>	
<b>(B) Plants under long term maintenance/ contract expired</b>													
141	Katobdi 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				Contract Expired
142	Haripur 360MW CAPP(HPL)	Gas (IPP)	1x235+1x125	360	0	0	0	0	0				Contract Expired
143	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				Contract Expired
144	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	0	0	0	0	0				Contract Expired
145	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				Contract Expired
<b>Sub-Total: Plants under long term maintenance/ contract expired</b>					<b>700</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	
<b>Gross Total</b>					<b>27054</b>	<b>25903</b>	<b>12667</b>	<b>13435</b>	<b>10255</b>	<b>12772</b>	<b>3289</b>	<b>1818</b>	
<b>(C) Actual data of 26.05.24 (Yesterday) Sunday :</b>													
01.	Max. Demand at eve. peak (Generation end)	: 13560 MW, at = 19:30 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :										
02.	Max. Demand at eve. peak (Sub-station end)	: 12870 MW, at = 19:30 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW			
03.	Highest Generation (Generation end)	: 14173 MW, at = 3:00 hrs	Dhaka	5182	5157	25	Mymensingh	991	966	25			
04.	Minimum Generation (Generation end)	: 12391 MW, at = 8:00 hrs	Chattogram	1275	1275	0	Sylhet	441	441	0			
05.	Day-peak Generation (Generation end)	: 12667 MW, at = 12:00 hrs	Khulna	1139	1139	0	Barishal	121	121	0			
06.	Evening-peak Generation (Generation end)	: 13435 MW, at = 19:30 hrs	Rajshahi	1387	1387	0	Rangpur	1072	1003	69			
07.	Evening Peak Load-shed (Sub-station end)	: 119 MW, at = 19:30 hrs	Cumilla	1262	1262	0	Total	12870	12751	119			
08.	Minimum Generation Forecast up to 8:00 hrs.	: 5553 MW, at = 5:00 hrs											
09.	Generation shortfall at evening peak due to :	:											
a)	Gas/LF limitation	: 3089 MW	13. Fuel cost :		a) Gas = 350466492 Taka		(c) Coal = 716786852 Taka						
d)	Coal supply Limitation	: 0 MW			b) Oil = 1228628459 Taka		Total = 2295881802 Taka						
b)	Low water level in Kaptai lake	: 200 MW											
c)	Plants under shut down/ maintenance	: 1818 MW											
10.	Total Energy (Generation + India Import)	: 313.54 MKWh	14. Maximum Temperature in Dhaka was : 34.8°C										
	By Gas = 114.408 MKWh	By Oil = 66.924 MKWh	15. Export through East-West interconnections :										
	By Coal = 105.649 MKWh	By Hydro = 0.780 MKWh	At evening peak-hour : 12667 MW, at 19:30 hrs										
	By Solar = 2.435 MKWh		Maximum : 584 MW, at 22:00 hrs										
11.	Total Gas Supplied	: 843.37 MCF	Energy : 8142.75 MKWh										
<b>(D) Forecast of 27.05.24 (Today) Monday :</b>													
01.	Maximum Demand	: 8500 MW (Generation end)	04. Maximum Load-shed : 0 MW At evening peak (Sub-station end)										
02.	Maximum Generation	: 12772 MW (Generation end)	05. Total Generation : 188.04 MKWh										
03.	Reserve / Shortage	: 4272 MW (Generation end)	06. Probable Max. Temperature in Dhaka : 34.8°C										

\* Captive Power \*\* Imported Power  
#Remarks: Highest Generation 16477 MW on 30-04-2024 at 21:00

(Md. Helalur Rahman)  
Deputy Secretary, Generation