

| Sl. No. | Name of the Power Stations | Producer | Installed Capacity | Present Capacity | | Peak Hour Generation | | Energy Generated | Remarks |
|-------------------------------|---|----------------|--------------------|---------------------|-------------|----------------------|-----|------------------------|---------|
| | | | | Unit No. X Capacity | MW | MW | KWH | | |
| 1 | Ghorasal Repowered CCPP Unit-3 (GT) | PDB | 1210 | 180 | 0 | 0 | 0 | Under maint. | |
| 2 | Ghorasal Repowered CCPP Unit-4 | PDB | 1210 | 180 | 0 | 0 | 0 | Gas shortage | |
| 3 | Ghorasal TPP Unit-5 | PDB | 1210 | 190 | 110 | 3244500 | 0 | Bad weather | |
| 4 | Ghorasal 365 MW CCPP Unit-7 | PDB | 1243*1122 | 365 | 0 | 0 | 0 | Air Compressor problem | |
| 5 | Ghorasal 73.5 MW PP(MIX) | ORPP | 240 | 0 | 0 | 0 | 0 | Contract Expired | |
| 6 | Ghorasal 108 MW PP (Regent) | IPP | 343*35 | 108 | 0 | 0 | 0 | Gas shortage | |
| 7 | Haripur GTPP | SBU, PDB | 232 | 20 | 0 | 0 | 0 | Under maint. | |
| 8 | Haripur 412 MW CCPP | EGCB | 1273*1139 | 400 | 340 | 7556400 | 0 | Bad weather | |
| 9 | Haripur 360 MW CCPP(HPL) | IPP | 1235*1125 | 0 | 0 | 0 | 0 | Contract Expired | |
| 10 | Meghnaghat 450 MW CCPP(MPL) | IPP | 2150*1150 | 450 | 420 | 7894000 | 0 | Bad weather | |
| 11 | Meghnaghat 100 MW(EL) | NENP | 128.924 | 0 | 0 | 0 | 0 | Bad weather | |
| 12 | Meghnaghat CCPP(Summit) | IPP | 2110*1110 | 335 | 150 | 3120640 | 0 | FGMO | |
| 13 | Madanganj 102 PP(Summit) | NENP | 617 | 0 | 0 | 0 | 0 | Bad weather | |
| 14 | Madanganj 55 MW PP(Summit) | IPP | 317.08*111.3 | 55 | 0 | 126445 | 0 | Bad weather | |
| 15 | Keranganj 100 MW PP (Powerpac) | NENP | 813.45 | 75 | 0 | 0 | 0 | Bad weather | |
| 16 | Narshang 22 MW PP (Green) | SIPP, REB | 82.90 | 22 | 0 | 0 | 0 | Contract Expired | |
| 17 | 210 MW Siddhirgonj TPP | PDB | 1210 | 115 | 0 | 0 | 0 | Under maint. | |
| 18 | Siddhirgonj 2120 MW GTTP | EGCB | 2105 | 210 | 0 | 0 | 0 | Gas shortage | |
| 19 | Siddhirgonj 100 PP(Dutch Bangla) | NENP | 128.9 | 0 | 0 | 0 | 0 | Bad weather | |
| 20 | Siddhirgonj 335 MW CCPP | EGCB | 1217*1118 | 335 | 0 | 2404546 | 0 | Bad weather | |
| 21 | Copalganj 102 MW PP (Digital Power) | IPP | 128.924 | 102 | 0 | 120696 | 0 | Bad weather | |
| 22 | Katpotti 52 MW PP (Sinha) | IPP | 177.9 | 0 | 0 | 0 | 0 | Fuel shortage | |
| 23 | Kamalaghat 54 MW PP(Banco Energy) | IPP | 318 | 54 | 0 | 80640 | 0 | Bad weather | |
| 24 | Kodda 150 MW PP | BPDB-RPCL | 917.06 | 149 | 0 | 71520 | 0 | Bad weather | |
| 25 | Manikganj 55 MW PP (Northern) | IPP | 319.3 | 55 | 0 | 197960 | 0 | Bad weather | |
| 26 | Nababhat 55 MW PP (Southern power) | IPP | 319.3 | 55 | 0 | 112695 | 0 | Bad weather | |
| 27 | Bosila 108 MW PP(CLC) | IPP | 128.775*113.5 | 0 | 0 | 0 | 0 | Bad weather | |
| 28 | Summit Power (Madhabdi+Ashulia) | SIPP, REB | 3167*487.3 | 80 | 0 | 220400 | 0 | Bad weather | |
| 29 | Maona 33 MW PP(Summit) | SIPP, REB | 48.73 | 33 | 0 | 302900 | 0 | Bad weather | |
| 30 | Rupganj 33 MW PP(Summit) | SIPP, REB | 48.73 | 33 | 0 | 165500 | 0 | Bad weather | |
| 31 | Gazipur 52 MW PP | RPCL | 61.9 | 52 | 0 | 0 | 0 | Fuel shortage | |
| 32 | Tongi 80 MW GTTP | PDB | 1105 | 105 | 0 | 0 | 0 | Gas shortage | |
| 33 | Kodda 300 MW PP Unit-2 (Summit) | IPP | 1817.076 | 300 | 0 | 82800 | 0 | Bad weather | |
| 34 | Bramhangonj 100 MW PP (Aggreko) | IPP | 1140.959 | 0 | 0 | 0 | 0 | Contract Expired | |
| 35 | Auraha 100MW PP (Aggreko) | IPP | 0.8523*0.967 | 0 | 0 | 0 | 0 | Contract Expired | |
| 36 | Kodda 149 MW PP Unit-1 (Summit) | IPP | 818.527 | 149 | 0 | 234964 | 0 | Bad weather | |
| 37 | Gazipur 100 MW PP | RPCL | 61.75 | 105 | 0 | 81120 | 0 | Bad weather | |
| 38 | Meghnaghat 104 MW PP (OPCL) | IPP | 18.56 | 104 | 0 | 191040 | 0 | Bad weather | |
| 39 | Manikgonj 162MW PP(MPL) | IPP | 918 | 162 | 0 | 486720 | 0 | Bad weather | |
| 40 | Spectra Solar Plant Ltd. | IPP | 35 | 35 | 0 | 1276 | 0 | Bad weather | |
| 41 | Kanchan Ribeschal Power Generation Ltd. | IPP | 118.3 | 65 | 0 | 85880 | 0 | Bad weather | |
| 42 | Meghnaghat Unique power | IPP | 586 | 584 | 0 | 0 | 0 | Bad weather | |
| 43 | Summit Meghnaghat-2 589 MW(Gas) | IPP | 589 | 0 | 0 | 0 | 0 | Bad weather | |
| Dhaka area Total | | | | 5332 | 1020 | 2878542 | | | |
| 44 | Chattogram TPP-1 | PDB | 1210 | 180 | 0 | 0 | 0 | Gas shortage | |
| 45 | Chattogram TPP-2 | PDB | 1210 | 180 | 0 | 0 | 0 | Bad weather | |
| 46 | Raxan 25 MW PP | RPCL | 378.9 | 25 | 0 | 0 | 0 | Bad weather | |
| 47 | Teknaf 20MW PP (Solartech) | IPP | 20 | 20 | 0 | 10260 | 0 | Bad weather | |
| 48 | Patenga 50MW PP (Baraka) | IPP | 816.98 | 50 | 0 | 0 | 0 | Bad weather | |
| 49 | Kapali Hydro Unit-1,2,3,4,5 | PDB | 240*350 | 230 | 0 | 293760 | 0 | Low water level | |
| 50 | Sikalbaha 225MW | PDB | 1150*1175 | 225 | 0 | 1194491 | 0 | Bad weather | |
| 51 | Sikalbaha Peaking GT | PDB | 1150 | 150 | 0 | 0 | 0 | Under maint. | |
| 52 | Sikalbaha 105 MW PP (Baraka Sikalbaha) | IPP | 6117.5 | 105 | 0 | 40982 | 0 | Bad weather | |
| 53 | Hathazari 100 MW peaking PP | PDB | 1118.9 | 98 | 0 | 226368 | 0 | Bad weather | |
| 54 | Dohazari-Kalash 100 MW Peaking | PDB | 617 | 102 | 0 | 175925 | 0 | Bad weather | |
| 55 | Julidah 100 MW Unit-1 (Acorn) | NENP | 813.45 | 100 | 0 | 13680 | 0 | Bad weather | |
| 56 | Julidah 100 MW PP Unit-3 (Acorn) | IPP | 813.5 | 100 | 0 | 115200 | 0 | Bad weather | |
| 57 | Barabkunda 22 MW PP (Regent) | SIPP, PDB | 82.90 | 22 | 0 | 0 | 0 | Bad weather | |
| 58 | Malanha, Clg. EPZ (Uniled) | IPP | 58.73*39.34 | 0 | 0 | 249600 | 0 | Bad weather | |
| 59 | Chattogram 108 MW PP (ECPV) | IPP | 167 | 108 | 0 | 73920 | 0 | Bad weather | |
| 60 | Kapali 7 MW Solar PP | PDB | 7.4 | 7 | 0 | 0 | 0 | Bad weather | |
| 61 | Anwara 300 MW PP (Uniled) | IPP | 1717*24 | 300 | 0 | 215782 | 0 | Bad weather | |
| 62 | Jodiach Power | IPP | 318.55*133.6 | 50 | 0 | 23915 | 0 | Bad weather | |
| 63 | Karnaphuli Power Ltd. | IPP | 18.415*6.5 | 110 | 0 | 137160 | 0 | Bad weather | |
| 64 | Julidah unit-2 (Acorn) | IPP | 813.6 | 100 | 0 | 151680 | 0 | Fuel shortage | |
| 65 | Anilima Energy Ltd. | IPP | 621.2 | 116 | 0 | 79036 | 0 | Bad weather | |
| 66 | Mirshar 50 MW | BPDB-RPCL | 18.639 | 163 | 0 | 30109 | 0 | Bad weather | |
| 67 | SS Power 1 | SS Power | 2612 | 1224 | 270 | 7510908 | 0 | Bad weather | |
| 68 | Cox's Bazar Wind | IPP | 66 | 60 | 51 | 1188960 | 0 | On test. | |
| 69 | Matarbari 2*600 MW (CPGCL) | CPGCL | 0 | 575 | 162 | 6407272 | 0 | Bad weather | |
| 70 | Mirshar 150 MW (Gas) | BPDB-RPCL | 18.59 | 0 | 0 | 0 | 0 | On test. | |
| 71 | Sonarga 75 MW Solar Plant | EGCB | 75 | 0 | 0 | 64818 | 0 | Bad weather | |
| Chattogram area Total | | | | 4404 | 483 | 18203826 | | | |
| 72 | Ashuganj TPP Unit-3 | APSCL | 1150 | 0 | 0 | 0 | 0 | Contract Expired | |
| 73 | Ashuganj TPP Unit-4 | APSCL | 1150 | 0 | 0 | 0 | 0 | Contract Expired | |
| 74 | Ashuganj TPP Unit-5 | APSCL | 1150 | 0 | 0 | 0 | 0 | Contract Expired | |
| 75 | Ashuganj 225 MW CCPP | APSCL | 1142*1175 | 221 | 109 | 3719000 | 0 | Bad weather | |
| 76 | Ashuganj 450 MW CCPP(North) | APSCL | 1360 | 360 | 0 | 0 | 0 | Under maint. | |
| 77 | Ashuganj 450 MW CCPP(South) | APSCL | 1360 | 360 | 0 | 1984000 | 0 | Bad weather | |
| 78 | Ashuganj 420 MW CCPP(East) | APSCL | 284*1116*1 | 400 | 315 | 5634000 | 0 | Bad weather | |
| 79 | Ashuganj 50 MW PP | APSCL | 143.968 | 45 | 0 | 127224 | 0 | Bad weather | |
| 80 | Ashuganj 55 MW PP (Precision) | ORPP | 0 | 55 | 0 | 31200 | 0 | Bad weather | |
| 81 | Ashuganj 195 MW PP (APSCL-Uniled) | IPP | 209.73*116 | 105 | 0 | 0 | 0 | Bad weather | |
| 82 | Ashuganj 51 MW PP (Midland) | IPP | 69.34 | 51 | 0 | 0 | 0 | Bad weather | |
| 83 | Ashuganj 150 MW PP (Midland) | IPP | 237.015 | 150 | 0 | 33454 | 0 | Bad weather | |
| 84 | Tilas 50 MW Peaking PP | PDB | 68.92 | 52 | 0 | 88432 | 0 | Bad weather | |
| 85 | Chandpur 150 MW CCPP | PDB | 1106*1157 | 163 | 0 | 941310 | 0 | Bad weather | |
| 86 | Chandpur 200 MW (Dash energy) | IPP | 1218.4 | 200 | 0 | 261120 | 0 | Bad weather | |
| 87 | Feni 11 MW PP (Doreen) | SIPP, REB | 42.90 | 11 | 0 | 0 | 0 | Bad weather | |
| 88 | Import (Tripura) | Imported power | 0 | 160 | 18 | 602880 | 0 | Bad weather | |
| 89 | Jangalia 33 MW PP (Summit) | SIPP, PDB | 48.73 | 33 | 0 | 162900 | 0 | Bad weather | |
| 90 | Jangalia 52 MW PP (Lakdanaw) | IPP | 68.92 | 52 | 0 | 27898 | 0 | Bad weather | |
| 91 | Cumilla 25 MW PP (Summit) | SIPP, REB | 313*216.97 | 25 | 0 | 65170 | 0 | Bad weather | |
| 92 | Daudkandi 200 MW PP (B.Trac) | IPP | 1541.4 | 0 | 0 | 0 | 0 | Bad weather | |
| 93 | Feni Lanka Power | IPP | 718.415*119.78 | 114 | 0 | 124260 | 0 | Bad weather | |
| 94 | Chowmuhani 113 MW | IPP | 129.78*23.1 | 113 | 0 | 82320 | 0 | Bad weather | |
| 95 | Bharob 54.5 MW | IPP | 318.2 | 54 | 0 | 83880 | 0 | Bad weather | |
| 96 | Chandpur 115(Doreen) | IPP | 418.5*222.5 | 115 | 0 | 205320 | 0 | Bad weather | |
| Cumilla Area Total | | | | 2929 | 442 | 1417368 | | | |
| 97 | RPCL 210MW CCPP | IPP | 435*1170 | 202 | 32 | 1045440 | 0 | Bad weather | |
| 98 | Jamalpur 95 MW PP(Powerpac) | IPP | 0 | 0 | 0 | 0 | 0 | Bad weather | |
| 99 | Sarashabari 3 MW Solar Plant | IPP | 13 | 3 | 0 | 0 | 0 | Bad weather | |
| 100 | Myemensingh 200 MW PP (Uniled) | IPP | 978*21 | 200 | 0 | 355000 | 0 | Bad weather | |
| 101 | Jamalpur 115 MW PP (Uniled) | IPP | 978*12 | 115 | 0 | 327600 | 0 | Bad weather | |
| 102 | Sutakhal 50 MW Solar PP | IPP | 50 | 50 | 0 | 43590 | 0 | Bad weather | |
| 103 | Tangail Palli Power Gen 22 MW | IPP | 46.7 | 22 | 0 | 59520 | 0 | Bad weather | |
| Myemensingh Area Total | | | | 592 | 32 | 1831350 | | | |
| 104 | Fenchugonj CCPP Phase-1 | PDB | 232*133 | 70 | 0 | 607000 | 0 | Bad weather | |
| 105 | Fenchugonj CCPP Phase-2 | PDB | 235*135 | 90 | 0 | 668040 | 0 | Bad weather | |
| 106 | Kushara 163 MW CCPP (KP) | IPP | 1109*154 | 163 | 0 | 45164 | 0 | Bad weather | |
| 107 | Shajibazar 330 MW CCPP | PDB | 31110 | 330 | 0 | 0 | 0 | Under maint. | |
| 108 | Fenchugonj 51 MW PP (Barakatalullah) | RPCL | 192.90 | 51 | 0 | 152400 | 0 | Bad weather | |
| 109 | Fenchugonj 44 MW PP (Energypima) | NENP | 123.34*52 | 60 | 0 | 70832 | 0 | Bad weather | |
| 110 | Hobiganj 11 MW PP Confidence-E | SPP, REB | 42.90 | 11 | 0 | 21168 | 0 | Bad weather | |
| 111 | Shajibazar GTTP Unit- 8 & 9 | PDB | 235 | 66 | 0 | 406080 | 0 | Contract Expired | |
| 112 | Shajibazar 86 MW PP (Shajibazar) | RPCL | 322.90 | 0 | 0 | 0 | 0 | Contract Expired | |
| 113 | Shajibazar 100 MW GTTP | PDB | 1100 | 100 | 0 | 0 | 0 | Bad weather | |
| 114 | Sylhet 225 MW CCPP | PDB | 1142*1169 | 221 | 177 | 4489090 | 0 | Bad weather | |
| 115 | Sylhet 20 MW GTTP | PDB | 120 | 20 | 0 | 0 | 0 | Under maint. | |
| 116 | Sylhet 50 MW PP (EPL) | NENP | 272 | 0 | 0 | 0 | 0 | Contract Expired | |
| 117 | Shahjahanulla 25 MW PP | SIPP, REB | 39.34 | 25 | 0 | 45312 | 0 | Bad weather | |
| 118 | Bibiana-1 341 MW CCPP (Summit) | IPP | 1222*1119 | 341 | 310 | 5519500 | 0 | FGMO | |
| 119 | Bibiana-II 400 MW CCPP | PDB | 2851*1341 | 400 | 0 | 2964000 | 0 | Bad weather | |
| 120 | Sylhet 10MW PP (Dash) | RPCL | 61.95 | 0 | 0 | 0 | 0 | Contract Expired | |
| 121 | Bibiana South 400 MW | PDB | 400 MW | 383 | 370 | 7340900 | 0 | FGMO | |
| Sylhet Area Total | | | | 2331 | 857 | 22329286 | | | |
| 122 | Bheranara GTTP Unit-3 | PDB | 120 | 16 | 0 | 0 | 0 | Bad weather | |
| 123 | Bheranara (WDC) | Imported power | 21500 | 10000 | 2000 | 13208080 | 0 | Bad weather | |
| 124 | Khulna 115 MW (KPCL-2) | NENP | 717 | 0 | 0 | 0 | 0 | Bad weather | |
| 125 | Fairdipur 50 MW Peaking PP | PDB | 86.89 | 54 | 0 | 0 | 0 | Bad weather | |
| 126 | Khulna 225 MW CCPP | NWPQCL | 1150*1175 | 230 | 0 | 0 | 0 | Fuel shortage | |
| 127 | Copalganj 100 MW Peaking PP | PDB | 166.98 | 109 | 0 | 0 | 0 | Bad weather | |
| 128 | Bheranara 410 MW CCPP | NWPQCL | 1278*1132 | 410 | 0 | 0 | 0 | Bad weather | |
| 129 | Noapara 40 MW PP (Khanjahan Ai) | NENP | 57.5 | 0 | 0 | 474000 | 0 | Bad weather | |
| 130 | Noapara 100 MW PP (Bangla Trac) | IPP | 701.4 | 0 | 0 | 0 | 0 | Contract Expired | |
| 131 | Rupsha 105 MW PP (Orion rupsha) | IPP | 618.445 | 105 | 0 | 0 | 0 | Bad weather | |
| 132 | Madhumati 100 MW PP | NWPQCL | 618 | 105 | 0 | 0 | 0 | Bad weather | |
| 133 | Monjira Chen 160 MW Solar PP | IPP | 160 | 100 | 0 | 67680 | 0 | Bad weather | |
| 134 | Khulna 330 MW CCPP (OL) | BPDB | 1220*1110 | 336 | 0 | 0 | 0 | On test | |
| 135 | Rampal 1320 MW (BFPCL) | NTPC&BPDB | 6172 | 1234 | 0 | 872727 | 0 | Bad weather | |
| 136 | Khulna 225 MW CCPP (GAS) | NWPQCL | 0 | 0 | 0 | 0 | 0 | Bad weather | |
| Khulna Area Total | | | | 3699 | 209 | 14622487 | | | |
| 137 | Barisal 110 MW PP (Summit) | IPP | 717.076 | 110 | 0 | 0 | 0 | Bad weather | |
| 138 | Bhola 225 MW CCPP | NENP | 1134.50 | 50 | 0 | 5954 | 0 | Bad weather | |
| 139 | Bhola 95 MW PP (Aggreko) | ORPP | 96*110 | 0 | 0 | 0 | 0 | Contract Expired | |
| 140 | Payra 1320 MW | BCPCL | 2622 | 1244 | 380 | 13909300 | 0 | Bad weather | |
| 141 | Bhola Nutan Bidduf BD LTD | IPP | 220 | 220 | 110 | 335164 | 0 | Bad weather | |
| 142 | Uniled Payra Power Ltd. | IPP | 818.5*119.5 | 150 | 0 | 150 | 0 | Bad weather | |
| 143 | Barisal 307 MW | IPP | 307*1 | 307 | 0 | 1789100 | 0 | Bad weather | |
| Barisal Area Total | | | | 2235 | 546 | 20603518 | | | |
| 144 | Baghabari 71 MW GTTP | PDB | 171 | 71 | 0 | 0 | 0 | Gas shortage | |
| 145 | Baghabari 100 MW GTTP | PDB | 1100 | | | | | | |