

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month May, 2024				Day : Wednesday				Date : 29.05.24			
Probable Maximum Demand : 15000 MW				Probable Maximum Generation : 15326 MW							
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 71.75 ft				Today = 74.22 ft			
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	28.05.24 (Yesterday)		29.05.24 (Today)		28.05.24 (Yesterday)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		
					Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation MW	Machines shut down (MW)	
(A) Plants in operation:											
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work
2	a) Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0		
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180		
3	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Awaiting for HGPI
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	37	71	60	70		
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Under maint.
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0		
7	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450		
8	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
9	Haripur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	400	403	403	400	400		
10	Siddhirgonj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage
11	Siddhirgonj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	1	320	300	330		
12	Meghnaghat 335MW CCGP(Summit)	Gas (IPP)	2x110+1x110	335	335	149	0	0	0		
13	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	40	55	55	55		
14	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	38	82	80	82		
15	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	0	0		
16	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+1x7.73	80	80	24	37	43	45		
17	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	10	25	25	25		
18	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	0	30	33	33		
19	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	8	8	8		
20	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	0	17	17	50		
21	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	20	132	48	150		
22	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	54	54	54		
23	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	260	260	270		
24	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	6x18.415+1x8.97	149	149	4	133	115	133		
25	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	10	17	17	17		
26	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	55	55		
27	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	72	53	72		
28	Manikganj 162MW PP(MPL)	HFO (IPP)	9x18	162	162	72	162	162	162		
29	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	29	0	35	0		
30	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	35	17	35		
31	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	13	0	15		
32	Unique Meghnaghat 584MW CCGP	Gas	1x400+1x184	584	584	0	125	580	580		
	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	0	0	27	77	75	77		
	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	0	0	0	75	34	34		
	Meghnaghat 100 MW(IEL)	HFO (NENP)	12x8.9	0	0	0	90	90	90		
	Meghnaghat 589 MW CCGP(Summit)	Gas		0	0	0	0	0	0		
Dhaka Zone Total				5526	5332	1546	2978	3246	3472	210	845
33	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	30	60	60	60	170	Inadequate Water Level
34	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0		
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.
35	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	0	0	5	0		
36	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	0	8	25		
37	Teknaf 20MW PP (Solaritech)	Solar (IPP)	1x20	20	20	13	0	20	0		
38	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	6	6	20		
39	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	5	51	51	51		
40	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.
41	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	143	147	100	150		
42	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.94	300	300	0	51	52	52		
43	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	37	37	25	25		
44	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	74	51	85		
45	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	82	55	80		
46	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0		
*	Malanchara Ctg EPZ (United)	Gas	5x8.73+3x9.34			6	31	10	20		
47	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	45	45	45		
48	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	35	35	35		
49	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	9	51	51	110		
50	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	24	25	48	60		
51	Juldah 100 MW Unit-1 (Acorn)	HFO (NENP)	8x13.45	100	100	56	68	68	68		
52	Chattogram 116 MW PP (Anlima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	53	35	53		
53	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	54	163	54	163		
54	Chattogram 2*612MW Coal Based PP (SS Power)	Coal (IPP)	2x612	1224	1224	425	610	480	490		
55	Matarani 2*600 MW (CPGCL)	Coal (CPGCL)	1x575	575	575	302	502	0	0		
56	Cox's Bazar Wind PP	(Wind) (IPP)		60	60	58	33	40	40		
	Sonagazi 75 MW Solar Plant	(Solar) (EGCB)				40	0	70	0		
Chattogram Zone Total				4464	4404	1219	2124	1369	1632	170	330
57	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	33	34	35	35		
58	Ashuganj 225 MW CCGP	Gas (APSCCL)	1x142+1*75	221	221	117	183	200	220		
59	Ashuganj 450 MW CCGP(South)	Gas (APSCCL)	1x360	360	360	0	100	300	310		
60	Ashuganj 450 MW CCGP(North)	Gas (APSCCL)	1x361	360	360	0	0	0	0		
61	Ashuganj 420 MW CCGP(East)	Gas (APSCCL)	1x284+1x116	400	400	310	325	330	330		
62	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*16	195	195	168	184	184	184		
63	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	24	43	43	43		
64	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	123	50	123		
65	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	31	39	40		
66	Chandpur 150 MW CCGP	Gas (PDB)	1X106+1x57	163	163	0	0	90	91		
67	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	51	68	51	68		
68	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0		
69	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	0	32	32	32		
70	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	43	43	43		
71	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	0	17	20	20		
72	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	34	80	52	80		
73	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	0	57	30	25		
74	Bharob 54 MW PP	HFO (IPP)	3x18.2	54	54	0	35	50	50		
75	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x5.428	115	115	32	110	115	115		
76	Ashuganj 55 MW PP (Precision)	Gas (NENP)	15*4	55	55	2	46	50	50		
**	Impoport (Tripura)	India		160	160	64	74	146	151		
Cumilla Zone Total				2937	2929	835	1585	1860	2010	0	0
77	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	130	145	145	145	57	Gas Shortage
78	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	0	88	57	88		
79	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	0	103	58	105		
80	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	0	0	1.6	0		
81	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	23	0	50	0		
82	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	0	18	12	12		
Mymensingh Zone Total				600	592	153	354	324	350	57	0

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	28.05.24 (Yesterday)		29.05.24 (Today)		28.05.24 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)			
83	Fenchugonj CCGP Phase-1	Gas (PDB)	2x32+1x33	97	70	0	0	0	0	70	Under maint.		
84	Fenchugonj CCGP Phase-2	Gas (PDB)	2x35+1x35	104	90	0	10	10	10	80	Under maint.		
85	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	46	49	50	50				
86	Kushnara 163 MW CCGP (KP)	Gas (IPP)	1x109+1x54	163	163	20	30	163	163				
87	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	5	5				
88	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	62	61	60	60				
89	Shahjibazar 330 MW CCGP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0	330	Under maint.		
90	Sylhet 225 MW CCGP	Gas (PDB)	1x142+1x89	231	231	206	204	204	204				
91	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0				
92	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	8	24	24				
93	Bibiana-II 341 MW CCGP (Summit)	Gas (IPP)	1x222+1x119	341	341	280	295	310	310				
94	Bibiyana-III 400 MW CCGP	Gas (PDB)	1x285+1x115	400	400	0	15	300	400				
95	Bibiyana South 383 MW CCGP	Gas (PDB)	1x252+1x131	383	383	320	226	230	230				
96	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0			Test run	
97	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3+5*2	50	50	39	42	42	42				
Sylhet Zone Total					2376	2331	981	940	1398	1498	0	480	
98	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
99	Bheramara 410 MW CCGP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	0	30	350	350				
100	Fandpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	41	30	41				
101	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	42	50	60				
102	Khulina 225 MW CCGP	HSD/ Gas (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	0				
103	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	17	53	70				
104	Machumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	105	15	100				
105	Monira Orion 100 MW Solar PP	Solar (IPP)		100	100	60	0	100	0				
106	Maitree Super Thermal 1320 MW PP	Coal (BIFCL)	2x617	1234	1234	0	230	550	550				
107	Khulina 330 MW CCGP	Gas/HSD (B/PDB)	1x220+1x116	336	336	0	0	0	0				
108	Nocapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5x8.5	0	0	0	40	32	40				
109	Khulina 115 PP MW (KPCL-2)	HFO (NENP)	7x17	0	0	0	91	20	90				
**	Bheramara (HVDC)	India		1000	1000	823	638	924	638				
Khulina Zone Total					3703	3699	883	1234	2104	1939	0	0	
108	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	64	0	110				
109	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	0	4	10	10				
110	Bhola 225 MW CCGP	Gas (PDB)	2x63+1x68	194	194	130	130	130	130	64	ST under maint.		
111	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	580	622	620	620				
112	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	35	17	35				
113	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	0	0	140	140				
114	Bhola 220MW CCGP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	110	220	200	220				
Barishal Zone Total					2265	2235	820	1075	1117	1265	0	64	
115	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0				
116	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100	Under maint.		
116	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	24	30	30				
117	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	25				
118	Chapanawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	90	0	90				
119	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	45	0	45				
120	Katakali 50 MW PP (Northern)	HFO (NENP)	6x8.9	50	50	0	0	0	0				
121	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	22	0	22				
122	Sirajgonj 225MW CCGP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	14	209	210	210				
123	Sirajgonj 225MW CCGP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	0	0	0	200				
124	Sirajgonj 225MW CCGP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	0	0	0	0				
125	Sirajgonj 400 MW CCGP Unit-4	Gas (IPP)	1x282+1x132	414	414	365	394	414	414				
126	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0				
127	Natore 52 MW PP (Rajanka)	HFO (IPP)	6x8.92	52	52	0	0	0	0				
128	Bagura 113 MW PP (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	95	50	113				
129	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	92	50	92				
130	Amnura 50 MW PP (Sinha)	HFO (NENP)	7x7.79	50	28	0	0	14	28				
131	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	0	0	6	0				
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	755	759	748	1400				
Raishahi Zone Total					3453	3431	1134	1730	1522	2669	0	100	
132	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	55	60				
132	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Under Overhauling		
133	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	220	210	210	210				
134	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
135	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x.2*3	113	113	34	106	70	106				
136	Sandpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
137	Majpara Talsia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	0	0	8	0				
138	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	70	115	115	115				
139	Lalmonirhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	25	0	30	0				
140	Teesa Solar Limited	Solar (IPP)	1 x 200	200	200	125	0	130	0				
Rangpur Zone Total					1030	950	480	431	618	491	0	85	
Sub-total: Plants in operation					26354	25903	8051.0	12451	13558	15326	437	1904	
(B) Plants under long term maintenance/ contract expired													
141	Katobdi 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			Contract Expired	
142	Haripur 360MW CCGP(HPL)	Gas (IPP)	1x235+1x125	360	0	0	0	0	0			Contract Expired	
143	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			Contract Expired	
144	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	0	0	0	0	0			Contract Expired	
145	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Contract Expired	
Sub-Total: Plants under long term maintenance/ contract expired					700	0	0	0	0	0	0	0	
Gross Total					27054	25903	8051	12451	13558	15326	437	1904	
(C) Actual data of 28.05.24 (Yesterday) Tuesday :													
01.	Max. Demand at eve. peak (Generation end)	: 12451 MW, at = 21:00 hrs		12.		Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	: 11907 MW, at = 21:00 hrs		Zone		Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW	
03.	Highest Generation (Generation end)	: 12675 MW, at = 24:00		Dhaka		4616	4616	0	Mymensingh	840	840	0	
04.	Minimum Generation (Generation end)	: 3651 MW, at = 5:00 hrs		Chattogram		1213	1213	0	Sylhet	332	332	0	
05.	Day-peak Generation (Generation end)	: 8051 MW, at = 12:00 hrs		Khulina		1505	1505	0	Barishal	140	140	0	
06.	Evening-peak Generation (Generation end)	: 12451 MW, at = 21:00 hrs		Rajshahi		1347	1347	0	Rangpur	931	931	0	
07.	Evening Peak Load-shed (Sub-station end)	: 0 MW, at = 21:00 hrs		Cumilla		984	984	0					
08.	Minimum Generation Forecast up to 8:00 hrs.	: 11296 MW, at = 5:00 hrs		13.		Fuel cost :		Total	11907	11907	0		
09.	Generation shortfall at evening peak due to :	:		(a) Gas =		265610844 Taka		(c) Coal =		344511953 Taka			
a)	Gas/LF limitation	: 267 MW		(b) Oil =		618229196 Taka		Total =		1228351993 Taka			
d)	Coal supply Limitation	: 0 MW		14.		Maximum Temperature in Dhaka was :		34.4°C					
b)	Low water level in Kaptai lake	: 170 MW		15.		Export through East-West interconnections :							
c)	Plants under shut down/ maintenance	: 1904 MW		At evening peak-hour		: 8051 MW, at		21:00 hrs					
10.	Total Energy (Generation + India Import)	: 188.61 MKWh		Maximum		: 102 MW, at		24:00					
	By Gas = 86.000 MKWh	By Oil = 33.858 MKWh		Energy		: 2575.65 MKWh							
	By Coal = 51.278 MKWh	By Hydro = 0.481 MKWh		11.		Total Gas Supplied		: 869.44 MMCFD					
	By Solar = 2.335 MKWh												
(D) Forecast of 29.05.24 (Today) Wednesday :													
01.	Maximum Demand	: 15000 MW (Generation end)		04.		Maximum Load-shed		: 0 MW		At evening peak (Sub-station end)			
02.	Maximum Generation	: 15326 MW (Generation end)		05.		Total Generation		: 223.20 MKWh					
03.	Reserve / Shortage	: 326 MW (Generation end)		06.		Probable Max. Temperature in Dhaka :		34.4°C					

#Remarks: Highest Generation 16477 MW on 30-04-2024 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation