POWER GRID COMPANY OF BANGLADESH LTD NATIONAL LOAD DESPATCH CENTER DAILY REPORT Till now the maximum generation is : The Summary of Yesterday's Day Peak Generation : Evening Peak Generation : E.P. Demand (at gen end) : Maximum, Generation : Hrs on 30-Apr-24 Today's Actual Min Gen. & Probable Gen. & Demand Min Gen. din Gen. din Gen. din Generation 7:00 Available Max Generation Max Demand (Evening): Reserve(Generation end) 12459.0 MW 14585.0 MW 14700.0 MW 14920.0 MW 29-May-24 ration & Demand Hour Hour Hour 12:00 11253 15897 15000 897 Maximum Generation Total Gen. (MKWH) 304.402 System Load Factor : 85.01% EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR Export from East grid to West grid :- Maximum Import from West grid to East grid :- Maximum Water Level of Kaptai Lake at 6:00 A M on 190 MW MW 1:00 30-May-24 Actual: Ft.(MSL), Rule curve : 76.40 Ft.(MSL) Total = 1076.00 MMCFD. Oil Consumed (PDB): Sas Consumed ost of the Consumed Fuel (PDB+Pvt) Gas : Coal : Total : Tk2,038,023,699 Oil : Tk1,089,449,468 Load Shedding & Other Information Today Estimated Shedding (S/S end) MW Rates of Shedding (On Estimated Demand) Estimated Demand (S/S end) (On Estir Dhaka Chittagong Area Khulna Area Rajshahi Area Cumilla Area Mymensingh Are Syihet Area Barisal Area 0:00 0:00 0:00 0:00 0:00 0:00 0% 0% 0% 0% 0% 0% 0% 1553 1349 1111 826 463 386 Rangpur Area Total 0:00 Information of the Generating Units under shut down Planned Shut- Down Forced Shut-Down 1) Barapukuria ST: Unit- 2 Barapukuria S 1. Oni Ghorasal-3,4,7 Shajibazar 330 MW Baghabari-100 MW Raozan unit-2 6) Siddhirganj 210 MW Outage Time Additional Information of Machines, lines, Interruption / Forced Load shed etc. Adani Power Jharkhanda Ltd Synchronized with remarks: U-2 Mithapukur 132/33W SIS TR-2 (414T) LT Forced SID Due to Red hot maintenance wor Mithapukur 132/33W SIS TR-2 (414T) HT Forced SID Due to Red hot maintenance wor Saw 09:07 09:08 09:27 10:24 10:23 11:08 09:43 10:14 10:14 10:33 10:29 10:29 18:50 18:50 11:21 10:33 10:56 11:33 11:48 12:00 12:01 12:02 13:01 13:17 13:17 13:17 13:25 14:20 Bogura 400/230K SIS 400 KV Reactor (125 MVAR) Forced SID Due to Due to Increase the voltage level Bogura 400/230K SIS 20 KV BUSA (A1-A2) Project Work SID Due to Due to DFDR commissioning Sonargaon 132/33KV SIS OPSL(EL-2) Forced SID Due to OPSL (gower plant) control panel signal displayed TC1/TC2 faulty CB gas pressure Lock out. Sonargaon 132/33KV SIS OPSL(EL-2) Scheduled SID Due to Control panel signal showing TC1/TC2 faulty CB SF6 gas pressure Lock out. Commissioning SID Commissioning CT2/TC2 faulty CB SF6 gas pressure Lock out. Commissioning CT2/TC2 faulty CB SF6 gas pressure Lock out. Commissioning CT2/TC2 faulty CB SF6 gas pressure Lock out. Commissioning CT2/TC2 faulty CB SF6 gas pressure Lock out. Commissioning CT2/TC2 faulty CB SF6 gas pressure Lock out. CT2 18:48 17:35 14:20 17:35 14:25 14:44 14:45 15:41 17:03 17:22 18:52 18:53 19:03 19:03 19:03 19:59 19:59 15:31 15:32 16:55 20:18 24.0MW load interrup 24.0MW load interrup 22:44 22:44 22:44 20:38 20:56 20:56 21:00 21:06 00:51 21:12 00:55 00:55 00:55 04:39 04:54 04:39 04:39 06:03 06:10 04:55 04:53 06:25 06:25 06:38 06:41 07:00 07:10 06:34 06:33 | Fabilian-Madengan| 152 KV DK-2 Scheduled SID from Fabilian 152/35W end. | Minimum generation 11253 MW | Birapulutian 2301132/35W CM-2 | Minimum generation 11253 MW | Birapulutian 2301132/33W end Due to Project work, and from Bogura 40/025W end Due to DFDR commissioning work | Hisanabas-Statishty 400 CM-1 Forced SID from Shitalabay 132/33W end | Minimum 24/2 Minimum 07:12 07:36 Aminbazar-Kaliakoir 230kV Ckt-1 Scheduled S/D from Kaliakoir 400/230/132kV end Due to BY NLDC

06:47

06:48

Aminbazar-Kaliakoir 230kV Ckt-2 Scheduled S/D from Kaliakoir 400/230/132kV end Due to By NLDC