

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month June, 2024				Day : Saturday				Date : 01.06.24							
Probable Maximum Demand : 15200 MW				Yesterday = 79.53 ft				Today = 80.73 ft				Rule Curve = 76.00 ft			
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	31.05.24 (Yesterday)		01.06.24 (Today)		31.05.24 (Yesterday)		Status of Machines under shut-down/ Maintenance				
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :						
					Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation MW	Machines shut down (MW)		Description/ Remarks	Probable start-up date		
(A) Plants in operation:															
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		Under project work				
2	a) Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage				
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180						
3	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365	Awaiting for HGPI			
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108	Gas Shortage				
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105	Under maint.			
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0						
7	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	370	450	450	450						
8	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling			
9	Haripur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	400	404	402	400	400						
10	Siddhirgonj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage				
11	Siddhirgonj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	318	320	100	320						
12	Meghnaghat 335MW CCGP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	20	150	150	315	Gas Shortage				
13	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	30	55	55	55						
14	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	90	90	90	90						
15	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	0	0						
16	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+1x7.73	80	80	15	43	32	32						
17	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	28	31	33	33						
18	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	24	22	28	29						
19	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	8	8	8						
20	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	34	52	17	50						
21	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	64	149	32	149						
22	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	44	35	54	54						
23	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	20	45	300	300						
24	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	6x18.415+1x8.97	149	149	132	132	135	135						
25	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	17	55	17	55						
26	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	17	55	17	55						
27	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	38	71	70	70						
28	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	90	126	162	162						
29	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	10	0	35	0						
30	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	17	17	35						
31	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	0	0	13						
32	Unique Meghnaghat 584MW CCGP	Gas	1x400+1x184	584	584	232	0	0	0						
	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	0	0	28	23	50	55						
	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	0	0	48	30	80	82						
	Meghnaghat 100 MW(IEL)	HFO (NENP)	12x8.9	0	0	15	12	74	74						
	Meghnaghat 589 MW CCGP(Summit)	Gas		0	0	0	0	0	0						
Dhaka Zone Total				5526	5332	2273	2423	2586	3036	813	845				
33	Karnaphuli Hydro PP Unit-1,2,3,4,5	Hydro (PDB)	2x40, 3x50	230	230	70	65	60	60	165		Inadequate Water Level			
34	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage			
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.			
35	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	5	0	5	0						
36	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	8	8	25						
37	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	14	0	20	0						
38	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	6	6	20						
39	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	20	85	105	105						
40	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.			
41	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	220	220	225	225						
42	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.94	300	300	51	52	52	52						
43	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	23	23	25	25						
44	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	17	85	51	85						
45	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	53	69	50	75						
46	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0						
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			20	34	10	30						
47	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	1	50	44	70						
48	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	35	35	35						
49	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	37	68	85	85						
50	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	24	24	24						
51	Juldah 100 MW Unit-1 (Acom)	HFO (NENP)	8x13.45	100	100	0	0	70	80						
52	Chattogram 116 MW PP (Anlima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	35	72	35	72						
53	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	54	163	54	163						
54	Chattogram 2*612MW Coal Based PP (SS Power)	Coal (IPP)	2x612	1224	1224	480	490	450	490						
55	Matarbari 2*600 MW (CPGCL)	Coal (CPGCL)	1x575	575	575	782	980	980	980						
56	Cox's Bazar Wind PP	(Wind) (IPP)		60	60	4	0	40	40						
	Sonagazi 75 MW Solar Plant	(Solar) (EGCB)				69	0	70	0						
Chattogram Zone Total				4464	4404	1980	2529	2504	2741	345	330				
57	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	0	0	0	0						
58	Ashuganj 225 MW CCGP	Gas (APSCCL)	1x142+1*75	221	221	170	201	200	220						
59	Ashuganj 450 MW CCGP(South)	Gas (APSCCL)	1x360	360	360	230	230	240	240	130		Gas Shortage			
60	Ashuganj 450 MW CCGP(North)	Gas (APSCCL)	1x361	360	360	280	280	280	280	80		Gas Shortage			
61	Ashuganj 420 MW CCGP(East)	Gas (APSCCL)	1x284+1x116	400	400	225	230	230	230	170		Gas Shortage			
62	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*16	195	195	0	0	0	0	195		Gas Shortage			
63	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	43	43	43						
64	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	13	135	70	135						
65	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	35	46	0	45						
66	Chandpur 150 MW CCGP	Gas (PDB)	1X106+1x57	163	163	86	85	85	85						
67	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	34	34	34	36						
68	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0						
69	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	32	31	32	32						
70	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	24	8	16	43						
71	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	17	17	17	17						
72	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	34	70	52	114						
73	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	46	103	46	86						
74	Bharob 54 MW PP	HFO (IPP)	3x18.2	54	54	17	0	17	17						
75	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x5.428	115	115	33	115	33	115						
76	Ashuganj 55 MW PP (Precision)	Gas (NENP)	15*4	55	55	0	0	0	0						
**	Impoport (Tripura)	India		160	160	62	72	146	151						
Cumilla Zone Total				2937	2929	1381	1700	1541	1889	575	0				
77	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	31	36	35	50	166		Gas Shortage			
78	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	87	96	57	80						
79	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	65	101	65	101						
80	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0						
81	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	20	0	50	0						
82	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	6	6	6	6						
Mymensingh Zone Total				600	592	211	239	215	237	166	0				

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	31.05.24 (Yesterday)		01.06.24 (Today)		31.05.24 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)			
83	Fenchugonj CCGP Phase-1	Gas (PDB)	2x32+1x33	97	70	28	30	30	30	40	Under maint.		
84	Fenchugonj CCGP Phase-2	Gas (PDB)	2x35+1x35	104	90	60	58	58	58	32	Under maint.		
85	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	50	53	53	53				
86	Kushiana 163 MW CCGP (KP)	Gas (IPP)	1x109+1x54	163	163	120	120	163	163				
87	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	5	8	8				
88	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	0	31	32	32				
89	Shahjibazar 330 MW CCGP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0	330	Under maint.		
90	Sylhet 225 MW CCGP	Gas (PDB)	1x142+1x89	231	231	206	208	210	210				
91	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0	20	Under maint.		
92	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16				
93	Bibiana-II 341 MW CCGP (Summit)	Gas (IPP)	1x222+1x119	341	341	270	295	310	310				
94	Bibiyana-III 400 MW CCGP	Gas (PDB)	1x285+1x115	400	400	318	365	300	400				
95	Bibiyana South 383 MW CCGP	Gas (PDB)	1x252+1x131	383	383	340	360	320	360				
96	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0			Test run	
97	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3+5*2	50	50	42	43	43	43				
Sylhet Zone Total					2376	2331	1458	1584	1543	1683	0	422	
98	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
99	Bheramara 410 MW CCGP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	355	340	350	410				
100	Fardpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	42	30	45				
101	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	65	50	60				
102	Khulina 225 MW CCGP	HSD/ Gas (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	0				
103	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	54	53	89				
104	Machumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	0	0	0				
105	Monira Orion 100 MW Solar PP	Solar (IPP)	100	100	100	44	0	100	0				
106	Maitree Super Thermal 1320 MW PP	Coal (BIFPCL)	2x617	1234	1234	395	618	530	640				
107	Khulina 330 MW CCGP	Gas/HSD (B/PDB)	1x220+1x116	336	336	0	0	0	0				
108	Nocapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5x8.5	0	0	0	0	32	40				
109	Khulina 115 PP MW (KPCL-2)	HFO (NENP)	7x17	0	0	0	16	20	90				
**	Bheramara (HVDC)	India	1000	1000	911	625	929	784	784				
Khulina Zone Total					3703	3699	1705	1760	2094	2158	0	0	
108	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	48	0	110				
109	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	10	6	8	10	10				
110	Bhola 225 MW CCGP	Gas (PDB)	2x63+1x68	194	194	80	130	130	130	64	ST under maint.		
111	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	410	590	620	620				
112	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	17	35				
113	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	140	140	140	140				
114	Bhola 220MW CCGP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	180	220	200	220				
Barishal Zone Total					2265	2235	816	1136	1117	1265	0	64	
115	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71	Gas Shortage		
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100	Under maint.		
116	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	24	30	32				
117	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	10	0	25				
118	Chapanawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	88	0	90				
119	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	46	0	43				
120	Katakali 50 MW PP (Northern)	HFO (NENP)	6x8.9	50	50	0	0	0	0				
121	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	28	0	28				
122	Sirajgonj 225MW CCGP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	155	171	190	190				
123	Sirajgonj 225MW CCGP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	0	0	0	0	220	Gas Shortage		
124	Sirajgonj 225MW CCGP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	0	0	0	0	220	Gas Shortage		
125	Sirajgonj 400 MW CCGP Unit-4	Gas (IPP)	1x282+1x132	414	414	349	348	414	414				
126	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	5	5	5	8				
127	Natore 52 MW PP (Rajjanka)	HFO (IPP)	6x8.92	52	52	0	0	0	0				
128	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	35	113	113				
129	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	35	94	94				
130	Ammura 50 MW PP (Sinha)	HFO (NENP)	7x7.79	50	28	0	0	14	28				
131	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	0	0	6	0				
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	917	1364	1200	1400				
Raishahi Zone Total					3453	3431	1426	2154	2066	2465	511	100	
132	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	60	58	60	62				
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Under Overhauling		
133	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	230	230	230	230				
134	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
135	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x.2*3	113	113	0	100	70	106				
136	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
137	Majpara Tahsil 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0				
138	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	115	35	115				
139	Lalmonirhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	0	0	30	0				
140	Teesa Solar Limited	Solar (IPP)	1 x 200	200	200	69	0	130	0				
Rangpur Zone Total					1030	950	364	503	563	513	0	85	
Sub-total: Plants in operation					26354	25903	11614.0	14028	14229	15987	2410	1846	
(B) Plants under long term maintenance/ contract expired													
141	Katobdi 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			Contract Expired	
142	Haripur 360MW CCGP(HPL)	Gas (IPP)	1x235+1x125	360	0	0	0	0	0			Contract Expired	
143	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			Contract Expired	
144	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	0	0	0	0	0			Contract Expired	
145	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Contract Expired	
Sub-Total: Plants under long term maintenance/ contract expired					700	0	0	0	0	0	0	0	
Gross Total					27054	25903	11614	14028	14229	15987	2410	1846	
(C) Actual data of 31.05.24 (Yesterday) Friday :													
01.	Max. Demand at eve. peak (Generation end)	: 14200 MW, at = 21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :										
02.	Max. Demand at eve. peak (Sub-station end)	: 13654 MW, at = 21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW			
03.	Highest Generation (Generation end)	: 14231 MW, at = 24:00	Dhaka	4901	4806	95	Mymensingh	1155	1086	69			
04.	Minimum Generation (Generation end)	: 11003 MW, at = 8:00 hrs	Chattogram	1363	1363	0	Sylhet	563	563	0			
05.	Day-peak Generation (Generation end)	: 11614 MW, at = 12:00 hrs	Khulina	1681	1681	0	Barishal	350	350	0			
06.	Evening-peak Generation (Generation end)	: 14028 MW, at = 21:00 hrs	Rajshahi	1409	1409	0	Rangpur	864	864	0			
07.	Evening Peak Load-shed (Sub-station end)	: 164 MW, at = 21:00 hrs	Cumilla	1368	1368	0							
08.	Minimum Generation Forecast up to 8:00 hrs.	: 11903 MW, at = 5:00 hrs											
09.	Generation shortfall at evening peak due to :	:											
a)	Gas/LF limitation	: 2245 MW											
d)	Coal supply Limitation	: 0 MW											
b)	Low water level in Kaptai lake	: 165 MW											
c)	Plants under shut down/ maintenance	: 1846 MW											
10.	Total Energy (Generation + India Import)	: 304.01 MCKWh											
	By Gas = 135.986 MCKWh	By Oil = 47.514 MCKWh											
	By Coal = 94.642 MCKWh	By Hydro = 1.630 MCKWh											
	By Solar = 2.292 MCKWh												
11.	Total Gas Supplied	: 1003.73 MCMCFD											
(D) Forecast of 01.06.24 (Today) Saturday :													
01.	Maximum Demand	: 15200 MW (Generation end)	04. Maximum Load-shed : 0 MW At evening peak (Sub-station end)										
02.	Maximum Generation	: 15987 MW (Generation end)	05. Total Generation : 324.71 MCKWh										
03.	Reserve / Shortage	: 787 MW (Generation end)	06. Probable Max. Temperature in Dhaka : 27.1°C										

* Captive Power ** Imported Power
#Remarks: Highest Generation 16477 MW on 30-04-2024 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation