

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month June, 2024				Day : Sunday				Date : 02.06.24				
Probable Maximum Demand : 16500 MW				Probable Maximum Generation : 16807 MW								
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 80.73 ft				Today = 81.34 ft				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	01.06.24 (Yesterday)		02.06.24 (Today)		01.06.24 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
					Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation MW	Machines shut down (MW)		Description/ Remarks
(A) Plants in operation:												
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		Under project work	
2	a) Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180			
3	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365	Awaiting for HGPI
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108	Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105	Under maint.
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	420	450	450	450			
8	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling
9	Haripur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	400	391	392	400	400			
10	Siddhirgonj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage	
11	Siddhirgonj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	170	314	320	320			
12	Meghnaghat 335MW CCGP(Summit)	Gas (IPP)	2x110+1x110	335	335	147	138	150	150	197		Gas Shortage
13	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	30	55	30	55			
14	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	90	16	24	90			
15	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	0	0			
16	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+1x7.73	80	80	37	37	32	32			
17	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	28	33	33	33			
18	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	18	10	28	29			
19	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	8	8	8			
20	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	35	52	17	50			
21	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	64	147	48	149			
22	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	54	54	54			
23	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	95	276	300	300			
24	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	6x18.415+1x8.97	149	149	74	133	115	135			
25	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	17	55	17	55			
26	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	17	55	17	55			
27	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	63	69	70	70			
28	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	108	162	162	162			
29	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	33	0	35	0			
30	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	17	17	35			
31	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	18	0	13			
32	Unique Meghnaghat 584MW CCGP	Gas	1x400+1x184	584	584	0	0	0	0	584	Gas Shortage	
	Siddhirgonj 100 MW PP (Dutch Bangla)	HFO (NENP)	12x8.9	0	0	50	43	50	55			
	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	0	0	80	80	80	82			
	Meghnaghat 100 MW(HEL)	HFO (NENP)	12x8.9	0	0	8	77	74	74			
	Meghnaghat 589 MW CCGP(Summit)	Gas		0	0	0	0	0	0			Under Maintenance
Dhaka Zone Total				5526	5332	2197	2871	2711	3036	1279	845	
33	Karnaphuli Hydro PP Unit-1,2,3,4,5	Hydro (PDB)	2x40, 3x50	230	230	60	60	60	60	170		Inadequate Water Level
34	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.
35	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	2	0	5	0				
36	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	17	8	25			
37	Teknaf 20MW PP (Solaritech)	Solar (IPP)	1x20	20	20	13	0	20	0			
38	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	27	6	20			
39	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	105	51	51	105			
40	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.
41	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	219	219	225	225			
42	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.94	300	300	52	51	52	52			
43	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	22	22	25	25			
44	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	51	85	51	85			
45	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	40	69	50	75			
46	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0			
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			3	15	10	30			
47	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	31	38	44	70			
48	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	35	35	35	35			
49	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	90	92	85	85			
50	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	24	24	24	24			
51	Juldah 100 MW Unit-1 (Acom)	HFO (NENP)	8x13.45	100	100	36	78	70	80			
52	Chattogram 116 MW PP (Anlima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	35	73	35	72			
53	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	54	163	54	163			
54	Chattogram 2*612MW Coal Based PP (SS Power)	Coal (IPP)	2x612	1224	1224	494	490	450	490			
55	Matarbari 2*600 MW (CPGCL)	Coal (CPGCL)	1x575	575	575	940	960	980	980			
56	Cox's Bazar Wind PP	(Wind) (IPP)		60	60	9	0	40	40			
	Sonagazi 75 MW Solar Plant	(Solar) (EGCB)				43	0	70	0			
Chattogram Zone Total				4464	4404	2364	2575	2450	2741	350	330	
57	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	0	0	0	0	45		Gas Shortage
58	Ashuganj 225 MW CCGP	Gas (APSCCL)	1x142+1*75	221	221	213	200	215	200			
59	Ashuganj 450 MW CCGP(South)	Gas (APSCCL)	1x360	360	360	230	300	300	300			
60	Ashuganj 450 MW CCGP(North)	Gas (APSCCL)	1x361	360	360	280	280	280	280			
61	Ashuganj 420 MW CCGP(East)	Gas (APSCCL)	1x284+1x116	400	400	255	230	230	230	170		Gas Shortage
62	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*16	195	195	0	0	0	0	195		Gas Shortage
63	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	43	43	43			
64	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	70	95	70	135			
65	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	43	45	45	45			
66	Chandpur 150 MW CCGP	Gas (PDB)	1X106+1x57	163	163	89	80	85	85			
67	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	34	148	100	150			
68	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0			
69	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	24	32	32	32			
70	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	12	34	25	43			
71	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	15	15	17	17			
72	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	52	97	52	114			
73	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	47	84	46	86			
74	Bharob 54 MW PP	HFO (IPP)	3x18.2	54	54	0	17	17	17			
75	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x5.428	115	115	33	115	50	115			
76	Ashuganj 55 MW PP (Precision)	Gas (NENP)	15*4	55	55	0	0	0	0			
**	Impoport (Tripura)	India		160	160	88	88	146	151			
Cumilla Zone Total				2937	2929	1528	1903	1753	2043	410	0	
77	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	28	33	35	45	169		Gas Shortage
78	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	86	95	80	95			
79	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	65	101	65	101			
80	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0			
81	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	51	0	50	0			
82	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	6	0	6	6			
Mymensingh Zone Total				600	592	237	229	238	247	169	0	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	01.06.24 (Yesterday)		02.06.24 (Today)		01.06.24 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :				
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)		Description/ Remarks	Probable start-up date
83	Fenchugonj CCGP Phase-1	Gas (PDB)	2x32+1x33	97	70	28	29	30	30		41	Under maint.	
84	Fenchugonj CCGP Phase-2	Gas (PDB)	2x35+1x35	104	90	58	58	58	58		32	Under maint.	
85	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	52	53	53	53				
86	Kushiana 163 MW CCGP (KP)	Gas (IPP)	1x109+1x54	163	163	120	163	163	163				
87	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	9	5	8	8				
88	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	55	56	56	56				
89	Shahjibazar 330 MW CCGP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
90	Sylhet 225 MW CCGP	Gas (PDB)	1x142+1x89	231	231	205	207	210	210				
91	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0		20	Under maint.	
92	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16				
93	Bibiana-II 341 MW CCGP (Summit)	Gas (IPP)	1x222+1x119	341	341	280	280	310	310				
94	Bibiana-III 400 MW CCGP	Gas (PDB)	1x285+1x115	400	400	320	0	0	0		400	Under maint.	
95	Bibiyana South 383 MW CCGP	Gas (PDB)	1x252+1x131	383	383	356	365	320	360				
96	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0			Test run	
97	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	42	38	43	43				
Sylhet Zone Total					2376	2331	1540	1270	1267	1307	0	823	
98	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
99	Bheramara 410 MW CCGP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	295	250	300	300				
100	Fardpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	34	30	45				
101	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	64	50	60				
102	Khulina 225 MW CCGP	HSD/ Gas (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	0				
103	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	91	53	89				
104	Machumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	0	0	0				
105	Monira Orion 100 MW Solar PP	Solar (IPP)		100	100	46	0	100	0				
106	Maitree Super Thermal 1320 MW PP	Coal (BIFPCL)	2x617	1234	1234	936	1025	1000	1200				
107	Khulina 330 MW CCGP	Gas/HSD (B/PDB)	1x220+1x116	336	336	0	0	0	0				
108	Nocapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5x8.5	0	0	0	24	32	40				
109	Khulina 115 PP MW (KPCL-2)	HFO (NENP)	7x17	0	0	0	23	20	90				
**	Bheramara (HVDC)	India		1000	1000	913	765	931	786				
Khulina Zone Total					3703	3699	2207	2276	2516	2610	0	0	
108	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	32	0	110				
109	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	10	6	6	10	10				
110	Bhola 225 MW CCGP	Gas (PDB)	2x63+1x68	194	194	120	126	130	130		68	ST under maint.	
111	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	510	810	950	1200				
112	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	17	35				
113	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	140	140	140	140				
114	Bhola 220MW CCGP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	220	220				
Barishal Zone Total					2265	2235	996	1334	1467	1845	0	68	
115	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.	
116	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	32	30	32				
117	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	5	0	25				
118	Chapanawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	55	86	50	90				
119	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	46	0	43				
120	Katakali 50 MW PP (Northern)	HFO (NENP)	6x8.9	50	50	0	0	0	0				
121	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	30	0	28				
122	Sirajgonj 225MW CCGP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	193	160	190	190				
123	Sirajgonj 225MW CCGP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	0	0	0	0		220	Gas Shortage	
124	Sirajgonj 225MW CCGP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	0	0	0	0		220	Gas Shortage	
125	Sirajgonj 400 MW CCGP Unit-4	Gas (IPP)	1x282+1x132	414	414	315	414	414	414				
126	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	5	8	5	8				
127	Natore 52 MW PP (Rajjanka)	HFO (IPP)	6x8.92	52	52	0	0	0	0				
128	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	113	113	113				
129	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	92	94	94				
130	Amnura 50 MW PP (Sinha)	HFO (NENP)	7x7.79	50	28	14	28	14	28				
131	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	5	0	6	0				
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	1202	1369	1200	1400				
Rajshahi Zone Total					3453	3431	1789	2383	2116	2465	511	100	
132	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	60	58	60	62				
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
133	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	230	220	230	230				
134	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
135	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x.2*3	113	113	34	102	70	106				
136	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
137	Majpara Tahsil 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	0	0	8	0				
138	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	35	115	35	115				
139	Lalmoinhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	24	0	30	0				
140	Teesa Solar Limited	Solar (IPP)	1 x 200	200	200	194	0	130	0				
Rangpur Zone Total					1030	950	577	495	563	513	0	85	
Sub-total: Plants in operation					26354	25903	13435.0	15336	15081	16807	2719	2251	
(B) Plants under long term maintenance/ contract expired													
141	Katobdi 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			Contract Expired	
142	Haripur 360MW CCGP(HPL)	Gas (IPP)	1x235+1x125	360	0	0	0	0	0			Contract Expired	
143	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			Contract Expired	
144	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	0	0	0	0	0			Contract Expired	
145	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Contract Expired	
Sub-Total: Plants under long term maintenance/ contract expired					700	0	0	0	0	0	0	0	
Gross Total					27054	25903	13435	15336	15081	16807	2719	2251	
(C) Actual data of 01.06.24 (Yesterday) Saturday :													
01.	Max. Demand at eve. peak (Generation end)	: 15750 MW, at = 21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :										
02.	Max. Demand at eve. peak (Sub-station end)	: 15151 MW, at = 21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW			
03.	Highest Generation (Generation end)	: 15336 MW, at = 21:00 hrs	Dhaka	5599	5419	140	Mymensingh	1238	1028	210			
04.	Minimum Generation (Generation end)	: 11903 MW, at = 8:00 hrs	Chattogram	1563	1563	0	Sylhet	630	610	20			
05.	Day-peak Generation (Generation end)	: 13435 MW, at = 12:00 hrs	Khulina	1897	1897	0	Barishal	407	407	0			
06.	Evening-peak Generation (Generation end)	: 15336 MW, at = 21:00 hrs	Rajshahi	1590	1590	0	Rangpur	715	715	0			
07.	Evening Peak Load-shed (Sub-station end)	: 395 MW, at = 21:00 hrs	Cumilla	1552	1527	25	Total	15151	14756	395			
08.	Minimum Generation Forecast up to 8:00 hrs.	: 12504 MW, at = 5:00 hrs	13. Fuel cost : (a) Gas = 407561993 Taka (c) Coal = 754467992 Taka (b) Oil = 1001363697 Taka Total = 2163393683 Taka										
09.	Generation shortfall at evening peak due to :		14. Maximum Temperature in Dhaka was : 36.5°C										
a)	Gas/LF limitation	: 2549 MW	15. Export through East-West interconnections :										
d)	Coal supply Limitation	: 0 MW	At evening peak-hour : 13435 MW, at 21:00 hrs										
b)	Low water level in Kaptai lake	: 170 MW	Maximum : 906 MW, at 19:30 hrs										
c)	Plants under shut down/ maintenance	: 2251 MW	Energy : 9266.4 MKWh										
10.	Total Energy (Generation + India Import)	: 327.47 MKWh	By Gas = 133.147 MKWh By Oil = 55.027 MKWh										
			By Coal = 111.423 MKWh By Hydro = 1.717 MKWh										
			By Solar = 3.100 MKWh										
11.	Total Gas Supplied	: 963.79 MMCFD											
(D) Forecast of 02.06.24 (Today) Sunday :													
01.	Maximum Demand	: 16500 MW (Generation end)	04. Maximum Load-shed : 0 MW At evening peak (Sub-station end)										
02.	Maximum Generation	: 16807 MW (Generation end)	05. Total Generation : 352.33 MKWh										
03.	Reserve / Shortage	: 307 MW (Generation end)	06. Probable Max. Temperature in Dhaka : 36.5°C										

* Captive Power ** Imported Power
#Remarks: Highest Generation 16477 MW on 30-04-2024 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation