

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month June, 2024				Day : Sunday				Date : 09.06.24				
Probable Maximum Demand : 16900 MW				Probable Maximum Generation : 16300 MW								
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 81.17 ft				Today = 81.20 ft				
				Rule Curve = 78.08 ft								
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	08.06.24 (Yesterday)		09.06.24 (Today)		08.06.24 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
					Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation MW	Machines shut down (MW)		Description/ Remarks
(A) Plants in operation:												
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		Under project work	
2	a) Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180			
3	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365	Awaiting for HGPI
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108		Gas Shortage
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0			
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	420	450			
8	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling
9	Haripur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	400	401	400	400	400			
10	Siddhirgonj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage
11	Siddhirgonj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	317	316	290	330			
12	Meghnaghat 335MW CCGP(Summit)	Gas (IPP)	2x110+1x110	335	335	152	150	150	150	185		Gas Shortage
13	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	30	55	55	55			
14	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	24	81	82	82			
15	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	0	0			
16	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+1x7.73	80	80	36	36	33	36			
17	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	32	33	33			
18	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	18	19	20	28			
19	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	33	32	8	8			
20	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	52	52	52	52			
21	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	48	147	48	150			
22	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	0	54	54			
23	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	240	270	270			
24	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	6x18.415+1x8.97	149	149	91	97	90	97			
25	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	55	55	17	55			
26	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	17	55	35	55			
27	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	51	71	50	70			
28	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	0	162	162	162			
29	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	32	0	35	0			
30	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	35	35	34	35			
31	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	25	0	25			
32	Unique Meghnaghat 584MW CCGP	Gas	1x400+1x184	584	584	0	0	0	0	584		Gas Shortage
	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	0	0	25	72	70	76			
	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	0	0	12	20	65	65			
	Meghnaghat 100 MW(HEL)	HFO (NENP)	12x8.9	0	0	19	90	90	90			
	Meghnaghat 589 MW CCGP(Summit)	Gas				0	0	0	0	589		Gas Shortage
Dhaka Zone Total				5526	5332	2111	2872	2743	3008	1856	740	
33	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	115	113	115	115	117		Inadequate Water Level
34	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.
35	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	2	0	5	0	0			
36	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	17	8	17			
37	Teknaf 20MW PP (Solaritech)	Solar (IPP)	1x20	20	20	3	0	20	0			
38	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	19	6	18			
39	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	34	51	51	51			
40	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.
41	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	220	219	220	220			
42	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.94	300	300	51	52	52	52			
43	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	25	25	25			
44	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	34	85	50	85			
45	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	46	58	32	64			
46	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0			
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			3	26	15	20			
47	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	32	38	30	38			
48	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	35	35	35			
49	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	34	110	85	110			
50	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	25	24	25			
51	Juldah 100 MW Unit-1 (Acom)	HFO (NENP)	8x13.45	100	100	12	70	70	70			
52	Chattogram 116 MW PP (Anlima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	53	35	53			
53	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	17	125	54	163			
54	Chattogram 2*612MW Coal Based PP (SS Power)	Coal (IPP)	2x612	1224	1224	440	470	470	470			
55	Matarbari 2*600 MW (CPGCL)	Coal (CPGCL)	1x575	575	575	748	624	700	700			
56	Cox's Bazar Wind PP	(Wind) (IPP)		60	60	32	17	40	40			
	Sonagazi 75 MW Solar Plant	(Solar) (EGCB)				34	0	70	0			
Chattogram Zone Total				4464	4404	1924	2232	2212	2371	297	330	
57	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	0	0	10	10	45		Gas Shortage
58	Ashuganj 225 MW CCGP	Gas (APSCCL)	1x142+1*75	221	221	214	217	200	220			
59	Ashuganj 450 MW CCGP(South)	Gas (APSCCL)	1x360	360	360	240	300	280	280			
60	Ashuganj 450 MW CCGP(North)	Gas (APSCCL)	1x361	360	360	280	300	280	300			
61	Ashuganj 420 MW CCGP(East)	Gas (APSCCL)	1x284+1x116	400	400	230	245	240	250	155		Gas Shortage
62	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*16	195	195	0	8	8	8	187		Gas Shortage
63	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	51	43	51			
64	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	50	122	130	130			
65	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	35	41	40	41			
66	Chandpur 150 MW CCGP	Gas (PDB)	1X106+1x57	163	163	0	80	80	80			
67	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	17	17	17			
68	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0			
69	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	32	32	32	32			
70	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	16	51	25	51			
71	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	6	6	6	6			
72	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	17	17	17			
73	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	39	75	37	75			
74	Bharob 54 MW PP	HFO (IPP)	3x18.2	54	54	0	17	17	17			
75	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x5.428	115	115	50	115	115	115			
76	Ashuganj 55 MW PP (Precision)	Gas (NENP)	15*4	55	55	0	0	0	0			
**	Impoport (Tripura)	India		160	160	82	78	146	151			
Cumilla Zone Total				2937	2929	1351	1772	1723	1851	387	0	
77	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	28	34	30	40	168		Gas Shortage
78	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	59	78	60	80			
79	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	93	120	90	120			
80	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
81	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	46	0	50	0			
82	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	6	12	6	12			
Mymensingh Zone Total				600	592	234	244	238	252	168	0	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	08.06.24 (Yesterday)		09.06.24 (Today)		08.06.24 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)			
83	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	41	41	40	40		29	Under maint.	
84	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	48	48	48	48		42	Under maint.	
85	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	53	53	53	53				
86	Kushiana 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163				
87	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	5	5	5				
88	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	61	56	56	60				
89	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
90	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	205	204	210	210				
91	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0		20	Under maint.	
92	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	14	16	16				
93	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	290	280	300				
94	Bibiyana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	367	367	350	380				
95	Bibiyana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	383	340	320	340				
96	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0			Under Construction Project	
97	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3+5*2	50	50	34	39	40	40				
Sylhet Zone Total					2376	2331	1679	1620	1581	1655	0	421	
98	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
99	Bheramara 410 MW CAPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	215	190	200	200		220	Gas shortage	
100	Fardpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	41	30	50				
101	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	45	50	60				
102	Khulina 225 MW CAPP	HSD/ Gas (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	0				
103	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	36	36	17	53				
104	Machumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	0	0	0				
105	Monira Orion 100 MW Solar PP	Solar (IPP)		100	100	84	0	100	0				
106	Maitree Super Thermal 1320 MW PP	Coal (BIFPCL)	2x617	1234	1234	405	1013	1000	1000				
107	Khulina 330 MW CAPP	Gas/HSD (B/PDB)	1x220+1x116	336	336	0	0	0	0				
108	Nocapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5x8.5	0	0	0	40	32	40				
109	Khulina 115 PP MW (KPCL-2)	HFO (NENP)	7x17	0	0	0	46	20	50				
**	Bheramara (HVDC)	India		1000	1000	923	779	943	801				
Khulina Zone Total					3703	3699	1663	2190	2392	2254	220	0	
108	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	16	16	110				
109	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	0	10	10	10				
110	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	126	126	130	130		68	ST under maint.	
111	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	860	1244	1000	1244				
112	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	17	35				
113	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	299	307	307	307				
114	Bhola 220MW CAPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	220	220				
Barishal Zone Total					2265	2235	1505	1923	1700	2056	0	68	
115	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.	
116	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	40	0	40				
117	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	10	0	10				
118	Chapanawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	88	50	88				
119	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	45	0	45				
120	Katakali 50 MW PP (Northern)	HFO (NENP)	6x8.9	50	50	0	0	0	0				
121	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	36	0	30				
122	Sirajgonj 225MW CAPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	160	140	150	150		70	Gas Shortage	
123	Sirajgonj 225MW CAPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	0	0	0	0		220	Gas Shortage	
124	Sirajgonj 225MW CAPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	0	0	0	0		220	Gas Shortage	
125	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	350	340	300	350		74	Gas Shortage	
126	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	5	5	5	5				
127	Natore 52 MW PP (Rajjanka)	HFO (IPP)	6x8.92	52	52	0	0	0	0				
128	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	113	113	113				
129	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	113	94	113				
130	Ammura 50 MW PP (Sinha)	HFO (NENP)	7x7.79	50	28	0	35	14	35				
131	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	2	0	6	0				
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	1209	1456	1200	1400				
Raishahi Zone Total					3453	3431	1726	2421	1932	2379	655	100	
132	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	63	61	60	64				
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
133	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	220	210	210	210				
134	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
135	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x.2*3	113	113	34	106	70	106				
136	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
137	Majpara Tabilis 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	2	0	8	0				
138	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	35	94	35	94				
139	Lalmonirhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	28	0	30	0				
140	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	106	0	130	0				
Rangpur Zone Total					1030	950	488	471	543	474	0	85	
Sub-total: Plants in operation					26354	25903	12681.0	15745	15064	16300	3583	1744	
(B) Plants under long term maintenance/ contract expired													
141	Katobdi 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			Contract Expired	
142	Haripur 360MW CAPP(HPL)	Gas (IPP)	1x235+1x125	360	0	0	0	0	0			Contract Expired	
143	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			Contract Expired	
144	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	0	0	0	0	0			Contract Expired	
145	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Contract Expired	
Sub-Total: Plants under long term maintenance/ contract expired					700	0	0	0	0	0	0	0	
Gross Total					27054	25903	12681	15745	15064	16300	3583	1744	
(C) Actual data of 08.06.24 (Yesterday) Saturday :													
01.	Max. Demand at eve. peak (Generation end)	: 16400 MW, at = 21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :										
02.	Max. Demand at eve. peak (Sub-station end)	: 15631 MW, at = 21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW			
03.	Highest Generation (Generation end)	: 15745 MW, at = 21:00 hrs	Dhaka	5578	5423	155	Mymensingh	1226	1036	190			
04.	Minimum Generation (Generation end)	: 11237 MW, at = 8:00 hrs	Chattogram	1473	1407	66	Sylhet	594	594	0			
05.	Day-peak Generation (Generation end)	: 12681 MW, at = 12:00 hrs	Khulina	2039	2024	15	Barishal	516	516	0			
06.	Evening-peak Generation (Generation end)	: 15745 MW, at = 21:00 hrs	Rajshahi	1644	1644	0	Rangpur	1052	985	67			
07.	Evening Peak Load-shed (Sub-station end)	: 626 MW, at = 21:00 hrs	Cumilla	1509	1376	133	Total	15631	15005	626			
08.	Minimum Generation Forecast up to 8:00 hrs.	: 12608 MW, at = 5:00 hrs											
09.	Generation shortfall at evening peak due to :	:											
a)	Gas/LF limitation	: 3466 MW											
d)	Coal supply Limitation	: 0 MW											
b)	Low water level in Kaptai lake	: 117 MW											
c)	Plants under shut down/ maintenance	: 1744 MW											
10.	Total Energy (Generation + India Import)	: 323.24 MKWh											
	By Gas = 133.042 MKWh	By Oil = 47.927 MKWh											
	By Coal = 113.378 MKWh	By Hydro = 2.651 MKWh											
	By Solar = 2.800 MKWh												
11.	Total Gas Supplied	: 975.65 MMCFD											
(D) Forecast of 09.06.24 (Today) Sunday :													
01.	Maximum Demand	: 16900 MW (Generation end)	04. Maximum Load-shed : 568 MW At evening peak (Sub-station end)										
02.	Maximum Generation	: 16300 MW (Generation end)	05. Total Generation : 346.96 MKWh										
03.	Reserve / Shortage	: -600 MW (Generation end)	06. Probable Max. Temperature in Dhaka : 35.6°C										

#Remarks: Highest Generation 16477 MW on 30-04-2024 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation