

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity		Peak Hour Generation		Energy Generated	Remarks
				Unit No. X Capacity	MW	MW	KWH		
1	Ghorasal Repowered CCPP-Unit-3 (GT)	PDB	1260	260	0	0	0	Under maint.	
2	Ghorasal Repowered CCPP Unit-4	PDB	1210	180	0	0	0	Gas shortage	
3	Ghorasal TPP Unit-5	PDB	1210	190	180	0	4221000		
4	Ghorasal 365 MW CCPP Unit-7	PDB	1243*1122	365	0	0	0	Air Compressor problem	
5	Ghorasal 75 MW PP (IMAX)	QRPP	240	0	0	0	0	Contract Expired	
6	Ghorasal 108 MW PP (Regent)	IPP	343.35	108	0	0	0	Gas shortage	
7	Haripur GTPP	SBU, PDB	232	20	0	0	0	Under maint.	
8	Haripur 412 MW CCPP	EGCB	1273*1139	400	372	0	9619200	Gas shortage	
9	Haripur 360 MW CCPP(HPL)	IPP	1235*1125	0	0	0	0	Contract Expired	
10	Meghnaghat 450 MW CCPP(MPL)	IPP	2150*1150	450	420	0	8852000	Gas shortage	
11	Meghnaghat 100 MW (Acrom)	NEP	129.9	61	0	0	800520	Fuel shortage	
12	Meghnaghat CCPP(Summit)	IPP	2110*1110	335	147	0	3447825	GT-1 Under Maint	
13	Madanganj 102 PP(Summit)	NENP	617	102	65	0	902011	Fuel shortage	
14	Madanganj-55 MW PP(Summit)	IPP	317.08*111.3	55	55	0	1057268		
15	Keranganj 100 MW PP (Powerpac)	IPP	813.45	75	13	0	650000	Engine problem	
16	Narshing 22 MW PP (Acrom)	SIPP, REB	82.90	22	0	0	0	Contract Expired	
17	210 MW Siddhirgonj TPP	PDB	1210	115	0	0	0	Under maint.	
18	Siddhirgonj 2120 MW GTPP	EGCB	2105	210	0	0	0	Gas shortage	
19	Siddhirgonj 100 PP(Dutch Bangla)	NENP	129.9	100	70	0	904320	Fuel shortage	
20	Siddhirgonj 335 MW CCPP	EGCB	1217*1118	335	320	0	7616767		
21	Copazang 102 MW PP (Digital Power)	IPP	129.924	102	0	0	1254240	Engine problem	
22	Katpott 52 MW PP (Sinha)	IPP	77.9	0	0	0	0	Fuel shortage	
23	Kamalaghat 54 MW PP(Banco Energy)	IPP	318	54	54	0	489960	Fuel shortage	
24	Kodda 150 MW PP	BPDB-RPCL	917.06	149	148	0	1723680		
25	Manikganj 55 MW PP (Northern)	IPP	319.3	55	55	0	670749		
26	Nababganj 55 MW PP (Southern power)	IPP	319.3	55	35	0	636385		
27	Bosila 108 MW PP(CLCL)	IPP	128.775*13.5	0	0	0	0		
28	Summit Power (Madhabdi+Ashulia)	SIPP, REB	33.67*48.73	80	31	0	555240	Engine problem	
29	Maona 33 MW PP(Summit)	SIPP, REB	48.73	33	17	0	392400	Engine problem	
30	Rupaganj 33 MW PP(Summit)	SIPP, REB	48.73	33	10	0	231500	Engine problem	
31	Gazipur 52 MW PP	RPCL	61.9	52	0	0	134400	Fuel shortage	
32	Tongi 80 MW GTPP	PDB	1105	105	0	0	0	Gas shortage	
33	Kodda 300 MW PP Unit-2 (Summit)	IPP	1817.076	300	275	0	3570435	Engine problem	
34	Bramhangonj 100 MW PP (Aggreko)	IPP	1140.959	0	0	0	0	Contract Expired	
35	Auraha 100MW PP (Aggreko)	IPP	0.8523*0.9691	0	0	0	0	Contract Expired	
36	Kodda 149 MW PP Unit-1 (Summit)	IPP	818.8297	149	47	0	2087280	Engine problem	
37	Gazipur 100 MW PP	RPCL	61.75	105	52	0	767040	Fuel shortage	
38	Meghnaghat 104 MW PP (OPCL)	IPP	18.56	104	70	0	1317120	Fuel shortage	
39	Manikgonj 162MW PP(MPGL)	IPP	918	162	162	0	1239840		
40	Spectra Solar Plant Ltd.	IPP	35	35	0	0	136290		
41	Kanchan Ritesha Power Generation Ltd.	IPP	18.13	65	17	0	566280	Engine problem	
42	Meghnaghat Unique power	IPP	588	584	0	0	0	Under maint.	
43	Summit Meghnaghat-2 589 MW(Gas)	IPP	589	0	0	0	0		
Dhaka area Total				5634	2781		53263750		
39	Chattogram TPP-1	PDB	1210	180	0	0	0	Gas shortage	
40	Chattogram TPP-2	PDB	1210	180	0	0	0		
41	Razzan 25 MW PP	RPCL	39.9	25	6	0	98573	Fuel shortage	
42	Teknaf 20MW PP (SolarTech)	IPP	20	20	0	0	30240		
43	Patenga 50MW PP (Baraka)	IPP	619.98	50	6	0	39840	Fuel shortage	
44	Kapali Hydro Unit-1,2,3,4,5	PDB	240*350	230	112	0	2761720	Low water level	
45	Sikalbaha 225MW	PDB	1150*1175	225	223	0	5215949		
46	Sikalbaha Peaking GT	PDB	1150	150	0	0	0	Under maint.	
47	Sikalbaha 105 MW PP (Baraka Sikalbaha)	IPP	6117.5	105	51	0	922509	Fuel shortage	
48	Hathazari 100 MW peaking PP	PDB	1118.9	98	72	0	653560	Fuel shortage	
49	Dohazari-Kalash 100 MW Peaking	PDB	617	102	75	0	841767	Engine problem	
50	Julidah 100 MW Unit-1 (Acrom)	NENP	813.45	105	12	0	165120	Low demand	
51	Julidah 100 MW PP Unit-3 (Acrom)	IPP	813.5	100	24	0	574080	Fuel shortage	
52	Barabkunda 22 MW PP (Regent)	SIPP, PDB	82.90	0	0	0	0	Contract Expired	
53	Malanha, Clg. EPZ (Uniled)	IPP	58.73*39.34	0	42	0	813120		
54	Chattogram 108 MW PP (ECPV)	IPP	167	108	25	0	490560	Fuel shortage	
55	Kapali 7 MW Solar PP	PDB	7.4 MW	7	0	0	16801		
56	Anwara 300 MW PP (Uniled)	IPP	1717*24	300	50	0	1254545	Fuel shortage	
57	Jodiach Power	IPP	318.55*13.6	54	17	0	189532	Fuel shortage	
58	Karnaphuli Power Ltd.	IPP	18.415*6.65	110	108	0	1384180		
59	Julidah unit-2 (Acrom)	IPP	813.6	100	24	0	581760	Fuel shortage	
60	Anilima Energy Ltd.	IPP	621.2	116	35	0	720109	Fuel shortage	
61	Mirshar 150 MW	BPDB-RPCL	18.59	163	145	0	826327	Engine problem	
62	SS Power 1	SS Power	2612	1224	1070	0	24518178	Unit-1 problem	
63	Cox's Bazar Wind	IPP	66	60	36	0	477120	On test.	
64	Matarbari 2*600 MW (CPGCL)	CPGCL	0	575	0	0	0	On test.	
65	Mirshar 150 MW (Gas)	BPDB-RPCL	18.59	0	0	0	0	On test.	
66	Sonagad 75 MW Solar Plant	EGCB	75	75	0	0	20727		
Chattogram area Total				4457	2135		42776518		
67	Ashuganj TPP Unit-3	APSCL	1150	0	0	0	0	Contract Expired	
68	Ashuganj TPP Unit-4	APSCL	1150	0	0	0	0	Contract Expired	
69	Ashuganj TPP Unit-5	APSCL	1150	0	0	0	0	Contract Expired	
70	Ashuganj 225 MW CCPP	APSCL	1142*1175	221	215	0	5007000		
71	Ashuganj 450 MW CCPP(North)	APSCL	1360	360	280	0	7377600		
72	Ashuganj 450 MW CCPP(South)	APSCL	1360	360	270	0	6871000	Gas shortage	
73	Ashuganj 420 MW CCPP(East)	APSCL	284*1116*1	400	240	0	6024800	Gas shortage	
74	Ashuganj 50 MW PP	APSCL	143.968	45	0	0	48744	Gas shortage	
75	Ashuganj 55 MW PP (Precision)	QRPP	0	0	0	0	0	Gas shortage	
76	Ashuganj 195 MW PP (APSCL-Uniled)	IPP	209.73*116	105	0	0	66909	Gas shortage	
77	Ashuganj 51 MW PP (Midland)	IPP	69.34	51	51	0	1183447		
78	Ashuganj 150 MW PP (Midland)	IPP	237.015	150	118	0	1199345	Fuel shortage	
79	Tilas 50 MW Peaking PP	PDB	68.92	52	38	0	288884	Engine problem	
80	Chandpur 150 MW CCPP	PDB	1106*1157	163	70	0	1414940	Machine problem.	
81	Chandpur 200 MW (Dash energy)	IPP	1218.4	200	155	0	2143680	Fuel shortage	
82	Feni 11 MW PP (Doreen)	SIPP, REB	42.90	11	0	0	0		
83	Import (Tripura)	Imported power	0	160	76	0	1480320		
84	Jangalia 33 MW PP (Summit)	SIPP, PDB	48.73	33	32	0	779100		
85	Jangalia 52 MW PP (Lakdanaw)	IPP	68.92	52	25	0	315158	Fuel shortage	
86	Cumilla 25 MW PP (Summit)	SIPP, REB	313*28.97	25	12	0	277900	Engine problem	
87	Daudkandi 200 MW PP (B.Trac)	IPP	1541.4	0	0	0	0		
88	Feni Lanka Power	IPP	718.415*19.78	114	70	0	1189020	Low demand	
89	Chowmuhani 113 MW	IPP	129.78*23.1	113	86	0	1228920	Fuel shortage	
90	Chandpur 115(Doreen)	IPP	418.5*2*2.5	115	59	0	679400	Fuel shortage	
Cumilla Area Total				2875	1797		37715167		
91	RPCL 210MW CCPP	IPP	435*1170	202	40	0	542400	Gas shortage	
92	Jamalpur 95 MW PP(Powerpac)	IPP	0	0	0	0	0		
93	Sarishabari 3 MW Solar Plant	IPP	13	3	0	0	5100		
94	Mymensingh 200 MW PP (Uniled)	IPP	978*21	200	121	0	2424000	Fuel shortage	
95	Jamalpur 115 MW PP (Uniled)	IPP	978*12	115	79	0	1482000	Fuel shortage	
96	Sutakhal 50 MW Solar PP	IPP	50	50	0	0	109340		
97	Tangail Palli Power Gen 22 MW	IPP	4*6.7	22	12	0	186480	Engine problem	
98	Bhairab 54.5 MW	IPP	318*2	54	17	0	608760		
Mymensingh Area Total				646	269		5358080		
99	Fenchugonj CCPP Phase-1	PDB	232*133	70	35	0	845000	Machine problem.	
100	Fenchugonj CCPP Phase-2	PDB	235*135	90	58	0	1383660	Machine problem.	
101	Kushnara 163 MW CCPP (KP)	IPP	1109*154	163	163	0	3596155		
102	Shahbazar 330 MW CCPP	PDB	3110	330	0	0	0	Under maint.	
103	Fenchugonj 51 MW PP (Barakattallah)	RP	192.90	51	53	0	954600		
104	Fenchugonj 44 MW (Energyprima)	NENP	123.3*52	60	42	0	773208	Engine problem	
105	Hobiganj 11 MW PP Confidence-E	SPP, REB	42.90	11	2	0	91008	Engine problem	
106	Shahbazar GTTP Unit- 8 & 9	PDB	235	66	61	0	1322208		
107	Shahbazar 86 MW PP (Shahbazar)	RP	322.90	0	0	0	0	Contract Expired	
108	Shahbazar 100 MW GTTP	IPP	1100	100	0	0	0		
109	Sylhet 225 MW CCPP	PDB	1142*1169	221	205	0	5163820	Machine problem.	
110	Sylhet 20 MW GTTP	PDB	120	20	0	0	0	Under maint.	
111	Sylhet 50 MW PP (EPL)	NENP	272	0	0	0	0	Contract Expired	
112	Shahjanulla 25 MW PP	SPP, REB	39.34	25	16	0	300000	Engine problem	
113	Bibiana-341 MW CCPP (Summit)	IPP	1222*1119	341	295	0	7222000		
114	Bibiana-II 400 MW CCPP	PDB	2851*1341	400	324	0	5910000	FCMO	
115	Sylhet 10MW PP (Dash)	RP	61.95	0	0	0	0	Contract Expired	
116	Bibiana South 400 MW	PDB	400 MW	383	15	0	4644400	ST Sync process	
Sylhet Area Total				2331	1269		32206359		
117	Bheranara GTTP Unit-3	PDB	120	16	0	0	0		
118	Bheranara (WDC)	Imported power	2500	1000	704	0	16645818		
119	Khulna 115 MW (KPCL-2)	NENP	717	115	94	0	1107840	Fuel shortage	
120	Fairdipur 50 MW Peaking PP	PDB	86.89	54	37	0	206400	Engine problem	
121	Khulna 225 MW CCPP	NWPQCL	1150*1175	230	0	0	0	Fuel shortage	
122	Copalganj 100 MW Peaking PP	PDB	166.98	109	51	0	369408	Engine problem	
123	Bheranara 110 MW CCPP	NWPQCL	1278*1132	410	165	0	41117248	Gas shortage	
124	Noapara 40 MW PP (Khanjahan AI)	NENP	59.5	40	40	0	193500		
125	Noapara 100 MW PP (Bangla Trac)	IPP	701.4	0	0	0	0	Contract Expired	
126	Rupsha 105 MW PP (Orion rupsha)	IPP	618.445	105	91	0	1128480	Fuel shortage	
127	Madhumati 100 MW PP	NWPQCL	618	105	0	0	0		
128	Monjira Onon 100 MW Solar PP	IPP	100	100	0	0	638640		
129	Khulna 330 MW CCPP (OL)	BPDB	1220*1110	336	0	0	0	On test	
130	Rampal 1320 MW (BFPCL)	NTPC&BPDB	6172	1234	358	0	13541818		
131	Khulna 225 MW CCPP (GAS)	NWPQCL	0	0	0	0	0		
Khulna Area Total				3854	1620		37949152		
132	Barisal 110 MW PP (Summit)	IPP	717.076	110	110	0	574368		
133	Bhola 50 MW PP (Venture)	NENP	134.50	10	10	0	229351		
134	Bhola 225 MW CCPP	PDB	2563*1168	194	128	0	2874000	Machine problem.	
135	Bhola 95 MW PP (Aggreko)	QRPP	961.10	0	0	0	0	Contract Expired	
136	Payra 1320 MW	BCPCL	2622	1244	1190	0	28415800		
137	Bhola Nutan Biddul BD LTD	IPP	220	220	220	0	5232709		
138	United Payra Power Ltd.	IPP	818.5*119.5	150	35	0	174000	Fuel shortage	
139	Barisal 307 MW	IPP	3071	307	307	0	6240		