

**Bangladesh Power Development Board**  
**DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation  
Tel: 9564667, 9551095

Month June, 2024		Day : Sunday				Date : 16.06.24						
Probable Maximum Demand : 13600 MW		Probable Maximum Generation : 16170 MW										
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 81.76 ft				Today = 81.86 ft				Rule Curve = 79.95 ft		
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	15.06.24 (Yesterday)		16.06.24 (Today)		15.06.24 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)		Description/ Remarks
<b>(A) Plants in operation:</b>												
1	Ghorasal Repowered CAPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	0	0	0	0			260	Under Repowering project
2	a) Ghorasal Repowered CAPP Unit-4	Gas (PDB)	1 x 210	210	180	140	140	140				
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	180	110	110	110				
3	Ghorasal 365 MW CAPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0			365	Awaiting for HGP1
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	108			Gas Shortage
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0				
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0				
7	Meghnaghat 450 MW CAPP(MPL)	Gas (IPP)	2x140+1x170	450	450	420	450	450	450			
8	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0			115	Under Overhauling
9	Haripur 412 MW CAPP	Gas (EGCB)	1x273+1x139	412	400	402	404	400	400			
10	Siddhirgonj 2'120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage
11	Siddhirgonj 335 MW CAPP	Gas (EGCB)	1 x 217+1x118	335	335	312	320	320	320			
12	Meghnaghat 335MW CAPP(Summit)	Gas (IPP)	2x110+1x110	335	335	147	141	150	150	194		Gas Shortage
13	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	2	55	55	55			
14	Gaganraj 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	8	8	82	85			
15	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)		22	22	0	0	0	0			
16	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	27	24	33	33			
17	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	17	8	33	33			
18	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	20	16	33	33			
19	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	8	8	8			
20	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	52	52	52			
21	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	32	48	100	150			
22	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	17	54	54			
23	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	145	270	300			
24	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	6x18.415+1x8.97	149	149	79	96	96	149			
25	Nabaganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	17	35	35	35			
26	Manikgonj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	55	35	55			
27	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	25	71	55	70			
28	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	0	35	72	162			
29	Manikgonj 35MW Solar PP (Inspecta Solar Ltd.)	Solar (IPP)	1x35	35	35	10	0	35	0			
30	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	35	30	35	35			
31	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	0	0	25			
32	Unique Meghnaghat 584MW CAPP	Gas	1x400+1x184	584	584	0	0	0	0	584		Gas Shortage
33	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	0	9	70	85			
34	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	51	64	64			
35	Meghnaghat 100 MW(EL)	HFO (NENP)	12x8.9	100	100	0	9	50	80			
	Meghnaghat 589 MW CAPP(Summit)	Gas				0	0	0	0	589		Gas Shortage
<b>Dhaka Zone Total</b>				<b>5828</b>	<b>5634</b>	<b>1750</b>	<b>2337</b>	<b>3133</b>	<b>1685</b>	<b>740</b>		
36	Karnaphuli Hydro PP Unit-1, 2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	115	112	115	115	118		Inadequate Water Level
37	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.
38	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	5	0	5	0			
39	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	17	8	17			
40	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	11	0	20	0			
41	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	0	6	18			
42	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	0	0	51	51			
43	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.
44	Sikalbaha 225 MW CAPP	Gas (PDB)	1 x 150+1 x 75	225	225	215	221	220	220			
45	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	55	52	52	52			
46	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	24	24	25	25			
47	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	50	85			
48	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	64	48	64			
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			34	40	40	40			
49	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	39	18	39			
50	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	0	35	35			
51	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	0	34	110	110			
52	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	25	25	25	25			
53	Juldah 100 MW Unit-1 (Acorn)	HFO (NENP)	8x13.45	100	100	0	0	35	46			
54	Chattogram 116 MW PP (Anilma Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	17	35	53			
55	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	0	17	54	163			
56	Chattogram 2'612MW Coal Based PP (SS Power)	Coal (IPP)	2x612	1224	1224	992	1003	1000	1040			
57	Matarbari 2'600 MW (CPGCL)	Coal (CPGCL)	1x575	575	575	0	0	0	0			
58	Cox's Bazar Wind PP	(Wind) (IPP)		60	60	47	39	40	40			
59	Sonagazi 75 MW Solar Plant	(Solar) (EGCB)		75	75	53	0	70	0			
<b>Chattogram Zone Total</b>				<b>4517</b>	<b>4457</b>	<b>1593</b>	<b>1755</b>	<b>2062</b>	<b>2238</b>	<b>298</b>	<b>330</b>	
60	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	20	10	10	10	35		Gas Shortage
61	Ashuganj 225 MW CAPP	Gas (APSCL)	1x142+1'75	221	221	212	187	220	220			
62	Ashuganj 450 MW CAPP(South)	Gas (APSCL)	1x360	360	360	320	270	280	280	90		Gas Shortage
63	Ashuganj 450 MW CAPP(North)	Gas (APSCL)	1x361	360	360	330	285	290	290	75		Gas Shortage
64	Ashuganj 420 MW CAPP(East)	Gas (APSCL)	1x284+1x116	400	400	280	260	280	300	140		Gas Shortage
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20'9.73+1'116	195	195	0	8	0	0	187		Gas Shortage
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	33	51	51	51			
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	20	92	150			
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	35	40	40			
69	Chandpur 150 MW CAPP	Gas (PDB)	1X106+1x57	163	163	70	80	50	80			
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	104	120	100	120			
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0			
72	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	32	32	32	32			
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	16	25	16	50			
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	12	12	12	12			
75	Feni 114 MW (Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	70	88	114	114			
76	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	37	76	42	85			
77	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	32	115	34	115			
78	Ashuganj 55 MW PP (Precision)	Gas (NENP)	15'4	55	55	0	3	0	0	52		Gas Shortage
**	Impoport (Tripura)	India		160	160	68	72	146	151			
<b>Cumilla Zone Total</b>				<b>2883</b>	<b>2875</b>	<b>1636</b>	<b>1749</b>	<b>1809</b>	<b>2100</b>	<b>579</b>	<b>0</b>	
79	RPCL 210MW CAPP	Gas (IPP)	4x35+1x70	210	202	35	75	40	75	127		Gas Shortage
80	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	58	79	68	80			
81	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	94	121	97	120			
82	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0			
83	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	16	0	50	0			
84	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	0	34	35	35			
85	Tangali 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	6	12	6	12			
<b>Mymensingh Zone Total</b>				<b>654</b>	<b>646</b>	<b>210</b>	<b>321</b>	<b>298</b>	<b>322</b>	<b>127</b>	<b>0</b>	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	15.06.24 (Yesterday)		16.06.24 (Today)		15.06.24 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Gas/Coal/Water Limitation MW	Machines shut down (MW)		
86	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	37	37	35	37		33	Under maint.
87	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	58	58	58	58		32	Under maint.
88	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	50	53	50	50			
89	Kushiana 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163			
90	Hobiganj 11 MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	5	5	5			
91	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	40	62	60	60			
92	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.
93	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	207	207	210	210			
94	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0		20	Under maint.
95	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16			
96	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	310	290	300	300			
97	Bibiyana-II 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	400	354	400	400			
98	Bibiyana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	140	340	340	340			
99	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0			Under Construction Project
100	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	10	39	40	40			
<b>Sylhet Zone Total</b>				<b>2376</b>	<b>2331</b>	<b>1436</b>	<b>1624</b>	<b>1677</b>	<b>1679</b>	<b>0</b>	<b>415</b>	
101	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0			
102	Bheramara 410 MW CAPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	205	240	240	240	170		Gas shortage
103	Fairpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	42	30	42			
104	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	39	50	60			
105	Khulna 225 MW CAPP	HSD/ Gas (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	0			
106	Russha 105 MW PP (Orion russha)	HFO (IPP)	6x18.445	105	105	0	35	17	73			
107	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	0	0	0			
108	Mongla Orion 100 MW Solar PP	Solar (IPP)	2x617	100	100	53	0	100	0			
109	Maitree Super Thermal 1320 MW PP	Coal (BIF/PCL)	1234	1234	358	360	350	360	360			
110	Khulna 330 MW CAPP	Gas/HSD (RPP)	1x220+1x116	336	336	0	0	0	0			
111	Nasipara 40 MW PP (Khanjahan Ali)	HFO NENP	5x8.5	40	40	0	24	32	40			
112	Khulna 115 PP MW (KPOL-2)	HFO NENP	7x17	115	115	0	32	20	50			
**	Bheramara (H/VD)	India		1000	1000	911	769	931	782			
<b>Khulna Zone Total</b>				<b>3858</b>	<b>3854</b>	<b>1527</b>	<b>1541</b>	<b>1770</b>	<b>1647</b>	<b>170</b>	<b>0</b>	
113	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	16	110			
114	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	10	8	10	10	10			
115	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	126	130	130	130		64	ST under maint.
116	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	1000	1200	1100	1244			
117	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	17	35			
118	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	220	307	307	307			
119	Barisal 1 MW Solar PP	Solar (PDB)	1 x 1	1	1	0	0	0	0			
120	Bhola 220MW CAPP (Nutan Bidyt BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	220	220			
<b>Barishal Zone Total</b>				<b>2266</b>	<b>2236</b>	<b>1574</b>	<b>1867</b>	<b>1800</b>	<b>2056</b>	<b>0</b>	<b>64</b>	
121	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage
122	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.
123	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	32	40			
124	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	10			
125	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	90	50	90			
126	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	42	0	45			
127	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	0	35			
128	Sirajgonj 225MW CAPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	170	151	170	170	59		Gas Shortage
129	Sirajgonj 225MW CAPP Unit-2	Gas (NWP/GCL)	1x150+1x75	220	220	0	0	0	0	220		Gas Shortage
130	Sirajgonj 225MW CAPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	0	0	0	0	220		Gas Shortage
131	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	350	414	400	414			
132	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	5	5	5	8			
133	Natore 52 MW PP (Rajjanka)	HFO (IPP)	6x8.92	52	52	0	0	0	0			
134	Bagura 113 MW PP (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	0	113	113			
135	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	0	94	113			
136	Ammara 50 MW PP (Sinha)	HFO (NENP)	7x7.79	50	28	0	0	14	35			
137	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	3	0	6	0			
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	1168	1362	1228	1400			
<b>Raishahi Zone Total</b>				<b>3403</b>	<b>3381</b>	<b>1696</b>	<b>2096</b>	<b>2112</b>	<b>2473</b>	<b>570</b>	<b>100</b>	
137	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	64	64	62	64			
138	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling
139	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	230	230	220	230			
140	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
141	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16.2*3	113	113	0	49	70	113			
142	Sardpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
143	Majpara Tabula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	1	0	8	0			
144	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	90	35	115			
145	Lalmoinhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	7	0	30	0			
146	Teesa Solar Limited	Solar (IPP)	1 x 200	200	200	33	0	130	0			
<b>Rangpur Zone Total</b>				<b>1030</b>	<b>950</b>	<b>335</b>	<b>433</b>	<b>555</b>	<b>522</b>	<b>0</b>	<b>85</b>	
<b>Sub-total: Plants in operation</b>				<b>26815</b>	<b>26364</b>	<b>11757.0</b>	<b>13723</b>	<b>14920</b>	<b>16170</b>	<b>3429</b>	<b>1734</b>	
<b>(B) Plants under long term maintenance/ contract expired</b>												
146	Katoboti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			Contract Expired
147	Haripur 360MW CAPP(HPL)	Gas (IPP)	1x235+1x125	360	0	0	0	0	0			Contract Expired
148	Jamalpur 95 MW PP (Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			Contract Expired
149	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	0	0	0	0	0			Contract Expired
150	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Contract Expired
<b>Sub-Total: Plants under long term maintenance/ contract expired</b>				<b>700</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	
<b>Gross Total</b>				<b>27515</b>	<b>26364</b>	<b>11757</b>	<b>13723</b>	<b>14920</b>	<b>16170</b>	<b>3429</b>	<b>1734</b>	
<b>(C) Actual data of 15.06.24 (Yesterday) Saturday :</b>												
01.	Max. Demand at eve. peak (Generation end)	:	13723 MW, at =	21:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand at eve. peak (Sub-station end)	:	13172 MW, at =	21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	14406 MW, at =	1:00 hrs	Dhaka	4032	4032	0	Mymensingh	1072	1072	0
04.	Minimum Generation (Generation end)	:	10854 MW, at =	8:00 hrs	Chattogram	1268	1268	0	Sylhet	475	475	0
05.	Day-peak Generation (Generation end)	:	11757 MW, at =	12:00 hrs	Khulna	1998	1998	0	Barishal	509	509	0
06.	Evening-peak Generation (Generation end)	:	13723 MW, at =	21:00 hrs	Rajshahi	1582	1582	0	Rangpur	848	848	0
07.	Evening Peak Load-shed (Sub-station end)	:	0 MW, at =	21:00 hrs	Cumilla	1390	1390	0				
08.	Minimum Generation Forecast up to 8.00 hrs.	:	9956 MW, at =	5:00 hrs					Total	13172	13172	0
09.	Generation shortfall at evening peak due to :	:			13.	Fuel cost :						
	a) Gas/LF limitation	:	3311 MW			a) Gas =	408392437 Taka			c) Coal =	727804436 Taka	
	d) Coal supply Limitation	:	0 MW			b) Oil =	644801568 Taka			Total =	1780998440 Taka	
	b) Low water level in Kaptai lake	:	118 MW									
	c) Plants under shut down/ maintenance	:	1734 MW		14.	Maximum Temperature in Dhaka was : 33.5°C						
10.	Total Energy (Generation + India Import)	:	301.39 MCKWh		15.	Export through East-West interconnections :						
	By Gas = 133.063 MCKWh		By Oil = 35.280 MCKWh			At evening peak-hour		:	11757 MW, at	21:00 hrs		
	By Coal = 105.203 MCKWh		By Hydro = 2.734 MCKWh			Maximum		:	514 MW, at	2:00 hrs		
	By Solar = 1.448 MCKWh					Energy		:	6270 MCKWh			
11.	Total Gas Supplied	:	1017.59 MCMCFD									
<b>(D) Forecast of 16.06.24 (Today) Sunday :</b>												
01.	Maximum Demand	:	13600 MW (Generation end)		04.	Maximum Load-shed : 0 MW At evening peak (Sub-station end)						
02.	Maximum Generation	:	16170 MW (Generation end)		05.	Total Generation : 284.52 MCKWh						
03.	Reserve / Shortage	:	2570 MW (Generation end)		06.	Probable Max. Temperature in Dhaka : 32.5°C						

#Remarks: Highest Generation 16477 MW on 30-04-2024 at 21:00

(Md. Helalur Rahman)  
Deputy Secretary, Generation