

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel: 9564667, 9551095

Month June, 2024		Day : Monday				Date : 17.06.24						
Probable Maximum Demand :		12500 MW		Probable Maximum Generation :		16682 MW						
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 81.86 ft		Today = 82.01 ft		Rule Curve = 80.22 ft						
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	16.06.24 (Yesterday)		17.06.24 (Today)		16.06.24 (Yesterday) Gen. shortfall for : Gas/Coal/oil/Water Limitation MW	80.22 (Yesterday) Machines shut down (MW)	Status of Machines under shut-down/ Maintenance Description/ Remarks	Probable start-up date
					Actual Peak Generation (MW)	Probable Peak Generation (MW)	Day	Evening				
					(A) Plants in operation:							
1	Ghorasal Repowered CAPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under Repowering project
2	a) Ghorasal Repowered CAPP Unit-4	Gas (PDB)	1 x 210	210	180	220	220	140	140			
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180			
3	Ghorasal 365 MW CAPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365	Awaiting for HGP1
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	13	12	0	0	96		Gas Shortage
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0			
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Meghnaghat 450 MW CAPP(MPL)	Gas (IPP)	2x140+1x170	450	450	380	420	450	450			
8	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling
9	Haripur 412 MW CAPP	Gas (EGCB)	1x273+1x139	412	400	301	401	400	400			
10	Siddhirgonj 2'120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage
11	Siddhirgonj 335 MW CAPP	Gas (EGCB)	1 x 217+1x118	335	335	280	320	320	320			
12	Meghnaghat 335MW CAPP(Summit)	Gas (IPP)	2x110+1x110	335	335	150	274	300	300			
13	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	15	55	55			
14	Gaganraj 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	0	0	82	85			
15	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)		22	22	0	0	0	0			
16	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	16	17	33	33			
17	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	8	8	33	33			
18	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	8	8	33	33			
19	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	0	8	8			
20	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	100	100	0	0	52	52			
21	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	0	16	100	150			
22	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	0	54	54			
23	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	0	270	300			
24	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	6x18.415+1x8.97	149	149	17	101	96	149			
25	Nabaganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	0	35	35			
26	Manikgonj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	0	35	35			
27	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	50	55	70			
28	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	0	0	72	162			
29	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	29	0	35	0			
30	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	0	35	35			
31	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	0	0	25			
32	Unique Meghnaghat 584MW CAPP	Gas	1x400+1x184	584	584	0	113	300	300	471		Gas Shortage
33	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	0	0	70	85			
34	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	7	64	64			
35	Meghnaghat 100 MW(EL)	HFO (NENP)	12x8.9	100	100	0	0	50	80			
	Meghnaghat 589 MW CAPP(Summit)	Gas				0	0	0	0	589		Gas Shortage
Dhaka Zone Total				5828	5634	1602	2162	3357	3653	1366	740	
36	Karnaphuli Hydro PP Unit-1, 2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	115	113	115	115	117		Inadequate Water Level
37	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.
38	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	5	0	5	0			
39	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	17	8	17			
40	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	13	0	20	0			
41	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	0	6	18			
42	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	0	0	51	51			
43	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.
44	Sikalbaha 225 MW CAPP	Gas (PDB)	1 x 150+1 x 75	225	225	215	220	220	220			
45	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	0	50	52	52			
46	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	0	24	25	25			
47	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	50	85			
48	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	39	48	64			
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			42	42	40	40			
49	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	38	18	39			
50	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	0	35	35			
51	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	0	0	110	110			
52	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	0	25	25	25			
53	Juldah 100 MW Unit-1 (Acorn)	HFO (NENP)	8x13.45	100	100	0	0	35	45			
54	Chattogram 116 MW PP (Anilma Energy Ltd.)	HFO (IPP)	6x21.06	116	116	0	0	35	53			
55	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	0	0	54	163			
56	Chattogram 2'612MW Coal Based PP (SS Power)	Coal (IPP)	2x612	1224	1224	756	836	600	600			
57	Matarbari 2'600 MW (CPGCL)	Coal (CPGCL)	1x575	575	575	0	0	0	0			
58	Cox's Bazar Wind PP	(Wind) (IPP)		60	60	10	28	40	40			
59	Sonagazi 75 MW Solar Plant	(Solar) (EGCB)		75	75	44	0	70	0			
Chattogram Zone Total				4517	4457	1200	1483	1662	1797	297	330	
60	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	10	37	5	5			
61	Ashuganj 225 MW CAPP	Gas (APSCL)	1x142+1'175	221	221	212	187	220	220			
62	Ashuganj 450 MW CAPP(South)	Gas (APSCL)	1x360	360	360	310	275	280	280			
63	Ashuganj 450 MW CAPP(North)	Gas (APSCL)	1x361	360	360	320	285	300	300	85		Gas Shortage
64	Ashuganj 420 MW CAPP(East)	Gas (APSCL)	1x284+1x116	400	400	260	285	280	300	115		Gas Shortage
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20'9.73+1'116	195	195	0	16	48	48	179		Gas Shortage
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	0	51	51	51			
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	0	92	150			
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	29	40	40			
69	Chandpur 150 MW CAPP	Gas (PDB)	1X106+1x57	163	163	80	80	80	80			
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	68	154	100	150			
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0			
72	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	32	32	32	32			
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	25	16	50			
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	12	0	12	12			
75	Feni 114 MW (Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	17	114	114	114			
76	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	38	75	42	85			
77	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	0	105	34	115			
78	Ashuganj 55 MW PP (Precision)	Gas (NENP)	15'4	55	55	0	20	0	0	35		Gas Shortage
**	Impoport (Tripura)	India		160	160	60	84	146	151			
Cumilla Zone Total				2883	2875	1419	1854	1892	2183	489	0	
79	RPCL 210MW CAPP	Gas (IPP)	4x35+1x70	210	202	163	204	200	200			
80	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	8	75	68	80			
81	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	0	32	97	120			
82	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0			
83	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	0	0	50	0			
84	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	0	0	35	35			
85	Tangali 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	0	12	6	12			
Mymensingh Zone Total				654	646	189	323	458	447	0	0	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	16.06.24 (Yesterday)		17.06.24 (Today)		16.06.24 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/Coal/Water Limitation MW	Machines shut down (MW)			
86	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	37	37	37	37		33	Under maint.	
87	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	58	58	58	58		32	Under maint.	
88	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	5	53	50	50				
89	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163				
90	Hobiganj 11 MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	5	5	5				
91	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	58	62	60	60				
92	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
93	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	211	208	210	210				
94	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0		20	Under maint.	
95	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	16	16	16				
96	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	320	285	300	300				
97	Bibiyana-II 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	363	366	240	400				
98	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	375	345	300	340				
99	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0			Under Construction Project	
100	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	5	39	40	40				
Sylhet Zone Total					2376	2331	1608	1637	1479	1679	0	415	
101	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
102	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	325	395	300	350				
103	Fairpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	43	30	42				
104	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	48	50	60				
105	Khulna 225 MW CCPP	HSD/ Gas (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	0				
106	Russha 105 MW PP (Orion russha)	HFO (IPP)	6x18.445	105	105	0	17	17	73				
107	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	0	0	0				
108	Mongla Orion 100 MW Solar PP	Solar (IPP)	2x617	100	100	80	0	100	0				
109	Maitree Super Thermal 1320 MW PP	Coal (BIF/PCL)	1234	1234	1234	364	363	360	360				
110	Khulna 330 MW PP (Khanjahan Ali)	Gas/HSD (RPP)	1x220+1x116	336	336	0	0	0	0				
111	Nasipara 40 MW PP (Khanjahan Ali)	HFO NENP	5x8.5	40	40	0	8	32	40				
112	Khulna 115 PP MW (KPOL-2)	HFO NENP	7x17	115	115	0	32	20	50				
**	Bheramara (HVDC)	India		1000	1000	908	766	931	931				
Bheramara Zone Total					3858	3854	1677	1672	1840	1906	0	0	
113	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	16	110				
114	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	10	10	10	10	10				
115	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	120	126	130	130		68	ST under maint.	
116	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	600	910	1100	1244				
117	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	17	35				
118	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	150	200	307	307				
119	Barisal 1 MW Solar PP	Solar (PDB)	1 x 1	1	1	0	0	0	0				
120	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	220	220				
Barishal Zone Total					2266	2236	1100	1466	1800	2056	0	68	
121	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage	
121	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.	
122	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	32	40				
123	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	10				
124	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	50	50	90				
125	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	42	0	45				
126	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	36	0	35				
127	Sirajgonj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	190	214	170	200				
128	Sirajgonj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	0	0	0	0		220	Gas Shortage	
129	Sirajgonj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	0	0	0	0		220	Gas Shortage	
130	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	300	414	400	414				
131	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	5	8	5	8				
132	Natore 52 MW PP (Rajjanka)	HFO (IPP)	6x8.92	52	52	0	0	0	0				
133	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	35	113	113				
134	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	0	94	113				
135	Amnara 50 MW PP (Sinha)	HFO (NENP)	7x7.79	50	28	0	0	14	35				
136	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	2	0	6	0				
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	819	1085	1228	1400				
Rangpur Zone Total					3403	3381	1316	1884	2112	2503	511	100	
137	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0				
137	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
138	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	200	230	220	230				
139	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
140	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*18.23	113	113	0	71	70	113				
141	Sardpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
142	Majpara Tabula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	2	0	8	0				
143	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	90	35	115				
144	Lalmonirhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	6	0	30	0				
145	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	18	0	130	0				
Rangpur Zone Total					1030	950	226	391	493	458	0	85	
Sub-total: Plants in operation					26815	26364	10337.0	12872	15093	16682	2663	1738	
(B) Plants under long term maintenance/ contract expired													
146	Katoboti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			Contract Expired	
147	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	0	0	0	0	0			Contract Expired	
148	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			Contract Expired	
149	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	0	0	0	0	0			Contract Expired	
150	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Contract Expired	
Sub-Total: Plants under long term maintenance/ contract expired					700	0	0	0	0	0	0	0	
Gross Total					27515	26364	10337	12872	15093	16682	2663	1738	
(C) Actual data of 16.06.24 (Yesterday) Sunday :													
01.	Max. Demand at eve. peak (Generation end)	: 12872 MW, at = 21:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :									
02.	Max. Demand at eve. peak (Sub-station end)	: 12410 MW, at = 21:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed			
03.	Highest Generation (Generation end)	: 13545 MW, at = 1:00 hrs	MW	MW	MW	MW	MW	MW	MW	MW			
04.	Minimum Generation (Generation end)	: 9737 MW, at = 9:00 hrs	Dhaka	3590	3590	0	Mymensingh	1094	1094	0			
05.	Day-peak Generation (Generation end)	: 10337 MW, at = 12:00 hrs	Chattogram	1119	1119	0	Sylhet	454	454	0			
06.	Evening-peak Generation (Generation end)	: 12872 MW, at = 21:00 hrs	Khulna	1900	1900	0	Barishal	520	520	0			
07.	Evening Peak Load-shed (Sub-station end)	: 0 MW, at = 21:00 hrs	Rajshahi	1539	1539	0	Rangpur	814	814	0			
08.	Minimum Generation Forecast up to 8.00 hrs.	: 9617 MW, at = 5:00 hrs	Cumilla	1380	1380	0							
09.	Generation shortfall at evening peak due to :	:	13.	Fuel cost :			Total	12410	12410	0			
	a) Gas/LF limitation	: 2546 MW		(a) Gas =	453398568 Taka		(c) Coal =	599605887 Taka					
	d) Coal supply Limitation	: 0 MW		(b) Oil =	315860846 Taka		Total =	1368865302 Taka					
	b) Low water level in Kaptai lake	: 117 MW											
	c) Plants under shut down/ maintenance	: 1738 MW	14.	Maximum Temperature in Dhaka was : 35.5°C									
10.	Total Energy (Generation + India Import)	: 278.63 MKWh	15.	Export through East-West interconnections :									
	By Gas = 147.126 MKWh	By Oil = 17.360 MKWh		At evening peak-hour	: 10337 MW, at 21:00 hrs								
	By Coal = 86.792 MKWh	By Hydro = 2.741 MKWh		Maximum	: 170 MW, at 20:00 hrs								
	By Solar = 1.515 MKWh			Energy	: 1410.75 MKWh								
11.	Total Gas Supplied	: 1126.64 MMCFD											
(D) Forecast of 17.06.24 (Today) Monday :													
01.	Maximum Demand	: 12500 MW (Generation end)	04.	Maximum Load-shed : 0 MW At evening peak (Sub-station end)									
02.	Maximum Generation	: 16682 MW (Generation end)	05.	Total Generation : 257.13 MKWh									
03.	Reserve / Shortage	: 4182 MW (Generation end)	06.	Probable Max. Temperature in Dhaka : 33.5°C									

#Remarks: Highest Generation 16477 MW on 30-04-2024 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation