

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel: 9564667, 9551095

Month June, 2024		Day : Saturday				Date : 22.06.24							
Probable Maximum Demand :		13700 MW		Probable Maximum Generation :		16274 MW							
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 83.19 ft		Today = 83.44 ft		Rule Curve = 81.57 ft							
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	21.06.24 (Yesterday)		22.06.24 (Today)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)	Status of Machines under shut-down/ Maintenance	Description/ Remarks	Probable start-up date
					Actual Peak Generation (MW)		Probable Peak Generation (MW)						
					Day	Evening	Day	Evening					
(A) Plants in operation:													
1	Ghorasal Repowered CAPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	0	0	0	0		260	Under Repowering project		
2	a) Ghorasal Repowered CAPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0					
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180					
3	Ghorasal 365 MW CAPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0		365	Awaiting for HGPI		
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	70	12	70				
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0				
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0				
7	Meghnaghat 450 MW CAPP(MPL)	Gas (IPP)	2x140+1x170	450	450	400	450	450	450				
8	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling	
9	Haripur 412 MW CAPP	Gas (EGCB)	1x273+1x139	412	400	343	407	400	400				
10	Siddhirgonj 2'120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage		
11	Siddhirgonj 335 MW CAPP	Gas (EGCB)	1 x 217+1x118	335	335	280	320	320	320				
12	Meghnaghat 335MW CAPP(Summit)	Gas (IPP)	2x110+1x110	335	335	309	291	300	300				
13	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	15	55	55				
14	Gaganraj 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	0	0	82	80				
15	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)		22	22	0	0	0	0				
16	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	17	24	27	27				
17	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	16	16	16	16				
18	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	24	15	33	33				
19	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	0	8	8				
20	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	0	0	52	52				
21	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	0	32	100	150				
22	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	0	54	54				
23	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	15	270	300				
24	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	6x18.415+1x8.97	149	149	0	47	96	149				
25	Nabaganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	0	35	35				
26	Manikgonj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	0	35	35				
27	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	17	17	50				
28	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	0	0	72	162				
29	Manikgonj 35MW Solar PP (Inspecta Solar Ltd.)	Solar (IPP)	1x35	35	35	28	0	35	0				
30	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	0	35	35				
31	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	0	0	25				
32	Unique Meghnaghat 584MW CAPP	Gas	1x400+1x184	584	584	255	255	400	400				
33	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	0	0	70	80				
34	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	64	80				
35	Meghnaghat 100 MW(EL)	HFO (NENP)	12x8.9	100	100	0	0	50	80				
	Meghnaghat 589 MW CAPP(Summit)	Gas				250	586	0	0	3		Gas Shortage	
Dhaka Zone Total				5828	5634	2102	2740	3268	3646	213	740		
36	Karnaphuli Hydro PP Unit-1,2,3,4,5	Hydro (PDB)	2x40, 3x50	230	230	113	115	115	115	115		Inadequate Water Level	
37	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.	
38	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	5	0	5	0				
39	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	0	8	17				
40	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	7	0	20	0				
41	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	0	6	18				
42	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	0	0	51	100				
43	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.	
44	Sikalbaha 225 MW CAPP	Gas (PDB)	1 x 150+1 x 75	225	225	174	222	220	220				
45	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	0	101	52	52				
46	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	0	24	25	25				
47	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	17	34	50				
48	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	64	48	60				
	* Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			15	20	10	20				
49	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	38	18	38				
50	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	0	35	35				
51	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	0	0	110	110				
52	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	0	25	25	28				
53	Juldah 100 MW Unit-1 (Acorn)	HFO (NENP)	8x13.45	100	100	0	0	35	45				
54	Chattogram 116 MW PP (Anilma Energy Ltd.)	HFO (IPP)	6x21.06	116	116	0	17	17	17				
55	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	0	0	54	163				
56	Chattogram 2'612MW Coal Based PP (SS Power)	Coal (IPP)	2x612	1224	1224	290	350	612	612				
57	Matarbari 2'600 MW (CPGCL)	Coal (CPGCL)	1x575	575	575	0	0	0	0				
58	Cox's Bazar Wind PP	(Wind) (IPP)		60	60	0	10	40	40				
59	Sonagazi 75 MW Solar Plant	(Solar) (EGCB)		75	75	69	0	70	0				
Chattogram Zone Total				4517	4457	673	1003	1610	1765	295	330		
60	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	10	36	10	38				
61	Ashuganj 225 MW CAPP	Gas (APSCL)	1x142+1'75	221	221	208	188	220	220				
62	Ashuganj 450 MW CAPP(South)	Gas (APSCL)	1x360	360	360	300	270	280	300				
63	Ashuganj 450 MW CAPP(North)	Gas (APSCL)	1x361	360	360	310	300	300	300				
64	Ashuganj 420 MW CAPP(East)	Gas (APSCL)	1x284+1x116	400	400	315	285	300	330				
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20'9.73+1'16	195	195	8	102	45	100	93		Gas Shortage	
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	3	51	51	51				
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	0	150	150				
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	15	40	40				
69	Chandpur 150 MW CAPP	Gas (PDB)	1X106+1x57	163	163	88	88	85	88				
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	104	17	100				
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0				
72	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	32	28	32	32				
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	16	25	50	52				
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	12	12	12	12				
75	Feni 114 MW (Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	52	70	70	114				
76	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	39	70	42	80				
77	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	54	115	34	115				
78	Ashuganj 55 MW PP (Precision)	Gas (NENP)	15'4	55	55	10	43	45	45	12		Gas Shortage	
**	Impoport (Tripura)	India		160	160	66	80	146	144				
Cumilla Zone Total				2883	2875	1540	1882	1929	2311	105	0		
79	RPCL 210MW CAPP	Gas (IPP)	4x35+1x70	210	202	196	198	180	200				
80	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	0	75	68	80				
81	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	0	121	97	120				
82	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0				
83	Sutahkhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	41	0	50	0				
84	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	0	0	35	35				
85	Tangali 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	0	24	6	12				
Mymensingh Zone Total				654	646	239	418	438	447</				

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	21.06.24 (Yesterday)		22.06.24 (Today)		21.06.24 (Yesterday)		Status of Machines under shut-down/ Maintenance				
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date			
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)					
86	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	28	28	28	28		42	Under maint.			
87	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	58	50	58	58		40	Under maint.			
88	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	11	53	50	52						
89	Kushiana 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	120	163	163	163						
90	Hobiganj 11 MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	2	5	5						
91	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	40	51	60	60						
92	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.			
93	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	70	100	100	100						
94	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	16	14	18	18		6	Under maint.			
95	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16						
96	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	310	280	300	300						
97	Bibiyana-II 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	348	366	350	370						
98	Bibiyana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	378	345	350	350						
99	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0			Under Construction Project			
100	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	10	39	39	39						
Sylhet Zone Total					2376	2331	1405	1507	1537	1559	0	418			
101	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0						
102	Bheramara 410 MW CAPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	385	345	350	400						
103	Fairpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	30	40						
104	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	50	60						
105	Khulna 225 MW CAPP	HSD/ Gas (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	0						
106	Russha 105 MW PP (Orion russha)	HFO (IPP)	6x18.445	105	105	0	0	17	73						
107	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	0	0	0						
108	Mongla Orion 100 MW Solar PP	Solar (IPP)	2x617	100	100	65	0	100	0						
109	Maitree Super Thermal 1320 MW PP	Coal (BIF/PCL)	1234	1234	363	415	360	360	360						
110	Khulna 330 MW PP (Khanjahan Ali)	Gas/HSD (RPP)	1x220+1x116	336	336	0	16	32	40						
111	Nasipara 40 MW PP (Khanjahan Ali)	HFO NENP	5x8.5	40	40	0	64	20	98						
112	Khulna 115 PP MW (KPCL-2)	HFO NENP	7x17	115	115	0	64	20	98						
**	Bheramara (HVDC)	India		1000	1000	920	919	939	939						
Khulna Zone Total					3858	3854	1733	1759	1898	2010	0	0			
113	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	16	16	110						
114	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	10	8	10	10	10						
115	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	80	130	130	130		64	ST under maint.			
116	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	540	980	1100	1244						
117	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	17	35						
118	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	140	140	307	307						
119	Barisal 1 MW Solar PP	Solar (PDB)	1 x 1	1	1	0	0	0	0						
120	Bhola 220MW CAPP (Nutan Bidyt BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	220	220						
Barishal Zone Total					2266	2236	988	1496	1800	2056	0	64			
121	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage			
122	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.			
123	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	32	40						
124	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	10						
125	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	41	50	90						
126	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	47	0	45						
127	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	22	0	36						
128	Sirajgonj 225MW CAPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	168	174	150	210		36	Gas Shortage			
129	Sirajgonj 225MW CAPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	166	185	150	210		35	Gas Shortage			
130	Sirajgonj 225MW CAPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	0	0	0	220			Gas Shortage			
131	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	350	387	350	414		27	Gas Shortage			
132	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	2	2	5	8						
133	Natore 52 MW PP (Rajjanka)	HFO (IPP)	6x8.92	52	52	0	0	0	0						
134	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	20	113	113						
135	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	1	94	113						
136	Ammura 50 MW PP (Sinha)	HFO (NENP)	7x7.79	50	28	0	0	15	35						
137	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	4	0	6	0						
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	424	731	500	748						
Rajshahi Zone Total					3403	3381	1114	1610	1465	2072	389	100			
137	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0						
138	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling			
139	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	180	180	180	180						
140	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0						
141	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16.2*3	113	113	0	113	70	113						
142	Sardpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0						
143	Majpara Tabula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0						
144	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	18	0	35	115						
145	Lalmoinhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	14	0	30	0						
146	Teesa Solar Limited	Solar (IPP)	1 x 200	200	200	186	0	130	0						
Rangpur Zone Total					1030	950	405	293	453	408	0	85			
Sub-total: Plants in operation					26815	26364	10199.0	12708	14398	16274	1002	1737			
(B) Plants under long term maintenance/ contract expired															
146	Katoboti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			Contract Expired			
147	Haripur 360MW CAPP(HPL)	Gas (IPP)	1x235+1x125	360	0	0	0	0	0			Contract Expired			
148	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			Contract Expired			
149	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	0	0	0	0	0			Contract Expired			
150	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Contract Expired			
Sub-Total: Plants under long term maintenance/ contract expired					700	0	0	0	0	0	0	0			
Gross Total					27515	26364	10199	12708	14398	16274	1002	1737			
(C) Actual data of 21.06.24 (Yesterday) Friday :															
01.	Max. Demand at eve. peak (Generation end)	: 12815 MW, at = 21:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :											
02.	Max. Demand at eve. peak (Sub-station end)	: 12390 MW, at = 21:00 hrs		Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed					
03.	Highest Generation (Generation end)	: 12886 MW, at = 23:00 hrs		MW	MW	MW		MW	MW	MW					
04.	Minimum Generation (Generation end)	: 8961 MW, at = 6:00 hrs		Dhaka	3570	3570	0	Mymensingh	1137	1137	0				
05.	Day-peak Generation (Generation end)	: 10199 MW, at = 12:00 hrs		Chattogram	1304	1304	0	Sylhet	567	567	0				
06.	Evening-peak Generation (Generation end)	: 12708 MW, at = 21:00 hrs		Khulna	1680	1680	0	Barishal	450	450	0				
07.	Evening Peak Load-shed (Sub-station end)	: 102 MW, at = 21:00 hrs		Rajshahi	1465	1465	0	Rangpur	915	813	102				
08.	Minimum Generation Forecast up to 8:00 hrs.	: 10115 MW, at = 5:00 hrs		Cumilla	1302	1302	0								
09.	Generation shortfall at evening peak due to :	:		13.	Fuel cost :			Total	12390	12288	102				
	a) Gas/LF limitation	: 887 MW			(a) Gas =	452896399	Taka	(c) Coal =	374415620	Taka					
	d) Coal supply Limitation	: 0 MW			(b) Oil =	243367789	Taka	Total =	1070679808	Taka					
	b) Low water level in Kaptai lake	: 115 MW													
	c) Plants under shut down/ maintenance	: 1737 MW		14.	Maximum Temperature in Dhaka was : 34.8°C										
10.	Total Energy (Generation + India Import)	: 257.90 MCKWh		15.	Export through East-West interconnections :										
	By Gas = 160.646 MCKWh	By Oil = 13.338 MCKWh			At evening peak-hour	: 10199 MW, at 21:00 hrs									
	By Coal = 53.984 MCKWh	By Hydro = 2.742 MCKWh			Maximum	: 94 MW, at 4:00 hrs									
	By Solar = 3.159 MCKWh				Energy	: 2234.1 MCKWh									
11.	Total Gas Supplied	: 1108.52 MMMCFD													
(D) Forecast of 22.06.24 (Today) Saturday :															
01.	Maximum Demand	: 13700 MW (Generation end)	04.	Maximum Load-shed : 0 MW At evening peak (Sub-station end)											
02.	Maximum Generation	: 16274 MW (Generation end)	05.	Total Generation : 274.19 MCKWh											
03.	Reserve / Shortage	: 2574 MW (Generation end)	06.	Probable Max. Temperature in Dhaka : 34.8°C											

#Remarks: Highest Generation 16477 MW on 30-04-2024 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation