

**Bangladesh Power Development Board**  
**DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation  
Tel: 9564667, 9551095

Month June, 2024		Day : Wednesday				Date : 26.06.24								
Probable Maximum Demand : 15600 MW		Probable Maximum Generation : 14520 MW												
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 83.21 ft		Today = 82.78 ft		Rule Curve = 82.65 ft								
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	25.06.24 (Yesterday)		26.06.24 (Today)		25.06.24 (Yesterday)		26.06.24 (Today)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Machines shut down (MW)	Description/ Remarks		Probable start-up date
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW					
<b>(A) Plants in operation:</b>														
1	Ghorasal Repowered CAPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0			260	Under Repowering project	
2	a) Ghorasal Repowered CAPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	240			Gas Shortage	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	110	110	110	110					
3	Ghorasal 365 MW CAPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0			365	Awaiting for HGPI	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0					
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0					
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0					
7	Meghnaghat 450 MW CAPP(MPL)	Gas (IPP)	2x140+1x170	450	450	380	360	380	400					
8	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0			115	Under Overhauling	
9	Haripur 412 MW CAPP	Gas (EGCB)	1x273+1x139	412	400	400	402	400	400					
10	Siddhirgonj 2'120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210			Gas Shortage	
11	Siddhirgonj 335 MW CAPP	Gas (EGCB)	1 x 217+1x118	335	335	306	317	300	320					
12	Meghnaghat 335MW CAPP(Summit)	Gas (IPP)	2x110+1x110	335	335	146	150	250	250					
13	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	40	55	55	55					
14	Gaganraj 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	24	90	24	92					
15	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)		22	22	0	0	0	0					
16	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x3.73	80	80	29	30	31	31					
17	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x3.73	33	33	16	25	25	25					
18	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x3.73	33	33	12	12	14	14					
19	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	8	8	8					
20	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	88	52	80					
21	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	64	149	48	149					
22	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54					
23	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	270	278	250	275					
24	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	6x18.415+1x8.97	149	149	132	131	135	149					
25	Nabaganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	55	55	55	55					
26	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55					
27	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	53	17	52					
28	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	144	162	162	162					
29	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	33	0	35	0					
30	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	18	35	35	35					
31	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	13	0	12					
32	Unique Meghnaghat 584MW CAPP	Gas	1x400+1x184	584	584	0	0	0	0	584			Gas Shortage	
33	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	33	41	40	60					
34	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	64	82	64	80					
35	Meghnaghat 100 MW(EL)	HFO (NENP)	12x8.9	100	100	19	9	50	80					
	Meghnaghat 589 MW CAPP(Summit)	Gas				0	0	0	0	589			Gas Shortage	
<b>Dhaka Zone Total</b>				<b>5828</b>	<b>5634</b>	<b>2446</b>	<b>2764</b>	<b>2649</b>	<b>3003</b>	<b>1623</b>	<b>740</b>			
36	Karnaphuli Hydro PP Unit-1, 2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	150	145	145	145	85			Inadequate Water Level	
37	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180			Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180		Under maint.	
38	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	5	0	5	0					
39	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	17	8	17					
40	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	8	0	20	0					
41	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	19	20	20					
42	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	51	68	51	51					
43	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150		Under maint.	
44	Sikalbaha 225 MW CAPP	Gas (PDB)	1 x 150+1 x 75	225	225	218	219	220	220					
45	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	69	52	52	52					
46	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	24	37	24	24					
47	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	68	85	68	68					
48	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	40	67	48	72					
	* Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			2	21	5	20					
49	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	31	31	25	32					
50	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54					
51	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	94	92	68	110					
52	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	27	37	25	25					
53	Juldah 100 MW Unit-1 (Acorn)	HFO (NENP)	8x13.45	100	100	25	25	25	25					
54	Chattogram 116 MW PP (Anilma Energy Ltd.)	HFO (IPP)	6x21.06	116	116	35	72	17	72					
55	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	54	163	54	163					
56	Chattogram 2'612MW Coal Based PP (SS Power)	Coal (IPP)	2x612	1224	1224	480	492	612	612					
57	Matarbari 2'600 MW (CPGCL)	Coal (CPGCL)	1x575	575	575	566	568	570	570					
58	Cox's Bazar Wind PP	(Wind) (IPP)		60	60	1	0	40	40					
59	Sonagazi 75 MW Solar Plant	(Solar) (EGCB)		75	75	75	0	70	0					
<b>Chattogram Zone Total</b>				<b>4517</b>	<b>4457</b>	<b>2083</b>	<b>2264</b>	<b>2226</b>	<b>2392</b>	<b>265</b>	<b>330</b>			
60	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	0	0	0	0	45			Gas Shortage	
61	Ashuganj 225 MW CAPP	Gas (APSCL)	1x142+1'75	221	221	208	211	210	210					
62	Ashuganj 450 MW CAPP(South)	Gas (APSCL)	1x360	360	360	240	240	240	250			120	Gas Shortage	
63	Ashuganj 450 MW CAPP(North)	Gas (APSCL)	1x361	360	360	310	280	280	280			80	Gas Shortage	
64	Ashuganj 420 MW CAPP(East)	Gas (APSCL)	1x284+1x116	400	400	230	230	230	230			170	Gas Shortage	
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20'9.73+1'116	195	195	0	0	0	0			195	Gas Shortage	
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	43	51	51					
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	90	40	100	135					
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	35	36	36	36					
69	Chandpur 150 MW CAPP	Gas (PDB)	1X106+1x57	163	163	40	40	50	50					
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	17	17	17					
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0					
72	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	0	0	32	32					
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	16	52	25	52					
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	12	0	12	12					
75	Feni 114 MW (Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	17	114	50	114					
76	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	36	73	36	75					
77	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	54	115	90	115					
78	Ashuganj 55 MW PP (Precision)	Gas (NENP)	15'4	55	55	0	0	0	0			55	Gas Shortage	
**	Impoport (Tripura)	India		160	160	92	88	146	142					
<b>Cumilla Zone Total</b>				<b>2883</b>	<b>2875</b>	<b>1440</b>	<b>1579</b>	<b>1605</b>	<b>1801</b>	<b>665</b>	<b>0</b>			
79	RPCL 210MW CAPP	Gas (IPP)	4x35+1x70	210	202	0	0	17	35	202			Gas Shortage	
80	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	77	87	68	80					
81	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	103	140	100	140					
82	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0					
83	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	30	0	50	0					
84	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	36	54	35	35					
85	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	12	18	12	12	</				

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	25.06.24 (Yesterday)		26.06.24 (Today)		25.06.24 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)			
86	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	28	28	28	28		42	Under maint.	
87	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	68	68	68	68		22	Under maint.	
88	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	53	53	50	52				
89	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163				
90	Hobiganj 11 MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	2	2	2	2				
91	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	56	60	60	60				
92	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
93	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	100	100	100	100				
94	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	12	0	0	0				
95	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	20	24	18	18				
96	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	320	310	300	300				
97	Bibiyana-II 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	400	370	365	365				
98	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	370	340	350	350				
99	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0			Under Construction Project	
100	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	35	39	39	39				
<b>Sylhet Zone Total</b>					<b>2376</b>	<b>2331</b>	<b>1627</b>	<b>1557</b>	<b>1543</b>	<b>1545</b>	<b>0</b>	<b>394</b>	
101	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
102	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	205	235	250	250	175		Gas Shortage	
103	Fairpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	20	34	30	45				
104	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	29	62	50	60				
105	Khulna 225 MW CCPP	HSD/ Gas (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	0				
106	Russha 105 MW PP (Orion russha)	HFO (IPP)	6x18.445	105	105	63	17	36	53				
107	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	0	0	0				
108	Mongla Orion 100 MW Solar PP	Solar (IPP)	2x617	100	100	97	0	100	0				
109	Maitree Super Thermal 1320 MW PP	Coal (BIF/PCL)	1234	1234	414	812	800	800	800				
110	Khulna 330 MW CCPP	Gas/HSD (BIF/PCL)	1x220+1x116	336	336	0	0	0	0				
111	Nasipara 40 MW PP (Khanjahan Ali)	HFO NENP	5x8.5	40	40	32	32	32	40				
112	Khulna 115 PP MW (KPCL-2)	HFO NENP	7x17	115	115	46	48	16	98				
**	Bheramara (H/VD)	India		1000	1000	920	921	936	936				
<b>Khulna Zone Total</b>					<b>3858</b>	<b>3854</b>	<b>1826</b>	<b>2161</b>	<b>2250</b>	<b>2282</b>	<b>175</b>	<b>0</b>	
113	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	100	110	110	110				
114	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	10	9	10	10	10				
115	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	130	126	130	130		68	ST under maint.	
116	Pavra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	622	622	622	622				
117	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	54	17	35				
118	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	200	200	200	200				
119	Barisal 1 MW Solar PP	Solar (PDB)	1 x 1	1	1	0	0	0	0				
120	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	148	178	220	220				
<b>Barishal Zone Total</b>					<b>2266</b>	<b>2236</b>	<b>1226</b>	<b>1300</b>	<b>1309</b>	<b>1327</b>	<b>0</b>	<b>68</b>	
121	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.	
122	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	40	38	32	40				
123	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	5	0	10				
124	Chapaiawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	41	85	50	90				
125	Katakhalai 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	38	42	36	45				
126	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	15	30	0	30				
127	Sirajgonj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage	
128	Sirajgonj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150+1x75	220	220	145	203	130	130	17		Gas Shortage	
129	Sirajgonj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	0	0	0	0	220		Gas Shortage	
130	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	414	414	400	414				
131	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	5	2	5	5				
132	Natore 52 MW PP (Rajjanka)	HFO (IPP)	6x8.92	52	52	0	0	0	0				
133	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	113	113	113	113				
134	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	113	113	113	113				
135	Amnura 50 MW PP (Sinha)	HFO (NENP)	7x7.79	50	28	35	35	20	35				
136	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	5	0	6	0				
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	375	370	370	370				
<b>Raishahi Zone Total</b>					<b>3403</b>	<b>3381</b>	<b>1339</b>	<b>1450</b>	<b>1275</b>	<b>1395</b>	<b>518</b>	<b>100</b>	
137	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	55	55		85	Under Maintenance	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
138	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	185	190	180	190				
139	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
140	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16.2*3	113	113	110	113	113	113				
141	Sardpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
142	Majpara Tabula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	3	0	8	0				
143	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	94	115	35	115				
144	Lalmoinhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	18	0	30	0				
145	Teesa Solar Limited	Solar (IPP)	1 x 200	200	200	100	0	130	0				
<b>Rangpur Zone Total</b>					<b>1030</b>	<b>950</b>	<b>510</b>	<b>418</b>	<b>551</b>	<b>473</b>	<b>0</b>	<b>170</b>	
<b>Sub-total: Plants in operation</b>					<b>26815</b>	<b>26364</b>	<b>12757.0</b>	<b>13792</b>	<b>13692</b>	<b>14520</b>	<b>3448</b>	<b>1802</b>	
<b>(B) Plants under long term maintenance/ contract expired</b>													
146	Katoboti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			Contract Expired	
147	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	0	0	0	0	0			Contract Expired	
148	Jamalpur 95 MW PP (Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			Contract Expired	
149	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	0	0	0	0	0			Contract Expired	
150	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Contract Expired	
<b>Sub-Total: Plants under long term maintenance/ contract expired</b>					<b>700</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	
<b>Gross Total</b>					<b>27515</b>	<b>26364</b>	<b>12757</b>	<b>13792</b>	<b>13692</b>	<b>14520</b>	<b>3448</b>	<b>1802</b>	
<b>(C) Actual data of 25.06.24 (Yesterday) Tuesday :</b>													
01.	Max. Demand at eve. peak (Generation end)	: 15600 MW, at = 21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :										
02.	Max. Demand at eve. peak (Sub-station end)	: 14915 MW, at = 21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW			
03.	Highest Generation (Generation end)	: 13792 MW, at = 21:00 hrs	Dhaka	5257	5002	255	Mymensingh	1205	995	210			
04.	Minimum Generation (Generation end)	: 12257 MW, at = 6:00 hrs	Chattogram	1387	1277	110	Sylhet	583	493	90			
05.	Day-peak Generation (Generation end)	: 12757 MW, at = 12:00 hrs	Khulna	1977	1645	332	Barishal	478	408	70			
06.	Evening-peak Generation (Generation end)	: 13792 MW, at = 21:00 hrs	Rajshahi	1524	1294	230	Rangpur	1061	846	215			
07.	Evening Peak Load-shed (Sub-station end)	: 1727 MW, at = 21:00 hrs	Cumilla	1443	1228	215	Total	14915	13188	1727			
08.	Minimum Generation Forecast up to 8:00 hrs.	: 12476 MW, at = 5:00 hrs	13. Fuel cost : (a) Gas = 399754799 Taka (c) Coal = 505764389 Taka (b) Oil = 1442710698 Taka Total = 2348229886 Taka										
09.	Generation shortfall at evening peak due to :	:	14. Maximum Temperature in Dhaka was : 37.2°C										
	a) Gas/LF limitation	: 3363 MW	15. Export through East-West interconnections :										
	d) Coal supply Limitation	: 0 MW	At evening peak-hour : 12757 MW, at 21:00 hrs										
	b) Low water level in Kaptai lake	: 85 MW	Maximum : 58 MW, at 6:00 hrs										
	c) Plants under shut down/ maintenance	: 1802 MW	Energy : 2088.9 MKWh										
10.	Total Energy (Generation + India Import)	: 313.46 MKWh	By Gas = 130.273 MKWh By Oil = 78.522 MKWh By Coal = 74.168 MKWh By Hydro = 3.482 MKWh By Solar = 2.663 MKWh										
11.	Total Gas Supplied	: 962.13 MMCFD											
<b>(D) Forecast of 26.06.24 (Today) Wednesday :</b>													
01.	Maximum Demand	: 15600 MW (Generation end)	04. Maximum Load-shed : 1021.568545 MW At evening peak (Sub-station end)										
02.	Maximum Generation	: 14520 MW (Generation end)	05. Total Generation : 354.56 MKWh										
03.	Reserve / Shortage	: -1080 MW (Generation end)	06. Probable Max. Temperature in Dhaka : 37.2°C										

#Remarks: Highest Generation 16477 MW on 30-04-2024 at 21:00

(Md. Helalur Rahman)  
Deputy Secretary, Generation