

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel: 9564667, 9551095

Month July, 2024		Day : Monday				Date : 01.07.24						
Probable Maximum Demand :		14300 MW		Probable Maximum Generation :		14825 MW						
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 82.06 ft		Today = 82.04 ft		Rule Curve = 83.46 ft						
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	30.06.24 (Yesterday)		01.07.24 (Today)		30.06.24 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)	Probable Peak Generation (MW)	Gen. shortfall for :		Description/ Remarks	Probable start-up date		
							Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)				
				Day		Evening						
(A) Plants in operation:												
1	Ghorasal Repowered CAPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work
2	a) Ghorasal Repowered CAPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	240		Gas Shortage
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	110	110	110	110			
3	Ghorasal 365 MW CAPP Unit-7	Gas (PDB)	1x254+1x126	365	365	0	0	0	0		365	Awaiting for HGPI
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108		Gas Shortage
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105	Machine Problem
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Meghnaghat 450 MW CAPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	420	450	450			
8	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling
9	Haripur 412 MW CAPP	Gas (EGCB)	1x273+1x139	412	400	0	0	0	0			
10	Siddhirgonj 2'120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage
11	Siddhirgonj 335 MW CAPP	Gas (EGCB)	1 x 217+1x118	335	335	314	327	325	325			
12	Meghnaghat 335MW CAPP(Summit)	Gas (IPP)	2x110+1x110	335	335	304	278	305	300	57		Gas Shortage
13	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	55	15	55			
14	Gaganraj 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	33	57	8	83			
15	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)		22	22	0	0	0	0			
16	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	29	29	31	31			
17	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	16	16	16	16			
18	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	12	11	14	16			
19	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	16	8	8	8			
20	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	52	71	52	70			
21	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	48	146	48	149			
22	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	35	54	54	54			
23	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	248	278	263	270			
24	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	114	133	115	130			
25	Nabaganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	35	35	35			
26	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55			
27	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	53	17	52			
28	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	162	162	162	162			
29	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	11	0	35	0			
30	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	4	35	35	35			
31	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	42	64	40	64			
32	Meghnaghat 100 MW(IEL)	HFO (NENP)	12x8.9	100	100	16	17	16	16			
33	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	82	97	85	97			
34	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	13	0	13			
35	Unique Meghnaghat 584MW CAPP	Gas	1x400+1x184	584	584	0	0	0	0	584		Gas Shortage
36	Meghnaghat 589 MW CAPP(Summit)	Gas				0	0	0	0			Test run
Dhaka Zone Total				5828	5634	2260	2524	2294	2596	1199	845	
36	Karnaphuli Hydro PP Unit-1,2,3,4,5	Hydro (PDB)	2x40, 3x50	230	230	144	143	111	104	87		Inadequate Water Level
37	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.
38	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	2	0	5	0			
39	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	17	8	17			
40	Teknaf 20MW PP (Solarsat)	Solar (IPP)	1x20	20	20	4	0	20	0			
41	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	20	6	20			
42	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	53	68	51	68			
43	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.
44	Sikalbaha 225 MW CAPP	Gas (PDB)	1 x 150+1 x 75	225	225	219	224	220	222			
45	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	52	52	52	52			
46	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	49	62	49	62			
47	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	51	85	85	85			
48	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	40	60	60	60			
*	Malancha, Ctg. EPZ (United)	Gas	5x8.73+3x9.34			10	28	10	20			
49	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	19	19	12	12			
50	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54			
51	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	74	92	51	110			
52	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	50	50	50	50			
53	Juldah 100 MW Unit-1 (Acorn)	HFO (NENP)	8x13.45	100	100	35	46	46	46			
54	Chattogram 116 MW PP (Anilma Energy Ltd.)	HFO (IPP)	6x21.06	116	116	35	72	17	60			
55	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	54	163	54	163			
56	Chattogram 2'612MW Coal Based PP (SS Power)	Coal (IPP)	2x612	1224	1224	602	545	612	612			
57	Matarbari 2'600 MW (CPGCL)	Coal (CPGCL)	1x575	575	575	519	514	550	550			
58	Cox's Bazar Wind PP	(Wind) (IPP)	1x60	60	60	50	45	44	62			Test run
59	Sonagazi 75 MW Solar Plant	(Solar) (EGCB)	1x75	75	75	22	0	70	0			Test run
Chattogram Zone Total				4517	4457	2144	2359	2237	2429	267	330	
60	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	20	30	30	30			
61	Ashuganj 225 MW CAPP	Gas (APSCCL)	1x142+1'75	221	221	213	213	215	215			
62	Ashuganj 450 MW CAPP(South)	Gas (APSCCL)	1x360	360	360	240	240	240	240			
63	Ashuganj 450 MW CAPP(North)	Gas (APSCCL)	1x361	360	360	280	280	280	310	80		Gas Shortage
64	Ashuganj 420 MW CAPP(East)	Gas (APSCCL)	1x284+1x116	400	400	230	230	230	230			
65	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20'9.73+1'16	195	195	0	0	0	0	195		Gas Shortage
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	43	43	43			
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	60	51	90	110			
68	Tilas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	14	34	35	35			
69	Chandpur 150 MW CAPP	Gas (PDB)	1X106+1x57	163	163	70	50	70	70			
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	17	17	17			
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0			
72	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	0	0	0	0			
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	34	52	25	52			
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	12	12	12	12			
75	Feni 114 MW (Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	34	52	50	114			
76	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	102	103	90	100			
77	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	49	106	104	115			
78	Ashuganj 55 MW PP (Precision)	Gas (NENP)	15'4	55	55	5	0	0	0			
**	Impoport (Tripura)	India		160	160	80	78	146	142			
Cumilla Zone Total				2883	2875	1503	1591	1677	1835	275	0	
79	RPCL 210MW CAPP	Gas (IPP)	4x35+1x70	210	202	10	18	20	20	184		Gas Shortage
80	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	67	88	69	88			
81	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	116	145	116	145			
82	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0			
83	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	28	0	50	0			
84	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	35	36	35			
85	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	6	6	12	12			
Mymensingh Zone Total				654	646	245	292	305	300	184	0	

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	30.06.24 (Yesterday)		01.07.24 (Today)		30.06.24 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)		
86	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	27	28	28	40		42	Under maint.	
87	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	67	68	68	68		22	GT-4 Under maint.	
88	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	49	53	50	51				
89	Kushnara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163				
90	Hobganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	8	2	2				
91	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	59	61	60	60				
92	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
93	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	207	207	205	210				
94	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0				
95	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	12	12	11	12				
96	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	315	285	300	320				
97	Bibiana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	404	327	365	400				
98	Bibiana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	366	340	368	368				
99	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0			under project	
100	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	30	36	36	36				
Sylhet Zone Total				2376	2331	1707	1588	1656	1730	0	394		
101	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
102	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	325	330	345	340	80		Gas Shortage	
103	Fariapur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	21	42	30	41				
104	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	25	45	50	60				
105	Khulna 225 MW CCPP	HSD/ Gas (NWPGL)	1 x 150+1x75	225	230	0	0	0	0				
106	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	2	55	25	53				
107	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	0				
108	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	2	0	100	0				
109	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	2x617	1234	1234	712	814	790	820				
110	Khulna 330 MW CCPP	Gas/HSD (BPDB)	1x220+1x116	336	336	0	0	0	0				
111	Khulna 115 MW PP (IKPCL-2)	HFO (NENP)	7x17	115	115	0	32	16	32				
112	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	8	8	8				
**	Bheramara (HVDC)	India		1000	1000	924	924	927	927				
Khulna Zone Total				3858	3854	2011	2250	2291	2281	80	0		
113	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	110	110	110				
114	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	10	8	10	10	10				
115	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	126	126	130	130		68	ST under maint.	
116	Payra 1320 MW TFP	Coal (BCPCL)	2x622	1244	1244	622	600	622	622		644	Unit 1 under maint.	
117	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	35	35	35	35				
118	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	307	307	307	307				
119	Barisal 1 MW Solar PP	Solar (BPDB)	1x1	1	1	0	0	0	0				
120	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	220	220				
Barishal Zone Total				2266	2236	1334	1408	1434	1434	0	712		
121	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.	
122	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	32	24	32	40				
123	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	4	10	0	10				
124	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	48	87	50	88				
125	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	30	42	36	48				
126	Sanlahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	22	35	25	35				
127	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0				
128	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	200	166	200	200	54		Gas Shortage	
129	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0	220		Gas Shortage	
130	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	401	385	400	414				
131	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	2	2	5	5				
132	Natore 52 MW PP (Rajanka)	HFO (IPP)	6x8.92	52	52	0	0	0	0				
133	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	95	95	60	95				
134	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	113	113	113	113				
135	Ammura 50 MW PP (Sinha)	HFO (NENP)	7x7.9	50	28	35	35	35	35				
136	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	0	0	6	0				
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	0	0	600	650		1496	Unit 1 & 2 UM	
**	Sirajgonj 6.55 MW Solar	Solar IPP	68	0	0	5	0	0	0				
Rajshahi Zone Total				3403	3381	987	994	1562	1733	345	1596		
137	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	62	60	60	60	25		Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
138	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	220	220	200	220	54		Coal Shortage	
139	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
140	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	100	113	113	113				
141	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
142	Mejpara, Tatula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0				
143	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	35	94	90	94				
144	Lalmoinhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	8	0	30	0				
145	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	26	0	130	0				
Rangpur Zone Total				1030	950	456	487	631	487	79	85		
Sub-total: Plants in operation				26815	26364	12647.0	13493	14087	14825	2429	3962		
(B) Plants under long term maintenance/ contract expired													
146	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			Contract Expired	
147	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	0	0	0	0	0			Contract Expired	
148	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			Contract Expired	
149	Shahjibazar 80MW PP (Shahjibazar)	Gas (RPP)	3x29.90	86	0	0	0	0	0			Contract Expired	
150	Besla 108MW PP(ICI)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Contract Expired	
Sub-Total: Plants under long term maintenance/ contract expired				100	0	0	0	0	0	0	0		
Gross Total				27515	26364	12647	13493	14087	14825	2429	3962		
(C) Actual data of 30.06.24 (Yesterday) Sunday :													
01.	Max. Demand at eve. peak (Generation end)	:	13493	MW, at =	21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	12754	MW, at =	21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	13493	MW, at =	21:00 hrs	Dhaka	4858	4858	0	Mymensingh	1003	1003	0
04.	Minimum Generation (Generation end)	:	11601	MW, at =	7:00 hrs	Chattogram	1244	1244	0	Sylhet	436	436	0
05.	Day-peak Generation (Generation end)	:	12647	MW, at =	12:00 hrs	Khulna	1472	1472	0	Barishal	427	427	0
06.	Evening-peak Generation (Generation end)	:	13493	MW, at =	21:00 hrs	Rajshahi	1306	1306	0	Rangpur	907	907	0
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW, at =	21:00 hrs	Cumilla	1102	1102	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	11049	MW, at =	5:00 hrs	Total 12754 12754 0							
09.	Generation shortfall at evening peak due to :	:				Total 12754 12754 0							
	a) Gas/LF limitation	:	2263	MW		Fuel cost : (a) Gas = 401585268 Taka (c) Coal = 502049440 Taka							
	d) Coal supply Limitation	:	79	MW		(b) Oil = 1262916197 Taka Total = 2166550905 Taka							
	b) Low water level in Kaptai lake	:	87	MW		14. Maximum Temperature in Dhaka was : 32.2°C							
	c) Plants under shut down/ maintenance	:	3962	MW		15. Export through East-West interconnections :							
10.	Total Energy (Generation + India Import)	:	300.66	MKWh		At evening peak-hour : 12647 MW, at 21:00 hrs							
	By Gas =	130.347	MKWh	By Oil =	68.540	Maximum : 86 MW, at 21:00 hrs							
	By Coal =	71.793	MKWh	By Hydro =	3.369	Energy : 3182.85 MKWh							
	By Solar =	1.440	MKWh										
11.	Total Gas Supplied	:	958.22	MMCFD									
(D) Forecast of 01.07.24 (Today) Monday :													
01.	Maximum Demand	:	14300	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	14825	MW	(Generation end)	05.	Total Generation	:	318.70	MKWh			
03.	Reserve / Shortage	:	525	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	32.2°C				

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation