



Probable Maximum		Generation : (a) At Day Peak Hour : 14641.6 MW				(b) At Evening Peak Hour : 15378 MW										
Sl. No.	Name of the Power Station	Fuel	Producer	Installed Capacity		Present Capacity	Actual Generation		Forecasted Available Gen. or		Ev. Peak for Fuel Limitation	Gen.Shortage for plant. S/D M/C Problem	Plants under Shut down (date)/ Remarks	Probable Start up Date		
				Unit No. X Capacity	MW		MW	MW	2-Jul-24	during					Ev. Peak	Ev. Peak
84	Sarshabari 3 MW Solar Plant	Solar	IPP	1*3	3	3	1	0	2	0						
85	Mymensingh 200 MW PP (Unit)	HFO	IPP	9.78*21	200	200	117	143	116	145	55		Fuel shortage			
86	Jamalpur 115 MW PP (Unit)	HFO	IPP	9.78*12	115	115	69	88	69	88	27		Fuel shortage			
87	Suiakhalai 50 MW Solar PP	Solar	IPP	50	50	50	16	0	50	0						
88	Tangail Pali Power Gen 22 MW	HFO	IPP	4*6.7	22	22	6	6	6	6	16		Engine prblem			
	Bhairab 54.5 MW	HFO	IPP	3*18.2	54	54	10	17	36	35						
<b>Mymensingh Area Total</b>					<b>749</b>	<b>646</b>	<b>230.0</b>	<b>271</b>	<b>299</b>	<b>294</b>	<b>182</b>	<b>0</b>				
89	Fenchugonj CCGP Phase-1	Gas	PDB	2*32+1*33	97	70	28	27	28	40		30	Machine problem.			
90	Fenchugonj CCGP Phase-2	Gas	PDB	2*35+1*35	104	90	67	68	70	70		20	Machine problem			
91	Kushiara 163 MW CCGP (KP)	Gas	IPP	1*109+1*54	163	163	163	163	163	163						
92	Shajibazar 330 MW CCGP	Gas	PDB	3*110	330	330	0	0	0	0		330	Under maint.			
93	Fenchugonj 51 MW PP (Baraka)	Gas	RPP	19*2.90	51	51	50	50	50	51						
94	Fenchugonj 44 MW (Energyprim)	Gas	NENP	12*3.3+5*2	50	50	36	39	36	36		14	Engine problem			
95	Hobiganj 11 MW PP Confidence	Gas	SIPP, REB	4*2.90	11	11	8	8	2	2		9	Engine problem			
96	Shahjibazar GTPP Unit- 8 & 9	Gas	PDB	2*35	70	66	61	61	60	60						
97	Shahjibazar 86 MW PP (Shahjib)	Gas	RPP	32*2.90	86	0	0	0	0	0			Contract Expired			
98	Shahjibazar 100 MW GTPP	Gas	PDB	1*100	100	100	0	0	0	0						
99	Sylhet 225 MW CCGP	Gas	PDB	1*142+1*89	231	231	208	210	205	210		21	Machine problem			
100	Sylhet 20 MW GTPP	Gas	PDB	1*20	20	20	0	0	0	0	20		Gas shortage			
	Sylhet 50 MW PP (EPL)	Gas	NENP	27*2	0	0	0	0	0	0			Contract Expired			
101	Shahjahanulla 25 MW PP	Gas	SIPP, REB	3*9.34	25	25	12	12	11	12		13	Engine problem			
102	Bibiana-II 341 MW CCGP (Sumr)	Gas	IPP	1*222+1*119	341	341	290	280	300	320			FGMO			
103	Bibiana-III 400 MW CCGP	Gas	PDB	285*1+134*1	400	400	364	340	364	400			FGMO			
104	Sylhet 10MW PP (Desh)	Gas	RPP	6*1.95	0	0	0	0	0	0			Contract Expired			
105	Bibiyana South 400 MW	Gas	PDB	400 MW	383	383	340	345	368	368			FGMO			
<b>Sylhet Area Total</b>					<b>2462</b>	<b>2331</b>	<b>1627</b>	<b>1603</b>	<b>1658</b>	<b>1732</b>	<b>20</b>	<b>437</b>				
106	Bheramara GTPP Unit-3	HSD	PDB	1*20	20	16	0	0	0	0	16		Fuel conservation			
**	Bheramara (HVDC )	0	ported powe	2*500	1000	1000	924	922	927	927						
107	Khulna 115 PP MW (KPCL-2)	HFO	NENP	7*17	115	115	48	47	66	98	17		Fuel shortage			
108	Faridpur 50 MW Peaking PP	HFO	PDB	8*6.89	54	54	0	42	30	41		13	Engine problem			
109	Khulna 225 MW CCGP	HSD	NWPGCL	1*150+1*75	230	230	0	0	0	0	230		Fuel shortage			
110	Gopalganj 100 MW Peaking PP	HFO	PDB	16*6.98	109	109	0	46	50	60		49	Engine problem			
111	Bheramara 410 MW CCGP	Gas	NWPGCL	1*278+1*132	410	410	335	350	345	350	60		Gas shortage			
112	Noapara 40 MW PP (Khanjahan)	HFO	NENP	5*8.5	40	40	8	16	8	16	24		Fuel shortage			
	Noapara 100 MW PP (Bangla T)	HSD	IPP	70*1.4	0	0	0	0	0	0						
113	Rupsha 105 MW PP (Orion rup)	HFO	IPP	6*18.445	105	105	5	55	25	53	52		Fuel shortage			
114	Madhumati 100 MW PP	HFO	NWPGCL	6*18	105	105	0	0	0	0						
115	Mongla Orion 100 MW Solar PP	Solar	IPP	100	100	100	46	0	100	0						
116	Khulna 330 MW CCGP (OIL)	Gas/HSD	BPDB	1*220+1*110	336	336	0	0	0	0	336		Fuel shortage			
117	Rampal 1320 MW (BIFPCL)	Coal	NTPC&BPDB	617*2	1234	1234	714	808	790	820	384		Coal shortage			
	Kulna 225 MW CCGP (GAS)	Gas	NWPGCL	0	0	0	0	0	0	0			On test.			
<b>Khulna Area Total</b>					<b>3858</b>	<b>3854</b>	<b>2080</b>	<b>2286</b>	<b>2341</b>	<b>2365</b>	<b>1119</b>	<b>62</b>				
118	Barisal 110 MW PP (Summit )	HFO	IPP	7*17.076	110	110	16	80	110	110						
119	Bhola 33 MW PP (Venture)	Gas	NENP	1*34.50	40	10	0	9	10	10						
120	Bhola 225 MW CCGP	Gas	PDB	2*63+1*68	194	194	130	130	130	130		64	ST Under maint.			
	Bhola 95 MW PP (Aggreko)	Gas	QRPP	96*1.10	0	0	0	0	0	0			Contract Expired	From 18-3-2022		
121	Payra 1320 MW	Coal	BCPCL	2*622	1244	1244	550	870	1000	1000		622	Unit-1 Under maint			
122	Bhola Nutan Biddut BD LTD	Gas	IPP	220	220	220	220	220	220	220						
123	United Payra Power Ltd.	HFO	IPP	8*18.5+1*9.5	150	150	35	35	35	35	115		Fuel shortage.			
124	Barisal 307 MW	Coal	IPP	307*1	307	307	200	276	307	307						
	Barisal 1 MW Solar Plant	Solar	BPDB	1	1	1	0	0	0	0						
<b>Barisal Area Total</b>					<b>2266</b>	<b>2236</b>	<b>1151</b>	<b>1620</b>	<b>1812</b>	<b>1812</b>	<b>115</b>	<b>686</b>				
125	Baghabari 71 MW GTPP	Gas	PDB	1*71	71	71	0	0	0	0	71		Gas shortage			
	Baghabari 100 MW GTPP	Gas	PDB	1*100	100	100	0	0	0	0	100		Gas shortage			
126	Baghabari 50 MW Peaking PP	HFO	PDB	6*8.9	52	52	0	32	32	40		12	Engine problem			
127	Bera 70 MW Peaking PP	HFO	PDB	9*8.29	71	71	0	10	0	10		61	Engine problem			
128	Amnura 50 MW PP(Sinha)	HFO	NENP	7*7.79	50	28	28	0	35	35			Engine problem			
129	Katakhalai 50 MW PP (Northern)	HFO	QRPP	6*8.9	0	0	0	0	0	0			Contract Expired			
130	Katakhalai 50 MW Peaking PP	HFO	PDB	6*8.7	50	50	0	39	36	48						
131	Sirajgonj 225MW CCGP Unit-1	Gas/HSD	NWPGCL	1*150+1*75	210	210	0	0	0	0		210	Under maint.			
132	Sirajgonj 225MW CCGP Unit-2	Gas/HSD	NWPGCL	1*150+1*75	220	220	185	179	200	200	20		Gas shortage			
133	Sirajgonj 225MW CCGP Unit-3	Gas/HSD	NWPGCL	1*141	220	220	0	0	0	0	220		Gas shortage			
134	Sirajgonj 400 MW CCGP Unit-4	Gas/HSD	SNWPGCL	1*282+1*132	414	414	394	366	400	414						
135	Santahar 50 MW Peaking PP	HFO	PDB	6*8.7	50	50	0	36	25	35		15	Engine problem			
	Bogra 22 MW PP (GBB)	Gas	RPP	0	0	0	0	0	0	0			Contract Expired			
	Bogra 20 MW PP (Energyprima)	Gas	NENP	5*3.3+5*2	0	0	0	0	0	0			Contract Expired			
136	Ullapara 11 MW PP (Summit)	Gas	SIPP, REB	4*2.90	11	11	2	5	5	5		6	Engine problem			
137	Natore 52 MW PP (Rajlanka)	HFO	IPP	6*8.92	52	52	0	0	0	0	52		Fuel shortage			
138	Chapainawabganj 100 MW Pea	HFO	PDB	12*8.924	104	104	39	90	50	90		14	Engine problem			
	Baghabari 200 MW PP (Paramo)	HSD	IPP	135*1.6	0	0	0	0	0	0			Contract Expired			
139	Bagura 113 MW PP (Confidence)	HFO	IPP	6*18.55+7.2	113	113	64	35	113	113						
140	Confidence Power Bogura Unit-1	HFO	IPP	6*18.55	113	113	80	35	60	95		18	Engine problem			
141	Sirajgonj 6.55 MW Solar	Solar	NWPGCL	1*6	6	6	2	0	6	0						
**	Adani Power Jharkhanda Ltd	Coal	ported powe	748*2	1496	1496	766	771	600	650		748	Unit-2 shut down			
	Sirajgonj 68 MW Solar Park	Solar	IPP	68	0	0	16	0	5	0						
<b>Rajshahi Area Total</b>					<b>3403</b>	<b>3381</b>	<b>1576</b>	<b>1598</b>	<b>1567</b>	<b>1735</b>	<b>463</b>	<b>1084</b>				
142	Barapukuria TPP Unit-1	Coal	PDB	1*125	125	85	62	60	60	60		25				
	Barapukuria TPP Unit-2	Coal	PDB	1*125	125	85	0	0	0	0		85	Under maint			
143	Barapukuria 275 MW TPP Unit-3	Coal	PDB	1*275	274	274	220	220	200	220		54	Machine problem			
144	Rangpur 20 MW GTPP	HSD	PDB	1*20	20	20	0	0	0	0	20					