

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month July, 2024					Day : Wednesday				Date : 03.07.24				
Probable Maximum Demand : 14200 MW					Probable Maximum Generation : 16697 MW								
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 83.35 ft		Today = 86.16 ft		Rule Curve = 84.32 ft				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	02.07.24 (Yesterday)		03.07.24 (Today)		02.07.24 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)			
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work		
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	240	Gas Shortage		
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	110	110	110	110				
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Awaiting for HGPI		
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108	Gas Shortage		
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Machine Problem		
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0				
7	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	390	450	450				
8	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling		
9	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	400	0	60	230	230				
10	Siddhirgonj 2'120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage		
11	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	280	327	325	325				
12	Meghnaghat 335MW CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	273	287	150	150				
13	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	25	55	25	55				
14	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	33	8	8	83				
15	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	0	0				
16	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	29	29	31	31				
17	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	16	16	16	16				
18	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	6	11	14	16				
19	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	16	8	8	8				
20	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	52	71	52	70				
21	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	32	149	48	149				
22	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	0	54	54				
23	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	203	145	263	285				
24	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	149	149	149	149				
25	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	55	35	55				
26	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	55	55				
27	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	52	17	52				
28	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	72	90	162	162				
29	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	5	0	35	0				
30	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	35	35	35				
31	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	9	24	40	64				
32	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	9	9	16	16				
33	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	82	80	85	97				
34	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	0	0	13				
35	Unique Meghnaghat 584MW CCPP	Gas	1x400+1x184	584	584	0	0	0	0	584	Gas Shortage		
	Meghnaghat 589 MW CCPP(Summit)	Gas				0	0	0	0		Gas Shortage		
Dhaka Zone Total				5828	5634	1972	2215	2413	2730	1142	845		
36	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	150	170	164	164	60	Inadequate Water Level		
37	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage		
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.	
38	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	0	0	5	0				
39	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	8	8	17				
40	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	2	0	20	0				
41	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	13	34	6	34				
42	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	34	51	68				
43	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.		
44	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	224	222	220	222				
45	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	69	49	52	52				
46	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	50	75	50	75				
47	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	68	68	85	85				
48	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	28	56	62	64				
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			2	21	10	20				
49	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	12	12	12	12				
50	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	5	0	54	54				
51	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	9	0	85	85				
52	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	50	75	50	75				
53	Juldah 100 MW Unit-1 (Acom)	HFO (NENP)	8x13.45	100	100	12	0	46	46				
54	Chattogram 116 MW PP (Anilma Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	72	17	60				
55	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	54	0	54	163				
56	Chattogram 2'612MW Coal Based PP (SS Power)	Coal (IPP)	2x612	1224	1224	440	450	612	612				
57	Matarbari 2'600 MW (CPGCL)	Coal (CPGCL)	1x575	575	575	518	480	550	550				
58	Cox's Bazar Wind PP	(Wind) (IPP)	1x60	60	60	10	25	44	62		Test run		
59	Sonagazi 75 MW Solar Plant	(Solar) (EGCB)	1x75	75	75	33	0	70	0		Test run		
Chattogram Zone Total				4517	4457	1783	1851	2327	2520	240	330		
60	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	30	15	30	30				
61	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1'75	221	221	189	217	215	215				
62	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	240	240	240	240				
63	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	280	280	280	310	80	Gas Shortage		
64	Ashuganj 420 MW CCPP(East)	Gas (APSCL)	1x284+1x116	400	400	230	230	230	230				
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20'9.73+1'116	195	195	0	8	8	8	187	Gas Shortage		
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	43	43	43				
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	73	0	135	135				
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	34	36	35	35				
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	70	45	70	70				
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	17	17	17				
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0				
72	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	0	0	0	0				
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	34	8	25	52				
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	12	12	12	12				
75	Feni 114 MW (Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	34	52	50	114				
76	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	42	94	46	75				
77	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	49	107	104	115				
78	Ashuganj 55 MW PP (Precision)	Gas (NENP)	15'4	55	55	0	2	10	10				
**	Impoport (Tripura)	India		160	160	86	80	146	142				
Cumilla Zone Total				2883	2875	1463	1486	1696	1853	267	0		
79	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	10	19	20	20	183	Gas Shortage		
80	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	78	88	69	88				
81	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	97	145	116	145				
82	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0				
83	Sutiakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	22	0	50	0				
84	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	36	35				
85	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	6	6	6	6				
Mymensingh Zone Total				654	646	231	275	299	294	183	0		

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	02.07.24 (Yesterday)		03.07.24 (Today)		02.07.24 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : r Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening				
86	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	29	29	28	40		41	Under maint.	
87	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	68	69	70	70		21	GT-4 Under maint.	
88	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)		51	51	50	46	50	51				
89	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	120	163	163	163				
90	Hobganij 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	5	2	2				
91	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	61	61	60	60				
92	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
93	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	214	210	205	210				
94	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	15	15	15				
95	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	12	12	11	12				
96	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	270	300	300	320				
97	Bibiayana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	350	374	400	400				
98	Bibiayana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	345	345	368	368				
99	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0			under project	
100	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	36	40	36	36				
Sylhet Zone Total						2376	2331	1560	1669	1708	1747	0	392
101	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
102	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	300	360	360	360	50		Gas Shortage	
103	Faridpur 50 MW Peaking PP	HFO (PDB)		54	54	0	0	30	41				
104	Gopalganj 100 MW Peaking PP	HFO (PDB)		109	109	0	0	50	60				
105	Khulna 225 MW CCPP	HSD/ Gas (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	0				
106	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)		105	105	27	73	25	53				
107	Madhumati 100 MW PP	HFO (NWP/GCL)		105	105	0	0	0	0				
108	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	39	0	100	0				
109	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)		1234	1234	717	722	790	820				
110	Khulna 330 MW CCPP	Gas/HSD (BPDB)	1x220+1x116	336	336	0	0	0	0				
111	Khulna 115 MW PP (KPCL-2)	HFO (NENP)		115	115	0	16	66	98				
112	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)		40	40	0	0	8	16				
**	Bheramara (HVDC)	India		1000	1000	924	924	927	927				
Khulna Zone Total						3858	3854	2007	2095	2356	2375	50	0
113	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	16	110	110				
114	Bhola 33 MW PP (Venture)	Gas (NENP)		40	10	8	6	10	10				
115	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	80	130	130	130		64	ST under maint.	
116	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	1244	1020	1200	1244		224	Unit 1 under maint.	
117	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	35	35				
118	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	307	232	307	307				
119	Barisal 1 MW Solar PP	Solar (BPDB)	1x1	1	1	0	0	0	0				
120	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	180	220	220	220				
Barishal Zone Total						2266	2236	1819	1624	2012	2056	0	288
121	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.	
122	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	30	32	40				
123	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	10				
124	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	0	50	90				
125	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	39	36	48				
126	Santhar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	36	25	35				
127	Sirajgonj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	0	0	0	0				
128	Sirajgonj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	157	165	200	200	55		Gas Shortage	
129	Sirajgonj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	0	0	0	0	220		Gas Shortage	
130	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	313	305	400	414				
131	Uliapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	2	5	5	5				
132	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	0	0	0				
133	Bagura 113 MW PP (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	0	60	95				
134	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	0	113	113				
135	Ammura 50 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	0	0	35	35				
136	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	1	0	6	0				
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	826	1510	1400	1550		-14	Unit 1 & 2 UM	
**	Sirajgonj 6.55 MW Solar	Solar IPP	68	0	0	14	0	5	0				
Rajshahi Zone Total						3403	3381	1313	2090	2367	2635	346	86
137	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	61	62	60	60	23		Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
138	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	190	220	200	220	54		Coal Shortage	
139	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
140	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	34	70	113	113				
141	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
142	Majpara, Tabula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	3	0	8	0				
143	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	55	72	90	94				
144	Lalmoinhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	5	0	30	0				
145	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	52	0	130	0				
Rangpur Zone Total						1030	950	400	424	631	487	77	85
Sub-total: Plants in operation						26815	26364	12548.0	13729	15809	16697	2305	2026
(B) Plants under long term maintenance/ contract expired													
146	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			Contract Expired	
147	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	0	0	0	0	0			Contract Expired	
148	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			Contract Expired	
149	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	0	0	0	0	0			Contract Expired	
150	Bosila 108MW PP(ICI)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Contract Expired	
Sub-Total: Plants under long term maintenance/ contract expired						700	0	0	0	0	0	0	0
Gross Total						27515	26364	12548	13729	15809	16697	2305	2026

(C) Actual data of 02.07.24 (Yesterday) Tuesday :													
01.	Max. Demand at eve. peak (Generation end)	:	13800	MW, at =	21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	13236	MW, at =	21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	13729	MW, at =	21:00 hrs	Dhaka	4780	4780	0	Mymensingh	1135	1067	68
04.	Minimum Generation (Generation end)	:	11107	MW, at =	8:00 hrs	Chattogram	1234	1234	0	Sylhet	556	556	0
05.	Day-peak Generation (Generation end)	:	12548	MW, at =	12:00 hrs	Khulna	1614	1614	0	Barishal	434	434	0
06.	Evening-peak Generation (Generation end)	:	13729	MW, at =	21:00 hrs	Rajshahi	1308	1308	0	Rangpur	874	874	0
07.	Evening Peak Load-shed (Sub-station end)	:	68	MW, at =	21:00 hrs	Cumilla	1302	1302	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	11080	MW, at =	5:00 hrs					Total	13236	13168	68
09.	Generation shortfall at evening peak due to :	:				13.	Fuel cost :	(a) Gas = 395034395 Taka		(c) Coal = 713216699 Taka		Taka	
a) Gas/LF limitation	:	2168	MW		(b) Oil = 714159335 Taka			Total = 1822410429		Taka			
d) Coal supply Limitation	:	77	MW										
b) Low water level in Kaptai lake	:	60	MW										
c) Plants under shut down/ maintenance	:	2026	MW										
10.	Total Energy (Generation + India Import)	:	301.66	MKWh		14.	Maximum Temperature in Dhaka was : 29.0°C						
	By Gas = 128.133 MKWh			By Oil = 39.300 MKWh		15.	Export through East-West interconnections :						
	By Coal = 104.477 MKWh			By Hydro = 3.895 MKWh			At evening peak-hour		:	12548	MW, at	21:00 hrs	
	By Solar= 1.201 MKWh						Maximum		:	420	MW, at	1:00 hrs	
							Energy		:	7977.75	MKWh		
11.	Total Gas Supplied	:	966.54	MMCFD									
(D) Forecast of 03.07.24 (Today) Wednesday :													
01.	Maximum Demand	:	14200	MW	(Generation end)	04.	Maximum Load-shed		:	0	MW	At evening peak (Sub-station end)	
02.	Maximum Generation	:	16697	MW	(Generation end)	05.	Total Generation		:	312.04	MKWh		
03.	Reserve / Shortage	:	2497	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka : 29.0°C						