

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month July, 2024				Day : Thursday				Date : 04.07.24					
Probable Maximum Demand : 14500 MW				Probable Maximum Generation : 15980 MW				Rule Curve = 84.48 ft.					
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 86.16 ft Today = 88.28 ft				Gen. shortfall for :					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	03.07.24 (Yesterday)		04.07.24 (Today)		03.07.24 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Machines shut down (MW)	Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW				
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	240		Gas Shortage	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	110	110	110	110				
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365	Awaiting for HGPI	
4	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108		Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105	Machine Problem	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0				
7	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	420	350	450	450				
8	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling	
9	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	400	268	329	400	400				
10	Siddhirgonj 2'120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage	
11	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	323	306	325	325				
12	Meghnaghat 335MW CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	150	124	150	150				
13	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	30	55	25	55				
14	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	8	8	8	8				
15	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	0	0				
16	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	29	14	29	29				
17	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	16	14	16	16				
18	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	10	5	14	16				
19	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	8	8	8				
20	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	52	70	52	70				
21	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	48	148	48	149				
22	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	17	17	17				
23	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	95	195	263	285				
24	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	131	149	149	149				
25	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	17	55	55				
26	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	55	55				
27	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	17	17	52				
28	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	90	162	162	162				
29	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	30	0	35	0				
30	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	35	35	35				
31	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	32	42	40	64				
32	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	8	9	16	16				
33	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	48	85	85	97				
34	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	0	0	13				
35	Unique Meghnaghat 584MW CCPP	Gas	1x400+1x184	584	584	0	0	0	0	584		Gas Shortage	
	Meghnaghat 589 MW CCPP(Summit)	Gas				0	0	0	0			Gas Shortage	
Dhaka Zone Total				5828	5634	2010	2324	2564	2786	1142	845		
36	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	156	172	166	172	58		Inadequate Water Level	
37	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.	
38	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	2	0	5	0				
39	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	8	8	17				
40	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	0	0	20	0				
41	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	44	6	44				
42	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	85	51	68				
43	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.	
44	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	222	218	220	222				
45	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	52	51	52	52				
46	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	49	60	50	60				
47	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	34	85	85	85				
48	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	42	72	62	80				
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			8	9	5	20				
49	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	12	12	12	12				
50	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	17	54	54				
51	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	17	17	17				
52	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	50	62	50	75				
53	Juldah 100 MW Unit-1 (Acom)	HFO (NENP)	8x13.45	100	100	0	12	12	12				
54	Chattogram 116 MW PP (Anilma Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	53	17	60				
55	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	0	163	54	163				
56	Chattogram 2'612MW Coal Based PP (SS Power)	Coal (IPP)	2x612	1224	1224	500	490	612	612				
57	Matarbari 2'600 MW (CPGCL)	Coal (CPGCL)	1x575	575	575	519	508	550	550				
58	Cox's Bazar Wind PP	(Wind) (IPP)	1x60	60	60	23	25	44	62			Test run	
59	Sonagazi 75 MW Solar Plant	(Solar) (EGCB)	1x75	75	75	59	0	70	0			Test run	
Chattogram Zone Total				4517	4457	1779	2163	2222	2437	238	330		
60	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	15	20	30	30				
61	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1'75	221	221	194	212	215	215				
62	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	240	240	240	240				
63	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	280	290	290	310	70		Gas Shortage	
64	Ashuganj 420 MW CCPP(East)	Gas (APSCL)	1x284+1x116	400	400	230	230	230	230				
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20'9.73+1'116	195	195	8	8	8	8	187		Gas Shortage	
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	34	43	43				
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	10	130	135	135				
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	3	43	43	43				
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	45	80	70	70				
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	30	17	17	17				
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0				
72	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	0	0	0	0				
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	50	25	52				
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	13	16	16	16				
75	Feni 114 MW (Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	70	86	50	114				
76	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	45	82	46	82				
77	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	52	104	104	115				
78	Ashuganj 55 MW PP (Precision)	Gas (NENP)	15'4	55	55	10	5	10	10				
**	Import (Tripura)	India		160	160	84	82	146	142				
Cumilla Zone Total				2883	2875	1380	1679	1718	1872	257	0		
79	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	10	12	16	16	190		Gas Shortage	
80	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	68	88	69	88				
81	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	98	140	116	145				
82	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0				
83	Sutlakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	24	0	50	0				
84	Bharob 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	36	35				
85	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	6	6	6	6				
Mymensingh Zone Total				654	646	224	263	295	290	190	0		

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	03.07.24 (Yesterday)		04.07.24 (Today)		03.07.24 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)		
86	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	27	27	27	27		43	Under maint.	
87	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	68	69	70	70		21	GT-4 Under maint.	
88	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)		51	51	50	53	50	51				
89	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	120	163	163	163				
90	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	2	2	2				
91	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	56	62	60	60				
92	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
93	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	212	212	210	210				
94	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	15	15	15	15				
95	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	12	12	12	12				
96	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	250	300	320				
97	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	402	396	400	400				
98	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	364	325	368	368				
99	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0			under project	
100	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	40	40	40	40				
Sylhet Zone Total				2376	2331	1656	1626	1717	1738	0	394		
101	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
102	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	340	330	350	350	80		Gas Shortage	
103	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	47	30	47				
104	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	46	50	60				
105	Khulna 225 MW CCPP	HSD/ Gas (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	0				
106	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	35	53	25	53				
107	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	0	0	0				
108	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	47	0	100	0				
109	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	2x617	1234	1234	342	357	350	350				
110	Khulna 330 MW CCPP	Gas/HSD (BPDB)	1x220+1x116	336	336	0	0	0	0				
111	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	16	80	66	98				
112	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	16	8	16				
**	Bheramara (HVDC)	India		1000	1000	482	910	927	927				
Khulna Zone Total				3858	3854	1262	1839	1906	1901	80	0		
113	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	16	110	110				
114	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	10	7	10	10	10				
115	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	130	126	130	130		68	ST under maint.	
116	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	1200	1020	1200	1244				
117	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	17	35	35				
118	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	250	307	250	307				
119	Barisal 1 MW Solar PP	Solar (BPDB)	1x1	1	1	0	0	0	0				
120	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	220	220				
Barishal Zone Total				2266	2236	1807	1716	1955	2056	0	68		
121	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.	
122	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	25	25	30				
123	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	4	0	10				
124	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	80	50	90				
125	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	18	36	42				
126	Santhar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	30	25	35				
127	Sirajgonj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	0	0	0	0				
128	Sirajgonj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	178	183	180	185	37		Gas Shortage	
129	Sirajgonj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	0	0	0	0	220		Gas Shortage	
130	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	346	298	350	350				
131	Uliapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	2	2	5	5				
132	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	0	0	0				
133	Bagura 113 MW PP (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	35	60	95				
134	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	35	113	113				
135	Ammura 50 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	0	0	35	35				
136	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	4	0	6	0				
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	1316	1365	1400	1400				
**	Sirajgonj 6.55 MW Solar	Solar IPP	68	0	0	30	0	5	0				
Rajshahi Zone Total				3403	3381	1876	2075	2290	2390	328	100		
137	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	62	62	62	62	23		Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
138	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	220	220	200	220	54		Coal Shortage	
139	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
140	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	0	53	113	113				
141	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
142	Majpara, Tabula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	3	0	8	0				
143	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	35	112	90	115				
144	Lalmoinhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	10	0	30	0				
145	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	35	0	130	0				
Rangpur Zone Total				1030	950	365	447	633	510	77	85		
Sub-total: Plants in operation				26815	26364	12359.0	14132	15300	15980	2312	1822		
(B) Plants under long term maintenance/ contract expired													
146	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			Contract Expired	
147	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	0	0	0	0	0			Contract Expired	
148	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			Contract Expired	
149	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	0	0	0	0	0			Contract Expired	
150	Bosila 108MW PP(ICI)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Contract Expired	
Sub-Total: Plants under long term maintenance/ contract expired				700	0	0	0	0	0	0	0		
Gross Total				27515	26364	12359	14132	15300	15980	2312	1822		

(C) Actual data of 03.07.24 (Yesterday) Wednesday :															
01.	Max. Demand at eve. peak (Generation end)	:	14350	MW,	at =	19:30 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	13678	MW,	at =	19:30 hrs		Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	14132	MW,	at =	19:30 hrs		Dhaka	5023	4975	48	Mymensingh	1129	969	160
04.	Minimum Generation (Generation end)	:	11080	MW,	at =	6:00 hrs		Chattogram	1265	1265	0	Sylhet	552	552	0
05.	Day-peak Generation (Generation end)	:	12359	MW,	at =	12:00 hrs		Khulna	1649	1649	0	Barishal	434	434	0
06.	Evening-peak Generation (Generation end)	:	14132	MW,	at =	19:30 hrs		Rajshahi	1345	1345	0	Rangpur	965	965	0
07.	Evening Peak Load-shed (Sub-station end)	:	208	MW,	at =	19:30 hrs		Cumilla	1315	1315	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	11302	MW,	at =	5:00 hrs						Total	13678	13470	208
09.	Generation shortfall at evening peak due to :	:						13.	Fuel cost :	(a) Gas = 402619150 Taka	(c) Coal = 720938931 Taka	Taka			
a)	Gas/LF limitation	:	2177	MW						(b) Oil = 747309887 Taka	Total = 1870867967 Taka	Taka			
d)	Coal supply Limitation	:	77	MW											
b)	Low water level in Kaptai lake	:	58	MW											
c)	Plants under shut down/ maintenance	:	1822	MW			14.	Maximum Temperature in Dhaka was : 31.0°C							
10.	Total Energy (Generation + India Import)	:	302.16	MKWh			15.	Export through East-West interconnections :							
	By Gas = 130.743 MKWh				By Oil = 41.14 MKWh			At evening peak-hour : 12359 MW, at 19:30 hrs							
	By Coal = 106.196 MKWh				By Hydro = 3.747 MKWh			Maximum : 420 MW, at 1:00 hrs							
	By Solar= 1.774 MKWh							Energy : 7977.75 MKWh							
11.	Total Gas Supplied	:	968.78	MMCFD											
(D) Forecast of 04.07.24 (Today) Thursday :															
01.	Maximum Demand	:	14500	MW	(Generation end)		04.	Maximum Load-shed : 0 MW At evening peak (Sub-station end)							
02.	Maximum Generation	:	15980	MW	(Generation end)		05.	Total Generation : 310.22 MKWh							
03.	Reserve / Shortage	:	1480	MW	(Generation end)		06.	Probable Max. Temperature in Dhaka : 31.0°C							