

### Clarification on

**“Procurement of Supply, Installation, Testing, Commissioning of Auxiliary Transformers, 6.6kV Bus Duct with other Rehabilitation Works of Shahjibazar 330MW CCPP, BPDB, Hobiganj, Sylhet, Bangladesh on Turnkey Basis.”**

Tender Reference No.: 27.11.0000.304.24.310.23; DATED: 22 – 11 – 2023

Sl No.	Reference No./ Clause No.	Tender Document Clause	Tenderer's Queries/ Clarification	BPDB's Comments/ Amended as
1.	Rejection Clause; SI No. 20	Tenderer shall have to submit Type Test Report of Step up/down Transformer or higher MVA capacity transformer of same voltage rating from any Independent Testing Laboratories [TDS (ITT 24.20(9))];	Tenderer shall have to submit Type Test Report of Step up/down Transformer or higher MVA capacity transformer of same or higher voltage rating from any Independent Testing Laboratories [TDS (ITT 24.20(9))];	Tenderer shall have to submit Type Test Report of Step up/down Transformer or higher MVA capacity transformer of same or higher voltage rating from any Independent Testing Laboratories [TDS (ITT 24.20(9))];
2.	Section 2. Tender Data Sheet; ITT 24.2(c) SI no 06	<p>the end user certificate from the concerned manufacturer of the following equipment stating that the performance of offered type equipment is satisfactory for two (02) years within last ten (10) years; years counting backward from the date of IFT;</p> <p>i. Auxiliary Transformer, 30 MVA, 14.5/ 6.6 KV.</p> <p>ii. 230KV Lightning Arrester</p> <p>iii. 230KV XLPE Cable</p> <p>The certificate(s) must contain the following information:</p> <ul style="list-style-type: none"> <li>• Certificate on Letterhead pad of the user containing detail contact information</li> <li>• Date of Issue</li> <li>• Duly signed by the proper authority mentioning designation</li> <li>• Date of supply/ mention 2 years satisfactory operation</li> </ul>	<p>the end user certificate from the concerned manufacturer of the following equipment stating that the performance of offered type similar/ higher rating equipment is satisfactory for two (02) years within last ten (10) years; years counting backward from the date of IFT;</p> <p>i. Auxiliary Transformer, 30 MVA, 14.5/ 6.6 KV.</p> <p>ii. 230KV Lightning Arrester</p> <p>iii. 230KV XLPE Cable</p> <p>The certificate(s) must contain the following information:</p> <ul style="list-style-type: none"> <li>• Certificate on Letterhead pad of the user containing detail contact information</li> <li>• Date of Issue</li> <li>• Duly signed by the proper authority mentioning designation</li> <li>• Date of supply/ mention 2 years satisfactory operation</li> </ul>	As per Tender Document.

*M*

*R*