

# Bangladesh Power Development Board



## Tender Document for Procurement of

Supply of 33/11kV, 10/13.33 MVA Power Transformer (Tongi Store)

(International)

Open Tendering Method

(As per CPTU STD PG-4)

International Tender No.: 27.11.0000.304.

Date:

Package No. GRF-03

FY: 2023-2024

Directorate of Purchase,  
WAPDA Building (9<sup>th</sup> floor),  
Motijheel C/A, Dhaka-1000.  
Phone: +88 02 223383081



# Table of Contents

Rejection Clause .....	0
Section 1. Instructions to Tenderers.....	1
A. General .....	1
1. Scope of Tender .....	1
2. Interpretation.....	1
3. Source of Funds .....	1
4. Corrupt, Fraudulent, Collusive or Coercive Practices .....	2
5. Eligible Tenderers .....	3
6. Eligible Goods and Related Services .....	4
7. Site Visit .....	4
B. Tender Document.....	4
8. Tender Document: General .....	4
9. Clarification of Tender Documents.....	5
10. Pre-Tender Meeting.....	5
11. Addendum to Tender Documents .....	6
Section 1.02 .....	6
C. Qualification Criteria .....	6
12. General Criteria .....	6
13. Litigation History .....	7
14. Experience Criteria .....	7
15. Financial Criteria .....	7
16. Appointment of Subcontractor .....	7
D. Tender Preparation .....	8
17. Only One Tender .....	8
18. Cost of Tendering .....	8
19. Issuance and Sale of Tender Document .....	8
20. Language of Tender .....	8
21. Contents of Tender .....	9
22. Alternatives .....	10
23. Tender Prices, Discounts .....	10
24. Tender Currency .....	13
25. Documents Establishing the Conformity of the Goods and Related services.....	13
26. Documents Establishing Qualifications of the Tenderer .....	13
27. Validity Period of Tender .....	14
28. Extension of Tender Validity and Tender Security.....	14
29. Tender Security .....	14
30. Form of Tender security.....	15
31. Authenticity of Tender Security .....	15
32. Return of Tender Security.....	15
33. Forfeiture of Tender Security .....	16
34. Format and Signing of Tender.....	16
E. Tender Submission.....	17
35. Sealing, Marking and Submission of Tender .....	17
36. Deadline for Submission of tenders .....	17
37. Late tender .....	17
38. Modification, Substitution or Withdrawal of Tenders .....	17
39. Tender Modification .....	18
40. Tender Substitution.....	18
41. Withdrawal of Tender .....	18
F. Tender Opening and Evaluation .....	18
42. Tender Opening.....	18
43. Evaluation of Tenders.....	20
44. Evaluation process .....	20
45. Preliminary Examination.....	20
46. Technical Examinations & Responsiveness .....	21
47. Clarification on Tender .....	22

48. Restrictions on the Disclosure of Information Relating to the Procurement Process .....	23
49. Correction of Arithmetical Errors .....	23
50. Conversion to Single Currency .....	23
51. Domestic Preference.....	23
52. Financial Evaluation .....	24
53. Assessing the Price of Unpriced Items.....	25
54. Evaluation of Domestic Preference .....	26
55. Price Comparison .....	26
56. Negotiation.....	26
57. Post-qualification .....	26
58. Rejection of All Tenders.....	27
59. Informing Reasons for Rejection .....	28
G. Contract Award .....	28
60. Award Criteria.....	28
61. Purchaser’s Right to Vary Quantities.....	28
62. Notification of Award .....	28
63. Performance Security .....	29
64. Form and Time Limit for furnishing of Performance security .....	29
65. Validity of Performance Security .....	29
66. Authenticity of performance Security .....	29
67. Contract Signing.....	30
68. Publication of Notification of Award of Contract .....	30
69. Debriefing of Tenderers.....	30
70. Right to Complain.....	30
Section 2. Tender Data Sheet.....	32
A. General .....	32
B. Tender Document.....	32
C. Qualification Criteria .....	33
E. Submission of Tender .....	36
F. Opening and Evaluation of Tenders .....	36
G. Award of Contract .....	37
Section 3. General Conditions of Contract.....	38
1. Definitions.....	38
2. Contract Documents .....	39
3. Corrupt, Fraudulent, Collusive or Coercive Practices.....	39
4. Interpretation.....	40
5. Documents Forming the Contract in order of precedence .....	41
6. Eligibility.....	41
7. Governing Language .....	41
8. Governing Law .....	41
9. No fees/Gratuities .....	41
10. Use of Contract Documents & Information .....	42
11. Communications & Notices .....	42
12. Trademark, Patent and Intellectual Property Rights.....	42
13. Copyright .....	42
14. Assignment .....	42
15. Sub contracting .....	42
16. Supplier’s Responsibilities .....	43
17. Purchaser’s Responsibilities .....	43
18. Scope of Supply .....	43
19. Amendment to Order.....	43
20. Instances When Amendment to Order May be Issued .....	44
21. Adjustments in Contract Price and/or Delivery Schedule in Amendment to Order .....	44
22. Packing and Documents.....	44
23. Delivery and Documents.....	45
24. Acceptance .....	45
25. Contract Price.....	45
26. Transportation .....	46

27. Terms of Payment .....	46
28. Insurance .....	46
29. Taxes and Duties .....	46
30. Performance Security .....	47
31. Specifications and Standards .....	47
32. Inspections and Tests .....	47
33. Warranty.....	48
34. Delays in Delivery and Extensions of Time .....	49
35. Liquidated Damages .....	49
36. Limitation of Liability .....	50
37. Change in Laws and Regulations .....	50
38. Definition of Force Majeure .....	50
39. Notice of Force Majeure .....	51
40. Duty to Minimise Delay.....	51
41. Consequences of Force Majeure.....	51
42. Termination for Default.....	51
43. Termination for insolvency.....	52
44. Termination for Convenience .....	52
45. Procedures for Termination of Contracts.....	53
46. Contract Amendment .....	54
47. Settlement of Disputes.....	54
Section 4. Particular Conditions of Contract.....	56
Section 5. Tender and Contract Forms .....	68
Tender Submission Letter (Form PG4 – 1A).....	69
Tender Submission Letter (Form PG4 – 1B).....	71
Tenderer Information Sheet (Form PG4-2) .....	74
Price Schedule for Goods (Form PG4-3A).....	80
Schedule for Goods (Form PG4-3B) .....	81
Price Schedule for Goods (Form PG4-3C).....	<b>Error! Bookmark not defined.</b>
Price and Completion Schedule - Related Services (Form PG4-3D).....	82
Specifications Submission and Compliance Sheet .....	84
(Form PG4-4) .....	84
Manufacturer’s Authorisation Letter (Form PG4 - 5) .....	85
Bank Guarantee for Tender Security (Form PG4 – 6) .....	85
Notification of Award (Form PG4 - 7) .....	86
Contract Agreement (Form PG4 - 8) .....	89
Bank Guarantee for Performance Security .....	90
(Form PG4 – 9) .....	90
Bank Guarantee for Advance Payment (Form PG4 – 10) .....	91
Deviation List (Form PG4-11).....	88
Warranty Certificate (Form PG4-12).....	89
Section 6. Schedule of Requirements .....	90
Section 7. Technical Specifications.....	
Section 8. Drawings .....	

### REJECTION CLAUSES

(Tender must comply with the following criteria, otherwise tender shall be rejected)

1. Tenderer shall have to comply with Eligibility criteria (ITT 5), Litigation history (ITT 13), Experience criteria (ITT 14), financial Criteria (ITT15);
2. Goods & related service to be supplied must be eligible (ITT 6.1)
3. Tenderer shall submit only one tender for each lot (ITT17)
4. Tender Submission Letter (Form PG4-1) shall be properly filled up by the Tenderer (ITT 21.1 a);
5. Tenderer information sheet (Form PG4-2) shall be properly filled up and required documents to be attached by the Tenderer (ITT 21.1 b);
6. The Price Schedule for Goods and Related Services (Form PG4-3A, 3B, 3C and PG4-3D) shall be properly filled up by the Tenderer (ITT 21.1 c). Tenderers are not allowed to change/ modify the format of Price Schedule.
7. The Specifications Submission and Compliance Sheet (Form PG4-4) shall be properly filled up by the Tenderer (ITT 21.1 e);
8. Tenderer shall submit valid tax identification number and VAT registration number or any any other document to fulfil of taxation obligations as per ITT 21.1(K)
9. To establish the conformity of the Goods and Related Services to the Tender Documents, the Tenderer shall furnish as part of its Tender the documentary evidence that the Goods and Related services conform to the technical specifications and standards in Section 7, Technical Specifications
10. Technical Alternatives shall not be considered [ITT 22.1]
11. Tenderer must quote 100% items specified for each lot and 100% quantities specified for each item of that lot (ITT 23.5);
12. If Tenderer does not manufacture or produce the Goods it offers to supply shall submit the Manufacturer's Authorization Letter (Form PG4-5) furnished in Section 5: Tender and Contract Forms as per ITT26.1(b)
13. Tender shall remain valid for the period specified in TDS after the date of Tender submission deadline (ITT 27.2);
14. Tender must be accompanied by a valid Tender Security (ITT 31.3);
15. Tender must be accompanied by Letter of Authorization the Signatory to sign the Tender on behalf of the Tenderer (ITT 34.3);
16. Tender must comply the scope of supply as stated under Section 6, Schedule of Requirements without any material deviation or reservation (ITT 46.2d);
17. Tenderer shall have to comply with the payment terms [GCC 27];
18. Tenderer shall have to comply with the Delivery and Completion Schedule specified in Price Schedule & Section 6: Schedule of Requirements.
19. Tenderer shall have to submit sealed & signed tender document [ITT {TDS 21.1(q)(1)}].
20. Compliance certificate confirming to the terms and condition of the tender document [ITT {TDS 21.1(q)(6)}].
21. Tenderer shall have to submit warranty certificate (Form PG4-12)[ITT {TDS 21.1(q)(8)}];
22. Tenderer shall submit Manufacturer's Printed Catalogue as per [ITT {TDS 21.1(q)(10)}];
23. Tenderer shall have to submit Certificate from the manufacturer confirming that his offered items are new, unused, in good condition and confirmed all features & accessories stated in Section 7: Technical Specification [ITT {TDS 21.1(q) (14)}];
24. If Tenderer has any reservation, Tenderer has to mention it in Deviation list (Form PG4-11) [ITT {TDS 21.1(q) (15)}];
25. Tenderer shall submit Guaranteed Technical Particulars (GTP) Section 8 shall be properly filled up in manufacturer's official pad with submission of related supporting documents & signed by the Manufacturer & Tenderer [ITT {TDS 21.1(q)(16)}];
26. Tenderer shall submit Manufacturer's Supply Experience [ITT {TDS 21.1(q)(17)}];
27. Tenderer Shall submit Satisfactory Performance Certificate [ITT {TDS 21.1(q)(18)}];
28. All pages of the original and of each copy of the Tender shall be numbered sequentially and signed or initialled by the person signing the Tender [ITT 34.5]
29. Tenderer shall submit Type Test Certificates & Reports as per [ITT {TDS 21.1(q)(19)}].

# Section 1. Instructions to Tenderers

## A. General

1. Scope of Tender
  - 1.1 The Purchaser named in the Tender Data Sheet (TDS) (hereinafter referred to as the "Purchaser") wishes to issues these Tender Documents for the supply of Goods, and Related Services incidental thereto, as specified in the TDS and as detailed in Section 6: Schedule of Requirements.
  - (a) 1.2 The name of the Tender and the number and identification of its constituent lot(s) are stated in the TDS.
  - (b) 1.3 The successful Tenderer will be required to complete the delivery of the goods and related services (when applicable) as specified in the GCC Clause 18.
2. Interpretation
  - 2.1 Throughout this Tender Document
    - (a) the term "in writing" means communication written by hand or machine duly signed and includes properly authenticated messages by facsimile or electronic mail;
    - (b) if the context so requires, singular means plural and vice versa; and
    - (c) "day" means calendar days unless otherwise specified as working days;
    - (d) "Tender Document ", means the Document provided by a Purchaser to a Tenderer as a basis for preparation of its Tender;
    - (e) "Tender ", depending on the context, means a Tender submitted by a Tenderer for delivery of Goods and Related Services to a Purchaser in response to an Invitation for Tender ;
3. Source of Funds
  - 3.1 The Purchaser has been allocated public funds from the source as indicated in the TDS and intends to apply a portion of the funds to eligible payments under the contract for which this Tender Document is issued.
  - 3.2 For the purpose of this provision, "public funds" means any funds allocated to a Purchaser under Government budget, or loan, grants and credits placed at the disposal of a Purchaser through the Government by the development partners or foreign states or organizations.
  - 3.3 Payments by the development partner, if so indicated in the TDS, will be made only at the request of the Government and upon approval by the development partner in accordance with the applicable Loan/Credit/Grant Agreement, and will be subject in all respects to the terms and conditions of that Agreement.

4. Corrupt, Fraudulent, Collusive or Coercive Practices

- 4.1 The Government requires that Procuring Entities, as well as Tenderers shall observe the highest standard of ethics during implementation of procurement proceedings and the execution of Contracts under public funds.
- 4.2 The Government requires that Procuring Entities, as well as Tenderers and Suppliers shall, during the Procurement proceedings and the execution of Contracts under public funds, ensure-
- (a) strict compliance with the provisions of Section 64 of the Public Procurement Act 2006 (Act 24 of 2006);
  - (b) abiding by the code of ethics as mentioned in the Rule 127 of the Public Procurement Rules, 2008;
  - (c) that neither it's any officer nor any staff or any other agents or intermediaries working on its behalf engages in any practice as detailed in ITT Sub Clause 4.3.
- 4.3 For the purposes of ITT Sub-clause 4.2 the terms set forth as bellows:
- (a) corrupt practice means offering, giving or promising to give, receiving, or soliciting, either directly or indirectly, to any officer or employee of a Purchaser or other public or private authority or individual, a gratuity in any form; employment or any other thing or service of value as an inducement with respect to an act or decision or method followed by a Purchaser in connection with a Procurement proceeding or contract execution;
  - (b) fraudulent practice means the misrepresentation or omission of facts in order to influence a decision to be taken in a Procurement proceeding or Contract execution;
  - (c) collusive practice means a scheme or arrangement between two (2) or more Persons, with or without the knowledge of the Purchaser, that is designed to arbitrarily reduce the number of Tenders submitted or fix Tender prices at artificial, non competitive levels, thereby denying a Purchaser the benefits of competitive price arising from genuine and open competition; or
  - (d) coercive practice means harming or threatening to harm, directly or indirectly, Persons or their property to influence a decision to be taken in a Procurement proceeding or the execution of a Contract, and this will include creating obstructions in the normal submission process used for Tenders.
- 4.4 Should any corrupt, fraudulent, collusive or coercive practice of any kind come to the knowledge of the Purchaser, it will, in the first place, allow the Tenderer to provide an explanation and shall, take actions only when a satisfactory explanation is not received. Such exclusion and the reasons thereof, shall be recorded in the record of the procurement proceedings and promptly communicated to the Tenderer concerned. Any communications between the Tenderer and the Purchaser related to matters of alleged fraud or corruption shall be in writing.



- 4.5 If corrupt, fraudulent, collusive or coercive practices of any kind determined by the Purchaser against any Tenderer alleged to have carried out such practices, the Purchaser shall -
- (a) exclude the concerned Tenderer from further participation in the particular Procurement proceeding; or
  - (b) reject any recommendation for award that had been proposed for that concerned Tenderer or;
  - (c) declare, at its discretion, the concerned Tenderer to be ineligible to participate in further Procurement proceedings, either indefinitely or for a specific period of time.
- 4.6 The Tenderer shall be aware of the provisions on corruption, fraudulence, collusion and coercion in Section 64 of the Public Procurement Act, 2006 and Rule 127 of the Public Procurement Rules, 2008 and others as stated in GCC Clause 3.

**5. Eligible Tenderers**

- 5.1 This Invitation for Tenders is open to eligible Tenderers from all countries, except for any specified in the TDS. A Tenderer will be eligible if it is a citizen, or is constituted, registered and operates in conformity with the provisions of the laws of that country.
- 5.2 A Tenderer may be a physical or juridical individual or body of individuals, or company, association invited to take part in public procurement or seeking to be so invited or submitting a Tender in response to an Invitation for Tenders.
- 5.3 Government-owned enterprises in Bangladesh shall be eligible only if they can establish that they (i) are legally and financially autonomous, (ii) operate under commercial law, and (iii) are not a dependent agency of the Purchaser.
- 5.4 Tenderers shall have the legal capacity to enter into the Contract. A Tenderer that is under a declaration of ineligibility by the Government of Bangladesh in accordance with applicable laws at the date of the deadline for Tender submission or thereafter shall be disqualified.
- 5.5 Tenderers and all parties constituting the Tenderer shall not have a conflict of interest pursuant to Rule 55 of the Public Procurement Rules, 2008.
- 5.6 Tenderers in its own name or its other names or also in the case of its Persons in different names, shall not be under a declaration of ineligibility for corrupt, fraudulent, collusive or coercive practices as stated under ITT Sub Clause 4.3.
- 5.7 Tenderers are not restrained or barred from participating in public Procurement on grounds of execution of defective supply in the past under any Contract.
- 5.8 Tenderers are not under a declaration of ineligibility by an international financing agency such as World Bank, Asian

Development Bank or any other international agency.

- 5.9 Tenderers shall not be insolvent, be in receivership, be bankrupt, be in the process of bankruptcy, be not temporarily barred from undertaking business and it shall not be the subject of legal proceedings for any of the foregoing.
  - 5.10 Tenderers shall have fulfilled its obligations to pay taxes and social security contributions under the provisions of laws and regulations of the country of its origin. In the case of foreign Tenderers, a certificate of competent authority in that country of which the Tenderer is citizen shall be provided.
  - 5.11 Tenderers shall provide such evidence of their continued eligibility satisfactory to the Purchaser, as the Purchaser will reasonably request.
  - 5.12 These requirements for eligibility will extend, as applicable, to Sub-contractor proposed by the Tenderer.
- 6. Eligible Goods and Related Services**
- 6.1 All goods and related services to be supplied under the contract are eligible, unless their origin is from a country specified in the TDS.
  - 6.2 For purposes of this Clause, the term “goods” includes commodities, raw material, machinery, equipment, and industrial plants; and “related services” includes services such as insurance, transportation, installation, and commissioning, training, and initial maintenance.
  - 6.3 For purposes of this clause, “origin” means the country where the goods have been mined, grown, cultivated, produced, manufactured or processed; or through manufacture, processing, or assembly, another commercially recognized article results that differs substantially in its basic characteristics from its components.
  - 6.4 The origin of goods and services is distinct from the nationality of the Tenderer. The nationality of the firm that produces, assembles, distributes, or sells the goods shall not determine their origin.
- 7. Site Visit**
- 7.1 For goods contracts requiring installation/ commissioning/ networking or similar services at site, the Tenderer, at the Tenderer’s own responsibility and risk, is encouraged to visit and examine the Site and obtain all information that may be necessary for preparing the Tender and entering into a contract for the supply of goods and related services.
  - 7.2 The Tenderer should ensure that the Purchaser is informed of the visit in adequate time to allow it to make appropriate arrangements.
  - 7.3 The costs of visiting the Site shall be at the Tenderer’s own expense.

## B. Tender Document

- 8. Tender Document:**
- 8.1 The Sections comprising the Tender Document are listed below and should be read in conjunction with any addendum issued under ITT

General

Clause 11.

- Section 1 Instructions to Tenderers (ITT)
- Section 2 Tender Data Sheet (TDS)
- Section 3 General Conditions of Contract (GCC)
- Section 4 Particular Conditions of Contract (PCC)
- Section 5 Tender and Contract Forms
- Section 6 Schedule of Requirements
- Section 7 Technical Specifications
- Section 8 Drawings

8.2 The Purchaser shall reject any Tender if the Tender Document was not purchased directly from the Purchaser, or through its agent as stated in the TDS.

8.3 The Tenderer is expected to examine all instructions, forms, terms, and specifications in the Tender Document as well as addendum to Tender Documents.

**9. Clarification of Tender Documents**

9.1 A prospective Tenderer requiring any clarification of the Tender Document shall contact the Purchaser in writing at the Purchaser's address indicated in the TDS before two-third of time allowed for preparation and submission of Tender elapses.

9.2 A Purchaser is not obliged to answer any clarification received after that date requested under ITT Sub-Clause 9.1.

9.3 The Purchaser shall respond in writing within five (5) working days of receipt of any such request for clarification received under ITT Sub-Clause 9.1

9.4 The Purchaser shall forward copies of its response to all those who have purchased the Tender Document, including a description of the enquiry but without identifying its source.

9.5 Should the Purchaser deem it necessary to amend the Tender Document as a result of a clarification, it shall do so following the procedure under ITT Clause 11.

**10. Pre-Tender Meeting**

10.1 To clarify issues and to answer questions on any matter arising in the Tender Document, the Purchaser may, if stated in the TDS, hold a Pre-Tender Meeting at the place, date and time as specified in the TDS. All Potential Tenderers are encouraged to attend the meeting, if it is held.

10.2 Minutes of the pre-Tender meeting, including the text of the questions raised and the responses given, together with any responses prepared after the meeting, will be transmitted within one week (7 days) after holding the meeting to all those who purchased the Tender Document and even those who did not attend the meeting.

10.3 Any amendment to the Tender Document listed in ITT Sub-Clause 8.1 that may become necessary as a result of the pre-Tender meeting shall be made by the Purchaser exclusively through the issue of an Addendum as stated under ITT Sub-Clause 11 and not through the minutes of the pre-Tender meeting.

10.4 Non-attendance at the pre-Tender meeting will not be a cause for disqualification of a Tenderer.

**11. Addendum to  
Tender  
Documents**

11.1 At any time prior to the deadline for submission of Tenders, the Purchaser on its own initiative or in response to a clarification request in writing from a Tenderer, having purchased the Tender Document or as a result of a Pre-Tender meeting, may revise the Tender Document by issuing an addendum pursuant to Rule 95 of the Public Procurement Rules, 2008.

11.2 The addendum issued under ITT Sub-Clause 11.1 shall become an integral part of the Tender Document and shall have a date and an issue number and shall be circulated by fax, mail or e-mail, to Tenderers who have purchased the Tender Documents within five (5) working days of issuance of such addendum, to enable Tenderers to take appropriate action.

11.3 The Tenderer shall acknowledge receipt of an addendum.

11.4 Tenderers who have purchased the Tender Documents but have not received any addendum issued under ITT Sub-clause 11.1 shall inform the Purchaser of the fact by fax, mail or e-mail before two-third of the time allowed for the submission of Tenders has elapsed.

11.5 Procuring Entities shall also ensure posting of relevant addenda with the reference number and date on their website.

11.6 To give a prospective Tenderer reasonable time in which to take an amendment into account in preparing its Tender, the Purchaser may, at its discretion, extend the deadline for the submission of Tenders, pursuant to Rule 95(6) of the Public Procurement Rule, 2008 and under ITT Clause 36.

11.7 If an addendum is issued when time remaining is less than one-third of the time allowed for the preparation of Tenders, a Purchaser shall extend the deadline by an appropriate number of days for the submission of Tenders, depending upon the nature of the Procurement requirement and the addendum. The minimum time for such extension shall not be less than seven (7) days.

## **C. Qualification Criteria**

**12. General Criteria**

12.1 The Purchaser requires the Tenderer to be qualified by meeting predefined, precise minimum requirements, which entails setting pass/fail criteria, which if not met by the Tenderer, will result in rejection of its Tender.

- )
- 12.2 In addition to meeting the eligibility criteria, as stated in ITT Clause 5, the Tenderer must satisfy the other criteria stated in ITT Clauses 13 to 15 inclusive.
- 12.3 To qualify for a multiple number of lots in a package for which tenders are invited in the Invitation for Tenders, The Tenderer shall demonstrate having resources and experience sufficient to meet the aggregate of the qualifying criteria for the individual lot. The requirement of overall experience and specific experience under ITT Sub-Clause 14.1 (a) and 14.1 (b) shall not be separately applicable for individual lot.
- 13. Litigation History** 13.1 The maximum number of arbitration awards against the Tenderer over a period shall be as specified in the TDS.
- 14. Experience Criteria** 14.1 Tenderers shall have the following minimum level of supply experience to qualify for supplying the Goods and Related Services under the contract:
- (a) A minimum number of years of overall experience in the supply of goods and related services as specified in the TDS; and
  - (b) Specific experience of satisfactory completion of supply of similar goods of minimum value stated in the TDS under maximum number of contracts stated in TDS within the period stated in TDS; and
  - (c) A minimum supply and/or production capacity of Goods as specified in the TDS.
- 15. Financial Criteria** 15.1 Tenderers shall have the following minimum level of financial capacity of qualify for the supply of goods under the contract:
- (a) Availability of minimum liquid assets or working capital or credit facilities from a Bank, as specified in the TDS.
- 16. Appointment of Subcontractor** 16.1 Tenderer, pursuant to Rule 53 of the PPR2008, is allowed to sub-contract a portion of the Supply.
- 16.2 The Tenderer shall specify in its Tender all portion of the Goods that will be Subcontracted, if any, including the entity(ies) to whom each portion will be subcontracted to, subject to the maximum allowable limit for subcontracting of Goods specified in the TDS.
- 16.3 All subcontracting arrangement must be disclosed at the time of Tendering, and subcontractors must be identified in the Tender submitted by Tenderer.
- 16.4 A Subcontractor may participate in more than one Tender, but only in that capacity.
- 16.5 Subcontractors must comply with the provision of ITT Clause 5. For this purpose contractor shall complete the Subcontractor's

information in Form PG4-1 for submission with tender.

- 16.6 If the Purchaser determines that a subcontractor is ineligible, the subcontracting of such portion of the Goods assigned to the ineligible subcontractor shall be disallowed.

## D. Tender Preparation

- 17. Only One Tender** 17.1 If a Tender for Goods is invited on 'lot-by-lot' basis, each lot shall constitute a Tender. A Tenderer shall submit only one (1) Tender for each lot, A Tenderer who submits or participates in more than one (1) Tender for each lot will cause all the Tenders with that Tenderer's participation to be rejected.
- 18. Cost of Tendering** 18.1 Tenderers shall bear all costs associated with the preparation and submission of its Tender, and the Purchaser shall not be responsible or liable for those costs, regardless of the conduct or outcome of the Tendering process.
- 19. Issuance and Sale of Tender Document** 19.1 A Purchaser, pursuant to Rule 94 of the Public Procurement Rules,2008 shall make Tender Documents available immediately to the potential Tenderers, requesting and willing to purchase at the corresponding price if the advertisement has been published in the newspaper pursuant to Rule 90 of the Public Procurement Rules,2008.
- 19.2 Full contact details with mailing address, telephone and facsimile numbers and electronic mail address, as applicable, of those to whom Tender Documents have been issued shall be recorded with a reference number by the Purchaser or its agent.
- 19.3 There shall not be any pre-conditions whatsoever, for sale of Tender Document and the sale of such Document shall be permitted up to the day prior to the day of deadline for the submission of Tender.
- 20. Language of Tender** 20.1 Tenders shall be written in English language. Supporting documents and printed literature furnished by the Tenderer may be in another language provided they are accompanied by an accurate translation of the relevant passages into the English language, in which case, for purposes of interpretation of the Tender, such translation shall govern.
- 20.2 Tenderers shall bear all costs of translation to the governing language and all risks of the accuracy of such translation.

**21. Contents of Tender**

- 21.1 The Tender prepared by the Tenderer shall comprise the following:
- (a) Tender Submission Letter (Form PG4-1) as furnished in Section 5: Tender and Contract Forms;
  - (b) Tenderer information sheet (Form PG4-2) as furnished in Section 5: Tender and Contract Forms;
  - (c) The completed Price Schedule for Goods and Related Services (Form PG4-3A, 3B, 3C and PG4-3D) as furnished in Section 5: Tender and Contract Forms as stated under ITT Clauses 23 and 24;
  - (d) Tender Security as stated under ITT Clause 29,30 and 31;
  - (e) The completed Specifications Submission and Compliance Sheet (Form PG4-4) as furnished in Section 5: Tender and Contract Forms as stated under ITT clause 25.2;
  - (f) Alternatives, if permitted, as stated under with ITT Clause 22;
  - (g) Written confirmation authorising the signatory of the Tender to commit the Tenderer, as stated under ITT Sub-Clause 34.3;
  - (h) The completed eligibility declarations, to establish its eligibility as stated under ITT Clause 5, in the Tender Submission Sheet (Form PG4-1), as furnished in section 5: Tender and Contract Forms;
  - (i) An affidavit confirming the legal capacity stating that there are no existing orders of any judicial court that prevents either the Tenderer or employees of a Tenderer entering into or signing a Contract with the Purchaser as stated under ITT clause 5;
  - (j) An affidavit confirming that the Tenderer is not insolvent, in receivership or not bankrupt or not in the process of bankruptcy, not temporarily barred from undertaking their business for financial reasons and shall not be the subject of legal proceedings for any of the foregoing as stated under ITT Clause 5;
  - (k) A certificate issued by the competent authority stating that the Tenderer is a Tax payer having valid Tax identification Number (TIN) and VAT registration number or in lieu any other document acceptable to the Purchaser demonstrating that the Tenderer is a genuine Tax payer and has a VAT registration number as a proof of fulfillment of taxation obligations as stated under ITT Clause 5. In the case of foreign Tenderers, a certificate of competent authority in that country of which the Tenderer is citizen shall be provided ;
  - (l) Documentary evidence demonstrating that they are enrolled in the relevant professional or trade organizations registered in Bangladesh or in case of foreign tenderer in their country of origin or a certificate concerning their competency issued by a professional institution in accordance with the law of the country of their origin, as stated under ITT Clause 5;



- (m) The country of origin declarations, to establish the eligibility of the Goods and Related Services as stated under ITT Clause 6, in the Price Schedule for Goods and Related Services (Form PG4-3B, 3C and PG4-3D) as, applicable, furnished in Section 5: Tender and Contract Forms;
- (n) Documentary evidence as stated under ITT Clauses 25, that the Goods and Related Services conform to the Tender Documents;
- (o) Documentary evidence as stated under ITT Clause 26 that the Tenderer's qualifications conform to the Tender Documents;
- (p) Documents establishing legal and financial autonomy and compliance with commercial law, as stated under ITT Sub-clause 5.3 in case of government owned entity; and
- (q) Any other document as specified in the TDS.

21.2 The Tenderer shall submit the Tender Submission Letter (Form PG4-1) as furnished in Section 5: Tender and Contract Forms. This form must be completed without any alterations to its format, and no substitutes shall be accepted. All blank spaces shall be filled in with the information requested.

21.3 The Tenderer shall submit the completed Price Schedule for Goods and Related Services (Form PG4-3A, 3B, 3C and PG4-3D), according to their origin as appropriate as furnished in section 5: Tender and Contract Forms.

**22. Alternatives**

22.1 Unless otherwise stated in the TDS, alternatives shall not be considered.

**23. Tender Prices, Discounts**

23.1 The prices and discounts quoted by the Tenderer in the Tender Submission Letter (Form PG4-1) and in the Price Schedule (Form PG4-3A, 3B, 3C and PG4-3D) shall conform to the requirements specified below.

23.2 All lots or items as listed in Section 6: Schedule of Requirements must be listed and priced separately on the Price Schedule following the Form PG4-3A, 3B, 3C and PG4-3D as applicable.

23.3 Tenders are being invited either for a single lot or for a number of lots on 'lot-by-lot' basis, as specified in the TDS.

23.4 Each lot shall constitute a Tender, If Tenders for Goods are invited on 'lot-by-lot' basis.

23.5 Tenders being invited for a single lot or for a number of lots on 'lot-by-lot' basis, price quoted shall correspond to 100% of the items specified for each lot and to 100% of the quantities specified for each item of that particular lot and shall correspond to 100% of the total offered lot value, unless otherwise stated in the TDS



- 23.6 A Lot Tender not offering minimum number of items of those being priced based on percentage of the total number of items, and, the corresponding minimum value based on percentage of the total lot value, as specified in the ITT Sub-Clause 23.5 shall also be considered non-responsive.
- 23.7 Subject to ITT Sub-Clause 23.5, a Lot tender not offering a particular item which represents more than fifty percent (50%) of the estimated lot value identified by the Purchaser and specified in the TDS, even if it complies with the requirement of minimum number of items based on percentage of the total number of items as stated under ITT Sub Clause 23.5, shall be considered non-responsive.
- 23.8 The price to be quoted in Tender Submission Letter (Form PG4-1) shall be the total price of the Tender, excluding any discounts offered, only in case of being awarded more than one lot, by the Tenderer
- 23.9 The Tenderer wishing to offer any discount shall indicate the methodology for their application in the Tender Submission Letter (Form PG4-1) for being awarded of more than one lot.
- 23.10 Prices shall be quoted as specified in each Price Schedule (Form PG4-3A, 3B, 3C and PG4-3D) as applicable. The dis-aggregation of price components is required solely for the purpose of facilitating the comparison of tenders by the Purchaser. This shall not in any way limit the Purchaser's right to contract on any of the terms offered. In quoting prices, the Tenderer shall be free to use transportation through carriers registered in any eligible Countries. Similarly, the Tenderer may obtain insurance services from any eligible country. Prices shall be entered in the following manner:
- 23.11 For Goods, manufactured within Bangladesh, the prices in the Price schedule (Form PG4-3A) shall be entered separately in the following manner:
- (a) the price of the Goods quoted EXW (ex works, ex factory, ex warehouse, ex showroom, or off-the-shelf, as applicable), including all customs duties and import vat and other taxes already paid or payable on the components and raw material used in the manufacture or assembly of the Goods;
  - (b) VAT payable on account of supplier, if the contract is awarded ; and
  - (c) the price for inland transportation, insurance, and other local costs for the delivery of the Goods to their final destination (Project Site) specified in the TDS.

23.12 For Goods, manufactured outside Bangladesh, to be imported, the prices in the Price schedule (Form PG4-3B) shall be entered separately in the following manner:

- (a) the price of the Goods, quoted CIP (named place of destination, in the Bangladesh ) or CIF (named port of destination, in Bangladesh) as specified in the TDS;
- (b) VAT payable on account of supplier, if the contract is awarded; and
- (c) the price for inland transportation, insurance, and other local costs for the delivery of the Goods to their final destination (Project Site) specified in the TDS;
- (d) in addition to the CIP/CIF prices specified in 23.12(a) above, the price of the Goods to be imported may be quoted in other *INCOTERM* and shall be governed by the rules prescribed in the current edition of *INCOTERM* published by the International Chamber of Commerce, Paris, if so specified in the TDS;

23.13 For Goods, manufactured outside Bangladesh, already imported, the prices in the Price schedule (Form PG4-3C) shall be entered separately in the following manner:

- (a) the price of the Goods, including the original import value of the Goods; plus any mark-up ; plus any other related local cost, and custom duties, import VAT and other import taxes already paid on the Goods already imported.
- (b) the custom duties, import VAT and other import taxes already paid (need to be supported with documentary evidence) on the Goods already imported;
- (c) the price of the Goods, obtained as the difference between (a) and (b) above;
- (d) VAT payable on account of supplier, if the contract is awarded; and
- (e) the price for inland transportation, insurance, and other local costs for the delivery of the Goods to their final destination (Project Site) specified in the TDS.

*[For previously imported Goods, the quoted price shall be distinguishable from the original import value of these Goods declared to customs and shall include any rebate or mark-up of the local agent or representative and all local costs except import duties and taxes, which have been paid. For clarity the tenderers are asked to quote the price including import duties, and additionally to provide the import duties and the price net of import duties which is the difference of those values.]*

23.14 for Related Services, other than inland transportation and other services required to convey the Goods to their final destination, whenever such Related Services are specified in the Schedule of

Requirements, the prices in the price schedule (Form PG4-3D) shall be entered in the following manner :

- (a) the price of each item comprising the Related Services (inclusive of any applicable taxes).

**24. Tender Currency** 24.1 For expenditures that will be incurred in Bangladesh, the Tenderer shall quote the prices in Bangladesh Taka.

24.2 Suppliers offering Goods manufactured or assembled in Bangladesh, are permitted to submit their Tender in a combination of local and foreign currencies.

24.3 For expenditures that will be incurred outside Bangladesh, the Tenderer may quote the prices in USD or GBP or EUR or JPY as specified in TDS.

**25. Documents Establishing the Conformity of the Goods and Related services** 25.1 To establish the conformity of the Goods and Related Services to the Tender Documents, the Tenderer shall furnish as part of its Tender the documentary evidence that the Goods and Related services conform to the technical specifications and standards in Section 7, Technical Specifications.

25.2 Documentary evidence of conformity of the Goods and services to the Tender Documents may be in the form of literature, drawings, and data, and shall consist of:

- (a) a detailed description of the essential technical and performance characteristics of the Goods;
- (b) if so required in TDS, tenderer shall also furnish a list giving full particulars, including available sources and current prices of spare parts, special tools, etc., necessary for the proper and continuing functioning of the Goods during the period specified in the TDS, following commencement of the use of the Goods by the Purchaser ; and
- (c) an item-by-item commentary on the Purchaser's Technical Specifications demonstrating substantial responsiveness of the Goods and Related services to those specifications, or a statement of deviations and exceptions to the provisions of Section 7. Technical Specifications.

**26. Documents Establishing Qualifications of the Tenderer** 26.1 The documentary evidence of the Tenderer's qualifications to perform the contract if its Tender is accepted shall establish to the Purchaser's satisfaction:

- (a) that the Tenderer meets each of the qualification criterion specified in Sub-Section C, Qualification Criteria of the ITT;
- (b) that, if required in the TDS, a Tenderer that does not manufacture or produce the Goods it offers to supply shall submit the Manufacturer's Authorization Letter (Form PG4-5) furnished in Section 5: Tender and Contract Forms, to demonstrate that it has been duly authorized by the manufacturer or producer of the Goods to supply the Goods to Bangladesh.; and

- (c) that, if required in the TDS, in case of a Tenderer not doing business within Bangladesh, the Tenderer is or will be (if awarded the contract) represented by an Agent in the country equipped and able to carry out the Supplier's maintenance.
  - (d) adequacy of minimum liquid assets i.e. working capital substantiated by Audit Reports or Bank Statement or credit line(s) substantiated in the format as specified (Form PG4-6A), without alteration as stated under ITT Sub Clause 15.1(a);
- 27. Validity Period of Tender**
- 27.1 Tender validities shall be determined on the basis of the complexity of the Tender and the time needed for its examination, evaluation, approval of the Tender and issuance of the Notification of Award pursuant to Rule 19 and 20 of the Public Procurement Rules,2008.
- 27.2 Tenders shall remain valid for the period specified in the TDS after the date of Tender submission deadline prescribed by the Purchaser, as stated under ITT Clause 36. A Tender valid for a period shorter than that specified will be rejected by the Purchaser as non- responsive.
- 28. Extension of Tender Validity and Tender Security**
- 28.1 In justified exceptional circumstances, prior to the expiration of the Tender validity period, the Purchaser following Rule 21 of the Public Procurement Rules,2008 may solicit, not later than ten (10) days before the expiry date of the Tender validity, compulsorily all the Tenderers' consent to an extension of the period of validity of their Tenders.
- 28.2 The request for extension of Tender validity period shall state the new date of the validity of the Tender.
- 28.3 The request from the Purchaser and the responses from the Tenderers will be made in writing.
- 28.4 Tenderers consenting in writing to the request made by the Purchaser under ITT Sub-Clause 28.1 shall also correspondingly extend the validity of its Tender Security for twenty-eight (28) days beyond the new date for the expiry of Tender validity.
- 28.5 Tenderers consenting in writing to the request under ITT Sub-Clause 28.1 shall not be required or permitted to modify its Tender in any circumstances.
- 28.6 If the Tenderers are not consenting in writing to the request made by the Purchaser under ITT Sub-Clause 28.1, its Tender will not be considered for subsequent evaluation.
- 29. Tender Security**
- 29.1 The Tender Security and its amount shall be determined sufficient to discourage the submission of frivolous and irresponsible tenders pursuant to Rule 22 of the Public Procurement Rule,2008 and shall be expressed as a rounded fixed amount and, shall not be stated as a precise percentage of the estimated total Contract value.
- 29.2 The Tenderer shall furnish as part of its Tender, in favour of the Purchaser or as otherwise directed on account of the Tenderer as

specified in TDS.

29.3 Amount of the Tender security may be determined on the basis of different percentages for each lot, but the amount in fixed and currency as specified in TDS, if so indicated that the Tenders are invited on lot-by-lot basis under ITT Sub Clause 23.3

**30. Form of Tender security**

30.1 The Tender Security shall be in the form of an irrevocable bank guarantee issued by an internationally reputable bank and shall require to be endorsed by its any correspondent bank located in Bangladesh, to make it enforceable, in the format (Form PG4-6) furnished in Section 5: Tender and Contract Forms;

30.2 be payable promptly upon written demand by the Purchaser in the case of the conditions listed in ITT Clause 33 being invoked; and

30.3 remain valid for at least twenty eight (28) days beyond the expiry date of the Tender Validity in order to make a claim in due course against a Tenderer in the circumstances detailed under ITT Clause 33 and pursuant to Rule 25 of the Public Procurement Rules,2008.

**31. Authenticity of Tender Security**

31.1 The authenticity of the Tender security submitted by a Tenderer shall be examined and verified by the Purchaser in writing from the Bank issuing the security, prior to finalization of the Evaluation Report pursuant to Rule 24 of the Public Procurement Rule, 2008.

31.2 If a Tender Security is found to be not authentic, the Tender which it covers shall not be considered for subsequent evaluation and in such case the Purchaser shall proceed to take punitive measures against that Tenderer as stated under ITT Sub-Clause 4.6, pursuant to Rule 127 of the Public Procurement Rules, 2008 and in accordance with Section 64(5) of the Public Procurement Act, 2006.

31.3 Tender not accompanied by a valid Tender Security as stated under Sub-Clause 29, 30 and 31, shall be considered as non-responsive.

**32. Return of Tender Security**

32.1 No Tender security shall be returned by the Tender Opening Committee (TOC) during and after the opening of the Tenders pursuant to Rule 26 of the Public Procurement Rules 2008.

32.2 No Tender security shall be returned to the Tenderers before contract signing, except to those who are found non-responsive.

32.3 Tender securities of the non-responsive Tenders shall be returned immediately after the Evaluation Report has been approved by the Purchaser.

32.4 Tender securities of the responsive Tenderers shall be returned only after the lowest evaluated responsive Tenderer has submitted the performance security and signed the contract , that being even before the expiration of the validity period specified in Clause 27.

- 32.5 Tender Securities of the Tenderers not consenting within the specified date in writing to the request made by the Purchaser under ITT Sub-Clause 28.1 in regard to extension of its Tender validity shall be discharged or returned forthwith.
- 33. Forfeiture of Tender Security**
- 33.1 The Tender security pursuant to Rule 25 of the Public Procurement Rules,2008 may be forfeited if a Tenderer:
- (a) withdraws its Tender after opening of Tenders but within the validity of the Tender as stated under ITT Clauses 27, and 28, pursuant to Rule 19 of the Public Procurement Rules 2008; or
  - (b) refuses to accept a Notification of Award as stated under ITT Sub-Clause 62.3, pursuant to Rule 102 of the Public Procurement Rules 2008; or
  - (c) fails to furnish performance security as stated under ITT Sub-Clause 63.2, pursuant to Rule 102 of the Public Procurement Rules 2008; or
  - (d) refuses to sign the Contract as stated under ITT Sub-Clause 67.2 pursuant to Rule 102 of the Public Procurement Rules 2008; or
  - (e) does not accept the correction of the Tender price following the correction of arithmetic errors as stated under ITT Clause 49, pursuant to Rule 98(11) of the Public Procurement Rules 2008
- 34. Format and Signing of Tender**
- 34.1 The Tenderer shall prepare one (1) original of the documents comprising the Tender as described in ITT Clause 21 and clearly mark it "ORIGINAL". In addition, the Tenderer shall prepare the number of copies of the Tender, as specified in the TDS and clearly mark each of them "COPY". In the event of any discrepancy between the original and the copies, the original shall prevail.
- 34.2 Alternatives, if permitted under ITT Clause 22, shall be clearly marked "Alternative".
- 34.3 The original and each copy of the Tender shall be typed or written in indelible ink and shall be signed by a person duly authorised to sign on behalf of the Tenderer. This authorisation shall consist of a written authorisation and shall be attached to the Tender Submission Letter (Form PG4-1).
- 34.4 The name and position held by each person signing the authorisation must be typed or printed below the signature.
- 34.5 All pages of the original and of each copy of the Tender, except for un-amended printed literature, shall be numbered sequentially and signed or initialled by the person signing the Tender.
- 34.6 Any interlineations, erasures, or overwriting shall be valid only if they are signed or initialled by the person(s) signing the Tender.
- 34.7 Person(s) signing the Tender shall describe his or her name, address, position.

## E. Tender Submission

- 35. Sealing, Marking and Submission of Tender**
- 35.1 The Tenderer shall enclose the original in one (1) envelope and all the copies of the Tender, including the alternative , if permitted under ITT Clause 22 in another envelope, duly marking the envelopes as “ORIGINAL” “ALTERNATIVE” (if permitted) and “COPY.” These sealed envelopes will then be enclosed and sealed in one (1) single outer envelope.
- 35.2 Tenders shall be properly marked by Tenderers in order not be confused with other types of correspondence which may also be hand-delivered or posted by mail or courier service. The inner and outer envelopes shall:
- (a) bear the name and address of the Tenderer ;
  - (b) be addressed to the Purchaser as stated under ITT Sub-Clause 36.1;
  - (c) bear the specific identification of this tendering process indicated in ITT Sub-Clause 1.2 and any additional identification marks as specified in the TDS; and
  - (d) bear a statement “DO NOT OPEN BEFORE...” the time and date for Tender opening, as stated under ITT Sub- Clause 42.2
- 35.3 The Tenderer is solely and entirely responsible for pre-disclosure of Tender information if the envelope(s) are not properly sealed and marked.
- 35.4 Tenders shall be delivered by hand or by mail, including courier services to location as designated in the ITT Sub-Clause 36.1.
- 35.5 Tenders shall be submitted on the basis of this Tender Document issued by the Purchaser.
- 35.6 The Purchaser will, on request, provide the Tenderer with a receipt showing the date and time when it’s Tender was received.
- 35.7 When so specified in the TDS, tenderers shall have the option of submitting their tenders electronically.
- 35.8 Tenderers submitting tenders electronically shall follow the electronic tender submission procedures specified in the TDS.
- 36. Deadline for Submission of tenders**
- 36.1 Tenders shall be delivered to the Purchaser at the address specified in the TDS and no later than the date and time specified in the TDS.
- 36.2 The Purchaser may, at its discretion on justifiably acceptable grounds duly recorded, extend the deadline for submission of Tender as stated under ITT Sub Clause 36.1, in which case all rights and obligations of the Purchaser and Tenderers previously subject to the deadline will thereafter be subject to the new deadline as extended.
- 37. Late tender**
- 37.1 Any Tender received by the Purchaser after the deadline for submission of Tenders as stated under ITT Sub-Clause 36.1, shall be declared LATE, rejected, returned unopened to the Tenderer.
- 38. Modification,**
- 38.1 A Tenderer may modify, substitute or withdraw its Tender after it has



Substitution or  
Withdrawal of  
Tenders

been submitted by sending a written notice duly signed by the authorised signatory properly sealed, and shall include a copy of the authorisation (the power of attorney), confirmed by an affidavit duly authenticated as stated under ITT Clause 34.3, provided that such written notice including the affidavit is received by the Purchaser prior to the deadline for submission of Tenders as stated under ITT Sub-Clause 36.1.

**39.** Tender  
Modification

39.1 The Tenderer shall not be allowed to retrieve its original Tender, but shall be allowed to submit corresponding modification to its original Tender marked as "MODIFICATION".

**40.** Tender  
Substitution

40.1 The Tenderer shall not be allowed to retrieve its original Tender, but shall be allowed to submit another Tender marked as "SUBSTITUTION".

**41.** Withdrawal of  
Tender

41.1 The Tenderer shall be allowed to withdraw its Tender by a Letter of Withdrawal marked as "WITHDRAWAL".

## **F. Tender Opening and Evaluation**

**42.** Tender Opening

42.1 Tenders shall be opened pursuant to Rule 97 following steps in Part D of Schedule IV of The Public Procurement Rule, 2008.

42.2 Tenders shall be opened in public immediately after the deadline for submission of Tenders at the place, date and time as specified in the TDS but no later than ONE HOUR after expiry of the submission deadline. Tender opening shall not be delayed on the plea of absence of Tenderers or his or her representatives.

42.3 Any specific electronic Tender opening procedures required if electronic tendering is permitted under ITT Sub-Clause 35.7, shall be as specified in the TDS.

42.4 Persons not associated with the Tender may not be allowed to attend the public opening of Tenders.

42.5 The Tenderers' representatives shall be duly authorised by the Tenderer. Tenderers or their authorised representatives will be allowed to attend and witness the opening of Tenders, and will sign a register evidencing their attendance.

42.6 The authenticity of withdrawal or substitution of, or modifications to original Tender, if any made by a Tenderer in specified manner, shall be examined and verified by the Tender Opening Committee based on documents submitted under ITT Sub Clause 38.1.

42.7 Tenders will be opened in the following manner:

- (a) firstly, envelopes marked "Withdrawal" shall be opened and "Withdrawal" notices read aloud and recorded, and the envelope with the corresponding Tender shall not be opened, but returned unopened to the Tenderer by the Purchaser at a later time immediately after preliminary examination by the Tender Evaluation Committee (TEC) as stated under ITT Sub-Clause 45.1. No Tender withdrawal shall be permitted unless the corresponding withdrawal notice contains a valid authorization to request the withdrawal and in such case the Tender shall be read aloud at the Tender opening ;



- (b) secondly, the remaining Tenders will be sorted out and those marked “substitutes” or “modified” will be linked with their corresponding “original”(O) Tender;
- (c) Next, envelopes marked “Substitution”(S) shall be opened and read aloud and recorded, and exchanged with the corresponding Tender being substituted, and the substituted Tender shall not be opened, but returned unopened to the Tenderer by the Purchaser at a later time immediately after preliminary examination by the Tender Evaluation Committee (TEC) as stated under ITT Sub-Clause 45.1 . No Tender substitution shall be permitted unless the corresponding substitution notice contains a valid authorization to request the substitution and in such case the Tender shall be read aloud at the Tender opening.
- (d) Next envelopes marked “Modification” (M) shall be opened and read aloud with the corresponding Tender and recorded. No Tender modification shall be permitted unless the corresponding modification notice contains a valid authorization to request the modification and in such case the Tender shall be read aloud at the Tender opening.
- (e) thirdly, if so specified in this Tender Document, the envelopes marked “ Alternative ”(A) shall be opened and read aloud with the corresponding Tender and recorded.

42.8 Ensuring that only the correct (M), (S), (A),(O) envelopes are opened, details of each Tender will be dealt with as follows:

- (a) the Chairperson of the Tender Opening Committee will read aloud each Tender and record in the Tender Opening Sheet (TOS)
  - (i) the name and address of the Tenderer;
  - (ii) state if it is a withdrawn, modified, substituted , or original tender;
  - (iii) the Tender price;
  - (iv) the number of initialled corrections;
  - (v) any discounts;
  - (vi) any alternatives;
  - (vii) the presence or absence of any requisite Tender Security; and
  - (viii) such other details as the Purchaser, at its discretion, may consider appropriate.
- (b) only discounts and alternative read aloud at the Tender opening will be considered in evaluation;
- (c) all pages of the original version of the Tender, except for un-amended printed literature, will be initialled by members of the Tender Opening Committee.

42.9 Upon completion of Tender opening, all members of the Tender Opening Committee and the Tenderers or Tenderer’s duly authorised representatives attending the Tender opening shall sign by name, address, designation and their national Identification Numbers the Tender Opening Sheet, copies of which shall be issued to the Head of the Purchaser or an officer authorised by him or her and also to the members of the Tender

Opening Committee and any authorised Consultants and, to the Tenderers immediately.

42.10 The omission of a Tenderer's signature on the record shall not invalidate the contents and effect of the record under ITT Sub-Clause 42.8.

42.11 No Tender will be rejected at the Tender opening stage except the LATE Tenders. .

42.12 A copy of the record shall be distributed to all Tenderers who submitted tenders in time, and posted online when electronic tendering is permitted.

**43. Evaluation of Tenders**

43.1 Purchaser's Tender Evaluation Committee (TEC) shall examine, evaluate and compare Tenders that are responsive to the mandatory requirements of Tender Documents in order to identify the successful Tenderer.

43.2 Tenders shall be examined and evaluated only on the basis of the criteria specified in the Tender Document.

**44. Evaluation process**

44.1 The TEC may consider a Tender as responsive in the Evaluation, only if it is submitted in compliance with the mandatory requirements set out in the Tender Document. The evaluation process should begin immediately after tender opening following four steps:

- (a) Preliminary Examination;
- (b) Technical Examinations and Responsiveness;
- (c) Financial evaluation and price comparison;
- (d) Post-qualification of the lowest evaluated responsive Tenders.

**45. Preliminary Examination**

45.1 Compliance, adequacy and authenticity of the documentary evidences for meeting the qualification criterion specified in the corresponding section of the Tender document shall have to be preliminarily examined and verified.

45.2 The TEC shall firstly examine the Tenders to confirm that all documentation requested in ITT Clause 21 has been provided. Examination of the compliance, adequacy and authenticity of the documentary evidence may follow the order below:

- (a) verification of the completeness of the eligibility declaration in the Tender Submission Letter (Form PG4-1), to determine the eligibility of the tenderer as stated under ITT Sub-Clause 21(h). Any alterations to its format, filling in all blank spaces with the information requested, failing which the tender may lead to rejection of the Tender;
- (b) verification of that the Tenderer is enrolled in the relevant professional or trade organisations as stated under ITT Clause 21(l);
- (c) verification of the eligibility in terms of legal capacity and fulfilment of taxation obligation by the tenderer in accordance as stated under ITT Sub-Clause 21(i) and 21(k);
- (d) verification of eligibility that the tenderer is not insolvent, in receivership, bankrupt, not in the process of bankruptcy, not

temporarily barred as stated under ITT Sub-Clause 21(j);

- (e) verification of eligibility of Tenderer's country of origin as stated under ITT Sub-Clause 21(b);
- (f) verification of the written authorization confirming the signatory of the Tenderer to commit the Tender has been attached with Tender Submission Letter (Form PG4-1) as stated under ITT Sub-Clause 21(g); in order to check the authenticity of Tender and Tenderer itself;
- (g) verification of the Tender Security as stated under ITT Sub-Clause 21(d); and
- (h) Verification of that the written notice for 'WITHDRAWL' and 'SUBSTITUTION of' or MODIFICATION to, the corresponding Tender is proper and authentic, if the tender is "WITHDRAWN", "SUBSTITUTION" or "MODIFICATION", as stated under ITT Sub-Clause 38.1

45.3 The TEC shall confirm that the above documents and information have been provided in the Tender and the completeness of the documents and compliance of instructions given in corresponding ITT Clauses shall be verified, failing which the tender shall be considered as non-responsive.

**46. Technical Examinations & Responsiveness**

46.1 Only those Tenders surviving preliminary examination need to be examined in this phase.

46.2 Secondly, the TEC will examine the adequacy and authenticity of the documentary evidence which may follow the order below:

- (a) verification of the completeness of the country of origin declaration in the Price Schedule for Goods and Related Services (Form PG4-3B, 3C and PG4-3D) as furnished in Section 5: Tender and Contract Forms to determine the eligibility of the Goods and Related Services as stated under ITT Sub Clause 21(m).
- (b) verification and examination of the documentary evidence and completed Specification Submission Sheet (Form PG4-4) as furnished in Section 5: Tender and Contract Forms to establish the conformity of the Goods and Related Services to the Tender Documents as stated under ITT Sub Clause 21(e) and 21(n).
- (c) verification and examination of the documentary evidence that the Tenderer's qualifications conform to the Tender Documents and the Tenderer meets each of the qualification criterion specified in Sub-Section C, Qualification Criteria as stated under ITT Sub Clause 21(o).
- (d) verification and examination of the documentary evidence that Tenderer has met all the requirements in regards to scope of Supply as stated under Section 6, Schedule of Requirements, without any material deviation or reservation.

46.3 TEC may consider a Tender as responsive in the evaluation, only if comply with the mandatory requirements as stated under Clause 46.2.

46.4 The TEC's determination of a Tender's responsiveness is to be based on the documentary evidence as requested in Clause 46.2 without recourse to extrinsic evidence.

- 46.5 Information contained in a Tender, that was not requested in the Tender Document shall not be considered in evaluation of the Tender.
- 46.6 If a Tender is not responsive to the mandatory requirements set out in the Tender Document it shall be rejected by the TEC and shall not subsequently be made responsive by the Tenderer by correction of the material deviation, reservation.
- 46.7 A material deviation or reservation is one-
- (a) which affects in any substantial way the scope, quality, or performance of the Goods and Related Services and Tenderer's qualifications mentioned in the Tender Document.
  - (b) which limits in any substantial way, inconsistent with the Tender Documents, the Purchaser's rights or the Tenderer's obligations under the Contract; or
  - (c) whose rectification would anyway affect unfairly the competitive position of other Tenderers presenting responsive Tenders.
- 46.8 During the evaluation of Tender, the following definitions apply:
- (a) "Deviation" is a departure from the requirements specified in the Tender Document;
  - (b) "Reservation" is the setting of limiting conditions or withholding from complete acceptance of the requirements specified in the Tender Document;
- 46.9 A TEC may regard a Tender as responsive, even if it contains-
- (a) minor or insignificant deviations, which do not meaningfully alter or depart from the technical specifications, characteristics and commercial terms and conditions or other requirements set out in the Tender Document;
  - (b) errors or oversights, which if corrected, would not alter the key aspects of the Tender.

**47. Clarification on Tender**

- 47.1 The TEC may ask Tenderers for clarifications of their Tenders, including breakdowns of unit rates, in order to assist the examination and evaluation of the Tenders, provided that, Tender clarifications which may lead to a change in the substance of the Tender or in any of the key elements of the Tender as stated under ITT Sub-Clause 46.7, shall neither be sought nor permitted by the TEC.
- 47.2 Change in the tender price shall not be sought or permitted, except to confirm correction of arithmetical errors discovered by the Purchaser in the evaluation of the Tender, as stated under ITT Clause 49.
- 47.3 Any request for clarifications by the TEC shall not be directed towards making an apparently non-responsive Tender responsive and reciprocally the response from the concerned Tenderer shall not be articulated towards any addition, alteration or modification to its Tender.
- 47.4 If a Tenderer does not provide clarifications of its Tender by the date and time set in the TEC's written request for clarification, its Tender shall not be considered in the evaluation.

- 47.5 Requests for clarification shall be in writing and shall be signed only by the Chairperson of the TEC.
- 48. Restrictions on the Disclosure of Information Relating to the Procurement Process**
- 48.1 Following the opening of Tenders until issuance of Notification of Award no Tenderer shall, unless requested to provide clarification to its Tender or unless necessary for submission of a complaint, communicate with the concerned Purchaser pursuant to Rule 31 of the Public Procurement Rule,2008.
- 48.2 Tenderers shall not seek to influence in anyway, the examination and evaluation of the Tenders.
- 48.3 Any effort by a Tenderer to influence a Purchaser in its decision concerning the evaluation of Tenders, Contract awards may result in the rejection of its Tender as well as further action in accordance with Section 64 (5) of the Public Procurement Act 2006.
- 48.4 All clarification requests shall remind Tenderers of the need for confidentiality and that any breach of confidentiality on the part of the Tenderer may result in their Tender being disqualified.
- 48.5 Information relating to the examination, evaluation, comparison, and post qualification of the tender or contract award, shall not be disclosed to tenderers or any other persons not officially concerned with such process.
- 49. Correction of Arithmetical Errors**
- 49.1 The TEC shall correct any arithmetic errors that are discovered during the examination of Tenders, and shall promptly notify the concerned Tenderer(s) of any such correction(s) pursuant to Rule 98(11) of the Public Procurement Rule, 2008.
- 49.2 Provided that the Tender is responsive, TEC shall correct arithmetical errors on the following basis:
- (a) If there is a discrepancy between the unit price and the line item total that is obtained by multiplying the unit price by the quantity, the unit price shall prevail and the line item total shall be corrected, unless in the opinion of the TEC there is an obvious misplacement of the decimal point in the unit price, in which case the total price as quoted will govern and the unit price will be corrected;
- (b) If there is an error in a total corresponding to the addition or subtraction of subtotals, the subtotals shall prevail and the total shall be corrected.
- 49.3 Any Tenderer that does not accept the correction of the Tender amount following correction of arithmetic errors as determined by the application of ITT Sub-Clause 49.2 shall be considered as non-responsive.
- 50. Conversion to Single Currency**
- 50.1 For evaluation and comparison purpose, TEC shall convert all Tender prices expressed in the amounts in various currencies into an amount in Bangladeshi Taka currency, using the selling exchange rates established by the Bangladesh Bank, on the date of Tender opening.
- 51. Domestic Preference**
- 51.1 Domestic preference shall be a factor in tender evaluation, unless otherwise specified in the TDS

51.2 If domestic preference shall be a tender-evaluation factor, the Purchaser will grant a margin of fifteen percent (15%) domestic preference to Goods manufactured in Bangladesh during the evaluation of its Tender while comparing the same with those of other Tenderers under the classification set out in ITT Sub-Clause 51.3. The evaluation will be carried out in accordance with the provisions set out in ITT Clause 54.

51.3 Tenders will be classified in one of two groups, as follows:

- (a) Group A: Tender offering goods manufactured in Bangladesh, for which:
  - (i) labour, raw materials, and components from within the Bangladesh account for more than thirty (30) percent of the EXW price; and
  - (ii) the production facility in which they will be manufactured or assembled has been engaged in manufacturing or assembling such goods at least since the date of tender submission.
- (b) Group B: Tenders offering Goods manufactured outside Bangladesh that have been already imported or that will be imported.

51.4 To facilitate this classification by the Tenderer, the Tenderer shall complete whichever Form of the Price Schedule furnished in the Tender Document is appropriate.

51.5 Completion of an inappropriate Form of the Price Schedule by the Tenderer shall not result in rejection of its tender, but merely in the Purchaser's reclassification of the tenderer into its appropriate tender group.

## **52. Financial Evaluation**

52.1 Thirdly the TEC, pursuant to Rule 98 of the Public Procurement Rules, 2008 shall evaluate each Tender that has been determined, up to this stage of the evaluation, to be responsive to the mandatory requirements in the Tender Document.

52.2 To evaluate a Tender in this stage , the Purchaser shall consider the following:

- (a) Verification and examination of the Price Schedule for Goods and Related Services (Form PG4-3A, 3B, 3C and PG4-3D) as furnished by the Tenderer and checking the compliance with the instructions provided under ITT Clause 23;
- (b) Evaluation will be done for Items or lot by lot as stated under ITT Clause 23 and the Total Tender Price as quoted in accordance with Clause 23 ;
- (c) Adjustment for correction of arithmetical errors as stated under ITT Sub-Clause 49.2;
- (d) Adjustment for price modification offered as stated under ITT Clause 38;
- (e) Adjustment due to discount as stated under ITT Sub-Clauses 23.8 , 23.9 and 52.3;

- (f) Adjustment due to the application of economic factors of evaluation as stated under ITT Sub-Clause 52.5 if any;
- (g) Adjustment due to the assessment of the price of unpriced items as stated under ITT Clause 53 if any;
- (h) Adjustment due to the application of a margin of preference (domestic preference), in accordance with ITT Clause 54 if applicable

52.3 If Tenders are invited for a single lot or for a number of lots as stated under ITT Sub-clauses 23.3, TEC shall evaluate only lots that that have included at least the percentage of items per lot as stated under ITT Sub-Clause 23.5 and 23.6. The TEC shall evaluate and compare the Tenders taking into account:

- (a) Lowest evaluated tender for each lot ;
- (b) The price discount/reduction per lot;
- (c) Least cost combination for the Purchaser, considering discounts and the methodology for its application as stated under ITT Sub-clauses 23.8 and 23.9 offered by the Tenderer in its Tender.

52.4 Only those spare parts and tools which are specified as a item in the List of Goods and Related Services in Section 6, Schedule of Requirement or adjustment as stated under ITT Sub-clause 52.5, shall be taken into account in the Tender evaluation. Supplier-recommended spare parts for a specified operating requirement as stated under ITT Sub-clause 25.2(b) shall not be considered in Tender evaluation.

52.5 The Purchaser's evaluation of a tender may require the consideration of other factors, in addition to the Tender Price quoted as stated under ITT Clause 23. The effect of the factors selected, if any, shall be expressed in monetary terms to facilitate comparison of tenders. The factors, methodologies and criteria to be used shall be as specified in TDS. The applicable economic factors, for the purposes of evaluation of Tenders shall be:

- (a) Adjustment for Deviations in the Delivery and Completion Schedule
- (b) Cost of major replacement components, mandatory spare parts, and service

52.6 Variations, deviations, and alternatives and other factors which are in excess of the requirements of the Tender Document or otherwise result in unsolicited benefits for the Purchaser will not be taken into account in Tender evaluation.

**53. Assessing the Price of Unpriced Items**

53.1 If it is so permitted under ITT Clause 23 , any Tenderer offered only eighty percent (80%) or minimum percent of the items of a lot as stated under ITT Sub-Clause 23.5, the TEC shall calculate the total lot value by adding up the average prices offered by other responsive Tenderers for the missing items to the lot value to establish the winning lot Tender. If the Tenderer offered less than the specified, the Tender shall be evaluated as sated under ITT Clause 23.

53.2 If the winning lot is missing some items as stated under ITT Sub Clause 53.1, comprising less than twenty percent (20%), the Purchaser may



procure the missing items from the Tenderer offering the least cost for those remaining items.

- 54. Evaluation of Domestic Preference**
- 54.1 If the Tender document so specifies, the Tenderer will grant a margin preference to goods manufactured in Bangladesh as stated in ITT Clause 51 for the purpose of Tender comparison, in accordance with the procedure outlined below:
- 54.2 The Purchaser will first review the tenders to confirm the appropriateness of, and to modify as necessary, the tenderer group classification to which Tenderers assigned their tenders in preparing their Tender Forms and Price Schedules.
- 54.3 All evaluated tenders in each group will then be compared to determine the lowest evaluated tender of each group. Such lowest evaluated tenders shall be compared with each other and if as a result of this comparison a tenderer from Group A and the Tenders offering Goods manufactured in Bangladesh is the lowest, it shall be selected for the award.
- 54.4 If, as a result of the preceding comparison, the lowest evaluated tender is from Group B,
- (a) all Group B tenders will then be further compared with the lowest evaluated tender from Group A, after adding to the evaluated tender price of goods offered in the tender for Group B, for the purpose of further comparison only an amount equal to fifteen (15) percent of the CIF/CIP (named place of destination or named port of destination) tender price.
  - (b) The lowest-evaluated tender determined from this last comparison shall be selected for the award.
- 55. Price Comparison**
- 55.1 The TEC shall compare all responsive Tenders to determine the lowest-evaluated Tender, as stated under ITT Clause 54.
- 55.2 In the extremely unlikely event that there is a tie for the lowest evaluated price, the Tenderer with the superior past performance with the Purchaser shall be selected, whereby factors such as delivery period, quality of Goods delivered, complaints history and performance indicators could be taken into consideration.
- 55.3 In the event that there is a tie for the lowest price and none of the Tenderers has the record of past performance with the Purchaser, then the the Tenderer shall be selected, subject to firm confirmation through the Post-qualification process described in ITT Clause 57, after consideration as to whether the quality of Goods that is considered more advantageous by the end-users.
- 55.4 The successful Tenderer as stated under ITT Sub Clauses 55.1, 55.2 and 55.3 shall not be selected through lottery under any circumstances.
- 56. Negotiation**
- 56.1 No negotiations shall be held during the Tender evaluation or award with the lowest or any other Tenderer pursuant to Rule 99 of the Public Procurement Rules, 2008.
- 57. Post-qualification**
- 57.1 After determining the lowest-evaluated responsive tender as sated under ITT Sub-Clause 55.1, the Purchaser's TEC pursuant to Rule 100 of the Public Procurement Rules, 2008, shall carry out the Post-Qualification of



the Tenderer, using only the requirements specified in Sub-Section C, Qualification Criteria.

- 57.2 The TEC shall contact the references given by Tenderers about their previous Supply experiences to verify, if necessary, statements made by them in their Tender and to obtain the most up-to-date information concerning the Tenderers.
- 57.3 The TEC may visit the premises of the Tenderer as a part of the post-qualification process, if practical and appropriate, to verify information contained in its Tender.
- 57.4 The TEC shall determine to its satisfaction whether the Tenderer that is selected as having submitted the lowest evaluated responsive Tender is qualified to perform the Contract satisfactorily.
- 57.5 The objective of any visit under ITT Sub-Clause 57.3 shall be limited to a general and visual inspection of the Tenderer's facilities and its plant and equipment, and there shall be no discussion concerning the Tender or its evaluation with the Tenderer during such visit(s).
- 57.6 In the event that the Tenderer with lowest evaluated cost fails the post-qualification, the TEC shall make a similar determination for the Tenderer offering the next lowest evaluated cost and so on from the remaining responsive Tenders, provided that,
- (a) such action shall only be taken if the evaluated costs of the Tenders under consideration are acceptable to the Purchaser;
  - (b) when the point is reached whereby the evaluated costs of the remaining responsive Tenders are significantly higher than that of the official estimate, or the market price, the Purchaser may take action pursuant to Rule 33 and may proceed for re-Tendering, using a revised Tender Document designed to achieve a more successful result.

**58. Rejection of All Tenders**

- 58.1 The Purchaser may, in the circumstances as stated under ITT Sub-Clause 58.2 and pursuant to Rule 33 of the Public Procurement Rules 2008, reject all Tenders following recommendations from the Evaluation Committee only after the approval of such recommendations by the Head of the Purchaser.
- 58.2 All Tenders can be rejected, if -
- (a) the price of the lowest evaluated Tender exceeds the official estimate, provided the estimate is realistic; or
  - (b) there is evidence of lack of effective competition; such as non-participation by a number of potential Tenderers; or
  - (c) the Tenderers are unable to propose completion of the delivery within the stipulated time in its offer, though the stipulated time is reasonable and realistic; or
  - (d) all Tenders are non-responsive; or
  - (e) evidence of professional misconduct, affecting seriously the Procurement process, is established pursuant to Rule 127 of the Public Procurement Rules, 2008.

- 58.3 Notwithstanding anything contained in ITT Sub-Clause 58.2 Tenders may not be rejected if the lowest evaluated price is in conformity with the market price.
- 58.4 A Purchaser may pursuant to Rule 35 of the Public Procurement Rules, 2008, on justifiable grounds, annul the Procurement proceedings prior to the deadline for the submission of Tenders.
- 58.5 All Tenders received by the Purchaser shall be returned unopened to the Tenderers in the event Procurement proceedings are annulled under ITT Sub-Clause 58.4.
- 59. Informing Reasons for Rejection**
- 59.1 Notice of the rejection, pursuant to Rule 35 of the Public Procurement Rules, 2008, will be given promptly within seven (7) days of decision taken by the Purchaser to all Tenderers and, the Purchaser will, upon receipt of a written request, communicate to any Tenderer the reason(s) for its rejection but is not required to justify those reason(s).

## G. Contract Award

- 60. Award Criteria**
- 60.1 The Purchaser shall award the Contract to the Tenderer whose offer is responsive to the Tender Document and that has been determined to be the lowest evaluated Tender, provided further that the Tenderer is determined to be Post-Qualified as stated under ITT Clause 57.
- 60.2 A Tenderer shall not be required, as a condition for award of contract, to undertake obligations not stipulated in the Tender Document, to change its price, or otherwise to modify its Tender.
- 61. Purchaser's Right to Vary Quantities**
- 61.1 The Purchaser reserves the right at the time of Contract Award to increase or decrease the quantity, per item, of Goods and Related Services originally specified in Section 6: Schedule of Requirements, provided this does not exceed the percentages indicated in the TDS, and without any change in the unit prices or other terms and conditions of the Tender and the Tender Document.
- 62. Notification of Award**
- 62.1 Prior to the expiry of the Tender validity period and within seven (7) working days of receipt of the approval of the award by the Approving Authority, the Purchaser pursuant to Rule 102 of the Public Procurement Rules, 2008, shall issue the Notification of Award (NOA) to the successful Tenderer
- 62.2 The Notification of Award, attaching the contract as per the sample (Form PG4-7) to be signed, shall state:
- (a) the acceptance of the Tender by the Purchaser;
  - (b) the price at which the contract is awarded;
  - (c) the amount of the Performance Security and its format;
  - (d) the date and time within which the Performance Security shall be submitted; and
  - (e) the date and time within which the contract shall be signed.
- 62.3 The Notification of Award shall be accepted in writing by the successful Tenderer within seven (7) working days from the date of issuance of NOA.

- 62.4 Until a formal contract is signed, the Notification of Award shall constitute a Contract, which shall become binding upon the furnishing of a Performance Security and the signing of the Contract by both parties.
- 62.5 The Notification of Award establishes a Contract between the Purchaser and the successful Tenderer and the existence of a Contract is confirmed through the signature of the Contract Document that includes all agreements between the Purchaser and the successful Tenderer.
- 63. Performance Security**
- 63.1 The Performance Security shall be determined sufficient to protect the performance of the Contract pursuant to Rule 27 of the Public Procurement Rules, 2008.
- 63.2 Performance Security shall be furnished by the successful Tenderer in the amount specified in the TDS and denominated in the currencies in which the Contract Price is payable pursuant to Rule 102 (8) of the Public Procurement Rules, 2008.
- 63.3 The proceeds of the Performance Security shall be payable to the Purchaser unconditionally upon first written demand as compensation for any loss resulting from the Supplier's failure to complete its obligations under the Contract.
- 64. Form and Time Limit for furnishing of Performance security**
- 64.1 The Performance Security shall be in the form of irrevocable Bank Guarantee in the format (Form PG4-9) as stated under ITT Clause 63, shall be issued by an internationally reputable bank and it shall have correspondent bank located in Bangladesh, to make it enforceable pursuant to Rule 27(4) of the Public Procurement Rules, 2008..
- 64.2 Within twenty-eight (28) days from issue of the Notification of Award, the successful Tenderer shall furnish the Performance Security for the due performance of the Contract in the amount specified under ITT Sub Clause 63.2.
- 65. Validity of Performance Security**
- 65.1 The Performance Security shall be required to be valid until a date twenty-eight (28) days beyond the date of completion of the Supplier's performance obligations under the Contract, including any warranty obligations.
- 65.2 If under any circumstances date of completion of the Supplier's performance obligations under the Contract, including any warranty obligations is to be extended, the Performance Security shall correspondingly be extended for the extended period.
- 66. Authenticity of performance Security**
- 66.1 The Purchaser shall verify the authenticity of the Performance Security submitted by the successful Tenderer by sending a written request to the branch of the bank issuing irrevocable Bank Guarantee in specified format.
- 66.2 If the Performance Security submitted under ITT Sub Clause 63.2 is not found to be authentic, the Purchaser shall proceed to take measures against the Tenderer in accordance with Section 64 of the Act and

pursuant to Rule 127 of the Public Procurement Rules, 2008.

- 67. Contract Signing**
- 67.1 At the same time as the Purchaser issues the Notification of Award, the Purchaser shall send the draft Contract Agreement and all documents forming the Contract pursuant to Rule 102 of the Public Procurement Rule, 2008, to the successful Tenderer.
- 67.2 Within twenty-eight (28) days of the issuance of Notification of Award, the successful Tenderer and the Purchaser shall sign the contract provided that the Performance Security submitted by the Tenderer is found to be genuine.
- 67.3 If the successful Tenderer fails to provide the required Performance Security, as stated under ITT Clause 63 or to sign the Contract, as stated under ITT Sub-Clause 67.2, Purchaser shall proceed to award the Contract to the next lowest evaluated Tenderer, and so on, by order of ranking pursuant to Rule 102 of the Public Procurement Rules, 2008.
- 68. Publication of Notification of Award of Contract**
- 68.1 Notification of Awards for Contracts of Taka 10(ten) million and above shall be notified by the Purchaser to the Central Procurement Technical Unit within 7(seven) days of issuance of the NOA for publication in their website, and that notice shall be kept posted for not less than a month pursuant to Rule 37 of the Public Procurement Rules, 2008.
- 68.2 Notification of Award for Contracts below Taka 10(ten) million, shall be published by the Purchaser on its Notice Board and where applicable on the website of the Purchaser and that notice shall be kept posted for not less than a month pursuant to Rule 37 of the Public Procurement Rules, 2008.
- 69. Debriefing of Tenderers**
- 69.1 Debriefing of Tenderers by Purchaser shall outline the relative status and weakness only of his or her Tender requesting to be informed of the grounds for not accepting the Tender submitted by him or her pursuant to Rule 37 of the Public Procurement Rule, 2008, without disclosing information about any other Tenderer.
- 69.2 In the case of debriefing confidentiality of the evaluation process shall be maintained.
- 70. Right to Complain**
- 70.1 Any Tenderer has the right to complain if it has suffered or likely to suffer loss or damage due to a failure of a duty imposed on the Purchaser to fulfil its obligations in accordance with Section 29 of the Public Procurement Act 2006 and pursuant to Part 12 of Chapter Three of the Public Procurement Rules, 2008.
- 70.2 Circumstances in which a formal complaint may be lodged in sequence by a potential Tenderer against a Purchaser pursuant to Rule 56 of the Public Procurement Rules, 2008, and the complaints, if any, be also processed pursuant to Rule 57 of the Public Procurement Rules 2008.
- 70.3 The potential Tenderer shall submit his or her complaint in writing within seven (7) calendar days of becoming aware of the circumstances giving rise to the complaint.

- 70.4 In the first instance, the potential Tenderer shall submit his or her complaint to the Purchaser who issued the Tender Document.
- 70.5 The place and address for the first stage in the submission of complaints to the Administrative Authority is provided in the TDS.
- 70.6 The Tenderer may appeal to a Review Panel only if the Tenderer has exhausted all his or her options of complaints to the administrative authority as stated under ITT Sub-Clause 70.2.

## Section 2. Tender Data Sheet

*Instructions for completing the Tender Data Sheet are provided, as needed, in the notes in italics and under lined mentioned for the relevant ITT clauses.*

ITT Clause	Amendments of, and Supplements to, Clauses in the Instruction to Tenderers
<b>A. General</b>	
ITT 1.1	<p>The Purchaser is: Bangladesh Power Development Board (BPDB)</p> <p style="text-align: center;">Representative</p> <p>Director, Directorate of Purchase, BPDB, WAPDA Building (9th floor), Motijheel C/A, Dhaka-1000. Phone: +88 02 223383081.</p> <p style="text-align: center;">Consignee</p> <p>Director, Directorate of Electrical Equipment, BPDB, Bidhut Bhaban (4th Floor), 1 Abdul Gani Road, Dhaka-1000. Phone: +88 02 223380509</p> <p style="text-align: center;">Engineer</p> <p>Director, Directorate of Design &amp; Inspection-II, 9/B, Motijheel C/A, Dhaka-1000. Phone: +88 02 223383613.</p> <p>The Name and Identification number of the tender are:</p> <p style="text-align: center;">Procurement of</p> <p>Supply of 33/11kV, 10/13.33MVA Power Transformer (Tongi Store)</p>
ITT 1.2	The number, identification and name of lots comprising the Tender are: Supply of 33/11kV, 10/13.33MVA Power Transformer (Tongi Store)
ITT 3.1	The source of public fund is Cash Foreign Exchange under Revenue Budget of BPDB.
ITT 3.3	The name of the Development Partner is: Not Applicable
ITT 5.1	Tenderers from the following countries are not eligible: Israel and countries having no diplomatic relation with the Government of Bangladesh
ITT 6.1	Goods and Related Services from the following countries are not eligible: Israel and countries having no diplomatic relation with the Government of Bangladesh
<b>B. Tender Document</b>	
ITT 8.2	<p>The following are the offices of the Purchaser for the purpose of providing the Tender Document:</p> <p>Director Directorate of Purchase, BPDB WAPDA Building (9th floor), Motijheel C/A Dhaka-1000 Tel No: +88 02 223383081.</p>
ITT 9.1	<p>For clarification of Tender purposes only, the Purchaser's address is: Attention: Director. Address: Directorate of Purchase, BPDB WAPDA Building (9th floor), Motijheel C/A Dhaka-1000, Bangladesh Tel No: +88 02 223383081.</p>

ITT 10.1	A Pre- Tender meeting shall not be held.
<b>C. Qualification Criteria</b>	
ITT 13.1	The maximum Three (3) number of arbitration against the Tenderer over a period of last five (5) years.
ITT 14.1(a)	The Tenderer shall have a minimum of 03(three) years of overall experience in the supply of goods and related services.
ITT 14.1(b)	The minimum specific experience as Supplier in supply of similar Goods of at least 02 (two) contracts successfully completed within the last 05 (five) years, i.e. years counting backward from the date of publication of IFT in the newspaper, each with a value of at least BDT 14.75 (Fourteen point seven five) crore or Equivalent. In addition, performance of the completed contracts as mentioned in Annexure: 4-1 shall be taken into consideration during evaluation. Similar Goods means : Electrical Equipment/Materials
ITT 14.1(c)	The minimum production capacity of similar type Goods must satisfy the assessment of Production Capacity as mentioned in Table- 3B of Annexure: 4-3.
ITT 15.1(a)	The minimum amount of liquid asset or working capital or credit facility must satisfy the assessment of Financial Resources Availability as mentioned in Table- 4B of Annexure: 4-4.
ITT 16.2	The maximum of percentage of Goods allowed to be subcontracted: Not Allowed.
<b>D. Preparation of Tender</b>	
ITT 21.1(q)	The Tenderer shall submit with its Tender the following additional documents: <ol style="list-style-type: none"> <li>1. Sealed &amp; signed original Tender Document (which was issued by BPDB) by a person duly authorized to sign on behalf of the tender. Copy of issued tender document will not be acceptable.</li> <li>2. Registration /Certificate of Incorporation /Trade licence in its country of origin / relevant documents as documentary evidence to satisfy experience criteria as stated in ITT 14.1(a).</li> <li>3. End User certificate (s) as documentary evidence to satisfy experience criteria as stated in ITT 14.1(b).</li> <li>4. Updated brochures of the supplier and/or manufacturer as documentary evidence to satisfy experience criteria as stated in ITT 14.1(c)</li> <li>5. Audited Financial reports or bank statement or credit line(s) substantiated by any schedule Bank as documentary evidence to satisfy financial criteria as stated in ITT 15.</li> </ol>

6. Compliance certificate confirming to the terms and condition of the tender document.
7. Name of the Manufacturer, Certificate of the country of Origin and port of shipment (where applicable) of the offered equipment / items.
8. Warranty Certificate (Form PG4-12) from Tenderer as per GCC 33
9. List of Goods and Delivery schedule as stated in Schedule of Requirements, Section : 6.
10. Manufacturer's Printed Catalogue describing specification and technical data of offered type equipment.
11. Outline and General Arrangement drawings of the offered type equipment.
12. Detail description of testing facilities at manufacturer's plant including calibration certificates of testing equipment.
13. Manufacturer's valid ISO 9001 Certificate.
14. Certification from the manufacturer confirming that his offered item is unused, new and in good condition and confirmed all features & accessories stated in Section 7: Technical Specification.
15. If Tenderer has any reservation, Tenderer has to mention it in Deviation list (Form PG4-11).
16. Guaranteed Technical Particulars (GTP) in Section 8 shall be properly filled up in manufacturer's official pad with submission of related supporting documents & signed by the Manufacturer & Tenderer.
17. At least 02 (two) nos. of Manufacturer's Supply Experience (supported by Copy of NOA/ Contract Agreement/Certificate from Purchaser) for offered type similar or higher capacity rating Power Transformer of same voltage class within the last 05 (five) years i.e. years counting backward from the date of publication of IFT in the news paper. Manufacturer's Supply Experience shall be furnished in the following supply record format. (The Supply Experience covering at least 25% of the tendered quantity in a single contract will be considered only):

Sl. No.	Name, Address, Phone & Fax No. of the Purchaser	Contract No. & Date/NOA	Contract Value	Description of materials with Quantity	Date of Completion of Supply

18. At least 02 (two) nos. Manufacturer's Satisfactory Performance Certificates (supported by the Supply Record) from Electricity Utility as End User depicting that the offered type similar or higher capacity rating Power Transformer of same voltage class has been supplied within last 10(ten) years i.e. years counting backward from the date of publication of IFT in the news paper and has been in satisfactorily service for at least 02(two) years. The Satisfactory Performance Certificate (SPC) shall be in End User's official pad and shall contain End User's full mailing address, fax/telephone number, website address, domain e-mail address for the convenience of authentication.

Note: Electricity Utility means an organization/company that engages in electricity generation/ transmission / distribution of electricity for sale in a regulated market.



	<p>19. Manufacturer's authorization for (On Load tap Changer) OLTC from MR, Germany/ ABB (Hitachi), Sweden in prescribed Form (PG4-5).</p> <p>20. Cross-sectional Drawing showing the arrangement of core and windings of the offered type Transformer.</p> <p>21. Type Test Certificates, Reports &amp; Special Tests for offered type similar or higher MVA rating power transformer for same voltage class from any short-circuit testing liaison (STL) Member [<a href="http://www.stl-liaison.org/web/03_Members.php">http://www.stl-liaison.org/web/03_Members.php</a>] Testing Organization or Laboratory as per relevant IEC standard. The type test report shall include at least the following tests along with results:</p> <p>a) Temperature Rise Test</p> <p>b) Lightning Impulse Test</p> <p>a) Short circuit withstands test report of HV-LV</p> <p>22. Loss calculation, short circuit calculation and temperature rise calculation. Tenderer's quoted No load Loss and Full load loss shall be supported by loss calculation. Moreover, Tenderer shall submit the characteristic curve (flux vs Loss/Kg) of core materials.</p> <p><i>Note: If required, Purchaser will authenticate Type Test Certificates &amp; Reports from the Certificates &amp; Reports Issuing laboratory and if any applicable charge /cost impose by issuing laboratory for said authentication shall be borne by Tenderer. The certificates and Reports shall contain laboratory's full mailing address, e-mail address, website address and fax/telephone number for the convenience of authentication. If these information are not mentioned in the Certificates &amp; Reports, all these information should be mentioned in the Letterhead pad of the manufacturer duly seal &amp; signed by the manufacturer representative.</i></p> <p>23. Tenderer shall have to submit the information of all completed similar contracts in govt. entities under power sector of Bangladesh within last 5 (five) years, i.e. years counting backward from the date of publication of IFT in the newspaper, with supporting document (end user's satisfactory performance certificate/ Acceptance Certificate) in the format attached as Annexure: 4-1.</p> <p>24. Tenderer shall have to submit the information of all ongoing similar contract(s) in govt. entities under power sector of Bangladesh in the format attached as Annexure: 4-2 with supporting document (Acceptance of NOA/Contact agreement) along with the upto date Acceptance certificate / R&amp;I certificate from end user.</p>
ITT 22.1	Alternative Tenders will not be permitted.
ITT 23.3	Tender is invited for Supply of 33/11kV, 10/13.33MVA Power Transformer (Tongi Store)
ITT 23.5	Price quoted for each lot shall correspond at least to 100 % of the items specified for each lot and correspond at least to 100% of the total lot value.
ITT 23.7	Not Applicable
ITT 23.11(c) ITT 23.12 (c) ITT 23.13 (e)	Insurance will be paid by Bangladesh Power Development Board Final destination is [Central Store, BPDB, at Tongi, Gazipur.]
ITT 23.12 (a)	Price of the Goods shall be quoted on CFR Port of Destination : Chittagong/ Dhaka/ Khulna (Mongla)/ Benapole.

ITT 23.12 (d)	As specified in ITT 23.12(a)
ITT 24.3	Name of the foreign currency: US Dollar/ Euro
ITT 25.2(b)	Spare parts are: Not Applicable
ITT 26.1(b)	<p>Manufacturer's authorization is: Required.</p> <p>Authorization Letter from Manufacturer's Sales office (if located outside the manufacturing country) and Dealer/ Trading house will not be accepted if not supported by Manufacturer's letter. In this regard, Scanning Paper, E-mail copy, Faxed copy &amp; Sealed signature will not be accepted. Manufacturer's signature in Authorization letter shall be handwritten by Pen i.e. signature through stamping /seal is not accepted. The Authorization letter shall mention domain E-mail address, Telephone/Fax, designation with detail address of the manufacturer representative duly signed in the manufacturer official pad.</p>
ITT 26.1(C)	After-sales service is Required.
ITT 27.2	The Tender validity period shall be 150 (One hundred and Fifty) days.
ITT 29.2	In favour of Director, Directorate of Purchase, Bangladesh Power Development Board
ITT 29.3	The amount of the Tender Security shall be as per Tender Notice.
ITT 34.1	In addition to the original of the Tender, 3(three) copies shall be submitted.
<b>E. Submission of Tender</b>	
ITT 35.2(c)	<p>The inner and outer envelopes of tender shall bear the following additional identification marks</p> <ol style="list-style-type: none"> <li>1. Date of Submission</li> <li>2. Seal and Signature of the Tenderer</li> </ol> <p>Book Binding is required for original and copies</p>
ITT 35.7	Tenderer shall not have the option of submitting their tender electronically.
ITT 35.8	If Tenderer shall have the option of submitting their tender electronically: Not Applicable.
ITT 35.9 (New Clause)	Submission of sample(s) and it's Evaluation: Not Applicable
ITT 36.1	<p>For <u>Tender submission purposes</u> , the Purchaser's address is:</p> <p>Attention: Director, Directorate of Purchase, BPDB.  Address: WAPDA Building (9<sup>th</sup> floor), Motijheel C/A, Dhaka-1000  Phone: +88 02 223383081.</p> <p>The deadline for submission of Tenders is: as specified in tender notice or amendment of submission time (if any)</p>
<b>F. Opening and Evaluation of Tenders</b>	
ITT 42.2	<p>The Tender opening shall take place at:</p> <p>The Office of the Director, Directorate of Purchase, BPDB,  Address: WAPDA Building (9th floor), Motijheel C/A,Dhaka-1000  Time &amp; Date: On Time &amp; Date as specified in tender notice or amendment of</p>

	opening time (if any)
ITT 42.3	If electronic tender submission is permitted as sated under ITT sub-clause 34.8, the specific tender opening procedures shall be: Not Applicable
ITT 51.1	Domestic Preference shall be a tender evaluation factor
ITT 52.5	The applicable economic factors, for the purposes of evaluation of Tenders shall be: as follows: <ol style="list-style-type: none"> <li>1. Capitalization cost</li> <li>2. Domestic Preference</li> </ol>
<b>G. Award of Contract</b>	
ITT 61.1	The maximum percentage by which quantities per item may be increased is 20%. The maximum percentage by which quantities per item may be decreased is 20%.
ITT 63.2	The amount of Performance Security shall be 10% (ten) percent of the Contract Price.
ITT 70.5	The name and address of the office where complaints to the Procuring Entity under Regulation 51 are to be submitted is: Director, Directorate of Purchase BPDB, WAPDA Building (9th floor), Motijheel C/A, Dhaka-1000, Bangladesh Phone: +88 02 223383081.

## Section 3. General Conditions of Contract

1. Definitions
- 1.1 The following words and expressions shall have the meaning hereby assigned to them. Boldface type is used to identify the defined term:
- (a) Completion Schedule means the fulfilment of the Related Services by the Supplier in accordance with the terms and conditions set forth in the Contract;
  - (b) Contract Agreement means the Agreement entered into between the Purchaser and the Supplier, together with the Contract Documents referred to therein, including all attachments, appendices, and all documents incorporated by reference therein;
  - (c) Contract Documents means the documents listed in the Contract Agreement, including any amendments thereto;
  - (d) Contract Price means the price stated in the Notification of Award and thereafter as adjusted in accordance with the provisions of the Contract; ;
  - (e) Day means calendar days unless otherwise specified as working days;
  - (f) Delivery means the transfer of ownership of the Goods from the Supplier to the Purchaser in accordance with the terms and conditions set forth in the Contract;
  - (g) GCC mean the General Conditions of Contract;
  - (h) Goods means raw materials, products and equipment and objects in solid, liquid or gaseous form, electricity, and related Services if the value of such Services does not exceed that of the Goods themselves ;
  - (i) Government means the Government of the People's Republic of Bangladesh;
  - (j) Procuring Entity/Purchaser means a Entity having administrative and financial powers to undertake Procurement of Goods, Works or Services using public funds, as specified in the PCC;
  - (k) Related Services means Services linked to the supply of Goods contracts.;
  - (l) PCC means the Particular Conditions of Contract;
  - (m) Subcontractor means any natural person, private or government entity, or a combination of the above, to whom any part of the Goods to be supplied or execution of any part of the Related Services is subcontracted by the Supplier;
  - (n) Supplier means a Person under contract with a Purchaser for the supply of Goods and related Services under the Act;
  - (o) Site means the point(s) of delivery named in the PCC
  - (p) Writing means communication written by hand or machine duly signed and includes properly authenticated messages by facsimile or electronic mail.

- (q) Verified Report means the report submitted by the Purchaser to the Head of the Purchaser setting forth its findings as to the existence of grounds or causes for termination and explicitly stating its recommendation for the issuance of a Notice to Terminate.
2. Contract Documents
- 2.1 Subject to the order of precedence set forth in the GCC Sub-Clause 5.1, all documents forming the Contract (and all parts thereof) are intended to be correlative, complementary, and mutually explanatory. The Contract Agreement shall be read as a whole.
3. Corrupt, Fraudulent, Collusive or Coercive Practices
- 3.1 The Government requires that Purchaser, as well as Suppliers, shall observe the highest standard of ethics during the implementation of procurement proceedings and the execution of contracts under public funds.
- 3.2 The Government requires that Procuring Entities, as well as Suppliers shall, during the execution of Contracts under public funds, ensure-
- (a) strict compliance with the provisions of Section 64 of the Public Procurement Act 2006 (Act 24 of 2006);
- (b) abiding by the code of ethics as mentioned in the Rule 127 of the Public Procurement Rules, 2008;
- (c) that neither it nor any other member of its staff or any other agents or intermediaries working on its behalf engages in any practice as detailed in GCC Sub -Clause 3.3
- 3.3 For the purpose of GCC Sub-clause 3.2 the terms –
- (a) corrupt practice means offering, giving or promising to give, receiving, or soliciting, either directly or indirectly, to any officer or employee of a Purchaser or other public or private authority or individual, a gratuity in any form; employment or any other thing or service of value as an inducement with respect to an act or decision or method followed by a Purchaser in connection with a Procurement proceeding or contract execution;
- (b) fraudulent practice means the misrepresentation or omission of facts in order to influence a decision to be taken in a Procurement proceeding or Contract execution;
- (c) collusive practice means a scheme or arrangement between two (2) or more Persons, with or without the knowledge of the Purchaser, that is designed to arbitrarily reduce the number of Tenders submitted or fix Tender prices at artificial, noncompetitive levels, thereby denying a Purchaser the benefits of competitive price arising from genuine and open competition; or
- (d) coercive practice means harming or threatening to harm, directly or indirectly, Persons or their property to influence a decision to be taken in a Procurement proceeding or the execution of a Contract, and this will include creating obstructions in the normal submission process used for Tenders.

- 3.4 Should any corrupt, fraudulent, collusive or coercive practice of any kind come to the knowledge of the Purchaser, it will, in the first place, allow the Supplier to provide an explanation and shall, take actions only when a satisfactory explanation is not received. Such exclusion and the reasons thereof, shall be recorded in the record of the procurement proceedings and promptly communicated to the Supplier concerned. Any communications between the Supplier and the Purchaser related to matters of alleged fraud or corruption shall be in writing.
- 3.5 If corrupt, fraudulent, collusive or coercive practices of any kind determined by the Purchaser against the Supplier alleged to have carried out such practices, the Purchaser shall proceed under GCC Clause 42.4
- 3.6 The Supplier shall permit the Purchaser to inspect the Supplier's accounts and records and other documents relating to the submission of the Tender and Contract performance.

#### 4. Interpretation

- 4.1 In interpreting the GCC, singular also means plural, male also means female or neuter, and the other way around. Headings in the GCC shall not be deemed part thereof or be taken into consideration in the interpretation or construction thereof or of the Contract. Words have their normal meaning under the English language unless specifically defined.
- 4.2 Entire Agreement
  - (a) The Contract constitutes the entire agreement between the Purchaser and the Supplier and supersedes all communications, negotiations and agreements (whether written or oral) of parties with respect thereto made prior to the date of Contract Agreement; except those stated under GCC Sub Clause 5.1(i) .
- 4.3 Amendment
  - (a) No amendment or other variation of the Contract shall be valid unless it is in writing, is dated, expressly refers to the Contract, and is signed by a duly authorised representative of each party thereto.
- 4.4 Non-waiver
  - (a) Subject to GCC Sub-Clause 4.4(b), no relaxation, forbearance, delay, or indulgence by either party in enforcing any of the terms and conditions of the Contract or the granting of time by either party to the other shall prejudice, affect, or restrict the rights of that party under the Contract, neither shall any waiver by either party of any breach of Contract operate as waiver of any subsequent or continuing breach of Contract.
  - (b) Any waiver of a party's rights, powers, or remedies under the Contract must be in writing, dated, and signed by an authorised representative of the party granting such waiver, and must specify the right and the extent to which it is being waived.
- 4.5 Severability
  - (a) If any provision or condition of the Contract is prohibited or rendered invalid or unenforceable, such prohibition, invalidity or unenforceability shall not affect the validity or enforceability of any other provisions and conditions of the Contract.

- 5. Documents Forming the Contract in order of precedence**
- 5.1 The following documents forming the Contract shall be in the following order of precedence, namely :
- (a) the signed Contract Agreement;
  - (b) the Notification of Award;
  - (c) The Tender and the appendices to the Tender;
  - (d) Particular Conditions of Contract;
  - (e) General Conditions of Contract;
  - (f) Technical Specifications;
  - (g) Drawings;
  - (h) Priced Schedule and schedule of requirements and ;
  - (i) Other Documents including correspondences listed in the PCC forming part of the Contract.
- 6. Eligibility**
- 6.1 The Supplier and its Subcontractors shall have the nationality of an eligible country. A Supplier or Subcontractor shall be deemed to have the nationality of a country if it is a citizen or constituted, incorporated, or registered, and operates in conformity with the provisions of the laws of that country.
- 6.2 All Goods and Related Services to be supplied under the Contract shall have their origin in Eligible Countries.
- 6.3 For the purpose of the GCC Clause 6.2, origin means the country where the goods have been grown, mined, cultivated, produced, manufactured, or processed; or through manufacture, processing, or assembly, another commercially recognized article results that differs substantially in its basic characteristics from its components.
- 7. Governing Language**
- 7.1 The Contract shall be written in English language. Correspondence and documents relating to the Contract exchanged by the Supplier and the Purchaser shall be written in English .Supporting documents and printed literature that are part of the Contract may be in another language provided they are accompanied by an accurate translation of the relevant passages in English language, in which case, for purposes of interpretation of the Contract, this translation shall govern.
- 7.2 The Supplier shall bear all costs of translation to the governing language and all risks of the accuracy of such translation.
- 8. Governing Law**
- 8.1 The Contract shall be governed by and interpreted in accordance with the laws of the People’s Republic of Bangladesh.
- 9. No fees/Gratuities**
- 9.1 No fees, gratuities, rebates, gifts, commissions or other payments, other than those shown in the Tender or the contract, shall be given or received in connection with the procurement process or in the contract execution.

- 10. Use of Contract Documents & Information**
- 10.1 The Supplier shall not, except for purposes of performing the obligations in this Contract, without the Purchaser's prior written consent, disclose this Contract, or any provision thereof, or any specification, plan, drawing, pattern, sample, or information furnished by or on behalf of the Purchaser. Any such disclosure shall be made in confidence and shall extend only as far as may be necessary for purposes of such performance.
- 10.2 Any document, other than this Contract itself, enumerated in GCC Clause 10.1 shall remain the property of the Purchaser and shall be returned (all copies) to the Purchaser on completion of the Supplier's performance under this Contract if so required by the Purchaser.
- 11. Communications & Notices**
- 11.1 Communications between Parties (notice, request or consent required or permitted to be given or made by one party to the other) pursuant to the Contract shall be in writing to the addresses specified in the PCC.
- 11.2 A notice shall be effective when delivered or on the notice's effective date, whichever is later.
- 11.3 A Party may change its address for notice hereunder by giving the other Party notice of such change to the address.
- 12. Trademark, Patent and Intellectual Property Rights**
- 12.1 The Purchaser should not be liable for any infringement of intellectual property rights arising from use of the goods procured. In case there are third-party claims of such infringement of patent, trademark, or industrial design rights, the supplier must indemnify and hold the Purchaser free and harmless against such claims and shall not be in contravention of The Trademark Act, 2009 and The Patents and Designs Act, 1911.
- 13. Copyright**
- 13.1 The copyright in all drawings, documents, and other materials containing data and information furnished to the Purchaser by the Supplier herein shall remain vested in the Supplier, or, if they are furnished to the Purchaser directly or through the Supplier by any third party, including suppliers of materials, the copyright in such materials shall remain vested in such third party.
- 14. Assignment**
- 14.1 The Supplier shall not assign his rights or obligations under the Contract, in whole or in part, except with the Purchaser's prior written consent.
- 15. Sub contracting**
- 15.1 Any subcontracting arrangements made during contract implementation and not disclosed at the time of the Tendering shall not be allowed.
- 15.2 Subcontracting of any portion of the Goods shall not relieve the Tenderer from any liability or obligations that may arise from its performance.
- 15.3 Supplier shall retain full responsibility for the contract and can not pass any contractual obligations to the subcontractor and under no circumstances assignment of the contract to the subcontractor be allowed.
- 15.4 Subcontractors shall comply with the provisions of GCC Clause 3 and 6.



- 16. Supplier's Responsibilities** 16.1 The Supplier shall supply all the Goods and Related Services specified in the Scope of Supply as stated under GCC Clause 18 and the Delivery and Completion schedule, as stated under GCC Clauses 23 and 24 in conformity with the provisions of the Contract Agreement.
- 17. Purchaser's Responsibilities** 17.1 Whenever the performance of the obligations in this Contract requires that the Supplier obtain permits, approvals and other license from local public authorities, the Purchaser may, if so needed by the Supplier, make its best effort to assist the Supplier in complying with such requirements in a timely and expeditious manner. However, the supplier shall bear the costs of such permits and/or licenses. On the other hand, the Purchaser shall pay all costs involved in the performance of its responsibilities, in accordance with the contract.
- 17.2 The Purchaser shall pay the Supplier, in consideration of the provision of Goods and Related Services, the Contract Price under the provisions of the Contract at the times and manner prescribed in the Contract Agreement.
- 18. Scope of Supply** 18.1 Subject to the PCC, the Goods and Related Services to be supplied shall be as specified in Section 6: Schedule of Requirements.
- 18.2 Unless otherwise stipulated in the Contract, the Scope of Supply shall include all such items not specifically mentioned in the Contract but that can be reasonably inferred from the Contract as being required for attaining Delivery and Completion of the Goods and Related Services as if such items were expressly mentioned in the Contract.
- 19. Amendment to Order** 19.1 The Purchaser may make an amendment to Order for necessary adjustment within the general scope of the contract in any one or more of the following aspects in order to fully meet the requirement of the Contract:
- (a) Drawing, design or specifications of the goods, provided that:
    - i. The goods to be furnished are to be specifically manufactured for the government in accordance therewith;
    - ii. The change is an improvement of the goods and advantageous to the Government;
    - iii. It is done at no extra cost; and
    - iv. It is not prejudicial to the losing Tenderers in the sense that such change/s could not have been foreseen during the conduct of the tendering and would have significantly affected the other tenderer's tender;
  - (b) The place of delivery;
  - (c) The place of performance of the services;
  - (d) Additional items needed and necessary for the protection of the goods procured, which were not included in the original contract.
- 19.2 Such amendment may or may not result to an increase or a decrease of the contract price, and/or an extension or reduction of the delivery period. However, the amendment should not have the result of changing the subject matter of the contract or the specifications of the goods or services, in any material aspect and to such an extent that, if introduced during the Tendering stage, may have had a significant effect on other Tenderer's tender, because this situation would actually require another tendering activity.

- 20. Instances When Amendment to Order May be Issued**
- 20.1 The Purchaser may issue amendments order at any time during contract implementation, through a notice as stated under GCC Clause 11, provided that such adjustment is required to fully meet the requirements of the contract. Any of the following circumstances may serve as basis for such amendment/s:
- (a) Emergency cases, fortuitous events or unforeseen contingencies arising during contract implementation, and such contingencies have an impact on the procurement at hand, such as:
    - i. Changes in the conditions affecting the contract, e.g., a change in the place of delivery;
    - ii. Time is of the essence in the implementation of the contract, and any changes require immediate implementation; and
    - iii. Additional requirements have been identified as necessary for the protection of the goods procured, such as changes in the packaging of the goods, or additional items have become necessary to ensure that the goods are sufficiently protected from the elements;
  - (b) When the contract does not reflect the real intention of the parties due to mistake or accident, and the amendment is necessary to reflect the party's intention; and
  - (c) Other analogous circumstances that could affect the conditions of the procurement at hand
- 21. Adjustments in Contract Price and/or Delivery Schedule in Amendment to Order**
- 21.1 If an amendment to order increases or decreases the cost of ,or the time required for executing any part of the delivery under the original contract, an equitable adjustment in contract price and/or delivery schedule should be mutually agreed upon between parties concerned, and the contract should be modified as stated under GCC Clause 46
- 21.2 If the amendment to order consists of additional items, the price adjustment shall be based on the unit price in the original contract for items of goods similar to those in the original contract. If the contract does not contain any rate applicable to the additional items, then suitable prices shall be mutually agreed upon between the parties, based on prevailing market prices.
- 21.3 It is required, however, that any increase in contract price must not exceed ten percent (10%) of the original contract price.
- 22. Packing and Documents**
- 22.1 The Supplier shall provide such packing of the goods as is required to prevent their damage or deterioration during transit to their final destination, as indicated in the Contract and in accordance with existing industry standards. The packing shall be sufficient to withstand, without limitation, rough handling and exposure to extreme temperatures, salt and precipitation, and open storage. Packing case size and weights shall take into consideration, where appropriate, the remoteness of the goods' final destination and the absence of heavy handling facilities at all points in transit.
- 22.2 The packing, marking, and documentation within and outside the packages shall comply strictly with such special requirements as shall be expressly provided for in the Contract as stated under GCC Clause 22.1,

including additional requirements, if any, specified in the PCC, and in any subsequent instructions ordered by the Purchaser.

- 22.3 The outer packaging must contain a "Packing List" which must reflect the actual contents of the package.
- 23. Delivery and Documents**
- 23.1 Subject to GCC Sub-Clause 19, the Delivery of the Goods and completion of the Related Services shall be in accordance with the Delivery and Completion Schedule specified in the Section 6: Schedule of Requirements.
- 23.2 The details of shipping and other documents to be furnished by the Supplier shall be specified in the PCC, and shall be received by the Purchaser at least one week before arrival of the Goods and, if not received the Supplier shall be responsible for consequent expenses.
- 24. Acceptance**
- 24.1 Acceptance by the Purchaser shall be completed not later than fourteen (14) days from receipt of the goods at final destination in the form of an Acceptance Certificate, unless any defects in the supply, any damage during transportation or any failure to meet the required performance criteria of the supply are identified and reported to the Supplier as stated under GCC Clause 31 and GCC Clause 32. In such cases the Acceptance Certificate will be issued only for those parts of the contract supplies which are accepted. The Acceptance Certificate for the remaining supplies will only be issued after the Supplier has remedied the defects and/or any non-conformity under GCC Clause 31 and GCC Clause 32.
- 24.2 The appropriate Technical Inspection and Acceptance Committee of the Purchaser must commence the inspection and acceptance process within two (2) days from delivery of the goods, and shall complete the same as soon as practicable.
- 25. Contract Price**
- 25.1 The Contract Price shall be specified in the PCC.
- 25.2 During evaluation, tender has excluded and not taken into account:
- (a) In the case of Goods manufactured in Bangladesh, VAT payable on account of Supplier, which will be payable on the goods if a contract is awarded to the Tenderer;
- (b) in the case of Goods manufactured outside the Bangladesh, already imported or to be imported, customs duties, import VAT and other import taxes levied on the imported Good, VAT, which will be payable on the Goods if the contract is awarded to the Tenderer.
- 25.3 The Contract price will include all the costs paid or payable as stated under GCC Clause 25.2.
- 25.4 Prices charged by the Supplier for the Goods delivered and the Related Services performed under the Contract shall not vary from the price as stated under GCC Sub-Clause 25.1, with the exception of any change in price resulting from a Change Order issued under GCC Clause 19.

- 26. Transportation**
- 26.1 The Supplier is required under the Contract to transport the Goods to a specified place of destination as specified in Section 6: Schedule of Requirements, defined as the Site, transport to such place of destination, including insurance, other incidental costs, and temporary storage, if any. These costs shall be included in the Contract Price.
- 26.2 If not in accordance GCC Clause 26.1, responsibility for transportation of the Goods shall be as specified in the *INCOTERM* indicated in the Price Schedule or any other trade terms specify the responsibilities of the Purchaser and Supplier as specified in PCC.
- 27. Terms of Payment**
- 27.1 The Contract Price, including any Advance Payments, if applicable, shall be paid in the manner as specified in the PCC.
- 27.2 The Supplier's request for payment shall be made to the Purchaser in writing, accompanied by an invoice describing, as appropriate, the Goods delivered and Related Services performed, and accompanied by the documents as stated under GCC Clause 23 and 24 and upon fulfilment of any other obligations stipulated in the Contract.
- 27.3 Payments shall be made promptly by the Purchaser, but in no case later than the days indicated in the PCC after submission of an invoice or request for payment by the Supplier, and after the Purchaser has accepted it.
- 27.4 The currencies in which payments shall be made to the Supplier under this Contract shall be those in which the tender price is expressed.
- 27.5 In the event that the Purchaser fails to pay the Supplier any payment by its respective due date or within the period set forth in the PCC, the Purchaser shall pay to the Supplier interest on the amount of such delayed payment at the rate shown in the PCC, for the period of delay until payment has been made in full, whether before or after judgment or arbitration award.
- 28. Insurance**
- 28.1 The Goods supplied under this Contract shall be fully insured by the Supplier in a freely convertible currency against loss or damage incidental to manufacture or acquisition, transportation, storage, and delivery. The Goods remain at the risk and title of the Supplier until their final acceptance by the Purchaser.
- 28.2 If not in accordance GCC Clause 28.1, the insurance coverage shall be as specified in the *INCOTERM* indicated in the Price Schedule or any other insurance provisions as specified in PCC.
- 29. Taxes and Duties**
- 29.1 For Goods Manufactured within Bangladesh, the Supplier shall be entirely responsible for all taxes, duties, VAT, license fees, and other such levies imposed or incurred until delivery of the contracted goods to the Purchaser.
- 29.2 For Goods manufactured outside Bangladesh, the Supplier shall be entirely responsible for all taxes, duties and other such levies imposed outside Bangladesh.
- 29.3 If any tax exemptions, reductions, allowances or privileges may be available to the Supplier in Bangladesh, the Purchaser shall use its best efforts to enable the Supplier to benefit from any such tax savings to the maximum allowable extent.

- 30. Performance Security**
- 30.1 The proceeds of the Performance Security shall be payable to the Purchaser as compensation for any loss resulting from the Supplier's failure to complete its obligations under the Contract.
- 30.2 The Performance Security shall be discharged by the Purchaser and returned to the Supplier not later than Thirty (30) days following the date of Completion of the Supplier's performance obligations under the Contract and the issuance of certification to that effect by the Purchaser, including any warranty obligations as stated under GCC Clause 33, provided that there are no claims filed against the supplier.
- 31. Specifications and Standards**
- 31.1 The Goods and Related Services supplied under this Contract shall conform to the technical specifications and standards mentioned in Section 7, Technical Specification and in Section 8, Drawings, if any.
- 31.2 If there is no applicable standard, the goods must conform to the authoritative standards appropriate to the good's country of origin. Such standards must be the latest issued by the concerned institution.
- 31.3 Subject to the GCC Clause 19, the Supplier shall be entitled to disclaim responsibility for any design, data, drawing, specification or other document, or any modification thereof provided or designed by or on behalf of the Purchaser, by giving a notice of such disclaimer to the Purchaser.
- 31.4 Wherever references are made in the Contract to codes and standards in accordance with which it shall be executed, the edition or the revised version of such codes and standards shall be those specified in the Technical Specification. During Contract execution, any changes in any such codes and standards shall be applied only after approval by the Purchaser and shall be treated under GCC Clause 19.
- 32. Inspections and Tests**
- 32.1 The Purchaser shall have the right to test the Goods to confirm their conformity to the Contract specifications. The PCC and Technical specifications shall specify what tests the Purchaser requires and where they are to be conducted. The supplier shall at its own expense and at no cost to the Purchaser, carry out all such tests of the Goods and related services as are specified in the Contract.
- 32.2 The Supplier shall provide the Purchaser with a report of the results of any such test.
- 32.3 The Purchaser may engage external agents for the purpose of conducting inspection or pre-shipment inspection of Goods, provided that the Purchaser shall bear all of its costs and expenses.
- 32.4 The Purchaser or its designated representative as specified shall be entitled to attend the tests and/or inspections under GCC Clause 32.1, provided that the Purchaser shall bear all of its own costs and expenses incurred in connection with such attendance.
- 32.5 Whenever the Supplier is ready to carry out any such test and inspection, it shall give a reasonable advance notice, including the place and time, to the Purchaser. The Supplier shall obtain from any relevant third party or manufacturer any necessary permission or consent to enable the Purchaser or its designated representative to attend the test and/or inspection.

- 32.6 The Purchaser may require the Supplier to carry out any test and/or inspection not required by the Contract, but deemed necessary to verify that the characteristics and performance of the Goods comply with the technical specifications, codes and standards under the Contract, provided that the Supplier's reasonable costs and expenses incurred in the carrying out of such test and/or inspection shall be added to the Contract Price. Further, if such test and/or inspection impede the progress of manufacturing and/or the Supplier's performance of its other obligations under the Contract, due allowance will be made in respect of the Delivery Dates and Completion Dates and the other obligations so affected.
- 32.7 The Purchaser may reject any Goods or any part thereof that fail to pass any test and/or inspection or do not conform to the specifications. The Supplier shall either rectify or replace such rejected Goods or parts thereof or make alterations necessary to meet the specifications at no cost to the Purchaser, and shall repeat the test and/or inspection, at no cost to the Purchaser, upon giving a notice under GCC Sub-Clause 32.5.
- 32.8 The Supplier agrees that neither the execution of a test and/or inspection of the Goods or any part thereof, nor the attendance by the Purchaser or its representative, nor the issue of any report as stated under GCC Sub-Clause 32.2, shall relieve the Supplier from any warranties or other obligations under the Contract.

### **33. Warranty**

- 33.1 The Supplier warrants that all the Goods supplied under the Contract are new, unused, and of the most recent or current models, and that they incorporate all recent improvements in design and materials, except when the design and/or material required by the Purchaser provides otherwise under GCC Clause 19.
- 33.2 The Supplier further warrants that the all Goods supplied under this Contract shall have no defect, arising from design, materials, or workmanship or from any act or omission of the Supplier that may develop under normal use of the supplied Goods in the conditions prevailing in Bangladesh.
- 33.3 In order to assure that manufacturing defects shall be corrected by the Supplier, manufacturer, or distributor, as the case may be, a warranty shall be required from the Supplier for a minimum period of three (3) months in the case of supplies, and one (1) year in the case of equipment, or other such period as may be specified in the PCC, after the Goods, or any portion thereof as the case may be, have been delivered to and accepted in the form of an Acceptance Certificate as indicated in the GCC Clause 24.1 at the final destination indicated in the PCC
- 33.4 The warranty periods may vary among the various items and lots. The warranty for Goods delivered ahead will lapse earlier than the succeeding deliveries.
- 33.5 The Purchaser shall promptly notify the Supplier in writing of any claims arising under this warranty.
- 33.6 Upon receipt of such notice, the Supplier shall, within the period specified in the PCC, expeditiously repair or replace the defective Goods or parts thereof, at no cost to the Purchaser.
- 33.7 If the Supplier, having been notified, fails to remedy the defect(s) within the period as stated under GCC Sub Clause 33.6, the Purchaser may



proceed to call upon the Performance security without prejudice to any other rights which the Purchaser may have against the Supplier under the Contract and under the applicable law.

- 33.8 Performance Security under GCC Clause no 30 shall only be released after the lapse of the warranty period, provided that the goods supplied are free from patent and latent defects and all the conditions imposed under the contract have been fully met.
- (a) A patent defect, which is one that is apparent to the buyer on normal observation. It is an apparent or obvious defect.
    - i. For example, a ball pen that does not write is patently defective.
  - (b) A latent defect, which is one that is not apparent to the buyer by reasonable observation. A latent defect is “hidden” or one that is not immediately determinable.
    - i. For example, a ball pen that writes .75 kilometers instead of the expected 1.5 kilometers, has a latent defect.

**34. Delays in Delivery and Extensions of Time**

- 34.1 The Supplier must deliver the Goods or perform the services procured within the period prescribed by the Purchaser, as specified in the Contract.
- 34.2 If at any time during performance of the Contract, the Supplier or its subcontractors should encounter conditions impeding timely delivery of the Goods or completion of Related Services as stated under GCC Clause 23, the Supplier shall promptly notify the Purchaser in writing. It must state therein the cause/s and duration of the expected delay. The Purchaser shall decide whether and by how much to extend the time. In all cases, the request for extension should be submitted before the lapse of the original delivery date.
- 34.3 Within twenty-one (21) days of receipt of the Supplier’s notice, the Purchaser shall evaluate the situation and may grant time extensions, if based on justifiable grounds, without liquidated damages.
- 34.4 The Procuring may extend up to twenty percent (20%) of the original contract time, above 20% of the original contract time approval of Head of Purchaser (HOPE) shall be required, in which case the extension shall be ratified by the Parties by amendment of the Contract as stated under GCC Clause 46.
- 34.5 Except in the case of Force Majeure, as provided under GCC Clause 38, a delay by the Supplier in the performance of its Delivery and Completion obligations shall render the Supplier liable to the imposition of liquidated damages as stated under GCC Clause 35, unless an extension of time is agreed upon, under GCC Sub-Clause 34.3.

**35. Liquidated Damages**

- 35.1 Subject to GCC Clause 34 and 38, if the , if the Supplier fails to deliver any or all of the Goods by the Date(s) of delivery and/or perform the Related Services within the period specified in the Contract as stated under GCC Clause 23, the Purchaser shall, without prejudice to all its other remedies under the Contract, deduct from the Contract Price, as liquidated damages, a sum equivalent to the percentage specified in the PCC of the Contract price of the delayed Goods or unperformed / Related Services for each week or part thereof of delay until actual delivery or performance, up to a maximum deduction of the percentage specified in those PCC. Once the maximum is reached, the Purchaser may terminate

the Contract as stated under GCC Clause 42.

- 36. Limitation of Liability**      36.1 Except in cases of criminal negligence or wilful misconduct, and in the case of infringement of patent and intellectual property rights, if applicable, the Supplier shall not be liable to the Purchaser, whether in contract, tort, or otherwise, for any indirect or consequential loss or damage, loss of use, loss of production, or loss of profits or interest costs, the aggregate liability of the Supplier to the Purchaser shall not exceed the total Contract Price, provided that this limitation shall not apply, to the cost of repairing or replacing defective equipment or, to any obligation of the Supplier to pay liquidated damages to the Purchaser.
- 37. Change in Laws and Regulations**      37.1 Unless otherwise specified in the Contract, if after the Contract, any law, regulation, ordinance, order or bylaw having the force of law is enacted, promulgated, abrogated, or changed in Bangladesh (which shall be deemed to include any change in interpretation or application by the competent authorities) that subsequently affects the Delivery Date and/or the Contract Price, then such Delivery Date and/or Contract Price shall be correspondingly increased or decreased, to the extent that the Supplier has thereby been affected in the performance of any of its obligations under the Contract.
- 38. Definition of Force Majeure**      38.1 In this Clause, "Force Majeure" means an exceptional event or circumstance:
- (a) which is beyond a Party's control;
  - (b) which such Party could not reasonably have provided against before entering into the Contract;
  - (c) which, having arisen, such Party could not reasonably have avoided or overcome; and
  - (d) which is not substantially attributable to the other Party.
- 38.2 Force Majeure may include, but is not limited to, exceptional events or circumstances of the kind listed below, so long as conditions (a) to (d) above are satisfied:
- (i) war, hostilities (whether war be declared or not), invasion, act of foreign enemies;
  - (ii) rebellion, terrorism, sabotage by persons other than the Contractor's Personnel, revolution, insurrection, military or usurped power, or civil war;
  - (iii) riot, commotion, disorder, strike or lockout by persons other than the Contractor's Personnel;
  - (iv) munitions of war, explosive materials, ionising radiation or contamination by radio-activity, except as may be attributable to the Contractor's use of such munitions, explosives, radiation or radio-activity, and
  - (v) natural catastrophes such as cyclone, hurricane, typhoon, tsunami, storm surge, floods, earthquake, landslides, fires, epidemics, quarantine restrictions, or volcanic activity;
  - (vi) freight embargoes;
  - (vii) acts of the Government in its sovereign capacity.



- 39. Notice of Force Majeure**
- 39.1 If a Party is or will be prevented from performing its substantial obligations under the Contract by Force Majeure, then it shall give notice to the other Party of the event or circumstances constituting the Force Majeure and shall specify the obligations, the performance of which is or will be prevented. The notice shall be given within 14 days after the Party became aware, or should have become aware, of the relevant event or circumstance constituting Force Majeure.
- 39.2 The Party shall, having given notice, be excused performance of its obligations for so long as such Force Majeure prevents it from performing them.
- 39.3 Notwithstanding any other provision of this Clause, Force Majeure shall not apply to obligations of either Party to make payments to the other Party under the Contract.
- 40. Duty to Minimise Delay**
- 40.1 Each Party shall at all times use all reasonable endeavours to minimise any delay in the performance of the Contract as a result of Force Majeure.
- 40.2 A Party shall give notice to the other Party when it ceases to be affected by the Force Majeure.
- 41. Consequences of Force Majeure**
- 41.1 The Supplier shall not be liable for forfeiture of its Performance Security, liquidated damages, or termination for default if and to the extent that its delay in performance or other failure to perform its obligations under the Contract is the result of an event of Force Majeure.
- 41.2 The Purchaser may suspend the delivery or contract implementation, wholly or partly, by written order for a certain period of time, as it deems necessary due to force majeure as defined in the contract.
- 41.3 Delivery made either upon the lifting or the expiration of the suspension order. However, if the Purchaser terminates the contract as stated under GCC clause 42, resumption of delivery cannot be done.
- 41.4 Head of Purchaser determines the existence of a force majeure that will be basis of the issuance of suspension of order.
- 41.5 Adjustments in the delivery or contract schedule and/or contract price, Including any need to modify contract under GCC Clause 46.
- 42. Termination for Default**
- 42.1 The Purchaser shall terminate this Contract for default when any of the following conditions attends its implementation:
- (a) Outside of force majeure, the Supplier fails to deliver or perform any or all of the GOODS within the period(s) specified in the contract, or within any extension thereof granted by the Purchaser pursuant to a request made by the Supplier prior to the delay;
- (b) As a result of force majeure, the Supplier is unable to deliver or perform any or all of the GOODS, amounting to at least ten percent (10%) of the contract price, for a period of not less than sixty (60) calendar days after receipt of the notice from the Purchaser stating that the circumstance of force majeure is deemed to have ceased; or

- (c) The Supplier fails to perform any other obligation under the Contract;
  - (d) If the Supplier, in the judgment of the Purchaser has engaged in corrupt, fraudulent, collusive or coercive practices, as stated under GCC Clause 3, in competing for or in executing the Contract;
  - (e) When deductible amount due to liquidated damage reaches its maximum as stated under GCC Clause 35.
- 42.2 Termination of a contract for default is without prejudice to other remedies available to the Purchaser for breach of contract, such as payment of liquidated and other damages, if there are grounds for the latter.
- 42.3 In the event the Purchaser terminates the Contract in whole or in part, as stated under GCC Clause 42.1, the Purchaser may procure, upon such terms and in such manner as it deems appropriate, Goods or Related Services similar to those undelivered or not performed, and the Supplier shall be liable to the Purchaser for any additional costs for such similar Goods or Related Services. However, the Supplier shall continue performance of the Contract to the extent not terminated.
- 42.4 In the event as stated under GCC Clause 42.1(d),the Purchaser shall,
- (a) terminate the Supplier's employment under the Contract and cancel the contract, after giving 14 days notice to the Supplier and the provisions of Clause 42 shall apply as if such expulsion had been made under Sub-Clause 42.1
  - (b) declare, at its discretion, the concerned Person to be ineligible to participate in further Procurement proceedings, either indefinitely or for a specific period of time.
- 43. Termination for insolvency**      43.1 The Purchaser shall terminate this Contract if the Supplier is declared bankrupt or insolvent as determined with finality by a court of competent jurisdiction. In this event, termination will be without compensation to the Supplier, provided that such termination will not prejudice or affect any right of action or remedy which has accrued or will accrue thereafter to the Purchaser and/or the Supplier.
- 44. Termination for Convenience**      44.1 The Purchaser, by written notice sent to the supplier, may terminate this Contract, in whole or in part, at any time for its convenience. The notice of termination shall specify that the termination is for the Purchaser's convenience, the extent to which performance of the supplier under the contract is terminated, and the date upon which such termination becomes effective.

44.2 Any of the following circumstances may constitute sufficient grounds to terminate a contract for conveniences :

- (a) If Physical and economic conditions have significantly changed so as to render the contract no longer economically, financially or technically feasible, as determined by the Head of Purchaser;
- (b) The Head of Purchaser has determined the existences of conditions that make contract implementation impractical and/or unnecessary, such as, but not limited to , fortuitous event/s, change in laws and government policies;
- (c) Funding for the contract has been withheld or reduced;
- (d) Any circumstances analogous to the foregoing.

44.3 The GOODS that have been delivered and/or performed or are ready for delivery or performance within thirty (30) calendar days after the Supplier's receipt of Notice to Terminate shall be accepted by the Purchaser at the contract terms and prices. For GOODS not yet performed and/or ready for delivery, the Purchaser may elect:

- (a) to have any portion delivered and/or performed and paid at the contract terms and prices; and/or
- (b) to cancel the remainder and pay to the Supplier an agreed amount for partially completed and/or performed goods and for materials and parts previously procured by the Supplier.

**45. Procedures for Termination of Contracts**

45.1 The following provisions shall govern the procedures for termination of this Contract as stated under GCC Clauses 42,43 and 44:

- (a) Upon receipt of a written report of acts or causes which may constitute ground(s) for termination as aforementioned, or upon its own initiative, the Purchaser shall, within a period of seven (7) calendar days, verify the existence of such ground(s) and cause the execution of a Verified Report, with all relevant evidence attached;
- (b) Upon recommendation by the Purchaser, the Head of the Purchaser shall terminate this Contract only by a written notice to the Supplier conveying the termination of this Contract. The notice shall state:
  - i. that this Contract is being terminated for any of the ground(s) afore-mentioned, and a statement of the acts that constitute the ground(s) constituting the same;
  - ii. the extent of termination, whether in whole or in part;
  - iii. an instruction to the Supplier to show cause as to why this Contract should not be terminated; and
  - iv. special instructions of the Purchaser, if any.
- (c) The Notice to Terminate shall be accompanied by a copy of the Verified Report;
- (d) Within a period of seven (7) calendar days from receipt of the Notice of Termination, the Supplier shall submit to the Head of the Purchaser a verified position paper stating why this Contract

should not be terminated. If the Supplier fails to show cause after the lapse of the seven (7) day period, either by inaction or by default, the Head of the Purchaser shall issue an order terminating this Contract;

- (e) The Purchaser may, at anytime before receipt of the Supplier's verified position paper, withdraw the Notice to Terminate if it is determined that certain items or works subject of the notice had been completed, delivered, or performed before the Supplier's receipt of the notice;
- (f) Within a non-extendible period of ten (10) calendar days from receipt of the verified position paper, the Head of the Purchaser shall decide whether or not to terminate this Contract. It shall serve a written notice to the Supplier of its decision and, unless otherwise provided, this Contract is deemed terminated from receipt of the Supplier of the notice of decision. The termination shall only be based on the ground(s) stated in the Notice to Terminate; and
- (g) The Head of the Purchaser may create a Contract Termination Review Committee (CTRC) to assist him in the discharge of this function. All decisions recommended by the CTRC shall be subject to the approval of the Head of the Purchaser.

**46. Contract  
Amendment**

- 46.1 Subject to applicable laws, no variation in or modification of the terms of this Contract shall be made except by written amendment signed by the parties.
- i) 46.2 The Purchaser, in accordance with their Delegation of Financial Powers, as required, may amend the Contract to reflect the changes introduced to the Original terms and Conditions of the Contract.

**47. Settlement of  
Disputes**

- 47.1 Amicable Settlement:
  - (a) The Purchaser and the Supplier shall use their best efforts to settle amicably all disputes arising out of or in connection with this Contract or its interpretation.
- 47.2 Adjudication
  - (a) If the Supplier /Purchaser believe that amicable settlement of dispute is not possible between the two parties, the dispute shall be refereed to the Adjudicator within fourteen (14) days of first written correspondence on the matter of disagreement;
  - (b) The Adjudicator named in the PCC is jointly appointed by the parties. In case of disagreement between the parties, the Appointing Authority designated in the PCC shall appoint the Adjudicator within fourteen (14) days of receipt of a request from either party;
  - (c) The Adjudicator shall give its decision in writing to both parties within twenty-eight (28) days of a dispute being referred to it;
  - (d) The supplier shall make all payments (fees and reimbursable expenses) to the Adjudicator, and the Purchaser shall reimburse half of these fees through the regular progress payments;

- (e) Should the Adjudicator resign or die, or should the Purchaser and the Supplier agree that the Adjudicator is not functioning in accordance with the provisions of the Contract; a new Adjudicator will be jointly appointed by the Purchaser and the Supplier. In case of disagreement between the Purchaser and the Supplier the Adjudicator shall be designated by the Appointing Authority designated in the PCC at the request of either party, within fourteen (14) days of receipt of a request from either party.

#### 47.3 Arbitration

- (a) If the Parties are unable to reach a settlement under GCC Clause 47.1(a) within twenty-eight (28) days of the first written correspondence on the matter of disagreement, then either Party may give notice to the other party of its intention to commence arbitration in accordance with GCC Sub-Clause 47.3(b);
- (b) The arbitration shall be conducted in accordance with the rules of procedure specified in the PCC.

## Section 4. Particular Conditions of Contract

<i>Instructions for completing the Particular Conditions of Contract are provided, as needed, in the notes in italics mentioned for the relevant GCC clauses.</i>	
GCC Clause	Amendments of, and Supplements to, Clauses in the General Conditions of Contract
GCC 1.1(j)	<p>The Procuring Entity/Purchaser is Bangladesh Power Development Board (BPDB),</p> <p style="text-align: center;">Representative</p> <p>Director, Directorate of Purchase, BPDB, WAPDA Building (9th floor), Motijheel C/A, Dhaka-1000. Phone: +88 02 223383081.</p> <p style="text-align: center;">Consignee</p> <p>Director, Directorate of Electrical Equipment, BPDB, Bidhut Bhaban (4th Floor), 1 Abdul Gani Road, Dhaka-1000. Phone: +88 02 223380509</p> <p style="text-align: center;">Engineer</p> <p>Director, Directorate of Design &amp; Inspection-II, 9/B, Motijheel C/A, Dhaka-1000. Phone: +88 02 223383613.</p>
GCC 1.1(o)	The site(s)/ point(s) of delivery is Central Store, BPDB, at Tongi, Gazipur.
GCC 5.1(i)	<p>The following documents shall also be part of the Contract:</p> <p>Acceptance of NOA, Performance Security and All Correspondences between purchaser and Supplier prior to signing of the contract</p>
GCC 11.1	<p>For <u>notices</u>, the Purchaser's contact details shall be:</p> <p>Attention: Director, Directorate of Purchase, BPDB, Dhaka.</p> <p>Address: WAPDA Building (9th floor), Motijheel C/A, Dhaka-1000, Bangladesh</p> <p>Telephone: +88 02 223383081.</p> <hr/> <p>For <u>notices</u>, the Supplier's contact details shall be:</p> <p>Attention:</p> <p>Address:</p> <p>Telephone:</p> <p>Facsimile number:</p> <p>Electronic mail address:</p>
GCC 18.1	<p>The scope of Supply shall be defined in:</p> <p>As specified in section 6, Schedule of Requirements. and section 7: Technical specification</p>

GCC 22.2	<p>The packing, marking and documentation inside and outside the packages shall be:</p> <p>A complete packing list indicating the content of each package shall be enclosed in a waterproof envelop and shall be secured to the outside of the packing case. In addition, each package shall be marked with indelible ink/paint in bold letters, as follows :</p> <p>Name and address of Procuring Entity</p> <p>Name of the Supplier</p> <p>Contract Description</p> <p>Final Destination/Delivery Point</p> <p>Gross weight</p> <p>Package number of total number of packages</p> <p>Brief description of the content</p> <p>Any special lifting instructions</p> <p>Any special handling instructions</p> <p>Upright markings, where appropriate, shall be placed on all four vertical sides of the package.</p> <p>All material used for packing shall be environmentally neutral.</p> <p>Additional markings and documentation within and outside the packages shall be :</p> <ol style="list-style-type: none"> <li>1) The Supplier shall provide such packing of the goods as is required to prevent their damage or deterioration during transit to their final destination as indicated in the Contract. The packing shall be sufficient to withstand, without limitation, rough handling during transit and exposure to extreme temperatures, salt and precipitation during transit and open storage. Packing case size and weights, shall take into consideration, where appropriate, the remoteness of final destination of the supply and the absence of heavy handling facilities at all points in transit.</li> <li>2) The packing, marking and documentation within and outside the packages shall comply strictly with such special requirements as shall be expressly provided for in the Contract and in any subsequent instructions ordered by the Purchaser.</li> <li>3) The supplier shall provide such crate for shipment of goods as to protect the equipment and materials.</li> <li>4) Delivery of the goods shall be made by the Supplier in accordance with the terms and conditions of the contract and the goods shall remain at the risk of the Supplier until delivery has been completed. Delivery shall be considered to have been completed when the last consignment to be delivered are accepted and taken over by the Purchaser at the final destination. All transportation, insurance and other costs incurred in delivering the goods to the final destination shall be entered in the Tenderer's price schedule.</li> <li>5) The Supplier warrants that the goods supplied under the Contract are new and unused of the most recent or current models and incorporate all recent improvements in design and materials unless provided otherwise in the Contract.</li> <li>6) The Supplier further warrants that all goods supplied under this Contract shall have no defect arising from design, materials or workmanship (except in so far</li> </ol>
----------	--


	<p>as the design or material is required by the Purchaser's Specifications) or from any act or omission of the Supplier, that may develop under normal use of the Supplied Goods in the conditions obtaining in the country of final destination.</p> <p>7) No goods should be shipped, without prior instruction from the Engineer /Purchaser. In cases, where the goods have been passed inspection but the Contractor from the Engineer/Purchaser has not received the instruction of delivery within one month from the date of inspection, the contractor may proceed with the shipment. In case of ex-factory basis delivery for domestic goods, the purchaser shall arrange to lift the goods from the specified place of the factory/warehouse within 30 (thirty) days after the date of inspection/ acceptance certificate issued by the Purchaser.</p> <p>8) All air cargoes destined for the site shall be landed at Hazrat Shahjalal International airport of Dhaka as specified in Tender Document.</p> <p>9) Any items liable to be damaged in transit shall be effectively protected and securely fixed in their cases. All lists of over 1(one) ton shall be marked to show where slings should be placed.</p> <p>10) The Supplier shall give complete shipping information concerning the weight, size, content of each package including any other information the Purchaser or the Engineer may require.</p> <p>11) All materials used in packing are to comply with the relevant Bangladesh regulations. Adequate protection and precautions are to be taken to exclude termites or other vermin, noxious insects, larva or fungus from the packing materials or plant. All contents are to be clearly marked for easy identification against the packing list.</p> <p>12) All galvanized ferrous materials shall, in any case, not be touched with water and shall not be handled with any chemical products during transportation to prevent the corrosive effect to the galvanized surface.</p> <p>13) The Supplier shall pack and crate all goods for export to a tropical, humid climate and for ocean transport and in accordance with internationally accepted export practice and such a manner as to protect it from damage and deterioration in transit by truck, rail and sea. The Supplier shall be held responsible for and make good any and all damages costs involved due to improper and inadequate packing. Each box or other unit of shipment shall be eligible and properly marked in addition to the usual Supplier's marking code. Detailed instructions for marking shown are given in tender document and such marking shall be written either on the box itself or on a metallic tag for drums, steel section etc. strongly attached to the Equipment.</p> <p>14) Two bands red and green, each 25 mm ( 1 inch ) wide or combined width not exceeding one- quarter the length of the package shall be painted around the package as shown in figure.</p> <p>15) The following monogram, measuring about one quarter of the side of the package shall also be painted in red on at least two sides of the package.</p> <p style="text-align: center;">BANGLADESH POWER DEVELOPMENT BOARD</p> <p>16) All equipment is to be packaged in bundles and labeled for the appropriate town according to the list that will be provided to the successful bidder for each lot. Any items liable to be damaged in transit shall be effectively protected and securely fixed in their cases. All lifts of over 2 tones shall be</p>
--	---



	<p>marked to show where slings should be placed.</p> <p>All identification marks on the outside of cases are to be waterproof and permanent and as shown in Figures.</p> <p>17) All delicate electrical equipment shall be adequately sealed and desiccating agents used where necessary to prevent damage from condensation. All equipment shall be packed and protected bearing in mind that it will be shipped to a tropical zone and that a considerable period may elapse between its arrival on site and its unpacking.</p> <p>18) Underground cables and overhead conductors shall be delivered wound on strong Aluminium or wooden drums. Drums with an outside diameter not exceeding 2.5 meters and an outside width exceeding 1.4 meters shall not be used except with the Engineers approval. The central hole of the drums shall be reinforced to fit an axle size 95mm diameter. The interior of the conductor drums shall be lined with bituminous paper to prevent the conductor from being in contact with the Aluminium or timber. Waterproof paper and felt lining shall overlap at seams by at least 20mm and the seams shall be sealed.</p> <p>19) Drums shall be adequately protected by securely fastening substantial wooden battens around the periphery. These battens shall be secured by means of hoop metal bindings to approval.</p> <p>20) Cables and conductors shall be securely fastened around the periphery of the drum. Cables shall be supplied with both ends properly capped and protected against damage. Each drum and one of each cable length shall bear a metal label detailing manufacturers name, specified voltage and type of conductor. Cables drums shall be treated in an approved manner to resist termite and fungus attacks and shall be suitable for outside storage for a minimum period of five years in an equatorial climate without undue deterioration. The leading end of cable on cable drums shall be the 'A' end as defined in BS 6480.</p> <p>21) The inner cable end attached to the drum shall be capped and sealed in such a manner that core screening and sheath are able to be measured from the outer cable and without removing the inner end cap. The thread of bolts used to strengthen the cable drums shall be pinned in such a way that the nut can be lightened but cannot be readily removed.</p> <p>22) Other electrical equipment items shall be packed for transport to site so that they are protected against the climatic conditions and handling to which they may be subjected in transit and in storage at the site. They shall be enclosed in planked wooden boxes with hoop metal bindings with ends sealed. Bindings shall be of rust less material.</p> <p>23) The Supplier shall pack and crate all Equipment for export to a tropical, humid climate and for ocean transport and in accordance with internationally accepted export practice and in such a manner as to protect it from damage and deterioration in transit by truck, rail and sea. The Supplier shall be held responsible for and make good any and all damages costs involved due to improper and inadequate packing.</p> <p>24) Each box or other unit of shipment shall be legible and properly marked in addition to the usual Suppliers marking code. Detailed instructions for marking as shown in Figure shall be written either on the box itself or on a metallic tag for drums, steel section etc, strongly attached to the Equipment.</p> <p>25) Contents of cases are to be bolted securely or fastened in position with</p>
--	--

struts or cross battens and not with wooden chocks wedged in place unless otherwise firmly fastened. All struts or cross battens are preferably to be supported by cleats fixed to the case, above and below, to form edges on which the batten may rest. Open cases shall not be used. Where parts are required to be bolted to the sides of the case, large washers are to be used to distribute the pressure and the timber is to be strengthened by means of a pad.

- 26) All cases shall be clearly identified giving particulars of manufacturers name and type of equipment.



GCC 23.2

Details of shipping and documents to be furnished by the Supplier shall be:

Upon shipment of goods, the Supplier shall notify the Purchaser and the Insurance Company by Cable or fax or telex: the full details of the shipment including Contract number, description of Goods, quantity, the bill of landing number and date, port of loading, date of shipment, port of discharge, etc. The Supplier shall mail the following documents to the Purchaser, with a copy to the Insurance Company: as applicable:

- i) Copies of the Supplier's invoice showing goods description, quantity, unit price, total amount.
  - ii) 1(one) original and 8 (eight) copies of the negotiable, clean, on-board bill of lading marked freight prepaid and 8 (eight) copies of non-negotiable bill of lading, where applicable.
  - iii) 8 (Eight) copies of packing list identifying contents of each package;
  - iv) Insurance certificate;
  - v) Certificate of origin;
  - vi) Manufacturer's/supplier's warranty certificate;
  - vii) Inspection certificate, issued by the nominated inspection agency (or Purchaser's Inspection Team) and/or the Supplier's factory inspection report (if any);
  - viii) Shipping advice issued by the Purchaser;
  - ix) Freight Memo/Truck Challan;
- 3) The Purchaser shall receive the above documents at least one week before arrival of Goods at the port and, if not received, the Supplier will be responsible for any consequent expenses.
- 4) The negotiable sets of documents shall be originals signed by the Supplier. The Commercial Invoice is to show material value plus freight as applicable.

Shipping Documents:

The Purchaser shall receive the shipping documents at the latest one-week before arrival of cargoes at the airport of Dhaka or any sea/ land port of entry in Bangladesh.

The shipping documents shall be supplied to as follows:

1	Director, Purchase, BPDB, WAPDA Building, Motijheel C/A., Dhaka 1000	2 (Two) sets
2	Director, Finance, Biddut Bhaban (7 <sup>th</sup> Floor)1, Abdul Gani Road, Dhaka-1000	2 (Two) sets
3	Director, Clearance & Movement, BPDB, Chittagong/Dhaka	2 (Two) sets
4	Deputy Director, Clearance & Movement BPDB, Chittagong/Dhaka /Khulna	1 (one) set
5	Dy. Director, Insurance, BPDB, Dhaka	1 (one) set

No goods should be shipped or delivered without prior instruction (shipping advice) from the Purchaser.

	<p>For Goods from within the Purchaser's country as per INCOTERM EXW:</p> <p>Upon delivery of the Goods to the transporter, the Supplier shall notify the Purchaser and send the following documents to the Purchaser:</p> <ul style="list-style-type: none"> <li>(a) 8 copies of the Supplier's invoice showing the description of the Goods, quantity, unit price, and total amount;</li> <li>(b) delivery note, railway receipt, or truck receipt;</li> <li>(c) Manufacturer's or Supplier's warranty certificate;</li> <li>(d) inspection certificate issued by the nominated inspection agency, and the Supplier's factory inspection report; and</li> <li>(e) certificate of origin.</li> </ul> <p>The Purchaser, shall receive the above documents before the arrival of the Goods and, if not received, the Supplier will be responsible for any consequent expenses.</p>
GCC 24.3 (New Clause)	ACCEPTANCE CERTIFICATE will be issued within fourteen (14) days after successfully completion of Post Landing Inspection, Satisfactory R&I Report and Successfully completion of related service (if any).
GCC 25.1	The Contract Price is .....
GCC 25.3	For Goods manufactured outside Bangladesh and to be imported, customs duties, import VAT and other import taxes levied on the imported Goods will be paid by Purchaser. Hence contract price will not include these costs.
GCC 26.2	Responsibility of the Purchaser and Supplier is: Marine Insurance as well as Local Insurance cost shall be paid by BPDB. Hence these cost shall not be included in the contract price.
GCC 27.1	<p>(a) Payment of foreign currency portion shall be made through Letter of Credit (L/C) opened in favor of the Supplier in a schedule Bank of Bangladesh.</p> <p>(b) Payment of Local currency portion shall be made direct through CP &amp; AA Cell, BPDB, Dhaka.</p> <p>1. Payment for Goods supplied from abroad (Form PG4-3B):</p> <ul style="list-style-type: none"> <li>i) Advance Payment : Not Applicable</li> <li>ii) On Shipment: Seventy (70) percent of the foreign currency Price of the Goods shipped shall be paid through letter of credit opened in favour of the Supplier in a bank in its country, upon submission of documents specified in GCC Clause 23. and issuance of payment advice by the Director, Purchase, BPDB</li> <li>iii) On Acceptance: Thirty (30) percent of the foreign currency price of Goods received shall be paid upon receipt of the goods within thirty (30) days of submission of claim bill duly verified by Consignee, certified by Engineer and payment certified by the Director, Purchase, BPDB supported by the Acceptance Certificate issued by the Director, Purchase, BPDB specified in GCC Clause 24.</li> </ul> <ul style="list-style-type: none"> <li>a) Partial Shipment is allowed. For a Tender (or for a lot of Tender), if contract is signed for a single item (as per price schedule), then only partial payment against On Shipment is allowed for shipment/ supply of partial quantities. Otherwise, partial payment is not allowed.</li> <li>b) Transshipments allowed as and when/where required as per prior approval of the procuring entity.</li> <li>c) Third Party B/L shall be allowed as and when/where required as per</li> </ul>

	<p>prior approval of the procuring entity.</p> <p>100% (hundred) percent Payment of local currency portion shall be made in Bangladesh Taka within thirty (30) days of presentation of claim bill duly certified by Director, Purchase, BPDB supported by Acceptance Certificate declaring that the Goods have been delivered and that all other contracted Related Services have been performed.</p>
	<p><b>2.</b> Payment for Goods manufactured outside Bangladesh, already imported(PG4-3C) , Payment for Goods manufactured in Bangladesh (PG4-3A) and Payment for Services (PG4-3D):</p> <p>i) Advance Payment : Not Applicable</p> <p>ii) On Delivery and Acceptance: Hundred (100%) percent of the Contract Price of the Goods delivered shall be paid within thirty (30) days of submission of documents specified in GCC Clause 23.2 supported by the Acceptance Certificate issued by the Director, Purchase, BPDB as per GCC Clause 24.</p> <p><b>BANKING CHARGES:</b></p> <p>a) Letter of Credit opening and other charges including amendment charges within Bangladesh shall be borne by BPDB and those outside Bangladesh shall be borne by the supplier.</p> <p>b) The supplier shall have to bear all such charges both inside and outside Bangladesh in case of extension of L/C if done at the request of the supplier.</p>
GCC 27.3	<p>Payments shall be made in no case later than the 60(sixty) days after submission of an invoice or request for payment by the Supplier, and after the Purchaser has accepted it.</p>
GCC 27.5	<p>The payment-delay period after which the Purchaser shall pay interest to the supplier shall be [ Nil ] days. : Not Allowed</p>
GCC 28.2	<p>The Contractor / supplier shall secure and maintain throughout the duration of the contract insurance of such types and in such amounts as may be necessary to protect himself and the interest of BPDB/ Purchaser against hazards of risk or loss at BPDB'S cost.</p>

GCC 28.2	<p>Failure of the Contractor/ supplier to maintain such coverage shall not relieve him of any contractual responsibility or obligations for transportation and ocean cargo insurance from port of loading to port of unloading and from warehouse to warehouse in Bangladesh. As Marine insurance as well as Local Insurance shall be from M/S. Sadharan Bima Corporation, 139, Motijheel Commercial Area, Dhaka, Bangladesh and the cost shall be paid by BPDB/Purchaser, the supplier shall promptly furnish 2(two) sets of shipping documents i.e. copies of Bill of Lading / Air way Bill, invoice, Packing list etc, of each and every consignment for insurance purpose directly to the Deputy Director, Finance (Insurance), Bangladesh Power Development Board, Abdul Ghani Road, Dhaka, Bangladesh indicating the Purchase order/ contract No. and date insurance cover note (open Policy) number, Bill of lading and invoice No. and date, invoice C&amp;F value, name of Port loading and unloading, name of goods with number of cases/ packages name of vessel with present age, flag of vessel and type of cargo, well ahead or immediately after shipment to the Consignee for payment of insurance charge by BPDB.</p> <p>If the Contractor /supplier fail to comply with these instructions they shall be held fully responsible for any loss or damage arising out of the non-compliance of these contract conditions.</p> <p>Shipment of goods in any chartered vessel over 15(fifteen) years of age and shipment of goods in the Deck are prohibited.</p>
GCC 29.2	<p>a) Bangladesh Income tax and VAT for Income Earned in Bangladesh</p> <p>i) The Supplier shall be entirely liable to pay Income Tax on Contract price both Foreign &amp; Local Currency (including CFR price) at the prevailing rule of the Government of Bangladesh. Such Income Tax will be deducted at source from the Contractor's invoice/bill during payment as per Income Tax Ordinance- 1984.</p> <p>ii) The Supplier shall not be responsible for payment of applicable Value Added Tax (VAT) on the imported permanent materials and equipment's (i.e. CFR portion) of the contract price. BPDB will pay the same VAT during clearing stage at the port. If any VAT applicable on CFR portion at payment stage, BPDB will adjust/pay that amount. But, the applicable VAT on the service portion of the contract price both foreign and local currency shall be paid by the supplier which will be deducted at source from the supplier's invoice/bill during payment.</p> <p>b) Foreign country Taxes and Permits The Supplier shall pay all sales, income and other taxes and duties, tariffs and imports that can be lawfully assessed against the supplier by the Government or any lawful authority of any country other than the people's Republic of Bangladesh which has jurisdiction over the Supplier in connection with this contract and shall pay for all licenses permits and inspection required for the supply including the cost or securing all export licenses and permits for materials, equipment, supplies and personnel exported from that country to Bangladesh.</p> <p>c) Import related duties, taxes, VAT, levies BPDB will be responsible for the payment of import related duties, taxes, VAT, levies and all sort of charges etc. to be liable by the port as well as other Govt. agencies inside Bangladesh for the goods to be imported in accordance with the specification. But BPDB shall not pay the custom duty on any replacement/ additional items.</p>

GCC 32.1

*The inspections and tests shall be :*

A. Witnessing of the manufacturing process and tests of the equipment at manufacturer's works including transfer of technical know-how.

During test, transfer of Technology and Technical know-how regarding spares, parameters and testing procedure including familiarization/ testing of equipments to BPDB Engineers is to be performed. The supplier shall bear the round air tickets, hotel accommodations, per diem allowances, internal transportations and out of this pocket expenses @ US\$ 100.00 per person per day for 07 days (excluding travel time) for the witnessing of manufacturing process and tests of concerned equipment at manufacturer's works. The number of such BPDB Engineers will be 3 (three) nos. Such witness/inspection shall not relieve the supplier from any obligation to supply the goods in accordance with contract document. For foreign manufacturer, Invitation letter from the manufacturer should be submitted to the purchaser at least 02(two) months prior to the schedule date of the witness and tests.

*For any reason, if Purchaser's/ Employer's representative(s) cannot attend above mentioned "Witnessing of the manufacturing process and tests of the Goods at manufacturer's works including transfer of technical know-how" program, a Third Party Inspection Company/Agency shall conduct/ witness Pre-shipment Inspections as well as Factory Acceptance Tests as per Contract and relevant standard at the manufacture's Premises with the concurrence of BPDB.*

The Third Party Inspector shall submit a comprehensive report to Purchaser with recommendation accompanied with photograph and video clips with date and time of the Equipment/ Materials/ Goods inspected within 7 days after completion of respective inspection/Test. After approval of Third Party Inspection report by BPDB, shipping advice shall be issued to Supplier/ Contractor. No Equipment/ Materials/ Goods shall be shipped without shipping advice.

The inspections/ Tests shall be performed on as-needed basis as per schedule provided by the respective manufacturers

Manufacturer/ Supplier/ Contractor shall bear cost pertaining to third party inspection team/BPDB's representative(s). Manufacturer/ Supplier/ Contractor shall facilitate and provide full support for the Pre-Shipment Inspection/Witnessing of Factory Acceptance Test and transfer of technical know-how to BPDB representative(s). The Manufacturer/ Supplier/ Contractor shall not claim any additional cost in this regard.

The third party inspection company/agency must not be involved in design, procurement, fabrication, construction and installation under this Contract.

BPDB will select any of the following companies/agencies as Third Party Inspector:

1. BUREAU VERITAS,
2. SGS,
3. Black and Veatch,
4. TUV SUD,
5. Lloyd Inspection Agency,
6. Mott MacDonald,
7. Intertek group,

With the approval of BPDB, Contractor/Supplier shall engage Third Party Inspection company/ agency. BPDB reserves the right to revise the above mentioned list.



	<p>Third party inspection is applicable for Equipment/ Materials/ Goods manufactured outside in Bangladesh.</p> <p>No goods/equipment/material shall be packed, prepared for shipment / delivery unless it has been approved including Test reports and written instruction has been issued by the Purchaser.</p> <p><i>B. RANDOM SAMPLE TEST DURING FACTORY INSPECTION AND WITNESS will be held (where required) will be held and detail description is provided in Section 7: Technical Specification.</i></p> <p>C. ACCEPTANCE REPORT OF GOODS FOR DELIVERY as per Section 7.</p> <p>D. POST-DELIVERY INSPECTION &amp; TESTING will be held in the following manner:</p> <p>a) Post Landing Inspection shall be done after arrival of the goods at Final destination. The post landing inspection shall be intimated to the representative of Supplier. The program of such inspection shall be intimated to the representative of contractor/supplier by BPDB upon arrival of the goods at Final destination store of BPDB. R&amp;I report will be issued after Post Landing Inspection.</p> <p>b) The purchaser has right to inspect, test and where necessary, reject the Goods arrival in purchaser's store shall in no way be limited or waived by reason of the goods having previously been tested and passed by the manufacturer/ supplier.</p> <p>c) Nothing in this clause shall in any way release the Supplier from any warranty or other obligation under provisions of the contract.</p> <p>d) Detail description is provided in Section 7: Technical Specification</p>
GCC 33.3	<p>The period of validity of the WARRANTY shall be 24(Twenty Four) months from the date of acceptance of Goods. During the warranty period, if any equipment/material is damaged and replaced by the Supplier, fresh warranty period for 24(Twenty Four) months shall be counted for the replaced equipment/material. Total warranty period shall not increase more than 48 (Forty Eight) months in any case.</p> <p>For the purpose of warranty, the place of final destination shall be: Central Store, BPDB, at Tongi, Gazipur as per instruction of Engineer.</p>
GCC 33.6	<p>The Supplier shall correct any defects covered by the Warranty within 90(Ninety) days of being notified by the Purchaser of the occurrence of such defects.</p>
GCC 35.1	<p>The applicable rate for liquidated damages for delay shall be: 0.5(zero point five) percent of the Contract Price of the delayed Goods or unperformed Related services for each week of delay until actual delivery or performance.</p> <p>All Goods and related services shall be considered as delayed and unperformed until the effective date of Acceptance Certificate. Hence Liquidated Damages for delay or Delay Damages until effective date of Acceptance Certificate shall be applicable on the final Contract Price.</p>
	<p>The maximum amount of liquidated damages shall be <i>Ten (10%) percent of the Contract Price.</i></p>



GCC 47.2(b)	<p>The name of the Adjudicator : shall be selected when necessary</p> <p>The name of the appointing authority of the Adjudicator: President, Institution of Engineers, Bangladesh (IEB)</p>
GCC 47.3(b)	<p>Any dispute, Controversy or claim arising out of or relating to this contract or breach, termination or invalidity thereof shall be settled by arbitration in accordance with Arbitration act (Act No 1 of 2001) of Bangladesh as at present in force.</p> <p>Arbitration shall be take place in Dhaka, Bangladesh.</p>
GCC 48 (New Clause)	<p>Submission &amp; Approval of Design, Drawing, Specification &amp; GTP/Engineering Data: Design, Drawing, Specification &amp; GTP/ Engineering Data etc, shall be submitted to the Engineer, Director, Design &amp; Inspection-II, BPDB by the Supplier for approval, prior to the manufacturing of the goods. The Supplier shall have to submit 3 (three) sets of the same for approval within 15 (fifteen) days from the date of signing Contract. Only Original copy shall be submitted (photocopy / scanned copy will not be allowed).</p> <p>One copy of Design, Drawing, Specification &amp; GTP/ Engineering Data shall be returned to the Supplier marked "APPROVED" or "APPROVED AS NOTED" or "RETURNED FOR CORRECTION" within 14 (Fourteen) days after receipt from the Supplier and if not returned within 14 (Fourteen) days after receipt by the Engineer, the Suppliers shall notify Engineer of such fact, and if the Design, Drawing, Specification &amp; GTP/ Engineering Data still have been not returned within 7(Seven) days after notice, the Supplier may proceed as if Design, Drawing, Specification &amp; GTP/ Engineering Data have been returned approved. When the Design, Drawing, Specification &amp; GTP/ Engineering Data are returned marked "APPROVED AS NOTED" or "RETURNED FOR CORRECTION" the corrections or changes shall be made and 3 (three) revised copies shall be submitted to the Engineer. One copy of the revised Design, Drawing, Specification &amp; GTP/ Engineering Data will be returned to the Supplier by 7(Seven) days from the receipt of the same with due approval, if re-submitted Design, Drawing, Specification &amp; GTP/ Engineering Data are in line with the earlier comments of the Engineer and satisfy contract specification.</p>

## Section 5. Tender and Contract Forms

Form	Title
	i. Tender Forms
PG4 – 1	Tender Submission Letter
PG4 – 2	Tenderer Information Sheet
PG4 – 3A,3B & 3C	Price Schedule for Goods
PG4 – 3D	Price Schedule for Related Services
PG4 – 4	Specifications Submission and Compliance Sheet
PG4 – 5	Manufacturer’s Authorisation Letter
PG4 – 6	Bank Guarantee for Tender Security
PG4 – 6A	Bank’s Commitment for Line of Credit <i>(when this option is chosen)</i>
PG4-11	Deviation List
	ii. Contract Forms
PG4 – 7	Notification of Award
PG4 – 8	Contract Agreement
PG4 – 9	Bank Guarantee for Performance Security
PG4 – 10	Bank Guarantee for Advance Payment
PG4-12	Warranty Certificate

Forms PG4-1 to PG4-6, PG4-11 comprises part of the Tender and should be completed as stated in ITT Clause 21.

Forms PG4-7 to PG4-10, PG4-12 comprises part of the Contract as stated in GCC Clause 5.

## Tender Submission Letter (Form PG4 – 1A)

(To be submitted with technical Proposal)

*[This letter shall be completed and signed by the Authorised Signatory preferably on the Letter-Head pad of the Tenderer].*

To: <i>[Contact Person]</i> <i>[Name of Purchaser]</i> <i>[Address of Purchaser]</i>	Date:
Invitation for Tender No:	<i>[indicate IFT No]</i>
Tender Package No:	<i>[indicate Package No]</i>
Lot No:	<i>[indicate number of Lots]</i>

We, the undersigned, offer to supply in conformity with the Tender Document the following Goods and related Services:

In signing this letter, and in submitting our Tender, we also confirm that:

- a) our Tender shall be valid for the period stated in the Tender Data Sheet (ITT Sub-Clause 27.2) and it shall remain binding upon us and may be accepted at any time before the expiration of that period;
- b) a Tender Security is attached in the form of a *bank guarantee* in the amount stated in the Tender Data Sheet (ITT Clause 29) and valid for a period of 28 days beyond the Tender validity date;
- c) if our Tender is accepted, we commit to furnishing a Performance Security in the amount stated in the Tender Data Sheet (ITT Sub-Clause 63.2) in the form stated in Tender Data Sheet (ITT Sub-Clause 64.1) and valid for a period of 28 days beyond the date of completion of our performance obligations;
- d) we have examined and have no reservations to the Tender Document, issued by you on *[insert date]*;  
  
 including Addendum to Tender Documents No(s) *[state numbers]* ,issued in accordance with the Instructions to Tenderers (ITT Clause 11). *[insert the number and issuing date of each addendum; or delete this sentence if no Addendum have been issued]*;
- e) we, including as applicable, subcontractor for any part of the contract resulting from this Tender process, have nationalities from eligible countries, in accordance with ITT Sub-Clause 5.1;
- f) we are submitting this Tender as a sole Tenderer

- g) we are not a Government owned entity as defined in ITT Sub-Clause 5.3  
or  
we are a Government owned entity, and we meet the requirements of ITT Sub-Clause 5.3];  
(delete one of the above as appropriate)
- h) we, declare that we are not associated, nor have been associated in the past, directly or indirectly, with a consultant or any other entity that has prepared the design, specifications and other documents, in accordance with ITT Sub-Clause 5.5;
- i) we, including as applicable subcontractor have not been declared ineligible by the Government of Bangladesh on charges of engaging in corrupt, fraudulent, collusive or coercive practices, in accordance with ITT Sub-Clause 5.6;
- j) furthermore, we are aware of ITT Sub Clause 4.3 concerning such practices and pledge not to indulge in such practices in competing for or in executing the Contract;
- k) we intend to subcontract an activity or part of the Supply, in accordance with ITT Sub-Clause 16.1 to the following Subcontractor(s);

Nature of the Supply or related service	Name and address of Subcontractor

- l) we, confirm that we do not have a record of poor performance, such as abandoning the Supply, not properly completing contracts, inordinate delays, or financial failure as stated in ITT Sub-Clause 5.8, and that we do not have, or have had, any litigation against us, other than that stated in the Tenderer Information Sheet(Form PG4-2);
- m) we are not participating as Tenderers in more than one Tender in this Tendering process. We understand that your written Notification of Award shall become a binding Contract between us, until a formal Contract is prepared and executed;
- n) we understand that you reserve the right to accept or reject any Tender, to cancel the Tender proceedings, or to reject all Tenders, without incurring any liability to Tenderers, in accordance with ITT Clause 58.1.

Signature:

<i>[insert signature of authorised representative of the Tenderer]</i>
--

Name:

<i>[insert full name of signatory with National ID]</i>
---

In the capacity of:

<i>[insert designation of signatory]</i>
--

Duly authorised to sign the Tender for and on behalf of the Tenderer

*[If there is more than one (1) signatory add other boxes and sign accordingly].*

Attachment 1: Written confirmation authorising the above signatory(ies) to commit the Tenderer, in accordance with ITT Sub-Clause 34.3;

## Tender Submission Letter (Form PG4 – 1B)

(To be submitted with Financial Proposal)

*[This letter shall be completed and signed by the Authorised Signatory preferably on the Letter-Head pad of the Tenderer].*

To: <i>[Contact Person]</i> <i>[Name of Purchaser]</i> <i>[Address of Purchaser]</i>	Date:
Invitation for Tender No:	<i>[indicate IFT No]</i>
Tender Package No:	<i>[indicate Package No]</i>
Lot No:	<i>[indicate number of Lots]</i>

We, the undersigned, offer to supply in conformity with the Tender Document the following Goods and related Services:

In accordance with ITT Clauses 22 and 23, the following prices and discounts apply to our Tender:

The Tender Price is: *Taka [state amount in figures]*  
 (ITT Sub-Clause 23.1) *and Taka[state amount in words]*

Mandatory Spare parts Price *Taka [state amount in figures]*  
 (If economic Factor is applicable) *and Taka[state amount in words]*  
 (ITT Sub-Clause 52.2 (f) & 52.5 (b))

The unconditional discount for being awarded more than one lot in this package is: *Taka [state amount in figures]*  
*and Taka[state amount in words]*  
 (ITT Sub-Clause 23.8)

The methodology for Application of the discount is: *[state the methodology]*  
 (ITT Sub-Clause 23.9)

The advance payment is: *[state the amount based on percentage of the Tender Price]*  
 (GCC Sub-Clause 27.1)

and we shall accordingly submit an Advance Payment Guarantee in the format shown in Form PG4 - 10.

In signing this letter, and in submitting our Tender, we also confirm that:

- o) our Tender shall be valid for the period stated in the Tender Data Sheet (ITT Sub-Clause 27.2) and it shall remain binding upon us and may be accepted at any time before the expiration of that period;
- p) a Tender Security is attached in the form of a *bank guarantee* in the amount stated in the Tender Data Sheet (ITT Clause 29) and valid for a period of 28 days beyond the

Tender validity date;

q) if our Tender is accepted, we commit to furnishing a Performance Security in the amount stated in the Tender Data Sheet (ITT Sub-Clause 63.2) in the form stated in Tender Data Sheet (ITT Sub-Clause 64.1) and valid for a period of 28 days beyond the date of completion of our performance obligations;

r) we have examined and have no reservations to the Tender Document, issued by you on *[insert date]*;

including Addendum to Tender Documents No(s) *[state numbers]* ,issued in accordance with the Instructions to Tenderers (ITT Clause 11). *[insert the number and issuing date of each addendum; or delete this sentence if no Addendum have been issued]*;

s) we, including as applicable, subcontractor for any part of the contract resulting from this Tender process, have nationalities from eligible countries, in accordance with ITT Sub-Clause 5.1;

t) we are submitting this Tender as a sole Tenderer

u) we are not a Government owned entity as defined in ITT Sub-Clause 5.3

or

we are a Government owned entity, and we meet the requirements of ITT Sub-Clause 5.3];

*(delete one of the above as appropriate)*

v) we, declare that we are not associated, nor have been associated in the past, directly or indirectly, with a consultant or any other entity that has prepared the design, specifications and other documents, in accordance with ITT Sub-Clause 5.5;

w) we, including as applicable subcontractor have not been declared ineligible by the Government of Bangladesh on charges of engaging in corrupt, fraudulent, collusive or coercive practices, in accordance with ITT Sub-Clause 5.6;

x) furthermore, we are aware of ITT Sub Clause 4.3 concerning such practices and pledge not to indulge in such practices in competing for or in executing the Contract;

y) we intend to subcontract an activity or part of the Supply, in accordance with ITT Sub-Clause 16.1 to the following Subcontractor(s);

Nature of the Supply or related service	Name and address of Subcontractor

- z) we, confirm that we do not have a record of poor performance, such as abandoning the Supply, not properly completing contracts, inordinate delays, or financial failure as stated in ITT Sub-Clause 5.8, and that we do not have, or have had, any litigation against us, other than that stated in the Tenderer Information Sheet(Form PG4-2);
- aa) we are not participating as Tenderers in more than one Tender in this Tendering process. We understand that your written Notification of Award shall become a binding Contract between us, until a formal Contract is prepared and executed;
- bb) we understand that you reserve the right to accept or reject any Tender, to cancel the Tender proceedings, or to reject all Tenders, without incurring any liability to Tenderers, in accordance with ITT Clause 58.1.

Signature:

<i>[insert signature of authorised representative of the Tenderer]</i>
--

Name:

<i>[insert full name of signatory with National ID]</i>
---

In the capacity of:

<i>[insert designation of signatory]</i>
--

Duly authorised to sign the Tender for and on behalf of the Tenderer

*[If there is more than one (1) signatory add other boxes and sign accordingly].*

Attachment 1: Written confirmation authorising the above signatory(ies) to commit the Tenderer, in accordance with ITT Sub-Clause 34.3;





<input type="checkbox"/> <i>A certificate issued by the competent authority of Bangladesh stating that the Tenderer is a Tax payer having valid Tax identification Number (TIN) and VAT registration number or in lieu any other document acceptable to the Purchaser demonstrating that the Tenderer is a genuine Tax payer and has a VAT registration number as a proof of fulfillment of taxation obligations in accordance with ITT Clause 5.</i>	
<input type="checkbox"/> <i>Documentary evidence demonstrating that they are enrolled in the relevant professional or trade organizations registered in Bangladesh in accordance with ITT Clause 5.</i>	
<b>2. Litigation History:</b> <i>[Number of arbitration awards against the tenderer over the period in accordance the ITT Clause 13.1] if no [state "None"]</i>	
<b>3. Qualification Information of the Tenderer:</b>	
3.1	<i>Number of years of overall experience of the Tenderer in the supply of goods and related services as stated under ITT Sub-Clause 14.1(a):</i>
3.2	<i>Number of completed supply contracts in the supply of similar goods and related services of required value within the period mentioned in TDS as stated under ITT Sub-Clause 14.1(b):</i> <ul style="list-style-type: none"> <li>▪ <i>Number of Contracts:</i></li> <li>▪ <i>Value of the Contracts:</i></li> <li>▪ <i>Period of the Contract:</i></li> </ul>
3.3	<i>The supply and/or production capacity of Goods, if applicable, as stated under ITT Sub-Clause 14.(c)</i>
3.4	<i>Available liquid assets or working capital or credit facility in accordance with ITT Clause 15.1(a)</i>

Annexure: 4-1 Tenderer's Completed Contracts.

Annexure: 4-2 Tenderer's Ongoing Contract(s).

Annexure: 4-3 Assessment for Manufacturer's Compliance to Production Capacity.

Annexure: 4-4 Assessment for Tenderer's Compliance to Financial Resources Availability.

Annexure: 4-1

Tenderer's Completed Contracts (within last five years):

Sl. No.	Name, Address, Phone No., Fax No. & domain E-mail of the Employer	Contract No. & Date	Description of Supply with quantity	Contract Value	Date of completion of Supply
1.					
2.					
3.					
4.					

I/We hereby declare that, above mentioned information\* is correct and there are no more completed similar contracts in Government entities under power sector of Bangladesh other than those mentioned in the above table.

Signatory Name:  
Designation:

Seal & Signature  
of the Tenderer

*\*Note: This information shall have to be mentioned in the Letterhead pad of the Tenderer duly seal & signed along with supporting document. Failure to submit or misrepresentation of the detail information for any completed similar contract, Tender shall be rejected without further evaluation.*

Annexure: 4-2

Tenderer's Ongoing Contract(s):

Sl. No.	Name, Address, Phone No., Fax No. & domain E-mail of the Employer	Contract /NOA No. & Date	Description of Supply as per Contract			Already supplied (if any)		Remaining items to be Supplied		Date of completion of Supply	
			Name of the Item	Quantity	Value	Quantity	Value	Quantity	Value	As per Contract	Target
(1)	(2)	(3)	(4)			(5)		6 = (4-5)		(7)	
Similar contract(s)											
1.											
2.											
3.											
4.											
Other contract(s) (if applicable)											
1.											
2.											
3.											
4.											

I/We hereby declare that, above mentioned information\* is correct and there are no more ongoing contracts in Government entities under power sector of Bangladesh other than those mentioned in the above table.

Signatory Name:  
Designation:

Seal & Signature  
of the Tenderer

*\*Note: This information shall have to be mentioned in the Letterhead pad of the Tenderer duly seal & signed along with supporting document. Failure to submit or misrepresentation of the detail information for any ongoing contract, Tender shall be rejected without further evaluation.*

Annexure: 4-3

Assessment for Manufacturer's Compliance to Production Capacity:

Ongoing Similar Contracts Commitments (Table-3A)					
Sl. No.	Name, Address, Phone No., Fax No. & domain E-mail of the Employer	Contract /NOA No. & Date	Outstanding Supply quantity  (X) <sup>a</sup>	Remaining Contract Period in months  (Y) <sup>b</sup>	Monthly Production Requirement  (X / Y)
1.					
2.					
3.					
4.					
Total Monthly Production Requirement for Ongoing Similar Contract(s) Commitments					

<sup>a</sup> Remaining outstanding supply quantity for ongoing similar contract(s) will be forwarded from Annexure: 4-2 and calculated from 28 days prior to the Tender submission deadline of this Tender.

<sup>b</sup> Remaining contract period to be calculated from 28 days prior to the Tender submission deadline of this Tender.

Assessment of Production Capacity (Table-3B)				
Production capacity of Goods per month from Tenderer Information Sheet (Form PG4-2), Sl. No. 3.3  (A)	Total Monthly Production Requirement for Ongoing Similar Contracts Commitments from Table- 3A (B)	Remaining Net Production Capacity per month  C= (A-B)	Requirement of the minimum production capacity of Goods per month for this Tender  (D)	Results: [C must be greater than or equal to D]  (E*)
			1/4 of the Tendered Quantity	

Note: \* "E" Must be satisfied to qualify the Tenderer.

Annexure: 4-4

Assessment for Tenderer's Compliance to Financial Resources Availability:

Ongoing Contracts Commitments (Table-4A)					
Sl. No.	Name, Address, Phone No., Fax No. & domain E-mail of the Employer	Contract /NOA No. & Date	Outstanding Contract Value  (X) <sup>a</sup>	Remaining Contract Period in months  (Y) <sup>b</sup>	Monthly Financial Resources Requirement  (X / Y)
1.					
2.					
3.					
4.					
Total Monthly Financial Requirement for Ongoing Contract(s) Commitments					

<sup>a</sup> Remaining outstanding supply value for ongoing contract(s) will be forwarded from Annexure 4-2 and calculated from 28 days prior to the Tender submission deadline of this Tender.

<sup>b</sup> Remaining contract period to be calculated from 28 days prior to the Tender submission deadline of this Tender.

Assessment of Financial Resources Availability (Table-4B)					
Available Financial Resources from Tenderer Information Sheet (Form PG4-2), Sl. No. 3.4 (A)	Monthly Financial Resources Requirement for Ongoing Contracts Commitments from Table- 4A (B)	Financial Requirement of Ongoing Contracts Commitments for 2(two) months  C= (2*B)	Net amount Available Financial Resources  D= (A-C)	Financial Requirement for this Tender  (E)	Results: [D must be greater than or equal to E]  (F*)
				[100% of the quoted price]	

Note: \* "E" Must be satisfied to qualify the Tenderer.

**Price Schedule for Goods (Form PG4-3A)**  
***[Group A Tenders: Goods Manufactured in Bangladesh]***

Invitation for Tender No:		Date:	
Tender Package No:	GRF-03	Package Description:	Procurement of Supply of 33/11kV, 10/13.33MVA Power Transformer (Tongi Store)
Tender Lot No:	N/A	Lot Description:	N/A

1	2	3	4	5	6	7	8	9	10	
Line Item No.	Description of Item	Unit of Measurement	Quantity	Unit price EXW <i>[FC or Taka.]</i>	EXW price per Line Item <i>(Col. 4 × 5)</i> <i>[FC or Taka.]</i>	Inland transportation and other local costs for the delivery of the Goods to their final destination <i>[Taka]</i>	Cost of local labour, raw materials and components from with origin in Bangladesh	VAT Payable on account of Supplier if the Contract is awarded <i>[Taka]</i>	Total Price per line item <i>(Col. 6+7)</i>	
									FC	Taka
1	Supply of 33/11kV, 10/13.33MVA Power Transformer (as per Technical Specification in Section 7)	Nos.	5							
<i>Note : Price offered in foreign currency (FC) &amp; Bangladesh Taka</i>							Total Price for Lot			
Point of Delivery as per Schedule of Requirement: Central Store, BPDB, at Tongi, Gazipur.						Period of Delivery as per Schedule of Requirement: 180 days from the L/C opening.				

Name:	<i>[insert full name of signatory]</i>	<i>Signature with Date and Seal</i>
In the capacity of:	<i>[insert designation of signatory]</i>	<i>[ Sign]</i>
Duly authorized to sign the Tender for and on behalf of the Tenderer		

## Schedule for Goods (Form PG4-3B)

*[Group B Tenders: Goods Manufactured outside Bangladesh, to be imported]*

Invitation for Tender No:		Date:	
Tender Package No:	GRF-03	Package Description:	Procurement of Supply of 33/11kV, 10/13.33MVA Power Transformer (Tongi Store)
Tender Lot No:	N/A	Lot Description:	N/A

1	2	3	4	5	6	7	8	9	10	
Line Item No.	Description of Item	Country Of Origin	Unit of Measurement	Quantity	Unit price CFR(Cost plus Freight) [insert the port of destination] [FC]	CFR price per Line Item (Col. 5 × 6) [FC]	Inland transportation, Port Handling Charge and other local costs for the delivery of the Goods to their final destination [Taka]	VAT Payable on account of Supplier if the Contract is awarded [Taka]	Total Price per line item	
									FC (Col.7)	Taka (Col.8)
1	Supply of 33/11kV, 10/13.33MVA Power Transformer (as per Technical Specification in section 7)		Nos.	5						
<i>Note : Price offered in foreign currency (FC) &amp; Bangladesh Taka</i>							Total Price for Lot			
Point of Delivery as per Schedule of Requirement Central Store, BPDB, at Tongi, Gazipur.						Period of Delivery as per Schedule of Requirement: 180 days from the L/C opening.				

*[Note: The Purchaser may also use other INCOTERMs, if deemed necessary, In such case Form PG4-3B, will require to be customized by the Purchaser]*

Name:	[insert full name of signatory]	Signature with Date and Seal
In the capacity of:	[insert designation of signatory]	[ Sign]
Duly authorised to sign the Tender for and on behalf of the Tenderer		

## Price Schedule for Goods (Form PG4-3C): Not Applicable

[ *Group B Tenders: Goods Manufactured outside Bangladesh, already imported* ]

Invitation for Tender No:		Date:	
Tender Package No:		Package Description:	
Tender Lot No:		Lot Description:	

1	2	3	4	5	6	7	8	9	10	11	12
Line Item No .	Description of Item	Country of Origin	Unit of Measurement	Quantity	Unit price Including Custom Duties, import VAT & other import taxes already paid <i>[Taka]</i>	Custom Duties, import VAT & other import taxes already paid per unit <i>[Taka]</i>	Unit Price per line item net of Custom Duties, import VAT & other import taxes already paid <i>[Taka]</i> (Col. 6 - Col.7)	Price per line item net of Custom Duties, import VAT & other import taxes already paid <i>[Taka]</i> (Col. 5X Col. 8)	Inland transportation and other local costs for the delivery of the Goods to their final destination <i>[Taka]</i>	VAT Payable on account of Supplier if the Contract is awarded  <i>[Taka]</i>	Total Price per line item (Col.9+ Col.10)  <i>[Taka]</i>
<i>Note : Price offered in Bangladesh Taka</i>								Total Price for Lot			
Point of Delivery as per Schedule of Requirement:						Period of Delivery as per Schedule of Requirement:					

Name:	<i>[insert full name of signatory]</i>	<i>Signature with Date and Seal</i>
In the capacity of:	<i>[insert designation of signatory]</i>	<i>[ Sign]</i>
Duly authorised to sign the Tender for and on behalf of the Tenderer		



## Price and Completion Schedule - Related Services (Form PG4-3D)

Invitation for Tender No:		Date:	
Tender Package No:		Package Description:	
Tender Lot No:		Lot Description:	

1	2	3	4	5	6	7	8	9	
Service No.	Description of Services (excludes inland transportation and other services required in Bangladesh to convey the goods to their final destination)	Country of Origin	Unit of Measurement	Quantity	Unit price of service [FC] or [Taka]	Price per line item of service  (Col. 5 X Col. 6) [FC] or [Taka]	VAT Payable on account of Supplier if the Contract is awarded [Taka]	Total Price per line item of service (Col. 7)	
								FC	Taka
	Pre-shipment inspection and/or Witnessing of the manufacturing process and tests of the Power Transformer as per Section 7 and GCC Clause no. 32.1		LS	1					
<i>Note Price offered in foreign currency (FC) &amp; Bangladesh Taka</i>						Total Price:			
Point of Delivery: At Manufacturer's premises					Period of Delivery as per Schedule of Requirement:				

Name:	<i>[insert full name of signatory]</i>	<i>Signature with Date and Seal</i>
In the capacity of:	<i>[insert designation of signatory]</i>	<i>[ Sign]</i>
Duly authorized to sign the Tender for and on behalf of the Tenderer		

## Specifications Submission and Compliance Sheet (Form PG4-4)

Invitation for Tender No:

Date:

Tender Package No:

Package Description: *[enter description as specified in Section 6]*

Tender Lot No:

Lot Description: *[enter description as specified in Section 6]*

Item No.	Name of Goods or Related Service	Country of Origin	Make and Model <i>(when applicable)</i>	Full Technical Specifications and Standards
1	2	3	4	5
	FOR GOODS			Note 1
1	33/11kV, 10/13.33MVA Power Transformer			
2				
	FOR RELATED SERVICES			

*[The Tenderer should complete all the columns as required]*

Signature:

<i>[insert signature of authorised representative of the Tenderer]</i>
--

Name:

<i>[insert full name of signatory]</i>
--

In the capacity of:

<i>[insert designation of signatory]</i>
--

Duly authorised to sign the Tender for and on behalf of the Tenderer

## Manufacturer's Authorisation Letter (Form PG4 - 5)

*[The Tenderer shall require the Manufacturer to fill in this Form in accordance with the instructions indicated. This letter of authorization should be on the letterhead of the Manufacturer and should be signed by a person with the proper authority to sign documents that are binding on the Manufacturer. The Tenderer shall include it in its tender, if so indicated in the TDS as stated under ITT Sub-Clause 26.1(b)]*

Invitation for Tender No:	Date:
Tender Package No:	
Tender Lot No:	
To: Name and address of Purchaser]	

WHEREAS

We *[insert complete name of Manufacturer]*,

who are official manufacturers of *[insert type of goods manufactured]*, having factories at *[insert full address of Manufacturer's factories]*, do hereby

authorize *[insert complete name of Tenderer]* to supply the following Goods, manufactured by us *[insert name and or brief description of the Goods]*.

We hereby extend our full guarantee and warranty as stated under GCC Clause 33 of the General Conditions of Contract, with respect to the Goods offered by the above Tenderer.

Signed: *[insert signature(s) of authorized representative(s) of the Manufacturer]*

Name: *[insert complete name(s) of authorized representative(s) of the Manufacturer]*

Address: *[insert full address including Fax and domain e-mail]*

Title: *[insert title]*

Date: *[insert date of signing]*

## Bank Guarantee for Tender Security (Form PG4 – 6)

*[this is the format for the Tender Security to be issued by a scheduled bank]*

*of Bangladesh as stated under ITT Clauses 29 and 30]*

Invitation for Tender No:

Date:

Tender Package No:

Tender Lot No:

To:

[Name and address of Purchaser]

**TENDER GUARANTEE NO:**

We have been informed that *[insert name of Tenderer]* (hereinafter called “the Tenderer”) intends to submit to you its Tender dated *[insert date of Tender]* (hereinafter called “the Tender”) for the supply of *[description of goods and related services]* under the above Invitation for Tenders (hereinafter called “the IFT”).

Furthermore, we understand that, according to your conditions, Tenders must be supported by a Bank Guarantee for Tender Security .

At the request of the Tenderer, we *[insert name of bank]* hereby irrevocably undertake to pay you, without cavil or argument, any sum or sums not exceeding in total an amount of Tk *[insert amount in figures and in words]* upon receipt by us of your first written demand accompanied by a written statement that the Tenderer is in breach of its obligation(s) under the Tender conditions, because the Tenderer:

- a. has withdrawn its Tender after opening of Tenders but within the validity of the Tender Security ; or
- b. refused to accept the Notification of Award (NOA) within the period as stated under Instructions to Tenderers (ITT) ; or
- c. failed to furnish Performance Security within the period as stipulated in the NOA; or
- d. refused to sign the Contract Agreement by the time specified in the NOA; or
- e. did not accept the correction of the Tender price following the correction of the arithmetic errors in accordance with the ITT; or

This guarantee will expire:

- (a) if the Tenderer is the successful Tenderer, upon our receipt of a copies of the contract signed by the Tenderer and the Performance Security issued to you in accordance with the ITT; or
- (b) if the Tenderer is not the successful Tenderer, twenty eight (28) days after the expiration of the Tenderer’s Tender validity period, being *[date of expiration of the Tender validity plus twenty eight(28) days]*

Consequently, we must receive at the above-mentioned office any demand for payment under this guarantee on or before that date.

Signature

Seal

**Letter of Commitment for Bank’s Undertaking for Line of Credit (Form PG4-6A)**

*[This is the format for the Credit Line to be issued by any internationally reputable bank in accordance with ITT Clause 26.1(d)]*

Memo No.:

Date:

Invitation for Tender No:

Date:

Tender Package No:

Lot No (*when applicable*):

To:

[*Name and address of the Procuring Entity*]

CREDIT COMMITMENT No: [*insert number*]

We have been informed that [*name of Tenderer*] (hereinafter called “the Tenderer”) intends to submit to you its Tender (hereinafter called “the Tender”) for the supply of Goods of [*description of Goods and related services*] under the above Invitation for Tenders (hereinafter called “the IFT”).

Furthermore, we understand that, according to your conditions, the Tenderer’s Financial Capacity i.e. Liquid Asset must be substantiated by a Letter of Commitment of Bank’s Undertaking for Line of Credit.

At the request of, and arrangement with, the Tenderer, we [*name and address of the Bank*] do hereby agree and undertake that [*name and address of the Tenderer*] will be provided by us with a revolving line of credit, in case awarded the Contract, for the delivery of Goods and related services viz. [*insert name of supply*], for an amount not less than [*name of currency(s)*] [*Amount in figure*] ( *in words*) for the sole purpose of the supply of Goods and related services under the above Contract. This Revolving Line of Credit will be maintained by us until issuance of “Acceptance Certificate” by the Procuring Entity.

In witness whereof, authorised representatives of the Bank have hereunto signed and sealed this Letter of Commitment.

Name and Signature

Name and Signature

## Notification of Award (Form PG4 - 7)

Contract No:

Date:

To:

*[Name of Contractor]*

This is to notify you that your Tender dated *[insert date]* for the supply of Goods and related Services for *[name of contract]* for the Contract Price of Tk *[state amount in figures and in words]* as corrected and modified in accordance with the Instructions to Tenderers, has been approved by *[name of Purchaser]*.

You are thus requested to take following actions:

- i. accept in writing the Notification of Award within seven (7) working days of its issuance pursuant to ITT Sub-Clause 62.3
- ii. furnish a Performance Security in the specified format and in the amount of Tk *[state amount in figures and words]* ,within Twenty-eight (28) days from issue of this Notification of Award but not later than *[specify date]*, in accordance with ITT Clause 64.2
- iii. sign the Contract within twenty eight (28 ) days of issuance of this Notification of Award but not later than *[specify date]*, in accordance with ITT Clause 67.2

You may proceed with the execution of the supply of Goods and related Services only upon completion of the above tasks. You may also please note that this Notification of Award shall constitute the formation of this Contract, which shall become binding upon you.

We attach the draft Contract and all other documents for your perusal and signature.

Signed

Duly authorised to sign for and on behalf  
of *[name of Purchaser]*

Date:

## Contract Agreement (Form PG4 - 8)

THIS AGREEMENT made the *[day]* day of *[month]* *[year]* between *[name and address of Purchaser]* (hereinafter called "the Purchaser") of the one part and *[name and address of Supplier]* (hereinafter called "the Supplier") of the other part:

WHEREAS the Purchaser invited Tenders for certain goods and related services, viz, *[brief description of goods and related services]* and has accepted a Tender by the Supplier for the supply of those goods and related services in the sum of Taka *[Contract Price in figures and in words]* (hereinafter called "the Contract Price").

NOW THIS AGREEMENT WITNESSETH AS FOLLOWS:

1. In this Agreement words and expressions shall have the same meanings as are respectively assigned to them in the General Conditions of Contract hereafter referred to.
2. The following documents forming the Contract shall be in the following order of precedence, namely :
  - (a) the signed Form of Contract Agreement;
  - (b) the Notification of Award
  - (c) The Tender and the appendices to the Tender
  - (d) Particular Conditions of Contract;
  - (e) General Conditions of Contract;
  - (f) Technical Specifications;
  - (g) Drawings;
  - (h) Price Schedules and Schedule of Requirements and;
  - (i) other document including correspondences listed in the PCC forming part of the Contract
3. In consideration of the payments to be made by the Purchaser to the Supplier as hereinafter mentioned, the Supplier hereby covenants with the Purchaser to provide the goods and related services and to remedy any defects therein in conformity in all respects with the provisions of the Contract.
4. The Purchaser hereby covenants to pay the Supplier in consideration of the provision of the goods and related services and the remedying of defects therein, the Contract Price or such other sum as may become payable under the provisions of the Contract at the times and in the manner prescribed by the Contract.

IN WITNESS whereof the parties hereto have caused this Agreement to be executed in accordance with the laws of Bangladesh on the day, month and year first written above.

For the Purchaser:

For the Supplier:

Signature

Print Name

Title

In the presence  
of Name  
Address



# Bank Guarantee for Performance Security (Form PG4 – 9)

*[This is the format for the Performance Security to be issued by an internationally reputable bank and it shall have correspondent bank located in Bangladesh, to make it enforceable in accordance with ITT Sub-Clause 64.1 pursuant to Rule 27(4) of the Public Procurement Rules, 2008.]*

Contract No:

Date:

To:

[Name and address of Purchaser]

PERFORMANCE GUARANTEE No: *[insert Performance Guarantee number]*

We have been informed that *[name of supplier]* (hereinafter called “the Supplier”) has undertaken, pursuant to Contract No *[reference number of Contract]* dated *[date of Contract]* (hereinafter called “the Contract”) for the supply of *[description of goods and related services]* under the Contract.

Furthermore, we understand that, according to your conditions, Contracts must be supported by a performance guarantee.

At the request of the Supplier, we *[name of bank]* hereby irrevocably undertake to pay you, without cavil or argument, any sum or sums not exceeding in total an amount of Tk *[insert amount in figures and in words]* upon receipt by us of your first written demand accompanied by a written statement that the Supplier is in breach of its obligation(s) under the Contract conditions, without you needing to prove or show grounds or reasons for your demand of the sum specified therein.

This guarantee is valid until *[date of validity of guarantee]*, consequently, we must receive at the above-mentioned office any demand for payment under this guarantee on or before that date.

*[Signatures of authorized representatives of the bank]*

Seal

Signature

## Bank Guarantee for Advance Payment (Form PG4 – 10)-N/A

*[this is the format for the Advance Payment Security to be issued by an internationally reputable bank and it shall have correspondent bank located in Bangladesh, to make it enforceable in accordance with GCC Clause 27.1]*

Contract No:

Date:

To:

[Name and address of Purchaser]

### ADVANCE PAYMENT GUARANTEE No:

We have been informed that *[name of supplier]* (hereinafter called “the Supplier”) has undertaken, pursuant to Contract No *[reference number of Contract]* dated *[date of Contract]* (hereinafter called “the Contract”) for the supply of *[description of goods and related services]* under the Contract.

Furthermore, we understand that, according to your Particular Conditions of Contract Clause 26.1, Advance Payment(s) on Contracts must be supported by a bank guarantee.

At the request of the Supplier, we *[name of bank]* hereby irrevocably undertake to pay you, without cavil or argument, any sum or sums not exceeding in total an amount of Tk *[insert amount in figures and in words]* upon receipt by us of your first written demand accompanied by a written statement that the Supplier is in breach of its obligation(s) under the Contract conditions, without you needing to prove or show grounds or reasons for your demand of the sum specified therein.

We further agree that no change, addition or other modification of the terms of the Contract to be performed, or of any of the Contract documents which may be made between the Purchaser and the Supplier, shall in any way release us from any liability under this guarantee, and we hereby waive notice of any such change, addition or modification.

This guarantee is valid until *[date of validity of guarantee]*, consequently, we must receive at the above-mentioned office any demand for payment under this guarantee on or before that date.

*[Signatures of authorized representatives of the bank]*

Signature	Seal
-----------	------

## Deviation List (Form PG4 – 11)

*[If Tenderer has any reservation on terms and conditions, Tenderer has to mention his reservations in Deviation list]*

Sl. No.	Reference No./ Clause No.	Proposed Deviation	Remarks

*[ Add rows if necessary]*

Signature: *[insert signature of authorised representative of the Tenderer]*

Name: *[insert full name of signatory]*

In the capacity of: *[insert designation of signatory]*

Duly authorised to sign the Tender for and on behalf of the Tenderer

## Warranty Certificate (Form PG4 - 12)

*[The Tenderer shall require to fill in this Form in accordance with the instructions indicated. This Certificate should be on the official pad of the Tenderer and should be signed by a person with the proper authority to sign documents.]*

*[The Tenderer shall include it in its Tender, if so indicated in the TDS as stated under ITT Sub Clause 21.1 (q)]*

Invitation for Tender No:	Date:
Tender Package No:	
Tender Lot No( <i>when applicable</i> ):	
To: [Name and address of Procuring Entity]	

**WHEREAS**

We *[insert complete name of Tenderer]*,

who are authorized Supplier of *[insert type of goods to be Supplied]*, having registered office at *[insert full address of Tenderer's registered office]* do hereby warrants that all the Goods *[insert name and brief description of the Goods]* will be supplied by us and extend our full guarantee and warranty as stated under GCC Clause 33 of the General Conditions of Contract with respect to the Goods offered by us under this contract.

Signed: *[insert signature(s) of authorized representative(s) of the Tenderer]*

Name: *[insert complete name(s) of authorized representative(s) of the Tenderer]*

Address: *[insert full address including Fax and e-mail]*

Title: *[insert title]*

Date: *[insert date of signing]*

## Section 6. Schedule of Requirements

Invitation for Tender No:

Date

Tender Package No: GRF-03

### A. List of Goods and Delivery Schedule

When completing Form PG4-3A, 3B & 3C the Tenderer shall quote prices and contract delivery dates for each lot separately, as specified in the List of Goods and Delivery Schedule.

Item No.	Description of Item	Unit of Measurement	Quantity	Point of Delivery <i>[Final (Project Site) Destination as specified in TDS]</i>	Delivery Date Required (in weeks)	
					Earliest Delivery Date	Latest Delivery Date
1	2	3	4	5	6	7
1	Supply of 33/11kV, 10/13.33MVA Power Transformer	Nos.	5	Central Store, BPDB, at Tongi, Gazipur.		
<i>Purchaser's Option for delivery terms is:</i>					<i>180 Days from the date of L/C opening</i>	
Lot No 1:						
<i>[add as many rows and details as there are individual items in the Lot]</i>						
Lot No 2:						
<i>[add as many rows and details as there are individual items in the Lot]</i>						

*Note: This Section provides the List of Goods and Delivery Schedule and List of Related Services and Completion Schedule and must be carefully prepared by a Purchaser for each object of procurement  
The Purchaser may include the delivery of a limited supply of fast-moving and/or hard-to-find spare parts in this Schedule of Requirement. This is to ensure the continued use or operation of the equipment.*

## B. List of Related Services and Completion Schedule

When completing Form PG4-3D, the Tenderer shall quote prices and Completion date for services for each item against each lot

Item No.	Description of Item	Unit of Measurement	Quantity	Place where Services shall be performed	Final Completion Date(s) of Services
1	2	3	4	5	6
	Pre-shipment inspection and/or Witnessing of the manufacturing process and tests of the Power Transformer as per Section 7 and GCC Clause no. 32.1	LS	1	At Manufacturer's premises	
[enter description]					
[add as many rows and details as there are individual items in the Lot]					

### Notes on Related Services

*The Purchaser shall clearly specify the related services/Incidental services, other than inland transportation and other services required to convey the Goods to their final destination, in this Schedule of requirement. In particular, these services may refer to any of the following but not limited to:*

- (a) *performance or supervision of on-site assembly and/or start-up of the supplied Goods;*
- (b) *performance or supervision or maintenance and/or repair of the supplied Goods, for a period of time as specified, provided that this service shall not relieve the Supplier of any warranty obligations under this Contract; and*
- (c) *training of the Purchaser's personnel, at the Supplier's plant and/or on-site, in assembly, start-up, operation, maintenance, and/or repair of the supplied Goods*

SECTION: 7

TECHNICAL SPECIFICATION  
AND  
GUARANTEED TECHNICAL PARTICULARS  
OF  
33/11kV, 10/13.33MVA Power Transformer



## Technical Specification of 33/11 KV, 10/13.33 MVA Power Transformer

### 7.1.0 GENERAL

This section of the document includes the design, engineering, manufacture, supply, delivery, offloading, testing & inspection and performance requirements of 33/11KV, 10/13.33 MVA, Power transformers and accessories as specified.

### 7.1.1 CLIMATE DATA

The distribution transformers to be supplied against this tender shall be suitable for satisfactory use under the following climatic condition:

Climate	:	Tropical, intense sunshine, heavy rain, humid.
Maximum Temperature	:	40 <sup>o</sup> C
Minimum Temperature	:	03 <sup>o</sup> C
Maximum yearly weighted average temperature	:	30 <sup>o</sup> C
Relative Humidity	:	50-100%
Annual mean Relative Humidity	:	75%
Average annual rain fall	:	3454 mm
Maximum wind velocity	:	200 km/ hour
Maximum altitude above the sea level	:	Sea level to 300 metres
Atmospherically, Mechanical and Chemical impurities	:	Moderately polluted

The information is given solely as a guide for Tenders and no responsibility for its, accuracy will be accepted nor will any claim based on the above be entertained.

Transformer supplied under this contract will be installed in tropical locations that can be considered hostile to its proper operation. Particular problems that shall receive special consideration relate to operation in a hot environment and presence of the insects and vermin.

### 7.1.2 SYSTEM PARTICULARS

SL. NO.	SYSTEM CHARACTERISTICS	VOLTAGE LEVEL			
1.	Normal System Voltage, kV (Voltage Class)	230	132	33	11
3.	Maximum System Voltage, kV	245	145	36	12
4.	System Frequency, Hz	50	50	50	50
5.	Phase Rotation (Anti-Clock wise)	RST	RST	RST	RST
6.	Type of System Grounding	Solid	Solid	Solid	Solid
7.	Rated Fault Level (3-Phase Symmetrical), MVA 3 sec.	16300	6000	1800	500
8.	Basic Insulation Level, kV	750	650	170	75

High Voltage current carrying equipment should be capable of carrying the three phase fault level for a period of 3 Sec.

### 7.1.3 STANDARDS

The equipment specified in this Section of the contract shall conform to the latest edition of the appropriate IEC specifications and other recognized international standard. In particular:

IEC	6076-1	Power transformers (General).
IEC	6076-2	Power transformers (Temperature Rise).
IEC	6076-3	Power transformers (Insulation Levels, Dielectric Tests and External Clearance

		in air).
IEC	6076-5	Power transformers (Ability to Withstand short circuit)
IEC	60137	Bushings for alternating voltages above 1 kV.
IEC	156	Method of determination of electrical strength of insulating oils.
IEC	296	Specification for unused mineral insulating oils for transformers and switchgear.
IEC	551	Measurement of transformer and reactor sound levels.
IEC	616	Terminal and tapping markings for power transformers.
IEC	722	Guide to lightning and switching impulse testing of power transformers.
IEC	5493	Protective coating of iron and steel structures against corrosion.
IEC	551	Noise and Vibration of power transformer.

#### 7.1.4 Technical Specification:

This section covers the specification, manufacture, design & testing of Power Transformer.

1.	Rated MVA (ONAN/ONAF)	10/13.33 MVA
2.	Number of Phases	3 (Three)
3.	Frequency	50 Hz
4.	Winding Insulation	Uniform
5.	Normal Transformation Ratio at No-load	33/11 kV
6.	Rated HT Voltage (Phase to Phase)	33 kV
7.	Maximum HT Voltage (Phase to Phase)	36 kV
8.	Rated LT Voltage (Phase to Phase)	11 kV
9.	Maximum LT Voltage (Phase to Phase)	12 kV
10.	Rated Current HT (ONAN / ONAF)	175 / 233 Amps
11.	Rated Current LT (ONAN / ONAF)	525 / 700 Amps
12.	Basic Insulation Level : a) High voltage winding b) Low voltage winding	170 kVp 75 kVp
13.	Installation	Outdoor, Tropical, High rainfall & Humidity.
14.	Type	Core, Conservator & Oil Immersed
15.	Type of Windings	Double Wound of Electrolytic Copper, free from burs and splinter.
16.	Type of Cooling	ONAN / ONAF
17.	Coolant	Mineral Oil as per IEC-60296
18.	Type of System Earthing	Effectively Earthed
19.	Bushing Material	Porcelain
20.	Type of Base	On wheels with adequate size and 10M length of rails and fixing arrangement
21.	Direction of Normal Power Flow	HT-LT
22.	Phase connection :( $\Delta$ -Y) a) 33 KV winding with bushing CT b) 11 KV winding with bushing CT	Delta Star
23.	Vector Group	Dyn11
24.	Neutral to be brought out :- a) HT b) LT	Nil Yes
25.	Neutral Insulation	Full uniform insulation insulation and 100% loading capacity
26.	Maximum Temperature Rise over 40°C ambient at Full load & tap changer is at normal position : a) Winding by Resistance (°C)	65 °C

	b) Oil by Thermometer (°C)	55 °C
27.	Impulse Front Wave Test Voltage (1.2/50 Micro Sec. Wave Shape) : a) High voltage side b) Low voltage Side	170 kVp 75 kVp
28.	Power Frequency withstand Test Voltage for 1 (one) Minute : a) High voltage side b) Low voltage Side	70 kV 28 kV
29.	Impedance Voltage at 75°C, at Normal ratio and rated frequency, at ONAN condition.	8.5%
30.	Type of Tap Changer control	
	Features	The Tap Changer will be on load auto regulation, remote control and manual. The On Load Tap Changer will immerse in the transformer tank. The diverter switch compartment can also be provided with its own oil conservator, which will not be connected to the main transformer oil tank. The diverter switch can easily be lifted out of its tank for maintenance and inspection without opening the transformer cover. The on load tap changer will operate by means of a motor drive unit. This unit will install on the side of the transformer. Vacuum type may also be proposed.  OLTC shall be operational from Local control panel, RTCC panel as well as from SAS. Tap position shall also be visible in Local control panel, RTCC panel as well as HMI of SAS. AVR relay shall have IEC-61850 communication protocol for communicating with SAS.
	On Load Tap Changer with Motor Drive Unit manufacturer's name & country	MR, Germany/ ABB (Hitachi), Sweden
	Tapping Range :	
	a) HT	17 Tapping $\pm$ 10% in steps of 1.25% (i.e. 33 kV $\pm$ 8 x 1.25%)
	b) LT	Nil
31.	Bushing CT for Differential protection	300/5A on HV & 900/5A on LV side of Accuracy Class 5P20 Burden 30 VA.
32.	Neutral Bushing CT for Standby Earth Fault (SEF) & Restricted Earth Fault (REF) protection	900/5-5A on LV neutral of Accuracy Class 5P20 Burden 30VA.
33.	Standard	Design, Manufacture, Testing, Installation and Performance shall be in accordance to the latest editions of the relevant IEC Standards.
34.	Transformer Oil	
	Application	Insulating mineral oil for Transformer. It will be free from PCB (polychlorinated biphenyl)
	Grade of oil	Type-A

	PHYSICAL PROPERTIES	
	Appearance	Liquid and free from suspended matter or sediment
	Density at 20 <sup>o</sup> C	0.895 g/cm <sup>3</sup> (Max <sup>m</sup> .)
	Flash point (Closed cup)	140 <sup>o</sup> C (Min <sup>m</sup> .)
	Kinematics Viscosity at -15 <sup>o</sup> C	800 cSt. (Max <sup>m</sup> .)
	Kinematics Viscosity at 20 <sup>o</sup> C	40 cSt. (Max <sup>m</sup> .)
	Pour point	-30 <sup>o</sup> C (Max <sup>m</sup> .)
	ELECTRICAL PROPERTIES	
	Dielectric Strength at 50 Hz (with 2.5 mm standard gap and 40 mm standard depth)	New untreated oil, shall go through filtration treatment before the oils are introduced into the apparatus or equipment. The break down voltage of this oil shall be at least 50kV.
	Loss tangent/ Dielectric dissipation factor at temp. 90 <sup>o</sup> C, stress 500V/mm to 1000 V/mm and frequency 40 Hz to 62 Hz.	0.05 (Max <sup>m</sup> .)
	CHEMICAL PROPERTIES	
	Neutralization value	0.3 mg KOH/g (Max <sup>m</sup> .)
	Neutralization value after oxidation	0.40 mg KOH/g (Max <sup>m</sup> .)
	Total sludge after oxidation	0.05% weight (Max <sup>m</sup> .)
	PCB Content	Free from PCB
	STANDARDS	Performance and testing of oil shall comply with the latest revision of the relevant standards BS 148: 1972, IEC-60296 or latest revision there on.
35.	<p>FEATURES &amp; ACCESSORIES OF TRANSFORMER:</p> <ol style="list-style-type: none"> <li>a) Bushing Insulator on HT and LT.</li> <li>b) Arcing horns on HT and LT bushings.</li> <li>c) Oil conservator.</li> <li>d) Buchholz relays in main conservator oil pipe.</li> <li>e) Tap changer protection relay in between conservator and tap changer oil pipe.</li> <li>f) Conservator drain valve, breather and oil level gauge with alarm contact.</li> <li>g) Pressure Relief Device (PRD).</li> <li>h) Dial type thermometers with alarm and trip contracts.</li> <li>i) CT for Winding Temperature shall be located at mid-phase (Y-phase) of the transformer.</li> <li>j) Radiators with valves.</li> <li>l) Bladder/Airbag in conservator to separate air from oil.</li> <li>k) One inspection hole with cover.</li> <li>l) Facilities for lifting cover and coil assembly from tank.</li> <li>m) Lifting lugs for lifting complete Transformer.</li> <li>n) Base designed for rollers with bi-directional flanged rollers parallel to either Centre line.</li> <li>o) Tank oil sampling, draining valve and oil centrifuging outlets.</li> <li>p) Tank earthing points.</li> <li>q) Fans for forced cooling (ONAF).</li> <li>r) All mounting accessories including rails (2 Nos. rails each 10 Meter long).</li> <li>s) All equipment should be fully tropicalized.</li> <li>t) Painting to approved colour and shade.</li> <li>u) Rating nameplate and diagram plate of stainless steel having engraved letters filled with black enamel paint.</li> </ol>	

	<p>v) The oil shall be supplied/delivered in non-returnable sealed containers/ drums.</p> <p>w) The oil shall be fresh, unused, cleaned and free from suspended matter or sediment.</p> <p>x) The test shall be carried out on the oil as to be supplied without drying and degassing.</p> <p>y) Uninhibited oils must not contain anti-oxidant additives.</p> <p>z) Laminated, detailed Schematic Diagram of control circuit of transformer &amp; tapchanger inside Marshalling kiosk.</p> <p>aa) Maintenance free dehydrating Silica-gel breather with self regulating heating element.</p> <p>bb) Dehydrating Silica-gel breather.</p> <p>cc) Air release plug.</p> <p>dd) Earthing terminals with lugs.</p> <p>ee) Thermometer pockets.</p> <p>ff) Winding temperature indicator with two contacts</p> <p>gg) Bottom mounting channel (min. size of channel shall be 10/13.33 MVA.</p> <p>hh) Operation and maintenance manual along with troubleshooting procedure and installation guideline/manual shall be supplied with each transformer.</p>
36	Following instructions to be followed for Submission of Test reports & Calculation:
	<p>aa) All Type test Report and related routine test report shall be of same transformer of same name plate serial no.</p> <p>bb) Calculation of load loss shall be provided for load loss in all 3( three) tap position (Nominal, Maximum, Minimum).</p>

#### 7.1.5 INFORMATION REQUIRED

The Tenderer/ Manufacturer as per tender requirements shall provide all information. Besides these, the following information/Documents has to be submitted along with the tender:-

- The Tenderer/Manufacturer shall submit with the bid the testing procedure & list of testing/measuring equipment, meters etc. used for Factory test witness.
- Construction, Installation, Operation & Maintenance Manual.

#### 7.1.6 CAPITALIZED COST:

Bidder shall declare guaranteed No Load Loss and Full Load Loss value in GTP. Any Tenderer quoted the No Load Loss & Full Load Loss above the upper limit of the loss as mentioned in GTP in Tender Document will not be considered for further evaluation & treated as non- responsive. The Tenderer who will quote the No Load Loss & Full Load Loss below the lower limit of No Load Loss & Full Load Loss as mentioned in GTP. In that case during evaluation Capitalization cost will be calculated only on the basis of the lower limit of No Load Loss & Full Load Loss. Their quoted loss will not be considered for evaluation of capitalization cost.

Tenderers quoted No load Loss and Full load loss shall be supported by loss calculation, otherwise the bid will also be treated as non- responsive.

The fixed and running losses are to be low as consistent with reliable and economical use of materials. The cost of losses is to be minimized and the following capitalized parameters will be used in the evaluation of the transformer:-

$$C = 68,706 \times e \times P_0 + 54,964 \times e \times P_{FL}$$

Where,

C = Capitalized cost of transformer loss in Bangladesh Taka.

e = Energy Cost, Tk. 6.50/Kwh.

P<sub>FL</sub> = Full Load losses at rated voltage, normal ratio and rated frequency in ONAF

$$P_0 = \frac{\text{condition at } 75^{\circ}\text{C in KW} + \text{Auxiliary loss in KW}}{\text{No load losses at rated voltage, normal ratio and rated frequency in KW}}$$

The cost of energy (C) will be added to the quoted prices to arrive at the evaluated cost of the transformer. The contract will be cancelled if losses exceed the guaranteed value by an amount in excess of followings:-

Total losses : 10%

Component : 15% of each component loss (Unless the total losses exceeds 10%).

#### 7.1.7 SHIPPING:

All the delicate components shall be dismantled and packed in strong wooden boxes having inside lined with metallic sheets with proper sealing to protect the content from accidental direct exposure to weather during storage. The holes of the transformer tank shall be sealed with proper metal plate and gaskets to prevent leakage of oil and its contamination with atmospheric moisture. The transformer shall be shipped with radiators, busing conservator etc. dismantled but the tank filled with oil. The transformer oil from radiators and conservator shall be shipped in non-returnable drums. The bushing shall be shipped in oil sealed containers to avoid moisture absorption during shipment and storage. Oil shall be complying with IEC-296. Packing procedure stated in detail elsewhere is to be complied.

#### 7.1.8 BUSHING:

The bushings shall have high factor of safety against leakage to ground and shall be so located as to provide adequate electrical clearances between bushings and grounded parts. Bushings of identical voltage rating shall be interchangeable. All bushings shall be equipped with suitable terminals of approved type and size & shall be suitable for bimetallic connection. The insulation class of the high voltage neutral bushing shall be properly coordinated with the insulation class, of the high voltage winding. Each bushing shall be so coordinated with the transformer insulation so that all flash over will occur outside the tank. All main winding and neutral leads shall be brought out through "out door" type bushings which shall be so located that the full flashover strength will be utilized and the adequate phase clearance shall realized. All porcelain used in bushings shall be of the wet process, homogeneous and free from cavities or other flaws. The glazing shall be uniform in colour and free from blisters, burrs and other defects.

##### 7.1.8.1 HT BUSHING:

Provide 3 porcelain outdoor type, oil filled, impulse tested bushing with arcing horns of standard gap and bolted type terminal connectors, with head shrink rubber insulated cap suitable for connection to the incomer leads of ACSR Grosbeak (636 MCM) conductor.

##### 7.1.8.2 LT BUSHING:

Provide 4 porcelain outdoor type bushing with bolted type connectors, suitable for connection to outgoing leads of two numbers of 240 Sq.mm/300 Sq.mm XLPE, single core copper conductors per phase and suitable for head shrink termination.

#### 7.1.9 FAULT CONDITIONS:

The transformer shall be capable of withstanding, on any tapping, for three seconds without damage an external short circuit between phases. The transformer winding shall be capable of withstanding for three seconds without damage a short circuit between one phase and earth with the neutral of the transformer directly earthed. For the purposes of this clause a fault level of 1800 MVA at the transformer 33KV terminals shall be assumed.

Evidence shall be submitted with the Tender as to the extent to which the manufacturer has provided or is able to prove either by calculation or test the ability of the specified transformers to withstand on any tapping, without damage under service conditions, the terminal and dynamic effects of external short circuit.

The Bid shall state in the Technical Schedule a brief description of those transformers or parts thereof, which have been subjected to short circuit tests or for which short circuit calculations are available. It is preferred that this information relates to designs comparable with the transformers bidder but in the event this is not so the Engineer reserves the right to require calculating to prove that the design of transformers tendered will satisfactorily comply with this clause, such calculations being in accordance with the latest revision of IEC/ BS standard.

#### 7.1.10 NOISE:

Vibration and noise levels of all transformers and auxiliary plant shall be in accordance with the IEC 551 and its latest version. The contract price shall include noise level tests to be carried out on one transformer.

#### 7.1.11 HARMONIC SUPPRESSION:

Transformer shall be designed with particular attention to the suppression of harmonic voltages especially the third and fifth harmonics and to minimize the detrimental effects resulting there from.

#### 7.1.12 IMPEDANCE AND REGULATION:

The Bidder shall be state in the Technical Schedules guaranteed values of impedance measured on normal and extreme tapping and the voltage regulation from no-load to CMR at unity power factor and at 0.9 lagging power factor with constant voltage across the higher voltage windings.

#### 7.1.13 MAGNETIC CIRCUIT:

The design of the magnetic circuit shall be such as to avoid static discharge development of short circuit paths internally or to the earthed clamping structure and the production of flux components normal to the plane of the laminations. Each lamination shall be insulated with a material stable under the action of pressure and hot oil.

The winding structure and major insulation shall be designed to permit an unobstructed flow of cooling oil through core cooling oil ducts to ensure efficient core cooling.

The magnetic circuit shall be insulated from all structural parts and shall be capable of withstanding a test voltage to core bolts and to the frame of 2000 volts rms for one minute.

#### 7.1.14 FLUX DENSITY:

Cores shall constructed from cold rolled grain oriented steel sheets. Provided the contractor can provide adequate evidence that there will be no adverse effects due to stray flux heating of core with the quality of steel employed, designs may be offered such that when operating under the most onerous conditions, flux density in any part of the magnetic circuit does not exceed 1.7 Tesla.

The Contractor shall determine the operating conditions under which the maximum flux density will be attained within the following simultaneously applied limits.

- Frequency : 50 Hz
- LV and HV Voltage : Up to but not exceeding the specified maximum System voltage.
- Load : The transformer may be subjected to intermittent overloading of 150% rated MVA at 0.8 power factor lagging in accordance with IEC-60035.

The maximum flux densities anticipated under these conditions are to be stated in Technical Schedules (GTP).

#### 7.1.15 WINDINGS:



- a) The windings shall be of high-conductivity electrolytic copper.
- b) The transformer windings shall have uniform insulation as defined in the latest revision of IEC standard. The insulation of the coils shall be such as to develop the full electrical strength of the windings. All materials used in the insulation and assembly of the windings shall be insoluble, non-catalytic and chemically inactive in the hot transformer oil, and shall not soften or otherwise be adversely affected under the operating conditions.
- c) The transformers shall be designed to withstand the impulse voltage levels and the power frequency voltage tests specified in the Technical Schedules.
- d) The winding shall be located in a manner which will ensure and that they remain Electro-statically balanced and that their magnetic centers remain coincident under all conditions of operation.
- e) The winding shall also be thoroughly seasoned during manufacture by the application of axial pressure at a high temperature for such length of time as will ensure that further shrinkage is unlikely to occur in service.
- f) All electrical connections within windings shall be brazed to withstand the shocks, which may occur through rough handling and vibration during transport switching and other transient service conditions.
- g) Coil clamping rings shall be of the on on-magnetic steel or insulating materials built up from flat laminations. Auxiliary laminated material other than Bakelite paper is not to be used. Where Bakelite paper rings are used with the layers of paper lying in the axial direction, the rings may be relied upon to provide the major insulation between the windings and frame subject to there being adequate creepage distance. Any metal pieces in contact with laminated rings shall be designed and secured so that they do not weaken the electrical or the mechanical properties of the rings. If the winding is built up of section or of disc-coils separated by spacers, the clamping arrangement shall be ensure that equal pressure are applied to all columns of spacers.
- h) The winding shall be so designed that all coil assemblies of identical voltage ratings shall be interchangeable and field repairs can be readily done, without special equipment. The coils shall be supported between adjacent sections by insulating spacers and the barriers, bracings and other insulation used in the assembly of the windings shall be arranged to ensure a free circulation of the oil and to reduce hot sports in the windings. The insulation paper shall be of high quality and the value of degree of polymerization shall not be less than 1200 dp and the necessary test certificate shall be submitted along with the Pre -delivery inspection report. Provision shall be made in the tank, for taking sample, in future, of paper for testing purpose and location shall be easily accessible and indicated on the transformer tank by affixing special caution plate.

#### 7.1.16 INTERNAL EARTHING ARRANGEMENT:

All metal parts of the transformer with the exception of the individual core lamination, core bolts and associated individual clamping plates, shall be maintained at some fixed potential.

The top main core clamping structure shall be connected to the tank body by a copper strap and the bottom main core clamping structure shall be earthen by one or more of the following methods:-

- by connection through vertical tie rods to the top structure.
- by direct metal-to-metal contact with the tank base maintained by the weight of the core and windings.
- by connection to the top structure on the same side of the core as the main earth connection to the tank.

The magnetic circuit shall be earthed to the clamping structure at one point through a removable link placed in an accessible position just beneath an inspection opening in the tank cover and which, by disconnection, will enable the insulation between the core and clamping plates, etc. to be tested at



voltages up to 2 kV for the purpose of checking deterioration during service. The connection to the link shall be on the same side of the core as the main earth connection. These requirements are mandatory.

Magnetic circuits having an insulated sectional construction shall be provided with a separate link for each individual section and the arrangement of the connections shall be subject to the approval of the Engineer.

Where oil ducts or insulated barriers parallel to the plane the laminations divide the magnetic circuits into two or more electrically separates parts, the ducts and insulating barriers which have the thickness greater than 0.25 mm, are to be bridged with tinned copper strips so inserted as to maintain electrical continuity.

Where coil-clamping rings are of metal at each potential, each rings shall be connected to the adjacent core clamping structure on the same side of the transformer as the main earthing connection.

Main earthing connections shall be a cross-sectional area of not less than 100mm<sup>2</sup> but connections inserted between laminations may have cross sectional areas reduced 20mm<sup>2</sup> when in close thermal contact with the core.

#### 7.1.17 CORE

The core shall be constructed from high grade cold rolled non-ageing grain oriented silicon steel laminations, M4 or Superior Grade. Only prime quality CRGO sheets should be used in the transformers and no Second/Defective/Scrap CRGO finds way into transformers. Therefore regarding quality control following documents are to be furnished with the Post – delivery inspection report.

1. Invoices of supplier
2. Mill's test certificate
3. Packing list.
4. Bill of lading
5. Bill of entry certificate by custom
6. Description of material, electrical analysis, Physical inspection, certificate for surface defects, thickness and width of the material.

It is to note that, using seconds/defective CRGO sheets or load losses found to be more than stipulated limit, heavy penalty will be imposed or the suppliers will be black listed.

#### 7.1.18 TRANSFORMER TANK

The Transformer Tank shall be welded construction fabricated from high tensile steel plate and shall be designed to withstand full vacuum. The transformer shall have air seal type oil conservator tank at the top.

- a) The transformer tank and cover shall be fabricated from good commercial grade low carbon steel suitable for welding and of adequate thickness.
- b) The transformers tank shall be capable of withstanding full vacuum without deflection.
- c) The plates (tank & Cover) shall have the following minimum thickness.

Length of Transformer Tank	Minimum Thickness	
	Side Plates	Bottom Plates
Less than 2500 mm	Min 6 mm	Min 9 mm
Greater than 2500 mm	Min 9 mm	Min 12 mm

- d) The base of each track shall be so designed that it is possible to move the complete transformer unit in any direction without injury when using rollers, plates or rails. A design, which required that slide rails be placed in a particular position, is not to be used. 10/13.33 MVA and lower rate transformers shall be provided with base plates having bi-directional wheels for placing on rails.

- e) An inspection window with a welded flange & a bolted cover shall be provided on the tank cover. The manhole shall be of a sufficient size to ease access to the lower ends of the bushings, terminals etc.
- f) Lifting eyes or lugs shall be provided on all parts of the transformers requiring independent handling during assembly or dismantling. In addition, the transformer tank shall be provided with lifting lugs and bosses properly secured to the sides of the tank for lifting the transformers either by crane or by jacks. The design of the tank, the lifting lugs and bosses shall be such that the complete transformer assembly filled with oil can be lifted with the use of those lugs without any damage or distortions.
- g) The tank shall be provided with two suitable copper alloy or any other suitable material lugs for the purpose of grounding.
- h) The tank shall be so designed that with the cores and windings in position there shall be no possibility of air or gas being trapped when filling the tank with oil. Likewise, water shall not be trapped on the exterior of the tank.
- i) The tank shall be fitted with pockets for a thermometer and the bulb of a winding temperature indicator and an oil temperature indicator.
- j) Necessary drain valves, filter valves, valves to take oil sample etc shall be provided.

#### 7.1.18.1 Conservator Tank

A conservator tank shall be mounted above the highest point of the oil circulating system of the equipment. Tanks shall be formed of substantial steel plate. Connections between the main tank and the conservator shall be such that air or gas is not entrapped and the Buchholz relays can be correctly installed. One end of the conservator shall be fixed by bolts so that it can be removed to enable the tank to be cleaned. The capacity of each conservator tank shall be adequate to accommodate the expansion and contraction of oil in the whole system, over the extreme range possible in operation, i.e. equipment unenergised in an ambient temperature of 5 deg. C to the condition corresponding to maximum oil temperature rise. Conservator shall be fitted with:-

- (a) A hydro compensator for separating oil and air. A dehydrating breather shall be used for the air intake of the hydro compensator. Alarm for leak of the hydro compensator shall also be provided.
- (b) At least one magnetic oil level indicator type visible from ground level and indicating the oil levels over the range specified above. The oil level indicator shall be marked to indicate the correct oil level with the oil at a temperature of 5 deg. C, 30 Deg. C and 90 deg. C. The temperature markings shall preferably be integral with the level indicating device but subject to the approval of the Authority.
- (c) Low oil alarm initiating device.

#### 7.1.18.2 Pressure Relief Device

The transformer shall be fitted with a pressure relief device designed to protect the tank from damage and to control the expulsion of oil during an internal fault. The pressure relief device shall be of the spring-loaded diaphragm type capable of opening fully within two milliseconds of detecting an excess pressure, and shall fully reseal after release of the exceeded pressure. Corrosion resistant materials shall be used and a visual indication of operation shall be provided. Two pairs of normally open contacts and a suitable terminal box shall be provided for remote electrical indication and tripping.

#### 7.1.19 GASKETS

Any gaskets provided with the transformers shall be suitable for making oil tight joints, and there shall be no deleterious effects of either gaskets or oil when the gaskets are continuously in contact with hot oil. No gaskets shall be used in which the material of the gasket is mounted on a textile backing. Exterior gaskets shall be weatherproof and shall not be affected by strong sunlight.

#### 7.1.20 OIL

All transformers shall be filled to the required level with new, unused, clean, standard mineral oil after treatment in compliance with IEC 60296 & BS 148.

## 7.1.21 ACCESSORIES

### 7.1.21.1 Winding Temperature Indicator

The transformer shall be provided with a winding temperature indicator and combined alarm and trip relays of approved design. The alarm and trip settings shall be adjustable. The winding Temperature Indicator shall also be provided with additional contacts for automatic 'start/stop' of cooling plant (fans). It shall be fitted with dial indicator calibrated in degrees Celsius and fitted with a hand reset pointer the highest temperature attained. The winding temperature indicator shall be so mounted in the transformer marshalling kiosk so that the dial is not more than 1500 mm from ground level. The cover shall be equipped with a viewing aperture of adequate size, fitted with clear, reinforced glass.

### 7.1.21.2 Oil Temperature Indicators

The transformer shall be provided with an oil temperature indicator of approved design incorporating contacts and relay(s) for initiating alarms and trips. The indicator shall be fitted with a dial calibrated in degrees Celsius, with a hand reset pointer to register the highest temperature attained.

The oil temperature indicator shall be mounted in the transformer marshalling kiosk so that the dial is not more than 1500 mm from the ground level and the cover shall be equipped with viewing aperture of adequate size, fitted with clear, reinforced glass.

### 7.1.21.3 Buchholz relay

A Buchholz relay with alarm and tripping contacts to detect accumulation of gas and sudden changes of oil pressures, complete with two shut-off valves and flange coupling to permit easy removal without lowering oil level in the main tank, a bleed valve for gas venting and test valve shall be provided. The relay shall be provided with a test cock suitable for a flexible pipe connection for checking its operation & taking gas sample.

### 7.1.21.4 Breathers

Each transformer and tap changer conservator shall be provided with a silica gel breather complete with oil seal, oil level indication window and a sight glass for inspection of the silica gel. Due to the climatic conditions at site, this breather shall be liberally sized and one size larger than would be fitted for use in a temperate climate.

A visual indication of the extent to which the drying agent has absorbed moisture is preferred, showing how much active material remains effective.

### 7.1.21.5 Padlocks

The supplier shall provide padlockable handles and non-ferrous padlocks with duplicate keys for tap changer control panel and kiosks door to prevent all unauthorized access and operation.

7.1.21.6 the other accessories shall be provided is listed below

- a) Ladder permanently fixed with transformer tank
- b) Dial Thermometer with pocket for oil temperature indicator with one set of alarm and one set of trip contacts and maximum reading pointer.

## 7.1.22 Marshalling Kiosk (box):

Marshalling box shall be connected at one side of transformer. It shall consist of WTI (winding temperature indicator) and OTI (oil temperature indicator), magnetic oil gauge and Buchholz relay and other control terminals. WTI are in two numbers, one for HV and other for LV. It shall also consist of all auxiliary contactors as required in the order to make necessary potential free contacts for remote alarm and tripping, a heater which is used to absorb the moisture in the box, SPN socket outlet, complete with switch and HRC fuse for hand lamp connection.

## 7.1.23 Painting

The minimum standards acceptable are :

- a) cleaning by shot blasting to Grade Sa 2.5 of ISO 8501-1
- b) All sheet steelwork shall be degreased, pickled and phosphated in accordance with IEC 60076.
- c) Interior surface of mechanism chambers, boxes and kiosks, after preparation, cleaning and priming shall be painted with one coat of zinc chromate primer, one coat of phenolic based undercoating, followed by one coat of phenolic based finishing paint to white colour followed by a final coat of anti-condensation white paint of a type and make to the approval of purchaser. A minimum overall paint film thickness of 150 microns shall be maintained throughout.
- d) Exterior steel work and metalwork, after preparation and priming shall be painted with one coat of zinc chromate primer, one coat of phenolic based under coating and two coat of micaceous iron oxide paint, then painted with final coat of phenolic based hard gloss finishing paint of the light grey shade to provide an overall minimum paint thickness of 200 microns.

#### 7.1.24 Galvanising

All galvanizing shall be carried out by the hot dip process, in accordance with specification ISO 1460. However, high tensile steel nuts, bolts and spring washers shall be electro galvanized. The zinc coating shall be smooth, continuous and uniform. It shall be free from acid spots and shall not scale, blister or be removable by handling or packing. There shall be no impurities in the zinc or additives to the galvanic bath which could have a detrimental effect on the durability of the zinc coating.

Before pickling, all welding, drilling, cutting, grinding etc must be complete and all grease, paint, varnish, oil, welding slag etc completely removed.

The weight of zinc deposited shall be in accordance with the stated in BS 729, ISO 1460 and shall be not less than 0.61Kg/sq. mtr. with minimum thickness of 86microns for items of thickness more than 5mm, 0.46Kg/sq.mtr. (64microns) for items thickness between 2mm and 5 mm and minimum 0.33kg/sqmm (47microns) for the item less than 2mm thick.

Repair of galvanizing on site will generally not permitted.

#### 7.1.25 Terminal marking

Each terminal including the neutral shall be clearly marked on both the primary and secondary side in accordance with the diagram of connection supplied with the transformers.

The terminal marking shall be clear and permanent. Painted markings are not acceptable. The winding shall be leveled as follows:

High voltage	:	3 phases	A B C
Low voltage	:	3 phases and neutral	a b c n

#### 7.1.26 EVALUATION CRITERIA

- a) The Tenders will be evaluated on the basis of the capitalized cost of the Transformer losses.
- b) Bidder will declare declared/ guaranteed No-load loss and Full Load loss value, otherwise the bid will be rejected.
- c) Bidders declared/ guaranteed Percentage Impedance value shall be within the specified value, otherwise the bid will be rejected.

7.1.27 ACCEPTANCE CRITERIA OF TRANSFORMER LOSS AND PERCENTAGE IMPEDANCE DURING FACTORY TEST

Transformer will be tested during technical orientation & quality acceptance and will be accepted if the measured transformer losses are within the offered value or within the following tolerance with deduction of amount from the contract price as below:

i) Any component loss (No load loss or Full load loss) may exceed up to 15% of the offered component loss, provided that the total loss ((No load loss + Full load loss) shall not exceed 10% of the offered total loss. If any component loss exceeds 15% of the offered component loss, the full consignment will be rejected.

ii) Total loss (No load loss + Full load loss) may exceed up to 10% of the offered total loss. If it exceeds 10%, the full consignment will be rejected.

iii) Percentage Impedance may vary up to ±10% of the specified value. If the value exceeds the tolerance (±10%), the full consignment will be rejected.

Transformer will be tested during factory test witness and will be accepted if the measured transformer losses are within the offered value or within the acceptable limit as specified in (i), (ii) and (iii) provided an amount will be deducted from the Contract price for the loss(s) exceeding the offered/declared loss(s) according to the following formula:-

Amount to be deducted from the Contract price

$$= \text{Contract Price} \times \{(\text{Measured loss} - \text{Specified offered /declared loss}) \div \text{Specified loss}\} \times \%MT$$

Where,

Measured Loss (in KW)	=	Measured Average No load Loss* <sup>1</sup> + Measured Average Full Load Loss* <sup>2</sup> .
Offered Loss (in KW)	=	Offered No Load Loss + Offered Full load loss
Transformer Economic Life	=	20 Years

%MT (Percentage of Monetized Transformer) = % of the Monetized Transformer found during factory test witness by BPDB's inspection team whose measured loss(s) (No load loss or Full load loss or Both) exceed the offered loss (No load loss or Full load loss or Both) but remain within acceptable limit. For example : If total no. of transformers to be inspected is 80 and the no. of selected transformers during QAT/pre-delivery inspection is 8, 6 nos. are found within the offered losses and 2 nos. are found exceeding the offered losses then the %MT will be (2/8)x100=25%

\*<sup>1</sup>Measured Average No Load Loss = [Sum of the measured No-load losses of the tested transformer(s) exceeding the offered No-load loss ÷ Nos. of tested transformer(s) which exceeds the offered No-load loss]

\*<sup>2</sup>Measured Average Full Load Loss = [Sum of the measured Full-load losses of the tested transformer(s) which exceeding the offered Full-load loss ÷ Nos. of tested transformer(s) which exceeds the offered Full-load loss]

7.1.28 Mandatory SPARE PARTS

The Supplier shall provide for every five transformers the following mandatory spares:

- One HV Bushing
- One LV Bushing
- One complete set of bi-metallic connectors for both HV & LV bushings.
- One OTI and WTI.

7.1.29 APPROVAL OF DRAWINGS

The successful bidder/tenderer shall submit the following drawings in AutoCAD format and in hard copy for the approval of the purchaser within commencement period.

1. Full Technical Specification and Guaranteed Technical Particulars

2. Max. Temp. Rise of Winding & Oil over 40°C ambient supported by Load Losses and Heat Dissipation by Radiator and also Short Circuit Calculation along with thermal & mechanical calculations on the basis of proposed Design Data
3. General outline drawing showing front, side elevation and plan of the transformer and accessories with detailed dimensions. The clearances between HV and LV terminals and ground should also to be shown.
4. Drawings of each type of bushings, lifting dimensions, clearance between HT and LT terminals and ground, quantity of insulating oil, name plate details etc. showing various weights and ratio of WT – CT, OT-CT, all bushing CT and details of OLTC & RTCC.
5. Large scale drawings of high, medium and low-tension windings of the transformers showing the nature and arrangement of insulators and terminal connections.
6. Schematic control and annunciation wiring diagram for all auxiliary equipment (temperature indicator, alarm circuits, Buchholz relay, oil surge relay, PRV, MOG, WTI, OTI, AVR relay, OLTC, cooling control etc, Schematic diagram showing the flow of oil in the cooling system, Large scale drawing of high and low tension winding of the transformer showing the nature and arrangement of insulation and terminal connections
7. Drawing/ Wiring diagram showing construction and mounting details of marshalling boxes.
8. Operation and maintenance guide for transformer and OLTC.
9. Detailed loading drawing to enable the Purchaser to design and construct foundations for the transformer.
10. Installation, Operation and maintenance manual along with troubleshooting procedure
11. Successful Bidder shall also submit a copy of approval in Soft format.

No work shall be performed in connection with the fabrication and manufacture of the Testing Equipment until the technical data and drawings have been approved. The manufacturing of the equipment shall be strictly in accordance with the approved drawings and no deviation shall be permitted without the written approval of the purchaser.

The cost of supplying drawings and specifications shall be borne by the supplier.

At the time of delivery of Equipment, the supplier shall supply three (3) sets of all approved technical data and drawings in bound book form along with manufacturer's original catalogue of the Equipment to the office of Director, Design & Inspection-II, BPDB, 9/B, Motijheel C/A, Dhaka, Bangladesh, Telephone # 88-02-9550404.

#### 7.1.30 TESTS AT MANUFACTURERS WORKS:

##### 7.1.30.1. GENERAL

Functional electrical, material, mechanical and hydraulic tests shall be carried out at manufacturers' premises. The extent and method of recording the results shall be agreed by the Purchaser in ample time to enable the tests to be satisfactorily witnessed or to make any changes to the proposed program of tests.

##### 7.1.30.2 MATERIAL TESTS:

The supplier shall provide test pieces free of charge as required to enable the quality of the material to be determined at the supplier's expense. Purchaser may at its own discretion and by specific arrangement accept certified particulars of tests carried out in the absence of his authorized representative.



#### 7.1.30.3 TYPE TEST:

Type tests are required on all items to prove the general design of the goods offered. The Bidders shall submit the type test report of offered item from internationally reputed independent testing laboratory.

#### 7.1.30.4 ROUTINE TESTS:

All items shall be subjected to routine tests in accordance with the relevant latest version of IEC, BS & BDS standards at the manufacturers works and shall include, but not be limited to, an operational test.

#### 7.1.31 TECHNICAL ORIENTATION AND QUALITY TEST WITNESS :

The following test shall be carried out as per latest version of IEC or equivalent standard unless otherwise mentioned at the manufacturer premises or other places where the test facilities are available:-

##### Acceptance Tests:-

1. Measurement of turn ratio test;
2. Vector group test;
3. Measurement of winding resistance;
4. Measurement of insulation resistance;
5. Measurement of no load loss & no-load current;
6. Measurement of impedance voltage & load loss;
7. Dielectric withstands Tests;
8. Transformer oil test;
9. Temperature rise test.
10. Separate source voltage withstand test.
11. Tap-changer operation test
12. Dimension and physical check.
13. Magnetic Balance Test
16. Bucholz, PRD, WTI, OTI Operation Check
17. WTI, OTI Operational Accuracy Check
18. Bushing CT Test

The purchaser can carry-out the testing of any no. of transformers during Quality Test Witness. But, the testing of transformers during Quality Test Witness will not be less than 10% at random basis of the transformer ready for inspection but in any case it will not be less than 3 nos. The manufacturer will provide all arrangements for the testing of transformers desired by the purchaser in his factory.

Where the supplier provides for tests on the premises of the supplier or of any manufacturer of the supplier, except where otherwise specified, shall provide free of charge such assistance, labor, materials, electricity, fuel, stores, apparatus and instruments as may be requisite and as may be reasonably demanded to carry out such test efficiently. These test shall be performed as per relevant IEC/BS Standard or equivalent and only routine tests as agreed upon, will be performed.

As and when the purchaser is satisfied that any materials/equipment shall have passes the tests referred to in this clause, purchaser shall notify the contractor in writing to that effect.

Should any inspected/tested goods fail to conform to the specification, the Purchaser shall have the right to reject any of the item or complete batch if necessary. In that case Supplier have to replace the Equipment and to make good of them without any financial involvement to the Purchaser. In case any of the Equipment found not conforming with the specification at the time of post landing Inspection, the supplier will in no way be relieved from the responsibility of replacing them on making them good at their own cost, despite the Equipment were found good

at the time of Factory Acceptance Test. Nothing in this clause shall in any way release the supplier from any warranty or other obligations under the contract.

No goods shall be packed, prepared for shipment/delivery unless it has been approved and written instruction have been received by the Purchaser.

**7.1.32 POST LANDING INSPECTION:**

Post landing inspection shall be done immediately after arrival of the goods/materials at the designated store of BPDB; the Engineer & representative from consignee shall conduct Post Landing Inspection in presence of the representative of Supplier. The program of such inspection shall be intimated to the representative of Supplier by BPDB upon arrival of the materials at BPDB store of the Inspector(s) to be selected for test witnessing. Any defect or damage have been found at post-delivery inspection, the defective or damaged panels/ materials/ goods to be repaired/ replaced by the Bidder/ supplier at his own cost.



## 7.2 Guaranteed Technical Particulars FOR 33/11kV, 10/13.33 MVA POWER TRANSFORMER

(To be filled up by the Manufacturer in Manufacturer Letterhead Pad, otherwise the bid shall be rejected.)

Sl. No.	Description	Unit	BPDB's Requirement	Manufacturer's Guaranteed Particulars
1.	RATING AND PERFORMANCE			
1.1	Manufacturer's name & country	-	To be mentioned	
1.2	Manufacturer's Model no.	-	To be mentioned	
1.3	Continuous maximum rating (ONAN / ONAF)	MVA	10 / 13.33	
1.4	No. of phases	Nos.	3	
1.5	Rated frequency	Hz	50	
1.6	Normal transformation ratio at No-load	kV	33/11	
1.7	Rated HT voltage (phase to phase)	kV	33	
1.8	Maximum HT voltage (phase to phase)	kV	36	
1.9	Rated LT voltage (phase to phase)	kV	11	
1.10	Maximum LT voltage (phase to phase)	kV	12	
1.11	Installation	-	Outdoor	
1.12	Type of Transformer	-	Core, Conservator, Oil immersed	
1.13	Direction of normal power flow	-	HT-LT	
1.14	No of windings	Nos.	2	
1.15	Bushing materials	-	Porcelain	
1.16	Type of cooling	-	ONAN/ONAF	
1.17	Coolant	-	Type- A, Unused insulating mineral oil, free from PCB (polychlorinated biphenyl)	
1.18	Type of earthing	-	Effectively earth	
1.19	Type of base	-	On wheels with adequate size and 10M length of rails and fixing arrangement	
1.20	Phase connection: a) 33 KV winding with bushing CT b) 11KV winding with bushing CT	- -	Delta Star	
1.21	Vector group	-	Dyn11	
1.22	Neutral to be brought out : a) HT b) LT	- -	Nil Yes	
1.23	Basic Insulation Level (BIL) : a) High voltage winding b) Low voltage winding	KVp KVp	170 75	
1.24	Max. Temp. Rise over 40°C of ambient (at CMR & normal tap change position) supported by Design Calculation sheet (to be enclosed) on the basis of Design Data:-			
	a) Winding Temp. Rise	°C	65	

	b) Top Oil Temp. Rise	°C	55	
TEST VOLTAGE :				
1.25	Impulse front wave test voltage (1.2/50 micro sec. wave shape) : a) High voltage side b) low voltage side	kVp kVp	170 75	
1.26	Power Frequency withstand test voltage for 1 (one) minute : a) High voltage side b) Low voltage side	kV kV	70 28	
1.27	Short circuit MVA available : a) at 33 KV b) at 11KV	MVA MVA	1800 500	
1.28	Impedance voltage at 75 °C and at normal ratio and rated frequency and at ONAN condition (supported by type test report).	%	8.5%	
1.29	All windings shall have uniform insulations	-	Yes	
2.	VOLTAGE CONTROL (OLTC)			
2.1	Type of Tap Changer control	-	On load auto regulation and remote & manual control	
2.2	OLTC, MDU & AVR Manufacturer's name & country	-	MR Germany/ABB (Hitachi), Sweden	
2.3	Model Number		Shall be mentioned	
2.4	Nos. of tapping	-	17	
2.5	Tapping steps	-	+10% in steps of 1.25% 17 tapping (i.e. 33+8x1.25%)	
2.6	HV or LV winding	-	HV winding	
2.7	Power Frequency withstand test voltage between first and last contracts of the selector switch between diverter and switch contract.	kV	75	
2.8	Rated Voltage for control circuit		Shall be mentioned	
2.9	Power Supply for control motor		Shall be mentioned	
3.	GENERAL			
3.1	Manufacturer's Name & Address		To be mentioned	
3.2	Material of core & grading		To be mentioned	
3.3	Core Loss/ Kg, supported by Characteristic Curve (to be submitted )		To be mentioned	
3.4	Thickness of core, mm		To be mentioned	
3.5	Core Dia, mm		To be mentioned	
3.6	Total weight of core, Kg		To be mentioned	
3.7	Maximum flux density in iron at normal voltage and frequency and at normal ratio (ONAF condition)	Tesla	< 1.7	

	a) Cores b) Yokes	Tesla	To be mentioned	
3.8	Magnetizing current (approx.)	%	To be mentioned	
3.9	a) No load losses at rated voltage, ratio and frequency. b) Full Load losses at rated voltage, normal ratio & frequency in ONAN condition at 75°C. c) Full Load losses at rated voltage, normal ratio & frequency in ONAF condition at 75°C. d) Auxiliary Losses e) Total Loss (a+c+d)	KW KW KW KW KW	7-12 To be mentioned 50-70 To be mentioned To be mentioned	
3.10	Maximum current density in core at CMR	A/m m <sup>2</sup>	To be mentioned	
3.11	Simultaneous operating conditions under which maximum flux density is attained: a) Frequency b) Voltage- HV LV c) Tab d) Load	Hz KV KV - MVA and P.F.	To be mentioned To be mentioned To be mentioned To be mentioned	
3.12	Maximum flux density in iron under conditions entered on line 3.6	Tesla	To be mentioned	
3.13	(a) Maximum current density in HV winding at CMR (b) Cross section of LV winding	A/m m <sup>2</sup> mm <sup>2</sup>	≤ 2.5 To be mentioned	
3.14	(a) Maximum current density in LV winding at CMR (b) Cross section of HV winding	A/m m <sup>2</sup> mm <sup>2</sup>	≤ 2.5 To be mentioned	
4.	DETAILS OF CONSTRUCTION			
4.1	Types of winding: a) HV b) LV	-	To be mentioned	
4.2	Copper Conductor's Manufacturer Name & Address		To be mentioned	
4.3	Material of windings	-	copper	
4.4	Winding resistance of : a) H.T. winding, b) L.T. winding,	Ohm. Ohm.	To be mentioned To be mentioned	
4.5	Current density of : a) H.T. winding, Amps/sq. mm b) L.T. winding, Amps/sq. mm	A/m m <sup>2</sup> A/m m <sup>2</sup>	≤ 2.5 ≤ 2.5	
4.6	Outer, Inner & Mean dia of copper winding: a) H.T. winding, b) L.T. winding,	mm mm	To be mentioned To be mentioned	
4.7	Size of Copper conductor/bar : a) H.T. winding SWG, dia. in mm / area in		To be mentioned	

	mm <sup>2</sup> b) L.T. winding SWG, area in mm <sup>2</sup>		To be mentioned	
--	---	--	-----------------	--

4.8	Number of Turns :			
	a) HT winding.	nos.	To be mentioned	
	b) LT winding	nos.	To be mentioned	
4.9	Copper weight of windings :			
	a) HT winding	Kg	To be mentioned	
	b) LT winding	Kg	To be mentioned	
4.10	Total weight of copper windings	Kg	To be mentioned	
4.11	Type of insulation of : a) Tapping b) Tapping connections c) Core bolts d) Core bolt washers e) Side plates f) Core laminations	-	To be mentioned	
4.12	Type of winding connections (crimped or brazed )	-	To be mentioned	
4.13	Thickness of transformer tank: a) Top b) Sides c) Bottom	mm mm mm	To be mentioned To be mentioned To be mentioned	
4.14	Vacuum withstand capability of the tank			
	Main tank	Kpa	To be mentioned	
	Conservator	Kpa	To be mentioned	
	Radiators	Kpa	To be mentioned	
4.15	Provision of tank earthing and Core earthing	-	Yes	
4.16	Bladder / Air bag in Conservator	-	Yes	
4.17	Material used for gaskets for oil tight joints	mm	To be mentioned	
5.	RADIATORS			
5.1	Thickness of radiator plates/ cooling tubes	mm	To be mentioned	
5.2	Equipment for ON cooling state a) radiators on main tank b) separate cooler banks	- -	To be mentioned To be mentioned	
5.3	Number of coolers/ radiators or cooler banks per transformer	Nos.	To be mentioned	
5.4	Rating of each cooler /radiator bank	KW	To be mentioned	
5.5	Power of each fan	KW	To be mentioned	
5.6	Nos. of fans	Nos.	To be mentioned	
6.	Oil Volume and Weight			
6.1	Type of oil		Type- A, Unused insulating mineral oil, free from PCB (polychlorinated biphenyl)	
6.2	Manufacturer Name of oil		Shall be mentioned	
6.3	Breakdown Voltage at 2.5mm gap between electrodes		>50 kV	
6.4	Appearance		Liquid and free from suspended matter or sediment	
6.5	Density at 20 <sup>0</sup> C		0.895 g/cm <sup>3</sup>	

			(maximum)	
6.6	Flash point (Closed cup)		140° C (minimum)	
6.7	Kinematics Viscosity at -15° C		800 cSt. (Maximum)	
6.8	Kinematics Viscosity at 20° C		40 cSt. (Maximum)	
6.9	Pour point		-30° C (maximum)	
6.10	Neutralization value		0.03 mg KOH/g (maximum)	
6.11	Neutralization value after oxidation		0.40 mg KOH/g (maximum)	
6.12	Total sludge after oxidation		0.10% weight (maximum)	
6.13	PCB Content		Free from PCB	
6.14	Water content		25ppm (maximum)	
6.15	Total oil required including cooler system	Litres	To be mentioned	
6.16	Volume of oil above of the top yoke	Litres	To be mentioned	
6.17	Total volume of conservator	Litres	To be mentioned	
6.18	Weight of core and winding assembly	Tones	To be mentioned	
6.19	Weight of each oil cooler bank complete with oil if mounted separately from transformer	Tones	To be mentioned	
6.20	Total weights of complete transformer, including attached coolers, voltage regulating equipment ,all fittings and oil	Tones	To be mentioned	
6.21	Weight of transformer arranged for transport	Tones	To be mentioned	
6.22	Brief description of transformer or parts thereof subjected to short-circuit test or for which short-circuit calculations are available	-	To be mentioned	
7.	TRANSFORMER BUSHING INSULATORS			
7.1	Manufacture's name & country	-	To be mentioned	
7.2	Insulator material	-	Porcelain	
7.3	Bushing housing		Porcelain	
7.4	Bushing Current Rating at 75°C	A	To be mentioned	
7.5	Insulator type and rated voltage	-	To be mentioned	
7.6	Pitch circle diameter and drilling of flange	mm appro x.	To be mentioned	
7.7	Length of Insulator (overall )	mm	To be mentioned	
7.8	Weight of Insulator	kg	To be mentioned	
7.9	One minute 50 Hz dry withstand routine test voltage	KV	To be mentioned	
7.10	Lightning Impulse flashover voltage (1.2/50 wave )	KV	To be mentioned	
7.11	Full wave Lightning Impulse Voltage withstand	KV	To be mentioned	
7.12	50 Hz wet withstand voltage across arcing horns	KV	To be mentioned	
7.13	Under oil flashover voltage type test	KV	To be mentioned	
7.14	Total creepage distance of shedding	mm	Min. 25mm per KV	
7.15	Protected creepage distance of shedding	mm	To be mentioned	

7.16	Rated Short circuit Current withstand capability		31.5KA, 3sec	
8.	BUSHING CTS 33 KV FOR DIFFERENTIAL PROTECTION			
8.1	Manufacturer's name & country	-	To be mentioned	
8.2	Rated Voltage		33KV	
8.3	Rated maximum Voltage		36KV	
8.4	Ratio	A	300/5	
8.5	Rated output	VA	30 VA	
8.6	Accuracy class	-	5P20	
8.7	Knee Point Voltage	V	To be mentioned	
8.8	Electrical Clearance from phase to phase	mm	To be mentioned	
8.9	Electrical Clearance phase to earth	mm	To be mentioned	
9.	BUSHING CTS 11 KV FOR DIFFERENTIAL PROTECTION			
9.1	Manufacturer's name & country	-	To be mentioned	
9.2	Rated voltage	KV	11	
9.3	Rated maximum voltage	KV	12	
9.4	Ratio	A	900/5	
9.5	Rated output	VA	30 VA	
9.6	Accuracy class	-	5P20	
9.7	Knee Point Voltage	V	To be mentioned	
10.	NEUTRAL BUSHING CTS 11 KV FOR SEF & REF PROTECTION			
10.1	Manufacturer's name & country	-	To be mentioned	
10.2	Rated voltage	KV	11	
10.3	Rated maximum voltage	KV	12	
10.4	Ratio	A	900/5-5A	
10.5	Rated output	VA	30 VA	
10.6	Accuracy class	-	5P20	
	Knee Point Voltage	V	To be mentioned	
11.0	Oil Temperature Indicator			
	Manufacturer Name		To be mentioned	
	Alarm contact		01No	
	Trip Contact		01No	
	Alarm & Trip Range			
12.0	Winding Temperature Indicator			
	Manufacturer Name		To be mentioned	
	Alarm contact		01No	
	Trip Contact		01No	
	Alarm & Trip Range			
13.0	Dial Thermometer			
	Alarm Contact		01No	
	Trip Contact		01No	
14.0	Buchholz relay		Yes/No	
	Manufacturer Name		To be mentioned	
	Make/Model Number		To be mentioned	
	Alarm contact		01No	
	Trip Contact		01No	
15.0	PRD		Yes/No	

	Manufacturer Name		To be mentioned	
	Make/Model Number		To be mentioned	
	Alarm contact		01No	
	Trip Contact		01No	
16.0	Is terminal permanent terminal marking provided?		Yes/No	
17.0	Parallel operation of identical transformer		Required	
18.0	Marshalling Box		Shall be provided	
19.0	Silica Gel Breather		Shall be provided	
20.0	Guaranteed Noise level as per IEC 551	db		
21.0	Harmonics			
	R.M.S. value of the fundamental current	Amp.	To be mentioned	
	R.M.S. value of 3rd harmonics current	Amp	To be mentioned	
	R.M.S. value of 5th harmonics current	Amp	To be mentioned	
22.0	Type of paint applied internally		To be mentioned	
23.0	Type of paint applied externally		To be mentioned	
24.0	Type of weatherproof anti rust material primer		To be mentioned	
25.0	Dimension of the transformer			
	Length	mm	To be mentioned	
	Width	mm	To be mentioned	
	Height	mm	To be mentioned	
26.0	Standard		Design, Manufacture, Testing, Installation and performance shall be in accordance to the latest edition of the IEC 60076	
27	Manufacturer must comply all the features of Technical Specification mentioned in Section-7.		Yes	

Seal & Signature  
of the Manufacturer

Seal & Signature  
of the Bidder

SECTION: 8  
DRAWINGS  
(To be Submitted)



FORMAT

LOGO

[Insert Full Contact Details of the Procuring Entity]

CONTRACT AMENDMENT

Contract No.	
Amendment No.	
Approval Reference No.	

Contract No. [insert number/year] by and between the [insert Procuring Entity's name] and [insert Supplier's legal title] for the contract named [insert name of the Goods and related services] is amended as follows:

1. GCC Clause [insert clause no], is hereby revised as \_\_\_\_\_  
\_\_\_\_\_

2. GCC Clause [insert clause no], is hereby revised as \_\_\_\_\_  
\_\_\_\_\_

and so on .

The effective date of this Amendment is [insert effective date] or upon execution whichever is later.

ALL OTHER TERMS AND CONDITIONS OF THE ORIGINAL CONTRACT SHALL  
REMAIN IN FULL FORCE AND EFFECT

THIS AMENDMENT, consisting of [insert number] page(s) and [insert number] attachment(s), is executed by the persons signing below who warrant that they have the authority to execute this Amendment under the original Contract.

IN WITNESS WHEREOF, the Procuring Entity and the Supplier have signed this Amendment.

[Supplier's Authorized Signatory]

[Procuring Entity's Authorized Signatory]

\_\_\_\_\_  
Signature

\_\_\_\_\_  
Signature

\_\_\_\_\_  
Title

\_\_\_\_\_  
Date

\_\_\_\_\_  
Title

\_\_\_\_\_  
Date

**FORMAT  
LOGO**

[Insert Full Contact Details of Issuing Authority]

Office Memo no: \_\_\_\_\_

Date: \_\_\_\_\_

**ACCEPTANCE CERTIFICATE**

01	Procuring Entity Details		
	(a) Division	:	
	(b) Circle/Directorate	:	
	(c) Zone/Region	:	
	(d) Others ( <i>specify</i> )	:	
02	Name of Supply	:	
03	Contract No	:	
04	Supplier's Legal Title	:	
05	Supplier's Contact Details	:	
06	Supplier's Trade License/Enlistment/Registration Details	:	
07	Reference to NOA with Date	:	
08	Original Contract Price as in NOA	:	
09	Final Contract Price as Delivered	:	
10	Original Contract Period		
	(a) Date of Commencement	:	
	(b) Date of Completion	:	
11	Actual Delivery Period		
	(a) Date of Actual Commencement	:	
	(b) Date of Actual Completion	:	
12	Days/Months Delivery Period Extended	:	
13	Amount of LD for Delayed Delivery	:	
14	Special Note ( <i>if any</i> )	:	

Certified that the Goods and related services under the Contract has been delivered and completed in all respects in strict compliance with the provisions of the Contract including all plans, designs, drawings, specifications and all modifications thereof as per direction and satisfaction of the Procuring Entity/Engineer-in Charge/Other (*specify*). All defects in the Goods reported during inspection and tests have been duly rectified or replaced.

\_\_\_\_\_  
Name and Signature of the Issuing Authority with Designation  
*please turn over*