

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month July, 2023		Day : Thursday				Date : 27.07.23						
Probable Maximum Demand :		15500 MW		Yesterday = 77.13 ft		Probable Maximum Generation :		16021 MW				
Water Level of Kaptai Lake at 06:00 AM				Today = 78.37 ft		Rule Curve = 88.00 ft						
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	26.07.23 (Yesterday)		27.07.23 (Today)		26.07.23 (Yesterday) Gen. shortfall for : Gas/Coal/Water Limitation MW	27.07.23 (Yesterday) Machines shut down (MW)	Status of Machines under shut-down/ Maintenance Description/ Remarks	Probable start-up date
					Actual Peak Generation (MW)		Probable Peak Generation (MW)					
					Day	Evening	Day	Evening				
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	200	210	210	210			
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180			
3	Ghorasal 108MW PP (Regent)	Gas (PDB)	1x 254+1x 126	385	365	0	0	0	0			
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108	Gas Shortage	
5	Tong 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	292	294	290	290			
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450			
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	383	387	390	390			
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	187	180	190	195			
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	316	126	220	220			
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	296	255	300	300			
14	Madangari 55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	15	15	25			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	25	66	25	66			
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	16	19	19	19			
17	Summit Power, Madhabdi+Ashulia	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	38	33	40	40			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33			
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	22	24	24	24			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	51	8	25			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	35	88	35	88			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	82	130	64	130			
23	Kamalghat 54 MW PP (Barico Energy)	HFO (IPP)	3x18.69	54	54	17	35	17	35			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	16x17.076	300	300	145	147	115	115			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.15+1x18.97	149	149	86	133	70	148			
26	Keraniganj 300 MW PP (AFR)	HSD (IPP)	25x11.4	300	300	95	126	150	250			
27	Nabaganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	35	35	55			
28	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	35	35	55			
29	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	16	17	17	17			
30	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	72	162	35	162			
31	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	0	30	0	0			
32	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	34	17	17			
33	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	26	34	24	34			
34	Meghnaghat 100 MW(EL)	HFO (NENP)	12x8.9	100	100	19	34	25	34			
35	Madangari 102 PP(Summit)	HFO (NENP)	6x17	102	102	96	96	96	96			
36	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	22	22	22	22			
Dhaka Zone Total			5904	5722	3259	3451	3181	3724	213	375		
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	74	75	75	155		Low water level	
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	102	120	120	60		Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
39	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	3	0	5	0			
40	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	25	8	25			
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	6	0	20	0			
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	47	6	47			
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	51	68	97	97			
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	213	227	225	225			
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	122	265	120	300			
47	Juldah 100 MW PP Unit 3 (Acorn)	HFO (IPP)	8x13.45	100	100	25	74	37	60			
48	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	50	50	50	50			
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	35	82	40	80			
50	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	9	10	11	11			
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			3	31	5	30			
51	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	22	12	20			
52	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	36	36	36			
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	55	56	54	54			
54	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	25	64	38	64			
55	Juldah 100 MW Unit-1 (Acorn)	HFO (QRPP)	8x13.45	100	100	25	68	45	70			
56	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	34	68	34	68			
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	88	144	52	163			
	SS Power Unit-1	Coal (IPP)				0	0	0	0			
	Cox's Bazar Wind PP	(Wind) (IPP)				24	13	25	25			
Chattogram Zone Total			2605	2545	975	1545	1115	1620	215	330		
58	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	0	0	0	0			
59	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+175	221	221	187	182	170	180			
60	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	230	230	230	230			
61	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	270	270	270	300			
62	Ashuganj 420 MW CCPP(East)	Gas (APSCCL)	1x284+1x116	400	400	240	230	230	230			
63	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	0	0	0	195	Gas Shortage	
64	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	43	43	43			
65	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	5	137	12	150			
66	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	32	41	44	44			
67	Chandpur 150 MW CCPP	Gas (PDB)	1x106+1x57	163	163	0	0	0	0	163	Under maint.	
68	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	34	129	51	100			
69	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	20	20	20			
70	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	10	10	10	10			
71	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	30	33	33	33			
72	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	43	43	43	43			
73	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	20	20	20			
74	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	87	105	17	105			
75	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	25	77	27	75			
76	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17			
77	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	72	114	72	115			
**	Impoport (Tripura)	India		160	160	120	112	146	169			
Cumilla Zone Total			2904	2896	1493	1813	1455	1884	195	163		
78	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	25	82	30	80	120	Gas Shortage	
79	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	19	19			
80	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	68	87	18	85			
81	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	19	83	68	88			
82	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
83	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	26	0	50	0			
84	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	6	6	6	12			
Mymensingh Zone Total			622	614	164	276	193	284	120	0		

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	26.07.23 (Yesterday)		27.07.23 (Today)		26.07.23 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/Coal/Water Limitation MW	Machines shut down (MW)			
85	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30	30		40	GT-1 Under maint.	
86	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	0	0	0	0			Under maint.	
87	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	44	49	50	50				
88	Kushiera 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	112	112	112		54	ST Under maint.	
89	Hobgajonj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	8	11	11				
90	Shahjibazar GTFP Unit- 8 & 9	Gas (PDB)	2x35	70	66	48	51	60	60				
91	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
92	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	3x2.90	86	86	72	84	78	80				
93	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	114	114	115	115				
94	Sylhet 20 MW GTPP	Gas (PDB)	1x 20	20	20	17	17	17	17				
95	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	10	10	10				
96	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	24	24	24	24				
97	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	275	300	300				
98	Bibiana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	394	402	400	400				
99	Bibiana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	350	350	350	385				
100	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
101	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.4*5*2	50	50	47	46	48	48				
Sylhet Zone Total													
102	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	15	0	0	0	0		524		
103	Bheramara 410 MW CAPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	105	95	110	110				
104	Fairdipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	10	28	20	30				
105	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	22	67	40	55				
106	Khulna 225 MW CAPP	HSD/ Gas (NWP/GCL)	1 x 150+1x75	230	230	120	120	120	120				
107	Rupsha 105 MW PP (Oron rupsha)	HFO (IPP)	6x18.445	105	105	35	35	35	35				
108	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	85	105	85	105				
109	Mongla Orion 100 MW Solar PP	Solar (IPP)	100	100	100	14	0	100	0				
110	Khulna 115 MW PP (KPCCL-2)	HFO (NENP)	7x17	115	115	79	80	80	95				
111	Noapara 40 MW PP (Khanaihan Ali)	HFO (NENP)	5*8.5	40	40	24	40	32	40				
112	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	500	500	500	507				
113	Khulna 330 MW CAPP (GT)	Gas/HSD (PDB)	1x220	220	220	0	120	220	220				
**	Bheramara (HVDC)	India	1000	1000	900	804	918	918					
Khulna Zone Total													
114	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	64	110	48	110				
115	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	22	33	22	34				
116	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	133	110	135	135				
117	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	1200	1244	1244	1244				
118	Potukhal 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	100	17	150				
119	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	250	250	250	250				
120	Bhola 220MW CAPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	220	220				
Barishal Zone Total													
121	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
121	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.	
122	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	21	35	35	35				
123	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	20	120	200	200				
124	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	20	0	35				
125	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	38	94	0	93				
126	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	25	36	35	35				
127	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	34	34	34	34				
128	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	35	35	30	35				
129	Sirajgonj 225MW CAPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage	
130	Sirajgonj 225MW CAPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	155	218	151	215			HSD	
131	Sirajgonj 225MW CAPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	136	141	145	145	84		Gas Shortage	
132	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	271	340	320	340	143		Gas Shortage	
133	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	0	0	0	0	0				
134	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8				
135	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	8	8	8				
136	Baigura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	55	35	55				
137	Baigura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	95	35	95				
138	Amnura 50 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	28	28	28	28				
139	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	3	0	6	0				
**	Adani Power Jharkhanda Ltd	Coal (Import)	2x748	1496	1496	755	761	750	750				
Rajshahi Zone Total													
140	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
140	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
141	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	230	220	180	180	54		Coal Shortage	
142	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
143	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	27	85	34	85				
144	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
145	Meghina Taluka 9 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	3	0	8	0				
146	Thakurgaon 119MW PP (Energypac)	HFO (IPP)	6*20	119	115	30	113	35	113				
147	Lalmohar 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	0	0	30	0				
148	Teesa Solar Limited	Solar (IPP)	1 x 200	200	200	144	0	130	0				
Rangpur Zone Total													
Sub-total: Plants in operation													
(B) Plants under long term maintenance/ contract expired													
149	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
150	Katcott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
151	Bosilia 108MW PP(CI)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
152	Ashugani 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	0	0	0	0				
Sub-Total: Plants under long term maintenance/ contract expired													
Gross Total													
(C) Actual data of 26.07.23 (Yesterday) Wednesday :													
01.	Max. Demand at eve. peak (Generation end)	:	0	MW, at =	21:00 hrs	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	14651	MW, at =	21:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed
03.	Highest Generation (Generation end)	:	15164	MW, at =	21:00 hrs	Dhaka	5148	5148	0	Mymensingh	1201	1101	100
04.	Minimum Generation (Generation end)	:	12359	MW, at =	8:00 hrs	Chattogram	1402	1402	0	Sylhet	546	546	0
05.	Day-peak Generation (Generation end)	:	13334	MW, at =	12:00 hrs	Khulna	1776	1776	0	Barishal	472	472	0
06.	Evening-peak Generation (Generation end)	:	15164	MW, at =	21:00 hrs	Rajshahi	1631	1601	30	Rangpur	1042	968	74
07.	Evening Peak Load-shed (Sub-station end)	:	244	MW, at =	21:00 hrs	Cumilla	1433	1393	40				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	12071	MW, at =	5:00 hrs								
09.	Generation shortfall at evening peak due to :	:								Total	14651	14407	244
a)	Gas/LF limitation	:	1096	MW		13.	Fuel cost :	(a) Gas = 169281123 Taka	(c) Coal = 306336445 Taka				
d)	Coal supply Limitation	:	139	MW				(b) Oil = 978345771 Taka	Total = 1453963338 Taka				
b)	Low water level in Kaptai lake	:	155	MW									
c)	Plants under shut down/ maintenance	:	1577	MW		14.	Maximum Temperature in Dhaka was :	36.6° C					
10.	Total Energy (Generation + India Import)	:	325.33	MKWh		15.	Export through East-West interconnections :						
	By Gas = 152.001 MKWh						At evening peak-hour	:	13334	MW, at	21:00 hrs		
	By Coal = 72.126 MKWh						Maximum	:	640	MW, at	22:00 hrs		
	By Solar = 2.677 MKWh						Energy	:	0	MKWh			
11.	Total Gas Supplied	:	1185.74	MMCFD									
(D) Forecast of 27.07.23 (Today) Thursday :													
01.	Maximum Demand	:	15500	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	16021	MW	(Generation end)	05.	Total Generation	:	332.54	MKWh			
03.	Reserve / Shortage	:	521	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	36.6° C				

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation